

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

March 30, 1981

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

Dear Mr. O'Reilly:


WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - NRC-OIE LETTER RII:NE
50-390/80-32, 50-391/80-25 - REVISED FINAL RESPONSES TO INFRACTIONS

The subject inspection report dated November 25, 1980, cited TVA with two infractions. An interim report in response to this inspection report was submitted on December 18, 1980, additional information was provided on January 26, 1981, and our final report was submitted on March 5, 1981.

On March 20, 1981, NRC-OIE Inspector N. Economos requested clarification of TVA's schedule for completing the corrective action. The work required to close this item is being completed by system as needed to support the construction and licensing schedule. At this time, the CVCS, SIS, RHR, and component cooling water systems for unit 1 have been completed with regard to reinspection and repair of fillet welds. TVA is closing these out as soon as possible with all fillet weld reinspection and repairs in all systems scheduled for completion by February 12, 1982, for unit 1 and October 13, 1982, for unit 2.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



L. M. Mills, Manager
Nuclear Regulation and Safety

cc: Mr. Victor Stello, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

8105110182