

APPENDIX B

NOTICE OF DEVIATION

Tennessee Valley Authority
Watts Bar 1,

Docket Nos. 50-390
License No. CPPR-91

Based on the results of the U.S. Nuclear Regulatory Commission inspection conducted on January 1-31, 1981 certain of your activities appear to deviate from your commitments to the Commission as indicated below:

In response to infraction 50-390/79-45-02 and 50-391/79-39-02, a letter from L. M. Mills to J. P. O'Reilly dated January 24, 1980, the licensee committed to transferring nonconforming condition report (NCR) status to an Information Processor to better review those NCRs for generic and repetitive conditions. This would allow an additional review by the Engineering Unit Supervisors and the Construction Engineer.

Contrary to the above, as of January 29, 1981, the monthly computer list of all outstanding NCRs was not being reviewed by the Unit Supervisors or the Construction Engineer for conditions of a generic and repetitive nature.

This is a deviation.

8105070574

Q