

Mr. Christopher M. Crane  
President and Chief Nuclear Officer  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

September 27, 2007

SUBJECT: BRAIDWOOD STATION, UNIT 1, EXEMPTION FROM THE REQUIREMENTS  
OF 10 CFR PART 50, SECTION 50.46, AND APPENDIX K TO PART 50  
(TAC NOS. MD3083 AND MD3084)

Dear Mr. Crane:

The Commission has approved the enclosed exemption from specific requirements of Title 10 of the *Code of Federal Regulations* (10 CFR), Part 50, Section 50.46, and Appendix K to Part 50, for Braidwood Station, Unit 1. This action is in response to your application dated September 26, 2006, as supplemented by letter dated August 8, 2007, that requested an exemption to allow the use of AREVA NP Inc. modified Advanced Mark-BW(A) fuel assemblies at Braidwood Station, Unit 1.

A copy of the exemption is enclosed. The exemption has been forwarded to the Office of the Federal Register for publication.

Sincerely,

/RA/

Robert F. Kuntz, Project Manager  
Plant Licensing Branch III-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. STN 50-456

Enclosure:  
Exemption

cc w/encl: See next page

Mr. Christopher M. Crane  
President and Chief Nuclear Officer  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

September 27, 2007

SUBJECT: BRAIDWOOD STATION, UNIT 1, EXEMPTION FROM THE REQUIREMENTS  
OF 10 CFR PART 50, SECTION 50.46, AND APPENDIX K TO PART 50  
(TAC NOS. MD3083 AND MD3084)

Dear Mr. Crane:

The Commission has approved the enclosed exemption from specific requirements of Title 10 of the *Code of Federal Regulations* (10 CFR), Part 50, Section 50.46, and Appendix K to Part 50, for Braidwood Station, Unit 1. This action is in response to your application dated September 26, 2006, as supplemented by letter dated August 8, 2007, that requested an exemption to allow the use of AREVA NP Inc. modified Advanced Mark-BW(A) fuel assemblies at Braidwood Station, Unit 1.

A copy of the exemption is enclosed. The exemption has been forwarded to the Office of the Federal Register for publication.

Sincerely,  
*/RA/*  
Robert F. Kuntz, Project Manager  
Plant Licensing Branch III-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. STN 50-456

Enclosure:  
Exemption

cc w/encl: See next page

Distribution:

PUBLIC	RidsNrrPMRKuntz	RidsRgn3MailCenter
LPL3-2 R/F	RidsNrrPMMThorpe-Kavanaugh	RidsNrrDssSpnb
RidsNrrDorlLpl3-2	RidsOgcRp	SWu, NRR
RidsNrrLAEWhitt	RidsAcrsAcnwMailCenter	

ADAMS Accession No. ML072610213

\*See previous concurrence    \*\*See SE

OFFICE	LPL3-2/PM	LPL3-2/PM	LPL3-2/LA	DSS/SNPB/BC	OGC - NLO	LPL3-2/BC	NRR/DORL/D
NAME	MThorpe-Kavanaugh*	RKuntz*	EWhitt*	AMendiola**	KWinsberg*	RGibbs*	Chaney (TMcGinty for)
DATE	9/ 26 /07	9/ 26 /07	9/ 26 /07	8/ 7 /07	9/ 26 /07	9/ 26 /07	9/27/07

OFFICIAL RECORD COPY

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION  
EXELON GENERATION COMPANY, LLC  
BRAIDWOOD STATION, UNIT 1  
DOCKET NO. STN 50-456  
EXEMPTION

1.0    BACKGROUND

Exelon Generation Company, LLC (Exelon, the licensee) is the holder of Facility Operating License No. NPF-72, which authorizes operation of Braidwood Station, Unit 1. The license provides, among other things, that the facility is subject to all rules, regulations, and orders of the Nuclear Regulatory Commission (NRC, the Commission) now or hereafter in effect.

The facility consists of two pressurized-water reactors located in Will County in Illinois.

2.0    REQUEST/ACTION

Title 10 of the *Code of Federal Regulations* (10 CFR), Part 50, Section 50.46, "Acceptance criteria for emergency core cooling systems for light-water nuclear power reactors," requires, in part, "that each boiling or pressurized light-water nuclear power reactor fueled with uranium oxide pellets within cylindrical Zircaloy or ZIRLO cladding must be provided with an emergency core cooling system (ECCS) that must be designed so that its calculated cooling performance following postulated loss-of-coolant accidents conforms to the criteria set forth in paragraph (b) of this section." 10 CFR Part 50, Appendix K, "ECCS Evaluation Models," requires, among other items, that the rate of energy release, hydrogen generation, and cladding oxidation from the metal/water reaction shall be calculated using the Baker-Just equation.

10 CFR 50.46 and 10 CFR Part 50, Appendix K make no provisions for use of fuel rods clad in a

material other than Zircaloy or ZIRLO.

The Braidwood, Unit 1 core consists of a combination of Westinghouse-designed VANTAGE 5 and VANTAGE+ fuel assemblies. Each fuel assembly has 264 fuel rods arranged in a 17 by 17 array. The licensee intends to insert up to eight fuel assemblies containing AREVA NP Inc. (AREVA) modified Advanced Mark-BW(A) (Advanced Mark-BW(A)) fuel. These assemblies will be placed in nonlimiting locations of the core during Cycles 15, 16, and 17. The Advanced Mark-BW(A) fuel assemblies are similar in design to the Advanced Mark-BW fuel assemblies using the approved M5 alloy for the cladding, structural tubing, and grids. The Advanced Mark-BW fuel design was approved in a topical report BAW-10239(P)-A, entitled "Advanced Mark-BW Fuel Assembly Mechanical Design Topical Report" (Advanced Mark-BW Topical Report).

The licensee requested an exemption from the requirements of 10 CFR 50.46 and 10 CFR Part 50, Appendix K to allow the use of fuel rods clad with AREVA's M5 alloy. The M5 alloys are proprietary alloys and chemically different from Zircaloy or ZIRLO fuel cladding materials which are approved for use. Therefore, a plant specific exemption from these regulations is required to support the use of the eight Advanced Mark-BW(A) fuel assemblies for Braidwood Station, Unit 1.

In summary, the licensee has requested an exemption from the requirements of 10 CFR 50.46 and 10 CFR Part 50, Appendix K, to allow the use of fuel assemblies containing Advanced Mark-BW(A) fuel design.

### 3.0 DISCUSSION

Pursuant to 10 CFR 50.12, the Commission may, upon application by any interested person or upon its own initiative, grant exemptions from the requirements of 10 CFR Part 50 when (1) the exemptions are authorized by law, will not present an undue risk to public health or safety, and are consistent with the common defense and security; and (2) when special circumstances are present. These circumstances include the special circumstances that

application of the regulation in 10 CFR 50.46 and 10 CFR Part 50, Appendix K is not necessary to achieve the underlying purpose of the rule.

Authorized by Law

This exemption would allow the licensee to load fuel assemblies containing Advanced Mark-BW(A) fuel at Braidwood Station, Unit 1. As stated above, 10 CFR 50.12 allows the NRC to grant exemptions from the requirements of 10 CFR 50.46 and 10 CFR Part 50, Appendix K. The NRC staff has determined that granting of the licensee's proposed exemption will not result in a violation of the Atomic Energy Act of 1954, as amended, or the Commission's regulations. Therefore, the exemption is authorized by law.

No Undue Risk to Public Health and Safety

The underlying purposes of 10 CFR 50.45 is to establish acceptance criteria for ECCS performance. Previously, the approved Advanced Mark-BW Topical Report demonstrated the acceptability of the M5 cladding under loss of coolant accident (LOCA) conditions. The unique features of the proposed fuel assemblies were evaluated for effects on the LOCA analysis. The results showed that the assemblies would not adversely affect the ECCS performance. Since the eight Advanced Mark-BW(A) fuel assemblies will be located at non-limiting core locations, the NRC concludes that the LOCA safety analyses will remain bounding for these assemblies at Braidwood Station, Unit 1.

Paragraph I.A.5 of 10 CFR Part 50, Appendix K states that the rates of energy, hydrogen concentration, and cladding oxidation from the metal-water reaction shall be calculated using the Baker-Just equation. Since the Baker-Just equation presumes the use of Zircaloy clad fuel, strict application of the rule would not permit use of the equation for the advanced zirconium-based and M5 alloys for determining acceptable fuel performance. The underlying intent of this portion of 10 CFR Part 50, Appendix K, however, is to ensure that analysis of fuel response to LOCAs is conservatively calculated. The approved Advanced Mark-BW Topical Report show that due to the similarities in the chemical composition of the M5 alloys and Zircaloy, the

application of the Baker-Just equation in the analysis of the M5 clad fuel rods will continue to conservatively bound all post-LOCA scenarios. Thus, application of 10 CFR Part 50, Appendix K, Paragraph I.A.5 is not necessary for the licensee to achieve its underlying purpose in these circumstances.

Based on the above, no new accident precursors are created by using the proposed Advanced Mark-BW(A) fuel assemblies at Braidwood Station, Unit 1, thus, the probability of postulated accidents is not increased. Also, based on the above, the consequences of postulated accidents are not increased. Therefore, there is no undue risk to public health and safety.

#### Consistent with Common Defense and Security

The proposed exemption would allow the use of Advanced Mark-BW(A) fuel assemblies at Braidwood Station, Unit 1. This change to the operation of the plant has no relation to security issues. Therefore, the common defense and security is not impacted by this exemption.

#### Special Circumstances

Special circumstances, in accordance with 10 CFR 50.12, are present whenever application of the regulation in the particular circumstances would not serve the underlying purpose of the rule, or is not necessary to achieve the underlying purpose of the rule. The underlying purpose of 10 CFR 50.46 is to establish acceptance criteria for ECCS performance. Since the eight Advanced Mark-BW(A) fuel assemblies will be located at non-limiting core locations, the NRC concludes that the LOCA safety analyses will remain bounding for these assemblies at Braidwood Station, Unit 1. The underlying purpose of 10 CFR Part 50, Appendix K is to ensure that analysis of fuel response to LOCAs is conservatively calculated. The approved Advanced Mark-BW Topical Report show that due to the similarities in the chemical composition of the M5 alloys and Zircaloy, the application of the Baker-Just equation in the analysis of the M5 clad fuel rods will continue to conservatively bound all post-LOCA scenarios. Thus, application of 10 CFR Part 50, Appendix K is not necessary for the licensee to

achieve its underlying purpose in these circumstances. Therefore, since the underlying purpose of 10 CFR 50.46 and 10 CFR Part 50, Appendix K is achieved, the special circumstances required by 10 CFR 50.12 for the granting of an exemption from 10 CFR 50.46 and 10 CFR Part 50, Appendix K exist.

4.0 CONCLUSION

Accordingly, the Commission has determined that, pursuant to 10 CFR 50.12, the exemption is authorized by law, will not present an undue risk to the public health and safety, and is consistent with the common defense and security. Also, special circumstances are present. Therefore, the Commission hereby grants Exelon, an exemption from the requirements of 10 CFR 50.46 "that each boiling or pressurized light-water nuclear power reactor fueled with uranium oxide pellets within cylindrical Zircaloy or ZIRLO cladding must be provided with an emergency core cooling system (ECCS) that must be designed so that its calculated cooling performance following postulated loss-of-coolant accidents conforms to the criteria set forth in paragraph (b) of this section," and 10 CFR Part 50, Appendix K that the rate of energy release, hydrogen generation, and cladding oxidation from the metal/water reaction shall be calculated using the Baker-Just equation for Braidwood Station, Unit 1.

Pursuant to 10 CFR 51.32, the Commission has determined that the granting of this exemption will not have a significant effect on the quality of the human environment (72 FR 52585).

This exemption is effective upon issuance.

Dated at Rockville, Maryland, this 27th day of September 2007.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

Tim McGinty, Acting Director  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

## **Braidwood Station, Units 1 and 2**

### **cc:**

Document Control Desk - Licensing  
via e-mail

Mr. Dwain W. Alexander, Project  
Manager  
Westinghouse Electric Corporation  
via e-mail

Ms. Bridget Little Rorem  
Appleseed Coordinator  
via e-mail

Howard A. Learner  
Environmental Law and Policy  
Center of the Midwest  
via e-mail

Braidwood Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
via e-mail

Ms. Lorraine Creek  
RR 1, Box 182  
Manteno, IL 60950

Illinois Emergency Management Agency  
Division of Disaster Assistance &  
Preparedness  
via e-mail

County Executive  
via e-mail

Attorney General  
500 S. Second Street  
Springfield, IL 62701

Plant Manager - Braidwood Station  
via e-mail

Site Vice President - Braidwood  
via e-mail

Senior Vice President - Operations  
Support  
via e-mail

Chairman, Ogle County Board  
Post Office Box 357  
Oregon, IL 61061

Manager Regulatory Assurance -  
Braidwood  
via e-mail

Director - Licensing and Regulatory  
Affairs  
via e-mail

Associate General Counsel  
via e-mail

Senior Vice President - Midwest  
Operations  
via e-mail

Vice President - Regulatory Affairs  
via e-mail

Manager Licensing - Braidwood, Byron  
and LaSalle  
via e-mail