



Serial: RNP-RA/07-0095

SEP 12 2007

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-261/LICENSE NO. DPR-23

CORRECTION TO TECHNICAL SPECIFICATIONS PAGE IN AMENDMENT 216

Ladies and Gentlemen:

License Amendment 216 for H. B. Robinson Steam Electric Plant, Unit No. 2, was issued in a July 16, 2007, letter from the NRC to Carolina Power and Light Company, "H. B. Robinson Steam Electric Plant, Unit No. 2 – Issuance of Amendment to Adopt Technical Specifications Task Force (TSTF) Standard TS Change Traveler, TSTF-447, Using the Consolidated Line Item Improvement Process (TAC No. MD4250)."

Prior to issuance of the Amendment, Carolina Power and Light Company, now doing business as Progress Energy Carolinas, Inc., had provided the NRC with camera-ready Technical Specifications (TS) pages for inclusion in the Amendment in a letter dated February 2, 2007. Subsequent review of these pages and discussion with the NRC has identified an error in camera-ready page 3.3-30 of TS Section 3.3.3 "Post Accident Monitoring." The error was then carried over into the issued Amendment.

The error involves the inadvertent omission of the change bar adjacent to the revised Action C in Section 3.3.3. Prior to the Amendment, Action C contained a note in the Condition column that stated:

"NOTE: Not applicable to hydrogen monitor channels."

Amendment 216 removed this note. However, the change bar was not included in the camera-ready pages provided for Amendment 216 due to an administrative oversight.

The corrected TS page is attached to this letter. The only change from the issued amendment is the editorial change to add the missing change bar.

A001

NCR

United States Nuclear Regulatory Commission

Serial: RNP-RA/07-0095

Page 2 of 2

If you have any questions concerning this matter, please call Curt Castell at (843) 857-1626.

Sincerely,

A handwritten signature in black ink that reads "C A Castell". The letters are cursive and connected.

C. A. Castell

Supervisor, Licensing/Regulatory Programs (Interim)

Attachment

RAC/rac

c: Dr. W. D. Travers, NRC, Region II
M. G. Vaaler, NRR
NRC Resident Inspector, HBRSEP

United States Nuclear Regulatory Commission
Attachment to Serial: RNP-RA/07-0095
2 Pages (including cover page)

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2

CORRECTION TO TECHNICAL SPECIFICATIONS PAGE IN AMENDMENT 216

CORRECTED TECHNICAL SPECIFICATIONS PAGE

Actions (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. One or more Functions with two required channels inoperable.	C.1 Restore one channel to OPERABLE status.	7 days
D. -----NOTE----- Only applicable to Functions 3, 4, 19, 22, 23, and 24. ----- One or more Functions with one required channel inoperable.	D.1 Restore required channel to OPERABLE status.	7 days
E. Required Action and associated Completion Time of Condition C or D not met.	E.1 Enter the Condition referenced in Table 3.3.3-1 for the channel.	Immediately
F. As required by Required Action E.1 and referenced in Table 3.3.3-1.	F.1 Be in MODE 3. <u>AND</u> F.2 Be in MODE 4.	6 hours 12 hours

(continued)