

(2) Technical Specifications

The Technical Specifications contained in Appendix A, revised through Amendment No. 240 and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto are hereby incorporated into the license. DNC shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

- (3) DNC shall not take any action that would cause Dominion Resources, Inc. (DRI) or its parent companies to void, cancel, or diminish DNC's commitment to have sufficient funds available to fund an extended plant shutdown as represented in the application for approval of the transfer of the licenses for MPS Unit No. 3.
- (4) Immediately after the transfer of interests in MPS Unit No. 3 to DNC, the amount in the decommissioning trust fund for MPS Unit No. 3 must, with respect to the interest in MPS Unit No. 3, that DNC would then hold, be at a level no less than the formula amount under 10 CFR 50.75.
- (5) The decommissioning trust agreement for MPS Unit No. 3 at the time the transfer of the unit to DNC is effected and thereafter is subject to the following:
- (a) The decommissioning trust agreement must be in a form acceptable to the NRC.
 - (b) With respect to the decommissioning trust fund, investments in the securities or other obligations of Dominion Resources, Inc. or its affiliates or subsidiaries, successors, or assigns are prohibited. Except for investments tied to market indexes or other non-nuclear-sector mutual funds, investments in any entity owning one or more nuclear power plants are prohibited.
 - (c) The decommissioning trust agreement for MPS Unit No. 3 must provide that no disbursements or payments from the trust, other than for ordinary administrative expenses, shall be made by the trustee until the trustee has first given the Director of the Office of Nuclear Reactor Regulation 30 days prior written notice of payment. The decommissioning trust agreement shall further contain a provision that no disbursements or payments from the trust shall be made if the trustee receives prior written notice of objection from the NRC.
 - (d) The decommissioning trust agreement must provide that the agreement can not be amended in any material respect without 30 days prior written notification to the Director of the Office of Nuclear Reactor Regulation.

EMERGENCY CORE COOLING SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- 2) A visual inspection of the containment sump and verifying that the subsystem suction inlets are not restricted by debris and that the sump components (strainers, etc.) show no evidence of structural distress or abnormal corrosion.

- e. At least once per 24 months by:
 - 1) Verifying that each automatic valve in the flow path actuates to its correct position on a Safety Injection actuation test signal, and
 - 2) Verifying that each of the following pumps start automatically upon receipt of a Safety Injection actuation test signal:
 - a) Centrifugal charging pump,
 - b) Safety Injection pump, and
 - c) RHR pump.
 - 3) Verifying that the Residual Heat Removal pumps stop automatically upon receipt of a Low-Low RWST Level test signal.

- f. By verifying that each of the following pump's developed head at the test flow point is greater than or equal to the required developed head when tested pursuant to Specification 4.0.5:
 - 1) Centrifugal charging pump
 - 2) Safety Injection pump
 - 3) RHR pump
 - 4) Containment recirculation pump

- g. By verifying the correct position of each electrical and/or mechanical position stop for the following ECCS throttle valves:
 - 1) Within 4 hours following completion of each valve stroking operation when the ECCS subsystems are required to be OPERABLE, and
 - 2) At least once per 24 months.

ECCS Throttle Valves

<u>Valve Number</u>	<u>Valve Number</u>
3SIH*V6	3SIH*V25
3SIH*V7	3SIH*V27