



RE: 0739-EQ

September 10, 2007

CERTIFIED MAIL 7006 0810 0004 5717 8651
RETURN RECEIPT REQUESTED

Ms. Roshini Nambiar
Enforcement and Compliance
DEPARTMENT OF ENVIRONMENTAL QUALITY
P.O. Box 1677
Oklahoma City, OK 73101-1677


Re: OPDES Permit OK0000191
Sequoyah Fuels Corporation

Dear Ms. Nambiar:

The pH measured during a storm water event at Outfall 008 was less than the permitted acceptable range of 6 to 9 on September 8, 2007. A value of 5.8 was measured during the 24 hour event. The pH ranged from 5.8 to 6.5 during the event. Andy Potter of the Oklahoma Department Environmental Quality was notified by phone voice mail on September 10th. The source of this exceedance is contaminated water present in Pond 2. This is a continuation of a problem that has persisted for the past several months and was described in a letter to you dated June 14, 2007. Planned corrective actions were also described in that letter.

If you have any questions or require further information, you may contact Scott Munson, Environmental Manager, at 918/489-5511 (Extension 20).

Sincerely,


Craig L. Harlin, Director
Regulatory Affairs

CLH:bt

Enclosures: As Stated Above

cc: Bob Evans, NRC Region IV
Myron H. Fliegel, NRC Headquarters