



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381

William J. Museler
Site Vice President, Watts Bar Nuclear Plant

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

JUL 09 1993

Gentlemen:

In the Matter of the Application of) Docket Nos. 50-390
Tennessee Valley Authority) 50-391

WATTS BAR NUCLEAR PLANT (WBN) - NRC INSPECTION REPORT NO. 390, 391/93-23 -
SUPPLEMENTAL RESPONSE TO NOTICE OF VIOLATION

This supplements TVA's letter of June 7, 1993, which responded to NRC's May 7, 1993 Notice of Violation concerning improper design control (390/93-23-02). TVA's June 7, 1993 letter committed to evaluate whether other design changes (DCNs) (i.e., in addition to the cited DCN) could have resulted in improper issuance of drawings which conflict with the field configuration. The cited violation had occurred due to a failure to properly consider all related design changes (i.e., predecessor relationships) for collective impact on drawing issuance.

The evaluation included a review of 10 electrical and mechanical design changes (DCNs) issued in 1992 or 1993, nine of which involved at least one predecessor DCN. The evaluation determined that predecessor change documents were correctly identified in eight of nine cases. Although in one example a predecessor DCN was not referenced in its associated successor DCN, both DCNs had been correctly incorporated into the affected drawing in the proper sequence. Based on the results of this evaluation, no further reviews are considered necessary.

Current engineering procedures and drawing practices ensure that when appropriate consideration is given to predecessor DCNs, issued drawings will incorporate the required information from predecessor and successor DCNs and will agree with the plant configuration.

Should there be any questions regarding this information, please telephone P. L. Pace at (615) 365-1824.

Very truly yours,

William J. Museler

Enclosure

cc: See page 2

9307200296 930709
PDR ADDCK 05000390
G PDR

90085

IFEO/
1/0

U.S. Nuclear Regulatory Commission
Page 2

JUL 09 1993

cc (Enclosure):

NRC Resident Inspector
Watts Bar Nuclear Plant
P.O. Box 700
Spring City, Tennessee 37381

Mr. P. S. Tam, Senior Project Manager
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323