



NOTES

1. 1/2" DIA. MATCHING PLATE TO FILTER PLENUM OUTLET WITH HOLE CUT IN CTR. OF PLATE TO MATCH INLET BELL TO FAN. HOLE INLET BELL TO MATCH INLET PLATE.
2. 1/2" DIA. MATCHING PLATE TO FILTER PLENUM INLET WITH HOLE CUT IN CTR. OF PLATE TO MATCH INLET BELL TO FAN. HOLE INLET BELL TO MATCH INLET PLATE.
3. 25/32" DIA. 1/2" DIA. STUD BOLTS, HEX NUTS W/LOCK WASHERS MATCHING 1/2" DIA. 1/2" DIA. HOLES IN FIELD.

- GENERAL NOTES:**
1. ALL SUPPLY DUCT SHALL BE LINED WITH 1" FIBER GLASS. SIZES SHOWN NET INTERNAL.
 2. SEE ARCH. DWGS. FOR LOUVER LOCAT.
 3. 3 HOUR (CLASS A) CURTAIN TYP. FIRE DOOR IN DUCT.
- NOTE: FOR FLOOR & WALL PENETRATIONS OF NEW HAV WORK, SEE CIVIL DWG. 5-800, 5-401 & 5-412

NOTES:

1. AIRTIGHT DUCT RUNNING OUTDOORS ALONG BUILDING WALL BETWEEN EXIT FROM AUX. BUILDING ADD. COL. G-23 TO ENTRANCE OF EXISTING BUILDING STACK PLENUM. SET. COL. G-19.5 AND J-19.5 SHALL BE REINFORCED AS REQUIRED TO WITHSTAND WIND LOADS AND SNOW LOADS, EACH AT 50#/SQ. FT.

REV.	DATE	DESCRIPTION	BY	CHK	APP.
6-26-07		REVISED PER CONTROL ROD DRIVE MECHANISM PER EC922 AND EC10061	DMB	MJC	MTN
22-09-15-03		REVISED TO RELOCATE DUCT PER EAR-00-0685 AND DCR 03-493 (REDRAWN ON CAD)	DMB	JDA	
Consumers Energy					
PALISADES PLANT			M120-1.CIT		
HEATING & VENTILATION AUXILIARY & CONTAINMENT					
PLAN AT ELEVATION 639'-0" & 649'-0"					
PASSPORT DOC. NO.			DRAWING NUMBER		

D-02X