

NOTICE OF DEVIATION

Tennessee Valley Authority
Watts Bar Unit 1

Docket No. 50-390
License No. CPPR-91

During an NRC inspection conducted August 21 through September 17, 1992, deviations of written commitments were identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1992), the deviations are listed below:

Tennessee Valley Authority Final Report WBRD-50-390/86-22 and WBRD-50-391/86-18, Incorrect Use of Typical Supports on Instrument Sense Lines, dated February 13, 1986, described corrective actions to correct design deficiencies associated with instrument line supports. This report was provided to NRC in accordance with 10 CFR 50.55(e).

Specifically, the report specified that TVA:

1. Will identify all 47A051-35 typical supports which are not installed in accordance with drawings 47A051-35 and 35A.
2. Will rework all deficient supports to conform to drawing requirements or deviation approval, via support variance sheets, will be obtained from the TVA's Office of Engineering on a case by case basis.
3. Will reinspect all 47A051-35 typical supports in accordance with WBNP Quality Control Procedures ... for Unit 1 ... and Unit 2 to ensure compliance with drawing requirements.

Contrary to the above, in August 1992 it was determined that the licensee had eliminated the commitments and implemented a sampling program to inspect instrument line supports without notifying the NRC of a change to the commitments specified in the report.

Please provide to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555, with a copy to the Regional Administrator, Region II, and a copy to the NRC Resident Inspector, Watts Bar, in writing within 30 days of the date of this Notice, the reason for the deviation, the corrective steps that have been taken and the results achieved, the corrective steps that will be taken to avoid further deviations, and the date when your corrective action will be completed. Where good cause is shown, consideration will be given to extending the response time.

Dated at Atlanta, Georgia
this 16th day of October 1992