Appendix C		Job Performan Worksh	ce Measure neet	Form ES-C-1
Facility:	Ginna		Task No.:	015-004-04-01A
Task Title:	Calculate QPTR	<u>l</u>	JPM No.:	<u>2007 NRC JPM ADMIN</u> <u>A1a</u>
K/A Reference:	GK\A 2.1.7 (3.7∖	4.4)		
Examinee:			NRC Examine	r:
Facility Evaluator:			Date:	
Method of testing:				
Simulated Perform	ance:		Actual Perform	nance: X
Classr	oomSi	mulator X	Plant	

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Initial Conditions:	The reactor is operating at approximately 65%	6 power (MOL).	
	Power Range Channel NI 41 has failed and b in accordance with ER-NIS.3.	een removed from service	
	Control Rod D10 has recently dropped into th	e Core.	
	The PPCS is unavailable.		
Task Standard:	All critical tasks evaluated as satisfactory.		
Required Materials:	Calculator		
	Curve Book		
General References:	O-6.4, Core Quadrant Power Tilt Calculation		
	Technical Specifications		
Handouts:	None		
Initiating Cue:	Calculate Quadrant Power Tilt for the present	conditions and take any	
unital good	necessary action.		
Time Critical Task:	NO		
2007 NRC Admin JPN	2007 NRC Admin JPM A1a NUREG 1021, Revision 9		

Validation Time: 12 minutes

SIMULATOR SETUP

Initiate to any 100% IC.
 Remove one PR NI Instrument (N41) from service in accordance with ER-NIS.3.
 Insert Malfunction ROD22-02-D10.

The PPCS is unavailable.

- Ensure that Curve Book is current and available.
- Place simulator in RUN.
- Freeze the Simulator (JPM is conducted with the Simulator in Freeze)

OR

- Initiate to IC 174.
- Ensure that Curve Book is current and available.
- Place simulator in RUN.
- Freeze the Simulator (JPM is conducted with the Simulator in Freeze)

1

(Denote Critical Steps with a check mark)		
	O-6.4 Step 6.1.1	
Performance Step: 1	If one power range channel is inoperable, then ensure the QPTR Monitor alarm has been declared non-functional and perform TSR 3.2.4.2	
Standard:	Verifies that the QPTR Monitor alarm has been declared non- functional and that TSR 3.2.4.2 has been performed.	
Comment:	Examiner Cue that both actions have been taken.	
	O-6.4 Step 6.1.2	
Performance Step: 2	If one power range channel is inoperable and thermal power is < 75% of RTP, calculate the QPTR using the remaining three power range channels.	
Standard:	Determines that QPTR can be calculated with the remaining three power range channels.	
Comment:		
	O-6.4 Step 6.1.4	
Performance Step: 3	Calculate the QPTR using Attachment 1, Quadrant Power Tilt Ratio Calculation.	
Standard:	Refers to Attachment 1 or obtains a computer generated form and verifies that it is current with O-6.4, Attachment 1.	
Comment:		

 $S_{\rm end}$

Appendix C	Page 5 of 9	Form ES-C-1
	PERFORMANCE INFORMATION	
	O-6.4 Attachment 1	
$\sqrt{-}$ Performance Step: 4	Record the N42 Upper Mamps, as well as Mamps. Record the Volts/Mamps convers the Curve Book. Calculate both N42 Uppe then determine total volts for N42.	the N42 Lower sion from Section 2 of r and Lower volts, and
Standard:	Reads power range channel N42 and Rec Lower Mamps on Attachment 1	ords N42 Upper and
	Obtains N42 Upper and Lower Volts/Mam Section 2 of Curve Book and Records on A	ps Conversion from Attachment 1.
	Determines N42 Upper volts by multiplying N42 Upper Volts/Mamps Conversion and Attachment 1.	g Upper Mamps by recording on
	Determines N42 Lower volts by multiplying N41 Lower Volts/Mamps Conversion and Attachment 1.	g Lower Mamps by recording on
	Determines total N42 volts by adding Upp	er and Lower volts.
Comment:		
	O-6.4 Attachment 1	
$\sqrt{-}$ Performance Step: 5	Record the N43 Upper Mamps, as well as Mamps. Record the Volts/Mamps convers the Curve Book. Calculate both N43 Uppe then determine total volts for N43.	the N43 Lower sion from Section 2 of r and Lower volts, and
Standard:	Reads power range channel N43 and Rec Lower Mamps on Attachment 1	ords N43 Upper and
	Obtains N43 Upper and Lower Volts/Mam Section 2 of Curve Book and Records on A	ps Conversion from Attachment 1.
	Determines N43 Upper volts by multiplying N43 Upper Volts/Mamps Conversion and Attachment 1.	g Upper Mamps by recording on
	Determines N43 Lower volts by multiplying N43 Lower Volts/Mamps Conversion and Attachment 1.	g Lower Mamps by recording on
	Determines total N43 volts by adding Upp	er and Lower volts.
Comment:		

F.

Appendix C		Page 6 of 9	Form ES-C-1
		PERFORMANCE INFORMATION	
		O 6 4 Attachment 1	
,			
V	Performance Step: 6	Record the N44 Upper Mamps, as well as Mamps. Record the Volts/Mamps convers the Curve Book. Calculate both N44 Upper then determine total volts for N44.	the N44 Lower ion from Section 2 of r and Lower volts, and
	Standard:	Reads power range channel N44 and Reco Lower Mamps on Attachment 1	ords N44 Upper and
		Obtains N44 Upper and Lower Volts/Mamp Section 2 of Curve Book and Records on A	os Conversion from Attachment 1.
		Determines N44 Upper volts by multiplying N44 Upper Volts/Mamps Conversion and r Attachment 1.	Upper Mamps by ecording on
		Determines N44 Lower volts by multiplying N44 Lower Volts/Mamps Conversion and r Attachment 1.	Lower Mamps by ecording on
		Determines total N44 volts by adding Uppe	er and Lower volts.
	Comment:		
		O-6.4 Attachment 1	
	Performance Step: 7	Calculate QPTR by determining the highes volts and multiplying by 3. Then, divide the total of the PR channel 42, 43 and 44 volts	st PR channel total e product by the sum
	Standard:	Determine the power range channel with the and multiply by three.	ne highest total volts
		Add the total volts for PR channels N42, N	43 and N44.
		Divide the product of the first by the sum o	f the second.
		Determine QPTR to be approximately 1.18	8.
	Comment:	Examiner cue Examinee that an indeper yielded in the same results.	ndent calculation has

4

 \mathbf{e}_{i_2}

Appendix C	Page 7 of 9	Form ES-C-1
	PERFORMANCE INFORMATION	
	Ω_{-6} / Step 6.1.5	
Derformance Step: 9	If OPTR is greater than 1.01 then notify the Br	eactor Engineer
Performance Step: 8	I QFTHIS greater that 1.01 then noting the ric	
Standard:	Recognizes that QPTR is > 1.01 and notifies F	Reactor Engineer.
Comment:	Simulator Operator acknowledges as react	or engineer.
	O-6.4 Step 6.1.6	
Performance Step: 9	If QPTR is greater than 1.02 then refer to ITS	3.2.4.
Standard:	Recognizes that QPTR is > 1.02 and refers to	ITS 3.2.4.
Comment:		
	Technical Specification 3.2.4	
Performance Step: 10	Address LCO 3.2.4 and determine if ACTION	is required.
Standard:	Determines that for current power level LCO 3 and not being met.	3.2.4 is applicable,
	Determines that Action Condition A is in effect	t.
	Determines that power must be reduced 54%	from present.
	Determines need to calculate QPTR once eve	ery 12 hours.
	Determines that SR 3.2.1.1, 3.2.1.2 and 3.2.2 completed every 7 days.	.1 must be
	Identifies that the Technical Specification is no 50%.	ot applicable <
Comment:		
Terminating Cue:	Evaluation on this JPM is complete.	
STOP TIME:	TIME CRITICAL STOP TIME:	:

i ...

Page 8 of 9 VERIFICATION OF COMPLETION

Job Performance Measure No.:	2007 NRC Admin JF	P <u>M A1a</u>	
Examinee's Name:			
Date Performed:			
Facility Evaluator:			
Number of Attempts:			
Time to Complete:			
Question Documentation:			
Question:			
Response:			
Result:	SAT UN	NSAT	
Examiner's Signature:		Date:	

ndix C	Page 9 of 9	Form ES-C-
	JPM CUE SHEET	
AL CONDITIONS:	The reactor is operating at approximately	65% power (MOL).
	Power Range Channel NI 41 has failed a service in accordance with ER-NIS.3.	nd been removed from
	Control Rod D10 has recently dropped in	to the Core.
	The PPCS is unavailable.	
ATING CUE:	Calculate Quadrant Power Tilt for the pre	sent conditions and tal
ATING CUE:	Calculate Quadrant Power Tilt for the pre any necessary action.	sent conditions

%

440

18c. .

Appendix C	Page 1 d	of 7	Form ES-C-1
	PERFORMANCE I	NFORMATION	
Facility:	Ginna	Task No.:	
Task Title:	Verify Required Service Water to Emergency Diesel Generators	JPM No.:	2007 NRC JPM ADMIN A1b
K/A Reference:	GK\A 2.1.25 (2.8\3.1)		
Examinee:		NRC Examine	n.
Facility Evaluator:		Date:	
Method of testing:			
Simulated Performance:		Actual Perform	ance: X
Class	room X Simulator	_ Plant	

READ TO THE EXAMINEE

14.1

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Initial Conditions:	The reactor is operating at 100% power, Steady-State conditions at MOL.
	The Daily Surveillance is in progress.
	The SW Controlotron flow instrumentation is unavailable.
	The A, B and C Service Water Pumps are operating.
	Lake Temperature is 69°F.
	SW ΔP for A EDG Lube Oil Cooler is 7.1 PSID.
	SW ΔP for A EDG Jacket Water Heat Exchanger is 10.2 PSID.
	SW ΔP for B EDG Lube Oil Cooler is 5.8 PSID.
	SW ΔP for B EDG Jacket Water Heat Exchanger is 11.5 PSID.
Task Standard:	All critical tasks evaluated as satisfactory.
Required Materials:	None
General References:	O-6.13, Daily Surveillance Log, Rev. 163 Technical Specifications
Handouts:	None

Appendix C	Page 2 of 7 PERFORMANCE INFORMATION	Form ES-C-1
Initiating Cue:	Verify that the EDG Service Water Differential Pres within required limits, and if not, identify required ac	sures (ΔPs) are ction.
Time Critical Task:	NO	
Validation Time:	10 minutes	

-

۰.

.

(Denote Critical Steps with a check mark)			
START TIME:			
	O-6.13 Step 6.4.3 (1) a		
Performance Step: 1	If current Emergency D/G SW inlet flowrates are known as measured by the Controlotron, the use Attachment 13 for SW D/P limits for Lube Oil and Jacket Water coolers.		
Standard:	Recognize that the SW Inlet flowrates are unknown because the Controlotrons are out of service, and that the use of Attachment 13 is unwarranted.		
Comment:			
	O-6.13 Step 6.4.3 (1) b		
Performance Step: 2	If current Emergency D/G SW inlet flowrates are unknown, then use Attachment 12 for SW D/P limits for Lube Oil and Jacket Water coolers.		
Standard:	Recognize that SW inlet flowrates are unknown, and that Attachment 12 may be applicable.		
Comment:			
	O-6.13 Step 6.4.3 (1) c		
Performance Step: 3	If lake temperature is < 70° F or > 80° F, and SW inlet flowrates are unknown, then use Attachment 14 as necessary.		
Standard:	Recognizes that the lake temperature is $< 70^{\circ}$ F and that this requires the use of Attachment 14 rather than Attachment 12.		
	Uses Attachment 14 to identify that for three Service Water Pumps in operation, and a lake temperature of 69°F, the B EDG Jacket Water Cooler and the A EDG Lube Oil Cooler Δ Ps are above the allowable limits.		
Comment:			

Ар	pendix C	Page 4 of 7 PERFORMANCE INFORMATION	Form ES-C-1
		O-6.13 Attachment 14, Step 1	
	Performance Step: 4	If the ΔP across any Diesel Generator content then refer to Step 6.4.3.(1).c for True Ope	oler exceeds the limits erability Limits.
	Standard:	Recognizes that because the B EDG Jac the A EDG Lube Oil Cooler Δ Ps are above must obtain True Operability Limits using	ket Water Cooler and ve the allowable limits, Step 6.4.3.(1)b.
	Comment:		
		O-6.13 Step 6.4.3 (1)b	
	Performance Step: 5	If current Emergency D/G SW inlet flowra use Attachment 12 for SW D/P limits for I Water coolers.	tes are unknown, then Lube Oil and Jacket
	Standard:	Recognizes that the True Operability Lim Water Cooler is 10.5 psid, and the A EDC psid.	it for B EDG Jacket 3 Lube Oil Cooler is 6.2
		Recognizes that the B EDG Jacket Water Lube Oil Cooler ΔPs are above the allow	r Cooler and the A ED(able limits.
	Comment:		
		O-6.13 Attachment 12*	
\checkmark	Performance Step: 6	If the ΔP is within 1 psig of the limit then plackflush and write a Condition Report.	perform a cooler
	Standard:	Recognizes that all four Heat Exchanger the allowable limits.	ΔPs are within 1psig o
		Recognizes that all four Heat Exchangers	s require flushing.
		Recognizes the need to write a Condition	n Report.
	Comment:	When appropriate, Examiner cue exan Condition Report will be written by and not part of exam)	ninee that the other individual. (i.e.

Ap	pendix C	Page 5 of 7 PERFORMANCE INFORMATION	Form ES-C-1
		O-6.13 Step 6.4.3 (1) d	
	Performance Step: 7	If the ΔP across any Diesel generator coole specified above, then ensure that the affect inoperable.	er exceeds the limits ted Diesel is declared
	Standard:	Recognizes that Both EDGs are affected an and B EDG inoperable.	nd declares both the A
	Comment:		
		Technical Specification 3.8.1	
Performance Step: 8		Address Technical Specification LCO 3.8.1 required.	and determine action
	Standard:	Determines that the LCO is not met, Condit LCO 3.0.3 must be entered immediately.	tion E exists, and that
	Comment:		
Те	rminating Cue:	Evaluation on this JPM is complete.	
~ -			

Appendix C	Page 6 of 7 VERIFICATION OF COMPLETION	Form ES-C-1
Job Performance Measure No.:	2007 NRC Admin JPM A1b	
Examinee's Name:		
Date Performed:		
Facility Evaluator:		
Number of Attempts:		
Time to Complete:		
Question Documentation:		
Question:		
Response:		
Result:	SAT UNSAT	
Examiner's Signature:	Date:	

.

Appendix C	Page 7 of 7	Form ES-C-1		
	JPM CUE SHEET			
INITIAL CONDITIONS:	The reactor is operating at 100% power, Ste	ady-State conditions		
	at MOL,	•		
	The Daily Surveillance is in progress.			
	The SW Controlotron flow instrumentation is unavailable.			
	The A, B and C Service Water Pumps are o	perating.		
	Lake Temperature is 69°F.			
	SW ΔP for A EDG Lube Oil Cooler is 7.1 PS	ID.		
	SW ΔP for A EDG Jacket Water Heat Excha	anger is 10.2 PSID.		
	SW ΔP for B EDG Lube Oil Cooler is 5.8 PS	SID.		
	SW ΔP for B EDG Jacket Water Heat Excha	anger is 11.5 PSID.		
	Varify that the EDC Service Mater Differenti	al Brooduran (ADa)		
INITIATING CUE:	are within required limits, and if not, identify	required action.		

4.-

 \mathbf{z}_{i}

Appendix C	Page 1	Form ES-C-1			
	PERFORMANCE				
Facility:	Ginna	Task No.:			
Task Title:	Determine if the Electrical System is JPM No.: Aligned for Mode 6 Operation		2007 NRC JPM ADMIN A2		
K/A Reference:	GK\A 2.2.26 (2.5\3.7)				
Examinee:		NRC Examiner:	:		
Facility Evaluator:	Date:				
Method of testing:					
Simulated Perform	ance:	Actual Performa	ance: <u>X</u>		
Classr	com X Simulator	Plant			

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Initial Conditions: The

The Plant is in Mode 5 with RHR in operation.

Preparations are being made to enter Mode 6 and to refuel the reactor.

The following Electrical Distribution System components are Operable meeting **all** Technical Specification surveillance requirements in accordance with O-6.11, and other surveillance documents:

- Circuit 7T powering Bus 12A
- A Emergency Diesel Generator (EDG)
- A EDG Fuel Oil Tank (Level 5200 gallons)
- Safeguards Busses 14 and 18
- Busses 13 and 16 are energized from Bus 14 tie breakers
- Bus 15 is powered from Bus 16 through tie breaker
- MCC C and D
- Main DC Battery B
- Battery Chargers B and B1
- Main DC Distribution Panel B
- TSC Battery Charger and Cabling connected to Main Distribution Panel A at 129 volts.
- Main DC Distribution Panel A
- Instrument Bus A powered from Inverter A which is operating normally
- Instrument Bus B on CVT which is operating normally

Appendix C	Page 2 of 9	Form ES-C-1	
	PERFORMANCE INFORMATION		
	 Instrument Bus C powered from Inverter B white normally 	ch is operating	
All other electrical Distribution equipment has been secured, and tag out for maintenance.			
	The Diesel Fuel Oil Properties are verified within the Fuel Oil Testing Program.	ne limits of the Diesel	
Task Standard:	All critical tasks evaluated as satisfactory.		
Required Materials:	None		
General References:	O-15.1, Administrative Requirements For Checklis 6, And Refueling Conditions, Rev. 29	t For Entry To Mode	
Handouts:	None		
Initiating Cue:	Determine whether or not the Electrical Distribution entry into Mode 6. Justify your conclusion.	n Systems will support	
Time Critical Task:	No		
Validation Time:	10 minutes		

(Denote Critical Steps with	a check mark)
START TIME:	
	O-15.1 Step 6.1.6 (1)
Performance Step: 1	Verify one independent off-site source is operable or backfeed through Unit Aux Transformer 11 by:
	CKT 767 is operable.
	CKT 7T is operable.
	Unit Transformer Backfeed is in place.
Standard:	Recognizes Circuit 7T is operable.
	Recognizes that Circuit 767 and Unit Aux Transformer are out of Service.
Comment:	
	O-15.1 Step 6.1.6 (2)
Performance Step: 2	Ensure Diesel Generator A and Safeguards Busses 14 and 18 are operable.
	or
	Ensure Diesel Generator B and Safeguards Busses 16 and 17 are operable.
Standard:	Recognizes that Diesel Generator A and Safeguards Busses 14 and 18 are operable.
	Recognizes that Diesel Generator B and Safeguards Busses 16 and 17 are out of service.
Comment:	

pendix C	Page 4 of 9 PERFORMANCE INFORMATION	Form ES-C-1
	O-15.1 Step 6.1.6 (3)	
Performance Step: 3	Verify \geq 5000 gallons of fuel oil available p	er operable Diesel.
	Verify that the Diesel Fuel Oil Properties a the Diesel Fuel Oil Testing Program (DFO	re within the limits of TP).
Standard:	Recognizes that Fuel Tank is operable.	
	Recognizes that the Fuel Oil properties are	e within the DFOTP
Comment:		
	O-15.1 Step 6.1.6 (4)	
Performance Step: 4	Verify operable safeguards busses are wit	hin voltage limits.
Standard:	Recognizes that Safeguards Busses 14 ar	nd 18 are operable.
Comment:		
	O-15.1 Step 6.1.6 (5)a	
Performance Step: 5	Verify DC Source Train A is operable by e DC Battery A, and Battery Chargers A and	nsuring that the Main A1 are operable.
Standard:	Recognizes that Train A DC Power source	es are out of service.
Comment:		
	O-15.1 Step 6.1.6 (5)b	
Performance Step: 6	Verify DC Source Train B is operable by e DC Battery B, and Battery Chargers B and	nsuring that the Main I B1 are operable.
Standard:	Recognizes that Train B DC Power source	es are operable.
Comment:		

'λ.

s. .

Appendix C	Page 5 of 9	Form ES-C-1
	PERFORMANCE INFORMATION	
	O-15.1 Step 6.1.6 (5)c	
Performance Step: 7	If TSC Battery Charger is used for the second that TSC Battery Charger is supplying a manual operable between 130.2 and 140 volts.	nd DC source, verify ain DC Bus and
Standard:	Recognizes that the TSC Battery Charger a connected to Main Distribution Panel A at 1 is insufficient voltage.	and Cabling is 29 volts, and that this
Comment:		
	O-15.1 Step 6.1.6 (5)d	
Performance Step: 8	8 Verify that DC Trains and Main DC Batterie voltage limits.	s are within DC
Standard:	Recognizes that Main Battery B, DC Train I operable.	B and DC Train A are
Comment:		
	O-15.1 Step 6.1.6 (5)e(1)	
Performance Step: 9	Verify Instrument Bus A is energized from t maintenance feed breaker.	he normal feed or the
Standard:	Recognizes that Instrument Bus A is power feed breaker.	red from the normal
Comment:		
	O-15.1 Step 6.1.6 (5)e(2)	
Performance Step: 1	10 Verify INVTCVTA INVERTER A output Bre	aker is on.
Standard:	Recognizes that output breaker is on (Inver normally).	ter operating
Commont.		
COMMENT		

Appendix C	Page 6 of 9	Form ES-C-1
Appendix C		
	O-15.1 Step 6.1.6 (5)e(3)	
Performance Step: 11	Verify INVTCVTA INVERTER A STATIC SV	
	POSITION light is illuminated.	
Standard:	Becognizes that Static Switch in Inverter Po	sition light is
	illuminated (Inverter operating normally).	
Comment		
Comment.		
	O-15.1 Step 6.1.6 (5)e(4)	
Performance Step: 12	Verify Instrument Bus B is energized from the	ne normal feed or the
•	maintenance feed breaker.	
Standard:	Recognizes that Instrument Bus B is power	ed from the normal
	feed breaker.	
Comment:		
	O-15.1 Step 6.1.6 (5)e(5)	
Performance Step: 13	Verify MCC C position 4H breaker is on.	
Standard:	Recognizes MCC C position 4H breaker is a	מר
Commont		
Comment:		
	O-15.1 Step 6.1.6 (5)e(6)	
Performance Step: 14	Verify Instrument Bus C is eperaized from the	ne normal feed or the
	maintenance feed breaker.	
Standard:	Recognizes that Instrument Rus C is nower	ed from the normal
	feed breaker.	ve nom and hornat
Comment:		

· e ...

·

Appendix C	Page 7 of 9	Form ES-C-1
	PERFORMANCE INFORMATION	
	O-15.1 Step 6.1.6 (5)e(7)	
Performance Step: 15	Verify INVTCVTA INVERTER B output Bre	eaker is on.
Standard:	Recognizes that output breaker is on (Invenormally).	erter operating
Comment:		
	O-15.1 Step 6.1.6 (5)e(8)	
Performance Step: 16	Verify INVTCVTA INVERTER A STATIC S POSITION light is illuminated.	WITCH IN INVERTER
Standard:	Recognizes that Static Switch in Inverter F illuminated (Inverter operating normally).	Position light is
Comment:		
	O-15.1 Step 6.1.6 (5)e(9)	
Performance Step: 17	Verify operable Instrument Busses are with	hin voltage limits.
Standard:	Recognizes that Instrument Busses A, B a voltage limits are within normal range.	and C are operable and
	Concludes that the Electrical Distribution S support entry into Mode 6 due to insufficie TSC Battery Charger.	Systems will NOT nt voltage from the
Comment:	, <u> </u>	
Terminating Cue:	Evaluation on this JPM is complete.	
STOP TIME:	TIME CRITICAL STOP TH	ME:

·k. .

4

 $z_{\rm el}$

Page 8 of 9 VERIFICATION OF COMPLETION

Form ES-C-1

Job Performance Measure No.:	2007_NRC Admir	1 JPM A2	
Examinee's Name:			
Date Performed:			
Facility Evaluator:			
Number of Attempts:			
Time to Complete:			
Question Documentation:			
Question:			
Response:			
Result:	SAT	UNSAT	
Examiner's Signature:			Date:

Appendix C	Page 9 of 9	Form ES-C-1
	JPM CUE SHEET	
INITIAL CONDITIONS:	The Plant is in Mode 5 with RHR in oper	ation.
	Preparations are being made to enter Me reactor.	ode 6 and to refuel the
	The following Electrical Distribution Syst Operable meeting all Technical Specifica requirements in accordance with O-6.11 documents:	em components are ation surveillance , and other surveillance
	Circuit 7T powering Bus 12A	
	A Emergency Diesel Generator (EDC	3)
	A EDG Fuel Oil Tank (Level 5200 ga	llons)
	Safeguards Busses 14 and 18	
	Busses 13 and 16 are energized from	n Bus 14 tie breakers
	Bus 15 is powered from Bus 16 through the second seco	ugh tie breaker
	MCC C and D	
	Main DC Battery B	
	Battery Chargers B and B1	
	Main DC Distribution Panel B	
	 TSC Battery Charger and Cabling co Distribution Panel A at 129 volts 	nnected to Main
	Main DC Distribution Panel A	
	 Instrument Bus A powered from Inve normally 	rter A which is operating
	Instrument Bus B on CVT which is op	perating normally
	 Instrument Bus C powered from Inve normally 	rter B which is operating
	All other electrical Distribution equipmer tagged out for maintenance.	nt has been secured, and
	The Diesel Fuel Oil Properties are verifie Diesel Fuel Oil Testing Program.	ed within the limits of the
INITIATING CUE:	Determine whether or not the Electrical I support entry into Mode 6. Justify your of	Distribution Systems will conclusion.

·***

ł

Appendix C	Page 1 o PERFORMANCE IN	f 8 FORMATION	Form ES-C-1
Facility:	Ginna	Task No.:	<u> </u>
Task Title:	Respond to a Contaminated Injure	d JPM No.:	<u>2007 NRC JPM ADMIN</u> <u>A3</u>
K/A Reference:	GK\A 2.3.10 (2.9\3.3)		
Examinee:		NRC Examiner	:
Facility Evaluator:		Date:	
Method of testing:			
Simulated Performa	ance:	Actual Perform	ance: X
Classro	oom X Simulator	Plant	

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Initial Conditions:	The Reactor is operating at 100% power, Steady-State, MOL.
Task Standard:	All critical tasks evaluated as satisfactory.
Required Materials:	None
General References:	A-7, Procedure for Handling Injuries/Medical Emergencies at Ginna Station, Rev. 10000 EPIP 1-5, Notifications, Rev. 72 O-9.3, NRC Immediate Notification, Rev. 58 NUREG-1022
Handouts:	None
Initiating Cue:	The Control Room receives a call from an Auxiliary Operator in the Intermediate Building (Hot Side) indicating that a Chemist has received serious steam burns while performing RCS sampling activities. The AO reports that the sampling system is stabilized and no radioactive releases are in progress. However, the Chemist is in pain, and most
	likely contaminated.

ŀ

Validation Time: 8 minutes

• •

à,

c

(Denote Critical Steps with a check mark)

Page 3 of 8 PERFORMANCE INFORMATION

ST	ART TIME:	
		A-7 Step 4.2.1, 4.2.2 and Attachment 1
\checkmark	Performance Step: 1	Make and announcement over the PA and have the Medical Emergency Response Team respond.
	Standard:	An announcement is made indicating that there is a major medical emergency in the Intermediate Building (Hot Side), Medical Team respond, and all others remain clear of the area.
	Comment:	
		A-7 Attachment 1
	Performance Step: 2	Make a follow-up announcement if conditions or locations have changed.
	Standard:	Note pending action and make additional announcements if necessary.
	Comment:	
		A-7 Attachment 1
1	Performance Step: 3	Dispatch the Fire Brigade Captain to the scene to assist with communication, ensure plant equipment is secure, and to report to the Control Room if any additional needs arise, or conditions change.
	Standard:	Contacts and dispatches Fire Brigade Captain to the scene.
	Comment:	After completion of step, Examiner cue examinee that the Communicator reports to the Control Room.

Ap	pendix C	Page 4 of 8	Form ES-C-1
		PERFORMANCE INFORMATION	
		A-7 Attachment 1	
\checkmark	Performance Step: 4	Direct Communicator to perform Appendix A.	
	Standard:	Directs Communicator to perform Appendix A	λ.
	Comment:	After step, Examiner cue the examinee that Captain reports that the Medical Team Lea an Ambulance, and the RP Technician has the patient is radioactively contaminated. Chemist has revealed that skin contaminated high as 30,000 μ c/100cm ² .	at the Fire Brigade ader has requested determined that Direct frisk of the tion levels are as
		A-7 Attachment 1	
	Performance Step: 5	Perform EPIP 1-5, Notifications, Attachment, Off-Site Assistance has been requested.	Notifications when
	Standard:	Addresses EPIP 1-5.	
	Comment:		
		EPIP 1-5 Step 6.1.5	
\checkmark	Performance Step: 6	When Off-Site assistance has been requested Attachment 5.	d, implement
	Standard:	Addresses EPIP 1-5, Attachment 5.	
	Comment:	NOTE: Examinee may elect to have the co the notifications required by EPIP 1-5, Atta this is acceptable, move forward to Perfor	ommunicator make achment 5. If so, mance Step 11.

÷

ppendix C	Page 5 of 8	Form ES-C-1
	PERFORMANCE INFORMATION	
	EPIP 1-5 Attachment 5, Step 2	
Performance Step: 7	Contact Security so that they can make prep arrival of the emergency vehicles and persor	arations for the nnel.
Standard:	Contacts Security and lets them know that an arriving at the station.	n ambulance will be
Comment:	Examiner cue examinee that Security has	been contacted.
	EPIP 1-5 Attachment 5, Step 3	
Performance Step: 8	Contact Ginna Management to act as a liaiso Control Room and Ginna corporate manager	on between the ment.
Standard:	Contacts one individual identified in procedu they act as a liaison between the Control Ro corporate management.	re and requests that om and Ginna
Comment:	Examiner cue examinee that one individu procedure has reported to the Control Ro liaison between the Control Room and Gi management.	al listed in om to act as a nna corporate
	EPIP 1-5 Attachment 5, Step 4	
Performance Step: 9	Contact Emergency Preparedness to activat communications and act as a liaison betwee and government agencies.	e corporate n the Control Room
Standard:	Contacts one individual identified in procedu they activate corporate communications and between the Control Room and government	re and requests that act as a liaison agencies.
Comment:	Examiner cue examinee that one individu procedure has reported to the Control Ro liaison between the Control Room and go agencies.	al listed in oom to act as a overnment

·

чk.

Appendix C	Page 6 of 8	Form ES-C-1
	PERFORMANCE INFORMATION	
	EPIP 1-5 Attachment 5, Step 5	
Performance Step: 10	Contact NRC Resident Inspector.	
Standard:	Contacts one individual identified in procedu	ure and provides a
	briefing of the situation.	
Comment	Examiner cue examinee that one NRC Be	esident inspector
Comment.	listed in procedure has been contacted.	
	A 7 Attachment 1	
	A-7 Attachment 1	
V Performance Step: 11	Notify the NRC in accordance with 0-9.3, N Notifications.	IRC Immediate
Standard:	Addresses O-9.3.	
	Determines that an 8-hour prompt report is 10CFR50.72, paragraph b(3).	required under
Comment:		
Terminating Cue:	Evaluation on this JPM is complete.	
STOP TIME:	TIME CRITICAL STOP TIM	IF:

 $\mathcal{A}_{d,1}$

Page 7 of 8 VERIFICATION OF COMPLETION Form ES-C-1

Job Performance Measure No.:	2007 NRC Admin JPM	<u>A3</u>	
Examinee's Name:			
Date Performed:			
Facility Evaluator:			
Number of Attempts:			
Time to Complete:			
Question Documentation:			
Question:			
Response:			
Result:	SAT UNS	AT	
Examiner's Signature:		Date:	

Appendix C	Page 8 of 8	Form ES-C-1
	JPM CUE SHEET	

ı.

INITIAL CONDITIONS:

The Reactor is operating at 100% power, Steady-State, MOL.

INITIATING CUE:

ywork we ??

The Control Room receives a call from an Auxiliary Operator in the Intermediate Building (Hot Side) indicating that a Chemist has received serious steam burns while performing RCS sampling activities.

The AO reports that the sampling system is stabilized and no radioactive releases are in progress. However, the Chemist is in pain, and most likely contaminated.

Appendix C			Form ES-C-1
Facility:	Ginna	Task No.:	
Task Title:	Make Protective Action Recommendations during a Gene Emergency	JPM No.: ral	<u>2007 NRC JPM ADMIN</u> <u>A4</u>
K/A Reference:	GK\A 2.4.44 (2.1\4.1)		
Examinee:		NRC Examine	r:
Facility Evaluator:		Date:	
Method of testing:			
Simulated Perform	ance:	Actual Perform	ance: X
Classr	oom <u>X</u> Simulator	Plant	<u>. </u>

READ TO THE EXAMINEE

 \mathbf{i}_{c}

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this Job Performance Measure will be satisfied.

Initial Conditions:	A Large Break LOCA has occurred.
	Indications are that the fuel has failed.
	There is an on-going uncontrolled unisolable radiation release from the Containment
	The Emergency Plan has been activated and a General Emergency has been declared.
	Wind direction is 315 degrees.
	Procedure ER-SC.1, "Adverse Weather Plan," has not been implemented.
Task Standard:	All critical tasks evaluated as satisfactory.
Required Materials:	None
General References:	EPIP 2-1, "Protective Action Recommendations," Rev. 02500 EPIP1-5, "Notifications," Rev. 72
Handouts:	Completed Attachment 3a for initial General Emergency declaration.
Initiating Cue:	Prepare Protection Action Recommendations for the current conditions.

۰.

÷.

 \mathbf{v}_{1}

Time Critical Task: NO

Validation Time: 12 minutes

 \mathbf{u}_{q}

Page 3 of 7 PERFORMANCE INFORMATION

(Denote Critical Steps with a check mark)		
START	TIME:	
		EPIP 2-1 Step 6.1
Perl	ormance Step: 1	Obtain the event classification using EPIP 1-0.
Star	ndard:	Recognizes that the event has been classified as a General Emergency.
Con	nment:	
		EPIP 2-1 Step 6.3.1
Peri	ormance Step: 2	Protective Action Recommendations shall be issued with the initial declaration of a General Emergency.
Star	ndard:	Recognizes that the PAR must be completed in a timely manner because declaration is dependent upon the preparation of the PAR.
Con	nment:	
		EPIP 2-1 Step 6.3.2
√ Per	formance Step: 3	Use the flowchart to determine Protective Action Recommendations.
Sta	ndard:	Recognizes that Procedure ER-SC.1 has not been entered.
		Recognizes that the on-going radiation release is not procedurally controlled.
		Recognizes that the on-going radiation release is not isolable.
		Recognizes the need to use Attachment 1 to determine PAR.
		Using Attachment 1, Page 1 of 2, and 315 degrees determines that Evacuation must occur for W1, 2 and 3 and KI Plan must be implemented and that all other ERPAs must be sheltered.
Cor	nment:	-

Appendix C)
------------	---

ι.

Page 4 of 7 PERFORMANCE INFORMATION

		EPIP 2-1 Step 6.3.3
	Performance Step: 4	Record in EPIP1-5, Attachment 3a (RECs Form), Item 7, the Protective Action Recommendation.
	Standard:	Records PAR in Block 6 of Attachment 3a.
	Comment:	Examiner hand Attachment 3a to examinee when it is identified that this form is needed.
		After Step completion the Examiner shall cue the examinee that on the subsequent event update the wind has shifted to 280 degrees.
		EPIP 2-1 Step 6.3.4
\checkmark	Performance Step: 5	After the initial PAR has been made, if the wind shifts, Use Attachment 1, Page 1 of 2, and the new wind direction to determine the Protection Action Recommendation.
	Standard:	Using Attachment 1, Page 1 of 2, and 280 degrees determines that Evacuation must occur for W1 and 3 and KI Plan must be implemented and that all other ERPAs must be sheltered.
		Recognizes that although ERPA W2 no longer requires evacuation, the original evacuation requirement cannot be rescinded (Note prior to Step 6.3.4), effectively requiring no change to PAR.
	Comment:	After Step completion the Examiner shall cue the examinee that the wind has shifted to 305 degrees, and that Dose Projections 6 miles from the plant indicate > 1 Rem TEDE.
		EPIP 2-1 Step 6.3.5
\checkmark	Performance Step: 6	Secondary PARs are required if conditions beyond five miles indicate that the evacuation criteria of 1 Rem, based on the duration of the release, has been exceeded.
	Standard:	Recognizes that a Secondary PAR is required.
	Comment:	

Appendix C	Page 5 of 7	Form ES-C-1
	PERFORMANCE INFORMATION	
	EPIP 2-1 Step 6.3.5.1	
Performance Step: 7	If exposures in non-evacuated areas is wa Attachment 1, Page 2 of 2, to expand Prot Recommendations to an evacuated area of miles downwind.	arranted, Use tective Action of 5 mile radius and 10
Standard:	Using Attachment 1, Page 2 of 2, and 305 that Evacuation must be expanded for ER KI Plan must be implemented in these ER ERPAs must be sheltered.	degrees determines PAs W1-7 and M1, the PAs, and that all other
Comment:		
Terminating Cue:	Evaluation on this JPM is complete.	
STOP TIME:	TIME CRITICAL STOP T	ME:

Appendix	С
----------	---

· : No

Page 6 of 7 VERIFICATION OF COMPLETION

Job Performance Measure No.:	2007 NRC Admir	1 JPM A4	
Examinee's Name:			
Date Performed:			
Facility Evaluator:			
Number of Attempts:			
Time to Complete:			
Question Documentation:			
Question:			
Response:			
Result:	SAT	UNSAT	
Examiner's Signature:			Date:

Appendix C	Page 7 of 7	Form ES-C-1
	JPM CUE SHEET	
INITIAL CONDITIONS:	A Large Break LOCA has occurred.	
	Indications are that the fuel has failed.	
7	There is an on-going uncontrolled unisolable from the Containment	e radiation release
¢	The Emergency Plan has been activated and Emergency has been declared.	d a General
	Wind direction is 315 degrees.	Sar
	Procedure ER-SC.1, "Adverse Weather Plar implemented.	n," has not been
		1 and
	/	Т Т. Т. Т
INITIATING CUE:	Prepare Protection Action Recommendation	is for the current
		کرم ۸
		N YV
		y La.
		it is a second sec
		for Or &
		1 1 1 2 7
	-	- J. Cra
		νу

l_{ks}

k,

5