



Entergy Nuclear Operations, Inc.
Palisades Nuclear Plant
27780 Blue Star Memorial Highway
Covert, MI 49043

September 25, 2007

10 CFR 50.55a

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Palisades Nuclear Plant
Docket 50-255
License No. DPR-20

Withdrawal of Request for Relief from ASME Section XI Code Requirements for Repair of Service Water System Pipe (TAC No. 6196)


Dear Sir or Madam:

On July 31, 2007, Entergy Nuclear Operations, Inc. (ENO) requested relief from certain sections of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI, 2001 Edition with addenda through 2003, for repair of a 16-inch service water pipe with through-wall leakage. ENO requested approval to use ASME Code Case N-513-2, "Evaluation Criteria for Temporary Acceptance of Flaws in Moderate Energy Class 2 or 3 Piping," with a modification to extend the duration of the use of the code case until the end of fuel cycle 20.

ENO subsequently identified a repair method that met ASME Code, Section XI, IWA-4000 "Repair/Replacement Activities." A Code repair is currently in progress. Therefore, ENO is withdrawing the relief request because it is no longer needed.

Summary of Commitments

This letter contains no new commitments and no revisions to existing commitments. The Code repair satisfies the commitment made in the July 31, 2007, submittal to perform repair or replacement in accordance with the applicable code requirements no later than the end of fuel cycle 20.


Christopher J. Schwarz
Site Vice President
Palisades Nuclear Plant

CC Administrator, Region III, USNRC
Project Manager, Palisades, USNRC
Resident Inspector, Palisades, USNRC