

NOTICE OF DEVIATION

Tennessee Valley Authority
Watts Bar Unit 1

Docket No. 50-390
License No. CPPR-91

During an NRC inspection conducted October 9 to November 5, 1994, a deviation from a written commitment was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the deviation is listed below:

In the enclosure to 10 CFR 50.55(e) Final Report WBN NEB 8010, Possible Inadvertent Boron Dilution, dated June 9, 1982, TVA stated that they had reviewed the Westinghouse recommended operating procedures to prevent or mitigate an inadvertent boron dilution at shutdown and committed to revise the appropriate Watts Bar operating instructions by January 2, 1983, to incorporate the procedures.

In deviation from the above, as of November 4, 1994, Watts Bar Abnormal Operating Instruction (AOI) 34, Immediate Boration, had not been revised to incorporate the Westinghouse operating procedures.

Please provide to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555, with a copy to the Regional Administrator, Region II, and to the NRC Resident Inspector, in writing within 30 days of the date of this Notice, the reasons for the deviation, the corrective steps which have been taken and the results achieved, the corrective steps which will be taken to avoid further deviations, and the date when your corrective action will be completed. Where good cause is shown, consideration will be given to extending the response time.

Dated at Atlanta, Georgia
this 5th day of December 1994

Enclosure 2

9412190077 941205
PDR ADDCK 05000390
Q PDR