



444 South 16th Street Mall
Omaha NE 68102-2247

October 5, 2007
LIC-07-0091

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

References: 1. Docket No. 50-285
2. Letter from OPPD (H. J. Faulhaber) to NRC (Document Control Desk),
dated January 8, 2007 (LIC-06-0131)

SUBJECT: Cancellation of Licensee Event Report 2006-007 for the Fort Calhoun Station

This letter constitutes notification to the NRC of the cancellation of Fort Calhoun's Licensee Event Report (LER) 2006-007, "Inadequate Seismic Design of Reactor Vessel Head Refueling Stand."

An evaluation of the seismic response of the reactor vessel head and stand was completed. As discussed in the evaluation, the Omaha Public Power District (OPPD) has concluded that during a Maximum Hypothetical Earthquake (MHE), the reactor vessel head does not overturn, the concrete piers that the head rests on do not fail, and the underlying floor beams do not fail. Therefore, the condition was not reportable. As a result of cancelling this LER OPPD will be revising the data for the Safety System Functional Failure performance indicator to eliminate this LER from the data in the next quarterly submittal.

If you have any questions, please contact me.

Sincerely,

D. J. Bannister
Site Director
Fort Calhoun Station

DJB/EPM/epm

c: E. E. Collins, NRC Regional Administrator, Region IV
J. D. Hanna, NRC Senior Resident Inspector
A. B. Wang, NRC Project Manager
INPO Records Center