

Peter P.Sena III Site Vice President 724-682-5234 Fax: 724-643-8069

October 3, 2007 L-07-132

ATTN: Document Control Desk U. S. Nuclear Regulatory Commission Washington, DC 20555-0001

Subject: Beaver Valley Power Station, Unit No. 1 Docket No. 50-334, License No. DPR-66 Emergency Response Data System

In accordance with 10 CFR 50, Appendix E, Section VI, revisions to the Beaver Valley Power Station (BVPS) Unit No. 1 Data Point Library (DPL) for the Emergency Response Data System (ERDS) are enclosed. The DPL changes are associated with the range re-scaling of the Charging Pump Discharge Header Uncorrected Flow instrumentation and related BVPS Unit No. 1 In-Plant Computer (IPC) System. Attachment 1 provides a summary of the changes made for this data point.

There are no regulatory commitments contained in this letter. If there are any questions or if additional information is required, please contact Mr. Thomas A. Lentz, Manager - FENOC Fleet Licensing, at (330) 761-6071.

Sincerely,

Peter P. Sena III

Attachment 1 – Summary Of Changes To Data Point Library Enclosure – Revision to Data Point Library (1 Page)

c: Ms. N. S. Morgan, NRR Project Manager (w/o enclosure) Mr. D. L. Werkheiser, NRC Senior Resident Inspector Mr. S. J. Collins, NRC Region I Administrator Mr. D. J. Allard, Director BRP/DEP Mr. L. E. Ryan (BRP/DEP)

A026

SUMMARY OF CHANGES TO DATA POINT LIBRARY (DPL)

ه م^{ور}ه الم

1

Reactor	DPL	Description of Change(s)
Unit	Point	
BV1	F0128A	Date: Changed to "9/20/2007"
		Maximum Instr Range: Replaced "150" with "200"
		Unique Sysem Desc.: Replaced "HI ALARM = 120 GPM (Modes 1 thru 6)" with "HI ALARM = 120 GPM (Modes 1 thru 3)
		HI ALARM = 180 GPM (Modes 4 thru 6)"

BEAVER VALLEY POWER STATION ERDS DATA POINT LIBRARY

ar an a

1

ł

Date:	9/20/2007
Reactor Unit:	BV1
Data Feeder:	IPC
NRC ERDS Parameter:	RCS-CHG-MU
Point ID:	F0128A
Plant Spec Point Desc.:	CHG PUMP DISCH HDR UNCORR FLOW
Generic/Cond Desc.:	PRIMARY SYSTEM CHG OR MU FLOW
Analog/Digital:	A
Engr Units/Dig States:	GPM
Engr Units Conversion:	N/A
Minimum Instr Range:	0
Maximum Instr Range:	200
Zero Point Reference:	N/A
Reference Point Notes:	N/A
PROC or SENS:	S
Number of Sensors:	1
How Processed:	N/A
Sensor Location:	SEE UNIQUE SYSTEM DESCRIPTION FIELD
Alarm/Trip Set Points:	SEE UNIQUE SYSTEM DESCRIPTION FIELD
NI Detector Power Supply Cut-Off Power Level:	N/A
NI Detector Power Supply Turn-ON Power Level:	N/A
Instrument Failure Mode:	LOW
Temperature Compensation for DP Transmitters:	Ν
Level Reference Leg:	N/A
Unique System Desc.:	Three Charging Pumps with a rated flow of 150 GPM at 2500 PSIG each provide borated water from the RWST through FCV-1CH-122 to the Reactor Coolant Loops. FT-1CH-122 senses charging flow between the discharge of the Charging Pumps CH-P-1A, B and C and the Regenerative Heat Exchanger. Ref: Op Manual Chapter 7; RM-407-1
	LOW ALARM = 20 GPM (Modes 1 and 2); 0 GPM (Modes 3 thru 6) HI ALARM = 120 GPM (Modes 1 thru 3), 180 GPM (Modes 4 thru 6)