

## **12.5 Health Physics Program**

The information in this section of the reference ABWR DCD, including all subsections, is incorporated by reference with the following supplements.

### **12.5.3.1 Radiation Protection Program**

The following standard supplement addresses COL License Information Item 12.9.

The Operational Radiation Protection Program is described in Section 12.5S.

### **12.5.3.2 Compliance with Paragraph 50.34 (f) (xxvii) of 10CFR50 and NUREG-0737 Item III.D.3.3**

The following site-specific supplement addresses COL License Information Item 12.10.

STPNOC has approximately 14 portable high volume air samplers, 14 portable low volume air samplers, and 6 portable continuous air samplers. Procedures have been developed to measure the iodine activity entrained on the silver zeolite cartridges or carbon filter units. Personnel have been trained, and will continue to be trained, to operate this equipment. The background activity in the counting rooms is normally maintained low enough to permit counting. Additionally, shielding materials are available to facilitate the counting operation, if necessary. The filter units are counted by a high resolution detector and a multi-channel analyzer or similar device, thereby eliminating the need for purging noble gases.

