
2.0 Safety Limits

The information in this section of the reference ABWR DCD, including all subsections, is incorporated by reference with the following departure.

STD DEP 16.2-1

2.2 SL Violations

With any SL violation, the following actions shall be completed within 2 hours:

~~2.2.1 — Within 1 hour, notify the NRC Operations Center, in accordance with 10 CFR 50.72.~~

~~2.2.2 — Within 2 hours:~~

~~2.2.1 2.2.2.1 Restore compliance with all SLs; and~~

~~2.2.2 2.2.2.2 Insert all insertable control rods.~~

~~2.2.3 — Within 24 hours, notify the [General Manager — Nuclear Plant and Vice President — Nuclear Operations] and the [offsite reviewers specified in Specification 5.5.2, “[Offsite] Review and Audit”].~~

~~2.2.4 — Within 30 days, a Licensee Event Report (LER) shall be prepared pursuant to 10 CFR 50.73. The LER shall be submitted to the NRC, the [offsite reviewers specified in Specification 5.5.2], and the [General Manager — Nuclear Plant and Vice President — Nuclear Operations].~~

~~2.2.5 — Operation of the unit shall not be resumed until authorized by the NRC.~~