

September 27, 2007 L-2007-150 10 CFR 50:36

U.S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, D. C. 20555-00001

Re:

Turkey Point Unit 3

Docket No. 50-250

**Core Operating Limits Report** 

In accordance with Technical Specification 6.9.1.7, the attached Core Operating Limits Report is provided for Turkey Point Unit 3. These curves are applicable for Unit 3 Cycle 23.

Should there be any questions, please contact James Connolly, Licensing Manager, at 305-246-6632.

Very truly yours,

William Jefferson, J Site Vice President

Turkey Point Nuclear Plant

Attachment

cc: Regional Administrator, Region II, USNRC

Senior Resident Inspector, USNRC, Turkey Point Plant

ADOI

## **CORE OPERATING LIMITS REPORT - UNIT 3 CYCLE 23**

The Technical Specifications (TS) affected by this report are:

3.1.3.2	Analog Rod Position Indication System
3.1.3.6	Control Rod Insertion Limits
3.2.1	Axial Flux Difference (AFD)
3.2.2	Heat Flux Hot Channel Factor - FQ(Z)
3.2.3	Nuclear Enthalpy Rise Hot Channel Factor - $F_{\Delta H}$

The Control Rod Insertion Limits, AFD,  $F_Q(Z)$ , K(Z), and  $F_{\Delta H}$  have been developed using the NRC approved methodology specified in TS 6.9.1.7.

## TS 3.1.3.2 Analog Rod Position Indication System

The All Rods Out position for all Shutdown Banks and Control Banks is defined to be 228 steps withdrawn.

## TS 3.1.3.6 Control Rod Insertion Limits

The control rod banks shall be limited in physical insertion as shown on Figure 1 for All Rods Out = 228 steps withdrawn.

## TS 3.2.1 Axial Flux Difference

The AFD limits are provided on Figure 2.

TS 3.2.2 Heat Flux Hot Channel Factor -  $F_O(Z)$ 

$$[F_{O}]^{L} = 2.50$$

K(Z) = 1.0 for 0 ft.  $\leq Z \leq 12$  ft. where Z = core height.

TS 3.2.3 Nuclear Enthalpy Rise Hot Channel Factor

$$F_{\Delta H}^{RTP} = 1.70$$

$$PF_{\Delta H} = 0.3$$



