

RAS 14374

U.S. NUCLEAR REGULATORY COMMISSION

In the Matter of AmerGen Energy Co., LLC

Docket No. 50-0219-LR Official Exhibit No. EX-57

OFFERED by: Applicant/Licensee Intervenor

NRC St. _____

IDENTIFIED on 9/27/07 via _____ Panel N/A

Action Taken: ADMITTED REJECTED WITHDRAWN

Reporter/Clerk GPU Nuclear Corporation

One Upper Pond Road
Parsippany, New Jersey 07054
201-316-7000
TELEX 136-482
Writer's Direct Dial Number:



DOCKETED
USNRC

May 26, 1992
5000-92-3026
C321-92-2163

October 1, 2007 (10:45am)

OFFICE OF SECRETARY
RULEMAKINGS AND
ADJUDICATIONS STAFF

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Gentlemen:

Subject: Oyster Creek Nuclear Generating Station (OCNGS)
Docket No. 50-219
Facility Operating License No. DPR-16
Oyster Creek Drywell Containment

References: (1) NRC Letter dated April 24, 1992, "Evaluation Report on Structural Integrity of the Oyster Creek Drywell (TAC No. M79166)."

(2) GPUN Letter C320-92-264 dated November 26, 1990, "Oyster Creek Drywell Containment."

In response to the Reference 1 request, GPU Nuclear commits to continue taking UT drywell measurements at refueling outages and at other outages of opportunity. The measurements will be at areas previously inspected and also at other accessible areas not previously inspected. Drywell thickness measurements will continue for the life of the plant.

The following is our current plan for Oyster Creek drywell UT thickness measurements.

- (1) During the 14R outage, GPU Nuclear will take UT thickness measurements in the drywell sandbed region, from the torus room side (outside the drywell), at shell locations not readily accessible from inside the drywell. These are areas not previously inspected. The specific locations selected for inspection will be identified once we have direct access to the sandbed region.

Assuming that these measurements confirm that we have bounded the corrosion problem with our current inspection locations, we currently do not plan to make repeat measurements at these specific locations.

9206010165 920526
PDR ADOCK 05000219
P PDR

GPU Nuclear Corporation is a subsidiary of General Public Utilities Corporation

Template = SECY-028

SECY-02

Handwritten signature/initials

- (2) Now through the 15R outage, GPU Nuclear will continue taking UT thickness measurements in accordance with the priority method described in Reference 2, Attachment I, "GPUN Specification IS-328227-004, Functional Requirements for Drywell Containment Vessel Thickness Examination".
- (3) After the 15R outage, GPU Nuclear will assess the condition of the drywell by evaluating the then current UT thickness measurements and will formulate an extended inspection plan. The plan will identify measurement locations including frequency of inspection for the remaining life of the plant.

If you have any questions or comments on this submittal or the overall drywell corrosion program, please contact Mr. Michael Laggart, Manager, Corporate Nuclear Licensing at (201) 316-7968.

Very truly yours,

J. C. DeVine, Jr.
for J. C. DeVine, Jr.
Vice President and Director
Technical Functions

JCD/RZ/amk

cc: Administrator, Region 1
Senior Resident Inspector
Oyster Creek NRC Project Manager