

Entergy Nuclear Northeast Indian Point Energy Center 450 Broadway, GSB Buchanan, NY 10511-0249

Robert Walpole Licensing Manager Tel (914) 734-6710

October 3, 2007

Re: Indian Point Unit 3 Docket 50-286

NL-07-120

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555-0001

SUBJECT: Response to Request for Additional Information Regarding Relief Request 3-43 for Temporary Repair to Service Water Pipe

Reference: 1. Entergy letter NL-07-118 dated September 27, 2007 regarding Relief Request 3-43 for Temporary Repair to Service Water Pipe

Dear Sir or Madam:

Entergy Nuclear Operations, Inc (Entergy) requested relief (Reference 1) in accordance with 10 CFR 50.55a(a)(3)(i) for a temporary non-code repair to an ASME Code Class 3 piping elbow in the Indian Point 3 (IP3) Service Water System. During a conference call with NRC staff on October 1, 2007, Entergy agreed to provide additional information regarding this request as summarized in Attachment 1. Based on this additional information, Entergy is providing Revision 1 of the Relief Request 3-43 in Attachment 2. Other information being provided to support NRC review of this Relief Request is:

- Attachment 3, Flaw Evaluation based on ASME Code Case N-513-1
- Attachment 4, Ultrasonic Test results for current flaw and historical data
- Attachment 5, Structural calculation for proposed repair

There are no new commitments being made in this submittal. If you have any questions or require additional information, please contact Mr. Robert Walpole, Manager, Licensing at (914) 734-6710.

Sincerely

[′]Robert ₩alpole Licensing Manager Indian Point Energy Center

NL-07-120 Docket 50-286 Page 2 of 2

 Mr. John P. Boska, Senior Project Manager, NRC NRR DORL Mr. Samuel J. Collins, Regional Administrator, NRC Region 1 NRC Resident Inspector, IP3 Mr. Paul D. Tonko, President NYSERDA Mr. Paul Eddy, New York State Dept. of Public Service ATTACHMENT 1 TO NL-07-120

REPLY TO REQUEST FOR ADDITIONAL INFORMATION REGARDING INDIAN POINT 3 RELIEF REQUEST 3-43 FOR TEMPORARY NON-CODE REPAIR TO SERVICE WATER PIPING

ENTERGY NUCLEAR OPERATIONS, INC INDIAN POINT NUCLEAR GENERATING UNIT NO. 3 DOCKET NO. 50-286

SUMMARY OF ADDITIONAL INFORMATION

The following summarizes the additional information being provided in this transmittal regarding IP3 Relief Request 3-43, based on a conference call with NRC staff on October 1, 2007. The revised relief request is provided in Attachment 2. The contents of Attachments 3, 4, and 5 are as described in the following summary.

- A. Flaw Characterization and Evaluation
 - The flaw evaluation performed per ASME Code Case N-513-1 is provided in Attachment 3.
 - Two ultrasonic examination test (UT) reports for the affected area are provided in Attachment 4. One is for the recent examination performed in September 2007 for the current flaw and one is for the examination performed in March 2007 for a repair performed prior to startup from the last refueling outage (3R14). A UT examination in 3R13 was not required and therefore no report for that timeframe is available. Radiography of the area prior to 3R13 identified an area of concern on the opposite side of the pipe which was investigated and repaired in March 2005. The Relief Request has been revised to include these previous inspections and repairs.
 - The typical unprotected metal corrosion rate for service water crevice corrosion observed at Indian point is 0.024 inches per two year cycle (0.012 inches per year). This is based on the wear rates observed and calculated for the evaluation of previous service water piping degradations.
- B. Repair Design and Installation
 - Additional description of the proposed repair has been added to the revised Relief Request, including dimensions and weld detail provided in Figure A. The reinforcing plate will be fabricated to match the contour of the repair area to the extent practical and the perimeter gap will be maintained within the limits of the procedure for this type of weld.
 - The design calculation, including the applied stress allowables and safety factors, is provided in Attachment 5.
 - The welding of the reinforcing plate will be in accordance with applicable requirements of ASME Section XI, with qualified welders using a welding procedure qualified per ASME Section IX.
- C. Repair Examination and Inservice Monitoring
 - The relief request has been revised to provide additional information regarding the NDE to be performed as part of the repair, for inservice monitoring, and for extent-of-condition augmented inspections.

- During the repair, Entergy will perform surface examinations prior to starting the welding, after the root pass weld, and after the final pass weld.
- Inservice examinations will use straight line UT. Initial baseline exam after repair installation will be followed by monthly exam for the first quarter, and then quarterly for the balance of the Relief Request duration, unless maintaining a more frequent exam is warranted based on UT results.
- Selection of the 5 locations for augmented inspections will be per ASME Code Case N-513-1.
- NPO visual check walkdowns will be performed at a frequency of at least once per day.

ATTACHMENT 2 TO NL-07-120

INDIAN POINT 3 RELIEF REQUEST 3-43, REVISION 1 REGARDING TEMPORARY NON-CODE REPAIR TO SERVICE WATER PIPING

(Supersedes Revision 0 from Entergy letter NL-07-118 dated September 27, 2007)

ENTERGY NUCLEAR OPERATIONS, INC INDIAN POINT NUCLEAR GENERATING UNIT NO. 3 DOCKET NO. 50-286

,

INDIAN POINT UNIT 3 RELIEF REQUEST 3-43, REVISION 1 PAGE 1 OF 6

Proposed Alternative in accordance with 10 CFR 50.55a (a)(3)(i)

Alternative Provides Acceptable Level of Quality and Safety

A. ASME Code Component Affected

18" Service Water supply line number 408 to the Containment Fan Cooler Units (FCU). This line is one of two lines which supplies Hudson River water to the FCUs which are used to remove containment heat during normal plant operation and following a design basis accident.

B. Applicable Code Edition and Addenda

The applicable Code of Record for the current 10 year inservice inspection interval is the ASME Section XI Code, 1989 Edition with no Addenda. However, for Repair and Replacement activities, Entergy has requested and the NRC has approved (Reference 1) the use of subsection IWA-4000 of the ASME Section XI, 2001 Edition through the 2003 Addenda.

The affected portion of the service water piping was designed and constructed in accordance with the requirements of the USAS B31.1.0, 1967 Edition of the Power Piping Code.

C. Applicable Code Requirement

IWA-4422.1 requires that defects be removed or reduced to an acceptable size prior to implementing a repair or replacement in accordance with the requirements of IWA-4000. Since the current through-wall defects are beyond the acceptance criteria of IWD-3000 and removal is not practical without system depressurization, the proposed repair method would not be consistent with IWA-4422.1.

D. Reason for Request

On September 18, 2007 a Nuclear Plant Operator conducting a routine plant walkdown noted minor leakage of approximately 5 drops per minute in one of the two cement-lined 18" diameter, 0.375" nominal thickness service water supply lines for the containment fan cooler units. As a result of this leak a volumetric examination of the surrounding area was performed and the results were evaluated (IP-CALC-07-00083) against the requirements of ASME Code Case N-513-1. Although this evaluation confirmed that the affected piping remains within the requirements of Code Case N-513-1, the calculated corrosion rate does not support continued structural integrity through the remainder of the current operating cycle.

A weld repair/replacement fully compliant with the requirements of IWA-4000 is not practical. The affected piping section would need to be removed from service which would result in 3 FCUs inoperable. Indian Point 3 Technical Specification 3.6.6 does not have a Condition Statement for that configuration.

INDIAN POINT UNIT 3 RELIEF REQUEST 3-43, REVISION 1 PAGE 2 OF 6

Entergy has evaluated alternative options for repairing this degraded area including weld overlay using ASME Code Case N-661 or an approach using a welded reinforcing plate. The weld overlay based on Code Case N-661 does not have a high probability of success due to the risk of "burn-through" in small areas where the remaining pipe thickness is insufficient to deposit weld metal. To protect against "burn-through" as shown in EPRI testing, a modified approach for weld overlay may be possible by placing a small intermediate plate over the localized area subject to "burn-through" and then the weld overlay could be applied over that plate. Both the reinforcing plate option and the overlay-with-intermediate-plate option could be designed to adequately restore the required structural margin for the remainder of the current operating cycle. The welded reinforcing plate is the preferred option because less welding will result in lower residual shrinkage stresses. Therefore the balance of the discussion provided in this relief request is directed at describing the welded reinforcing plate approach.

E. Proposed Alternative and Basis for Use

As discussed above, IWA-4422.1 requires that a defect be removed prior to implementing an IWA-4000 repair. However, this is not practical for the reason described in Section D regarding Technical Specification 3.6.6 for the FCUs. The preferred alternative proposed under this relief request would install a reinforcing plate over the degraded area to allow the attachment welding (Figure A) to be located in an area with minimal degradation therefore ensuring a structurally sound load path while minimizing the risk of "burn-through" and increased leakage.

The design will also ensure that the configuration of the repair will allow continued monitoring of the region by volumetric examination to ensure that future degradation will not adversely impact the structural capability of the repaired section.

1. Materials and Installation

The material of the component to be repaired is concrete lined Carbon Steel, A-234, Grade WPB. The proposed reinforcing material to be installed is ASTM A-234, Grade WPB/A-106 or equivalent carbon steel material with an ASME Code stress allowable of 15,000 psi. The welding process to be used in this repair is SMAW with a Carbon Steel, 7018 weld wire. The reinforcing material would either be plate stock rolled to fit the contour of the affected repair area or a section from pipe will be used to fit the contour. The gap between the repair area and the reinforcing material will be controlled by procedure.

The welding will be performed per the requirements of ASME Section XI using qualified welders and the weld procedure will be qualified in accordance with ASME Section IX. The weld procedure specifies 50 ^oF pre-heat for welds less than ¾ inch thickness and no post weld heat treatment required for P-1 materials less than ¾ inch thick.

2. Design Parameters

The welded plate/weld repair option will be designed and installed consistent with the original USAS B31.1.0, 1967 Edition of the Power Piping Code requirements for a reinforcing plate (paragraph 104.3). A structural evaluation (IP-CALC-07-00209) has

INDIAN POINT UNIT 3 RELIEF REQUEST 3-43, REVISION 1 PAGE 3 OF 6

been performed to ensure that the resulting stresses in the piping, the plate and the attaching welds do not exceed the allowable stresses of the USAS B31.1.0 Code, 1967 Edition. The repair material will be carbon steel or pipe equivalent to the existing pipe material with allowable stress of S = 15,000 psi. The Code Case N-513-1 evaluation used the required factors of safety of 2.77 for the normal / upset condition and 1.39 for the emergency / faulted condition.

For purposes of this repair design and monitoring, Entergy will assume that the cement lining is no longer present in the area of the planned repair so that the corrosion rate for unprotected carbon steel will be applied.

3. Non Destructive Examinations

The area to be repaired has been characterized by performing straight beam UT mapping (Report IP3-UT-07-110) of the region to bound the degraded area and to ensure that the welds for repair are located in areas of sound base metal. At least ½ inch of the weld for attaching the reinforcing plate to the elbow will be performed in an area of average wall thickness exceeding 0.18 inches to ensure a structurally sound load path around the perimeter of the repair area.

NDE of this area was also performed in March 2007 (Report IP3-UT-07-049) when a through-wall flaw was discovered during startup from refueling outage 3R14. Plant conditions at that time allowed for a weld repair consistent with ASME IWA-4422.1, so that a relief request was not needed. Four areas with thickness readings less than 0.110 inches were excavated and weld repaired in accordance with the requirements of ASME Section XI. Corrective action at that time also included developing plans for replacing this elbow at the next refueling outage (3R15, Spring 2009).

The pipe wall was repaired to a minimum wall thickness needed to support operation until the next refueling outage, based on nominal corrosion rate assumptions. The typical unprotected metal corrosion rate for service water crevice corrosion observed at Indian point is 0.024 inches per two year cycle (0.012 inches per year). This is based on the wear rates observed and calculated for the evaluation of previous service water piping degradations. However, corrosion rates could be higher in localized areas.

The location of the March 2007 repair with respect to the current area of interest is adjacent to grid location H6 as shown on the UT map in IP3-UT-07-110. A final assessment of why a new through-wall leak developed near the area of the prior repair has not been completed at this time. Further characterization of the degradation in this elbow will be accomplished when the component is replaced.

Prior to shutdown for 3R13 (March 2005) radiography of this elbow as part of the Generic Letter 89-13 Corrosion Monitoring Program identified an area of interest on the opposite side of the elbow from the current flaw. Localized UT performed during 3R13 identified a 0.25-inch diameter area in the weld with a thickness less than 0.135 inches. An ASME Section XI repair was implemented prior to startup from that outage. There is no historical UT data resulting from the March 2005 repair for the current area of interest.

INDIAN POINT UNIT 3 RELIEF REQUEST 3-43, REVISION 1 PAGE 4 OF 6

NDE inspections for the extent-of-condition review will also be performed as stated in section E.5. NDE related to the repair and inservice monitoring is discussed in Section E.4.

4. Repair Monitoring

During installation of the reinforcing plate, welds will be examined, consistent with the requirements described in Code Case N-661. This includes performing a surface examination of the area to be welded, a surface examination (dye penetrant or magnetic particle) after the first weld pass and a final surface examination of the completed weld.

Inservice monitoring of the repair will be accomplished by applying a 1-inch by 1-inch grid over the area which will cover the reinforcing plate and the flat portion of the attaching weld (refer to Figure A). The intersection points in the grid will be inspected using straight beam UT. An initial baseline UT will be performed after installing the repair. Subsequent UTs will then be performed to verify that the structural requirements of the original construction code are maintained through the remainder of the current operating cycle. The UTs will be performed monthly for the first quarter and if no unexpected degradation is identified, UTs will then be performed quarterly for the balance of the duration of this relief request.

Also, routine walkdowns will be performed by Nuclear Plant Operators at least daily. This piping is not insulated and is accessible for visual inspection.

5. Degradation mechanism

Based on the location of the defect and based on the UT inspections of the degraded area, Entergy concludes that this was likely caused by degradation of the protective concrete lining directly under the degraded area which allowed brackish water from the Hudson River to contact the unprotected carbon steel piping resulting in localized corrosion. The degradation of the concrete lining was likely caused by the high flow velocities and turbulence from the valve located just upstream of the degraded area. Further evaluation of the degradation mechanism will be performed during the next outage as stated in Section F, when the elbow can be removed and replaced.

Entergy will perform augmented inspections, as required by Code Case N-513-1, for the extent-of-condition evaluation. The inspections will be at 5 locations selected as most susceptible to the degradation mechanism suspected at this time. Parameters to be considered for selection of the augmented inspection locations will include system operating conditions, proximity of upstream valves, and years of service.

6. Applicable Loads

The repair will be designed to accommodate all appropriate deadweight, pressure, and seismic loads. Since the system is a moderate energy system which operates at a low temperature, differential thermal expansion between the repair plate and the repaired component is not a concern.

INDIAN POINT UNIT 3 RELIEF REQUEST 3-43, REVISION 1 PAGE 5 OF 6

F. Duration of Proposed Alternative

The duration of the temporary repair is limited until the next scheduled outage exceeding 30 days, but no later than the next refueling outage currently scheduled for the Spring of 2009.

G. References

、

1. NRC Safety Evaluation dated April 24, 2007 for Relief Request 3-42 (ML070880358).



NUCLEA			QUALITY R	ELATED	EN-DC-126	REV. 0				
[™] Entergy	MANAGEM MANUAL	ENT	REFERENC	e Use	PAGE 27 (DF 32				
	En	igineering C	Calculation Proces	SS						
	NO-2	🗌 GGNS	S 🗌 I	P-2	🖾 IP-3					
	PS			<u>/Y</u>	<u> </u>					
CALCULATION COVER PAGE	⁽¹⁾ EC #	3047			⁽²⁾ Page 1 of	<u>12</u>				
(3) Design Basis Calc.	YES	NO	(4) 🗌 CAL	CULATION		Markup				
⁽⁵⁾ Calculation No: IP	-CALC-07-00	0083 EC :	3047		⁽⁵⁾ Revisior	n: O				
⁽⁷⁾ Title: Evaluation OF Through Wall Flaw at leak downstream of SWN-38										
⁽⁸⁾ System(s): SWS		⁽⁹⁾ Review Org (Department): Civil / Structural Design Engineering								
(10) Safety Class:		⁽¹¹⁾ Cor	nponent/Equi	pment/Struc	ture Type/Nu	mber:				
🛛 Safety / Quality Re	lated	SWN-38								
Augmented Quality	y Program	Line 408								
	2									
⁽¹²⁾ Document Type: C	ALC									
⁽¹³⁾ Keywords (Description/Topical C	Codes):									
		RE	VIEWS							
(14) Name/Signature/Da Kai Lo 9-19-07 / //	ate (15) GOPAL er X Dec	Name/Sig BHALLA (sign Verif	nature/Date	⁽¹⁶⁾ Na <u>R. Dra</u> Supe	me/Signature/I ake <i>yel - (</i>	Date 7/19/8 7				
		nments A	ttached		mments Attach	ied				

ATTACHMENT 9.3 Sheet 1 of 3

,

 (k_i)

CALCULATION REFERENCE SHEET

		N	NUCLEAR				QUALITY RELATED	b	EN-DC-126	REV. 0
	<i>≈ Enter</i> gy	M. M.	ANAGE ANUAL	MENT			REFERENCE USE		PAGE 27	OF 32
		L		Engineer	ring C	alculatio	on Process	l		
C R	ALCULATION EFERENCE SHEET	-	CALC Page	2 of 12		NO: IP	P-CALC-07-0	0083, R	EV. 0	
I. 1, 2. 3. 4. 5.	EC Markups Incorpo	rated	: NO	NE						
11.	Relationships:		Sht	Rev	lr C	iput Doc	Output Doc	Impact Y/N	Tracking No.	
1.										
2.	·····		ļ			<u> </u>		 		
3.	<u></u>		 							
<u>4.</u> 5		- <u></u>								
11. 2. 3. 4. 5.	CROSS REFEREN See page 6	ICES	:							
IV Ti	SOFTWARE USE	D: NC _)NE Ver	rsion/Ri	elea	se:	Disk/0	CD No		
v.	DISK/CDS INCLU	DED:	NONE							
Ti	le:		Ver	sion/Re	eleas	Se	Disk/(CD No		
VI	OTHER CHANGES	5: NC	DNE							

• 44

Entergy	NUCLEAR	QUALITY RELATED	EN-DC-126	REV. 0					
	MANAGEMENT	REFERENCE USE	PAGE 27 OF 32						
Engineering Calculation Process									

• • 2₂

Page 3 of 12

Revision	Record of Revision
	Initial issue of Calculation IP-CALC-07-00083
0	
	· · · · · · · · · · · · · · · · · · ·

	NUCLEAR	QUALITY RELATED	EN-DC-126	REV. 0					
Entergy	MANUAL	REFERENCE USE	PAGE 27 C)F 32					
Engineering Calculation Process									

LIST OF EFFECTIVE PAGES

Page 4 of 12

Calculation Number: IP-CALC-07-00083 Revision Number: 0_____

PAGE REV. PAGE REV. PAGE REV.

All 0

	NUCLEAR	QUALITY RELATED	EN-DC-126	REV. 0					
= Entergy	MANAGEMENT	REFERENCE USE	PAGE 27 C)F 32					
Engineering Calculation Process									

TABLE OF CONTENTS

•

Topic

PAGE 5 OF 12 Page No.

1	Calcul	ation Cover Page		1
2	Calcul	ation Reference Sheet		2
3	Record	d of Revisions		3
4	List of	Effective Pages		4
5	Table	of Contents		5
6	Calcul	ation Section		6
	6.1	Background		6
	6.2	Purpose		6
	6.3	Method of Analysis		6
	6.4	Assumptions		6
	6.5	Design Input	۲ .	6
	6.6	References		6
	6.7	Calculation		7
	6.8	Results/Conclusions		12

٦

Entergy	NUCLEAR	QUALITY RELATED	EN-DC-126	REV. 0					
	MANAGEMENT	REFERENCE USE	PAGE 27 OF 32						
Engineering Calculation Process									

6.0 Calculation Section

Page _6_of _12

6.1 Background

Two through wall leaks were found on an elbow downstream of SWN-38. This line is for the Service Water supply line. This weld was weld repaired at end of 3R14.

6.2 Purpose

The leak is at downstream of SWN-38 and is ISI class 3, seismic class I. It is necessary to evaluate the structural integrity of the through wall leak for operability and extent of weld repair.

6.3 Method of analysis

- 1. Based on the reference, "Companion Guide to the ASME BPVC", page 555, the SIF at an elbow is maximum at the 45 degrees location. Since the leak and thinned area is approximately 3" from the elbow weld, an SIF of 1.0 for a straight pipe is used, i.e. 0.75i = 1.0.
- 2. Instead of using an uniform thinning approach to determine the minimum required wall thickness t'min, the exact method was used by using average UT readings at locations of leakage and wall thinning.
- 3. Determine the minimum required wall thickness to satisfy the 1967 B31.1 code limit.
- 4. ASME CC-N513 is used to determine the acceptable flaw length for normal/upset and emergency/faulted loading condition.

6.4 Assumption

- 1. The wall thickness of locations beyond the 1"x1" grids (A1 through K6) are assumed to be the same as the average wall thickness of section 1,2 & 3 for the 2" grids at the weld section UT.
- 2. The wall thickness used for the CC N-513 evaluation is an average value of the thickness around the thinned area.

6.5 Design Input

- 1. This leak location is the same as inspection ID PAB-90 in 3R13.
- 2. IP3 Pipe specification MS-TS-027
- 3. Flow diagram 9321-F-27223
- 4. Drawing 9321-F-53533
- 5. IP3 Line List
- 6. IP-CALC-07-00083 Rev. 0
- 7. UT Report IP3-UT-07-110

6.6 Reference

- 1. ENN-CS-S-008, "Pipe Wall Thinning Structural Evaluation"
- 2. EN-DC-185, "Through-Wall Leaks in ASME XI Class 3 Moderate Energy Piping Systems"
- 3. ASME 1995 B & PV Code, Section XI, Appendix H, Article H-4000
- 4. ASME B & PV Nuclear Code Case N-513, Rev. 1.
- 5. USAS B31.1, Power Piping Code, 1967.
- 6. "Companion Guide to the ASME BPVC", volume 1

Page 7_of 12_

6.7 Calculation

.

For pipe stress corresponding to 0.75i = 1.0)	
P = design pressure =	15 0	psi
D = outside diameter =	18	in
t = pipe wall thickness =	0.375	in for std size pipe
0.75i = SIF at pipe section =	1.00	
0.75i' = SIF used in stress run = .75*3.5 =	2.625	at 45 degrees portion of elbow [Ref. 6]
f' _{nor} = normal stress from stress run =	3120	psi, from PAB-90 inpsection point
f' _{dw+obe} = DW+OBE stress from stress run =	5490	psi
$f'_{dw+dbe} = DW+DBE$ stress from stress run =	6680	psi
Based on 0.75i = 1.0		
$f_p = longitudinal stress due to pressure = F$	PD/(4t) =	1800 psí
f' _{dw} = dead weight stress w/out pressure =	$f'_{nor} - f'_p =$	1320 psi
f _{dw} = dead weight stress =	= f' _{dw} (i/i') =	503 psi
f _{nor} = normal stress =	$= f_p + f_{dw} =$	2303 psi
f'_{dw+obe} = obe pipe stress w/out pressure = f'_{dt}	_{w+obe} - f _p ≃	2370 psi
f _{obe} = obe pipe stress =	$f'_{\rm obe}({\rm i}/{\rm i}') =$	903 psi
f _{ups} = DW+OBE stress =	$f_p + f_{obe} =$	2703 psi
f'_{dbe} = dbe pipe stress w/out pressure = f'_{db}	$w_{+dbe} - f_0 =$	4880 psi
f _{dbe} = dbe pipe stress =	f' _{dbe} (i/i') =	1859 psi
f _{ema} = DW+DBE stress =	$f_{\rm p} + f_{\rm dbe} =$	- 3659 psi
g	F 484	,

,

PAGE & OF 12

6.7 Calculation

Determine Minimum Wall for Operability based on Axial Stress Calculation for Actual Thinned Section

1. Actual Section Modulus Calculation:

(See Ref. 2.7)

										(Boxed y	alues are	input.)
D _o : Pi	pe OD, (inj)									18	
R _o : Pi	pe outside	radius,	= D/2, (in)							9	
t _{nom} : F	Pipe nomin	al wail th	ickness, i	(in)							0.375	
Y' : To	tal service	years up	to latest	inspectio	on, (yr)					Γ	30	
Y:Se	rvice years	betweer	h latest in:	spection	and next i	nspection,	(yr)				1.5	
N : Tot	tal no. of th	ickness	measurer	nents (e	qual grid) i	in circumfe	erential di	rection			20	
$\Delta \theta = 2$	π/N, angle	of each	grid, (rad))	(where	π =	3.142)	l i			0.314	
Sectio	on 4 UT rea	ading wa	is used:									
<u>n</u>	(t _{meas})n	(t _p) _n	R _{in}	θ _n	Ain	A _{mn}	Biyn	Bixn	l _{xn}	l _{yn}	I _{xyn}	
		(in.)	(in.)	(rad)	(in ²)	(in ²)	(in ³)	(in ³)	(in⁴)	(in⁴)	(in⁴)	
1	0.229	0.221	8.7 8	0.00	12.1	0.62	70. 9	0.0	48.8	0.0	0.0	
2	0.152	0.140	8.86	0.31	12.3	0.39	69.3	22.5	28.3	3.0	9.2	note 1
3	0.090	0.074	8.93	0.63	12.5	0.21	60.2	43.8	11.0	5. 8	8.0	
4	0.186	0.175	8.82	0.94	12.2	0. 49	42.3	58.2	13.5	25.5	18.5	
5	0.255	0.248	8.75	1.26	12.0	0. 69	21.7	66.8	5.2	49.4	16.0	note 2
6	0.255	0.248	8.75	1.57	12.0	0.69	0.0	70.2	0.0	54. 6	0.0	
7	0.255	0.248	8.75	1.8 8	12.0	0. 69	-21.7	66.8	5.2	49.4	-16.0	
8	0.255	0.248	8.75	2.20	12.0	0.6 9	-41.3	56.8	18.9	35.7	-26.0	
9	0.255	0.248	8.75	2.51	12.0	0.6 9	-56.8	41.3	35.7	18.9	-26.0	
10	0.255	0.248	8.75	2.83	12.0	0.6 9	-66.8	21.7	49.4	5.2	-16.0	
11	0.255	0.248	8.75	3.14	12.0	0.6 9	-70.2	0.0	54.6	0.0	0.0	•
12	0.255	0.248	8.75	3.46	12.0	0. 69	-66.8	-21.7	49.4	5.2	16.0	
13	0.255	0.248	8.75	3.77	12.0	0.6 9	-5 6.8	-41.3	35.7	18.9	26.0	
14	0.255	0.248	8.75	4.0 8	12.0	0.6 9	-41.3	-56.8	18. 9	35.7	26.0	
15	0.255	0.248	8.75	4.40	12.0	0.6 9	-21.7	-66.8	5.2	49.4	16.0	
16	0.255	0.248	8.75	4.71	12.0	0.69	0.0	-70.2	0.0	54.6	0.0	
17	0.255	0.248	8.75	5.0 3	12.0	0.69	21.7	-66.8	5.2	49.4	-16.0	
18	0.255	0.248	8.75	5.34	12.0	0. 69	41.3	-56.8	18. 9	35.7	-26.0	
19	0.255	0.248	8.75	5.65	12.0	0.69	56.8	-41.3	35.7	18.9	-26.0	
	0.255	0.248	8.75	5.97	12.0	0.69	66.8	-21.7	49.4	5.2	16.0	
Min.	0.09	0.074		Σ _n =	A,	A _m	В _{іу}	Bix	l _x	<u> </u>	1 _{xy}	
aver	0.23683				241.7	12.8	7.7	4.8	488.8	520.3	-32.2	

Where n : ID of measurement grid

(tmeas)n : Min. thickness measured in nth grid

 $(t_p)_n$: Min. predicted thickness of nth grid at next inspection, = $(t_{meas})_n - Y^*[1, 1(t_{nom} - (t_{meas})_n)/Y^i]$

 R_{in} : Inside thinned radius = $R_o - (t_{meas})_n$ of nth grid

 θ_n : Circumferential angle clockwise of nth grid (from vertical axis of pipe section)

 $A_{mn} = (R_o^2 \cdot R_{in}^2)^* (\Delta \theta)/2,$ $A_{in} = R_{in}^{2*}(\Delta \theta)/2$

$$\begin{split} & H_{in} = (H_0^4 - R_{in}^{-3} \cos(\theta_n)^* (\Delta \theta)/3, \\ & H_{in} = (R_0^4 - R_{in}^{-3} \cos^2(\theta_n)^* (\Delta \theta)/4, \\ & H_{yn} = (R_0^4 - R_{in}^{-4})^* \cos^2(\theta_n)^* (\Delta \theta)/4, \\ & H_{yn} = (R_0^4 - R_{in}^{-4})^* \sin(\theta_n)^* (\Delta \theta)/4, \\ & H_{yn} = (R_0^4 - R_{in}^{-4})^* \sin(\theta_n)^* \cos(\theta_n)^* (\Delta \theta)/4, \\ & H_{yn} = (R_0^4 - R_{in}^{-4})^* \sin(\theta_n)^* \cos(\theta_n)^* (\Delta \theta)/4, \\ & H_{yn} = (R_0^4 - R_{in}^{-4})^* \sin(\theta_n)^* \cos(\theta_n)^* (\Delta \theta)/4, \\ & H_{yn} = (R_0^4 - R_{in}^{-4})^* \sin(\theta_n)^* \cos(\theta_n)^* (\Delta \theta)/4, \\ & H_{yn} = (R_0^4 - R_{in}^{-4})^* \sin(\theta_n)^* \cos(\theta_n)^* (\Delta \theta)/4, \\ & H_{yn} = (R_0^4 - R_{in}^{-4})^* \sin(\theta_n)^* \cos(\theta_n)^* (\Delta \theta)/4, \\ & H_{yn} = (R_0^4 - R_{in}^{-4})^* \sin(\theta_n)^* \cos(\theta_n)^* (\Delta \theta)/4, \\ & H_{yn} = (R_0^4 - R_{in}^{-4})^* \sin(\theta_n)^* \cos(\theta_n)^* (\Delta \theta)/4, \\ & H_{yn} = (R_0^4 - R_{in}^{-4})^* \sin(\theta_n)^* \cos(\theta_n)^* (\Delta \theta)/4, \\ & H_{yn} = (R_0^4 - R_{in}^{-4})^* \sin(\theta_n)^* \sin(\theta_n)^* \cos(\theta_n)^* (\Delta \theta)/4, \\ & H_{yn} = (R_0^4 - R_{in}^{-4})^* \sin(\theta_n)^* \sin(\theta_n)$$

$A_m = 2$	n∍t A _m	n, similar	tor A _i ,	B _{iy} , B _{ix}	, I _x , I _j	_y , and	l _{vy} (Th	e origin	of x-	y coordina	tes is at	the cente	r of	pipe	section	i.)
-----------	--------------------	------------	----------------------	-----------------------------------	-----------------------------------	--------------------	---------------------	----------	-------	------------	-----------	-----------	------	------	---------	-----

Gravity center of pressure area	$Y_{p} = B_{iy}/A_{i}; X_{p} = B_{ix}/A_{i};$ (in)		0.032	0.020	
Gravity center of metal area :	$X_m = -A/A_m^*X_p$; $Y_m = -A/A_m^*X_p$	*Υ _ρ ; (in)	-0.373	-0.600	
Moment inertias at G.C. of meta	al area : $I_x = I_x - A_m X_m^2$, $I_y = I_y$	$A_m^* Y_m^2$, & $I_{xy} = ixy \cdot A_m^* X_m^* Y_m$;(in ³)	487.0	515.7	-35.09
Actual thinned Section: $I_{min} = 0$	$[_{x}+ _{y}-[(_{x}+ _{y})^{2}+4^{*} _{xy}^{-2}]^{0.5}]/2, R_{m}$	$ax = R_0 + (X_m^2 + Y_m^2)^{0.5}, Z_{min} = I_{min}/R_{max}$	463.4	9.71	47.7
Nominal section:	Inom, Ro, Znom (for thom=	0.375 in.); (in ³ , in, in ²)	806.6	9.00	89.6
Uniformly thinned section:	I, R_0 , Z (for $(t_{meas})_{min} =$	0.074 in.); (in ³ , in, in ²)	168.1	9.00	18.7

PASE 9 OF 12

2. Axial Stress for Actual Thinned Section

۰,

.

Page 2 of 2

P : Design pressure, (psi)	150
$S_p = P^*A/A_m / 1000$, (ksi)	2.83
$\delta = (X_m^2 + Y_m^2)^{0.5}$, Eccentricity of thinned section, (in)	0.71
$M_p = (\pi^* R_o^2)^* P^* \delta/1000$, Bending moment due to eccentricity of pressure force, (k-in)	27.0

Operating Condition		Normal	Upset	Emerg.
S : Code axial stress, (ksi)	Ref. Inspection ID. PAB-90 in3R13	3.12	5.49	6.68
$M_b = (S - P^*D_o/4t_{norm}/1000)^*Z_{norm}$: Bending moment due of	ode loadings, (k-in)	118	331	437
$M' = M_b + M_p$: Total bending moment for thinned section	, (k-in)	145	358	464
$S' = S_p + M'/Z_{min}$: Actual stress due to thinning, (ksi)		5.88	10.33	12.56
new (0.75x sif) :	use 1.0	1.00	1.00	1.00
original (0.75xsif) used in stress calc		2.625	2.625	2.625
[(new 0.75xsif) / (old 0.75xsif)](S') : Stress adjusted for ne	ew sif from wall thinning	2.2	3.9	4.8
S _{allow} : Allowable stress, (ksi)		15.0	18.0	27.0
Acceptable if $S_{allow} \ge S'$		Yes	Yes	Yes

Note: Due to accessibility, the wall thickness beyond the 10" region is an average of all the 2" grid UT readings

Note 1: $t_{min} = PD/[2(S_h+.4P)] = 0.090$ inch for hoop stress

Note 2: average wall thicknes = 0.255

IP-CALC-07-00083 mark up.xls

7

ID No. Through wall leak and flaw at

A. Pipe Parameters

Υ.

•

.

$D_o = Pipe OD (in)$		18
t = Pipe wall thickness (in) (.179+.185+.	231+.156+.131+.159+.149)/7.231)/7 =	0.170
t _{nom} = nominal pipe wall thickness (in)		0.375
P' = Operational Pressure (psi)	[70
P = Design Pressure (psi)		150
T = Design Temperature (°F)		160
$R = pipe mean radius (in) = (D_o - t)/2$		8.915
E = elastic modulus at T (ksi)		27800
J _{1c} = material toughness (lb/in)		45
K_{1c} = material critical stress intensity factor = J_{1c} *E/1000) ^{0.5} (ksi(in) ^{0.5})	-	35.37

B. Evaluation of Axial Flaw

$c = \ell/2 =$ Half axial flaw length (in) , try "c" to make K_{ic}	- K _l > 0.0	1.31	1.23
$\lambda = c / (\iota R)^{0.5}$		1.07	1.00
$F = 1 + A\lambda + B\hat{x} + C\lambda^{2} + D\hat{x}^{2} + E\hat{x}^{4}$ Where A= 0.0724 B= 0.6486 C= -0.2327 D=	0.0382	1.58 E= -0.0023	1.52
Operating Conditions		Nor/Ups	Eme/Fau
$P' \approx Pressure (psi)$, use P' for Nor/Ups & P for Eme/Fau condition	•	70	150
σ _n = P ^{**} R/V1000 = Hoop Stress (ksi)		3.67	7.87
SF : Safety Factor		3.00	1.50
$K_{ic} - K_{i} \approx K_{ic} - (SF)^{*} (P^{*}R/t)^{*} (\pi^{*}c)^{0.5} F \ge 0.0$		0.0	0.0
Flaw length (2c) =		2.63	2.46

C. Evaluation of Circumferential Flaw

c : Half circumferential flaw length			, try "c" to	make K	- K _i > 0.0	1.48	1.98
$\alpha = c/\pi R$						0.052	0.071
r = R/t						52.4	52.4
	i=	0	1	2	3		
$A_{m} = A_{m0} + A_{m1} r + A_{m2} r^{2} + A_{m3} r^{3}$	A _{mi}	-2.02 92	1.6776	-0.079 9	0.0018	120.1	120.1
$B_{m} = B_{m0} + B_{m1}$ *r + B_{m2} *r ² + B_{m3} *r ³	B _{ml}	7.0999	-4.423 9	0.2104	-0.0046	-314.1	-314.1
$C_m = C_{m0} + C_{m1} r + C_{m2} r^2 + C_{m3} r^3$	C _{mi}	7.7966	5.1668	-0.2458	0.0054	383.1	383.1
$A_{b} \approx A_{b0} + A_{b1} r + A_{b2} r^{2} + A_{b3} r^{3}$	Аы	-3.2654	1.5278	-0.0727	0.0016	107.8	107.8
$B_{b} = B_{b0} + B_{b1} r + B_{b2} r^{2} + B_{b3} r^{3}$	Bbi	11.363	-3.9141	0.1862	-0.0041	-273.0	-273.0
$C_b = C_{b0} + C_{b1} r + C_{b2} r^2 + C_{b3} r^3$	Сы	-3.1861	3.8476	-0.1830	0.0040	276.4	276.4
Operating Conditions						Nor/Ups	Eme/Fau
$F_m = 1 + A_m^* \alpha^{1.5} + B_m^* \alpha^{2.5} + C_m^* \alpha^{3.5}$						2.25	2.88
$F_{b} = 1 + A_{b} * \alpha^{1.5} + B_{b} * \alpha^{2.5} + C_{b} * \alpha^{3.5}$						2.12	2,69
$P_m = P^*D/4t_{nom}$: Axial stress due to d	lesign pre	essure (k	si)			1.80	1.80
$S \approx P_m + P_b$: Piping Axial Stress						2.70	3.66
$P_b = S - P_m$						0.90	1.86
SF : Safety Factor						2.77	1.39
K _{ic} =						35.4	35.4
$K_{ic} - K_{i} = K_{ic} - (SF)^{*} (\pi^{*}c)^{0.5*} (P_{m}^{*}F_{m} + K_{ic})^{0.5*}$	P₀ [•] F₀) ≥	0.0				0.0	0.0
Flaw length (2°c) =						2.92	3.97

PASE 11 OF 12

The acceptable circumferential flaw length for normal/upset loading condition is 2.9", less than the combined (1" + 0.5" + 1.875") = 3.375", the flaw must be repaired and can not delayed until 3R15. Since the acceptable circumferential flaw length for emergency/upset loading condition is 3.9", greater than the 3.375" flaw, the flaw is structural acceptable and operable for the past and present. The wall thinning area and the leak need to be repaired by weld overlay.

Provide minimum weld overlay from 1.5" beyond section 1 to 1.5" beyond section K in the circumferential direction and 1.5" beyond section 1 to 1.5" beyond section 6 in the axial direction. The minimum overlay area is 9" axial by 14" circumferential.

After weld overlay, the SIF needs to be 2.1 for even a straight pipe. Since the pipe stress is low, the new stress after using the SIF multiplier of 2.1 will still be below code limit.

New ut Realts show flow is less that 2.92" therefore acceptable Per N-513.

	NUCLEAR	QUALITY RELATED	EN-DC-126 REV.					
= Entergy	MANAGEMENT	REFERENCE USE	PAGE 27 OF 32					
Engineering Calculation Process								

PAGE 12 OF 12

6.8 Conclusion

The acceptable circumferential flaw length for normal/upset loading condition is 2.9", less than the combined (1" + 0.5" + 1.875") = 3.375", the flaw must be repaired and can not delayed until 3R15. Since the acceptable circumferential flaw length for emergency/upset loading condition is 3.9", greater than the 3.375" flaw, the flaw is structural acceptable and operable for the past and present. The wall thinning area and the leak need to be repaired by weld overlay.

	NUCLEAR	QUALITY RELATED	EN-OP-104	REV. 2				
[™] Entergy	MANAGEMENT MANUAL	INFORMATIONAL USE	PAGE 3	4 OF 53				
Operability Determinations								

ATTACHMENT 9.4

OPERABILITY EVALUATION/FUNCTIONALITY FORM

Sheet 1 of 1

. . .

Operability/Functionality Evaluation Page 1 of 1
1. Condition Report No./Operability Evaluation No.CR-IP3-2007-03630
2. Summary of Operability Evaluation:
A thru wall leak was observed on the base metal of the elbow just above the weld of the 18" diameter SW FCU
supply line downstream of SWN-38 on line #408.
The leak is a downstream of SWN-38 on a ISI class 3, Seismic class I line. The flaw was measured and
characterized by UT Report IP3-UT-07-110 as three flaws (two leaking). The flaws were evaluated one flaw
.75" circumferential by 1.75" axial and another combined flaw of 3.375" circumferentially by 1.75" axial. These
flaws were evaluated by using the ASME Code Case N-513 and acceptable at this time since they are less
than the allowable flaw length of 3.97" circumferential and 2.46" axial. (See attached calculation).
The flaws are acceptable but will not last until the next outage. The pipe needs to be repaired as soon as possible, Within the month, so an proper repair can be made and to prevent the flaw from growing beyond the acceptable length.
3. Basis for Operability Evaluation attached. X IP-CALC-07-00083 mark up attached.
4. Are there any other affected SSCs? ∐ No ⊠ Yes Service Water supply header to the FCUs
5. Recommendation: ⊠ Operable; □ Operable – COMP; □ Inoperable □ Functional; □ Non-functional
6. Identify any Limitations, Long Term Actions and/or Compensatory Measures to maintain Operability:
accordance with ASME Code Case N-513 "Evaluation Criteria for Temporary Acceptance of
Flaws in Class 3 Piping". The pipe needs to be repaired as soon as possible, within the month,
so an effective repair can be made and to prevent the flaw from growing beyond the acceptable
length. ECR#2532 (EC 00003047).
50.59 Process Completed for Compensatory Actions Required to Maintain Operability
Approvals: Only Dates A.A.A. Stal
Prepared By (Name/Date): KICharl Drake Kuchar N Alahan 1110 F
Additional Reviews (Assign thru CA Process) By (Name/Date): KHI Lo 62 949 CA No.
Additional Reviews (Assign thru CA Process) By (Name/Date)CA No
Engineering Manager Approval By (Complete only if not entered in PCRS) (Print/Sign/Date) 7 Mc Caffrey 87
Shift Manager (Complete only if not entered in PCRS) (Print/Sign/Date)
OE Closed: Date: Shift Manager:
Send a copy of the Operability Evaluation to the System Engineer for use in the System Health Report.
(Attach additional pages as necessary)

ATTACHMENT 4 TO NL-07-120

REPLY TO REQUEST FOR ADDITIONAL INFORMATION REGARDING INDIAN POINT 3 RELIEF REQUEST 3-43

Ultrasonic Test Results for Area of Interest Downstream of SWN-38

IP3-UT-07-110, September 2007

IP3-UT-07-049, March 2007

ENTERGY NUCLEAR OPERATIONS, INC INDIAN POINT NUCLEAR GENERATING UNIT NO. 3 DOCKET NO. 50-286

UT Erosion/Corr

	terov				UT Erosion	/Corr	n Examin	ation				
	Site/Unit: IP3	1	3			Procedur	e: ENN-	-NDE-9.05	Ou	utage No.:	N/A	
Sumn	nary No.:	18" Line	# 408			Procedure Rev	/.:	1	- R	eport No.:	IP3-UT-07-110	
Wo	orkscope:	BOI	P			Work Order No	o.: 001:	23409-02	_	Page:	1 of 5	
Code: AN	SI B31.1 1967 Ec	l. Thru 19	969 Add.	Ca	t./Item:	N/A	Loc	cation:	PAB / Mir	nim Contain	ment	_
Drawing No.:		9321-F-	27223		Desc	ription: Charac	terize thru wall	pipe leak				_
System ID:	Service Water											_
Component ID	: 18" Line # 408	D/S of va	alve SWN-	38			Size/Le	ength: 18" Sch S	TD Thick	ness/Diamet	ter: 0.375"	- -
_imitations:	Partially painte	ed		Compo	onent File No.: SI	WN-38		Start Time:	0800	Finish Tin	ne: 1630	-
										· · · · · · · · · · · · · · · · · · ·		
	Calibration In	formatio	<u>n</u>	(1.1)	Parti		ation		Compone	nt Informati	on	
Calibration	Thickness (In)	Cali	bration Times	s / Initials			Enaing/Col/Row	Component G	eometry:	90 D	eg. Elbow	-
100"		Start:	0945	REA	Main UPST	N/A		Outside Diame	eter: 18"	Gr	id Size: <u>1" X 2"</u>	
.200"	N/A	Verify:	1120		Main	A1	AC3	Max. micknes				-
.300"	N/A	Verify:	1410	BEA	Main DNST.	A1	K6	Nominal Inick	iness:		1 min.: <u>.090"</u>	-
.400"	N/A	Final:	1445	REA	M. DNST Ext.	N/A		Min. Thicknes	s Location:	Micro	grid 14	
			·=		Branch	N/A		Max. Thicknes	ss Location:	Weld	grid Q1	
					Branch Ext.	<u>N/A</u>						
nstrument:			Transe	ducer:		F	Reference/Simu	lator Block:	Ter	np. Tool:		
lanutacturer:	Panametri		Manufa	acturer:	Panametri	i cs S	Serial No.:	A23867	Mai	nufacturer:	Control Co., Inc	<u> </u>
erial No ·			Serial	No.:	1003013	۲ <u>۲</u>	уре:	C/S .04"5"	Ser	ial No.:	QS-78	
iain:	60		Size:	.312	Freq.:	5 MHZ F	Ref./Simulator B	llock Temp.: 9 [.]	1.2 °F _	uplant:		
lange:	00		Model:		D7906	A	laterial/Compo	nent Temp · _ 94	⊺yp 56.°⊑ ⊂ :)e:	Ultragel	
- · · · ·			. #01Ei		Dual	n			<u>5.0</u> F Bat	cn No.:	05325	
Comments/OI	ostructions: <u>Thr</u>	u coat m	ode used	tor micro	& weld grids. D	/98 probe (S/N	532905) use fo	r area sizing da		-	9/20(67
Results:	Accept [_]	Rejec	n 🔽	Into 📋	Tmin = .0	90" per IP-CA	JL-07-00083.	KEFU	LANCE (2-IP3-	2007-0363	0
Examiner	Level III-PDI	$\overline{\langle}$	A st	nature	572 0/	Date Revie	ewer		Signat	ure	Da	ate
Examiner			all		<u> </u>	Date Site F	N/A			ura	1 Di	h te
N/A			Οų	jiiuiuiu		Miz	hael A. T	ERDENIALG	LUJ A	lena	Mina 9/19	07
Other	Level N/A		Się	gnature	<u></u>	Date ANII	Review		Signat	ure		ate
N/A						A	1/A				<u> </u>	

		Supplement	al Report	Report No.:) IP3-UT-07-110
1	Entergy			Page:	2 of 5
Summ	nary No.: 18" Line # 408				
E×	kaminer: Allen II, Robert E.	E Level: III-PDI	Reviewer: NA	1 lil Do. perin	Date:
Ex	kaminer: N/A	Level: <u>N/A</u>	Site Review: Michael	A TERPENING	Date: 9 19 67
	Other: <u>N/A</u>	Level: N/A	ANII Review: N/A		Date:

Comments: Sketch of weld & micro grid layouts. Weld grid locations U3, V3, W3, X3 and Y3 correspond with micro grid locations B6, D6, F6, H6, and J6 and are only shown in th micro grid data printouts.

Sketch or Photo:



Win37DLPlus-Pata Grid

18" Line # 408 D/S of 🚬 .1-38 - Weld Grid

File Name :	SWN-38						s	Survey	Date	:		9/19/	2007								
File Type :	2D Grid Mi						Ainimum thickness: 152" @ 02														
File Description :	E/C						N	/laximu	um th	ickness:		.369"	@ Q1								
Location Note :	;IP3						F	Report	No.:			IP3-U	IT-07-	110							
Inspector ID :	214											Page	3 of 6								
Robert Allen	J. M.	R																			-
Obstructions:	F1-H3, need scaf	fold to reach										_							•		
	U3-Y3, locations	on micro grid					F	Reviwe	er: i	Mich	NEL	A	Ter	SPENI	NG	Lli	A.	u	Lee_		-
														515 e 11 0 5 a							
	<u> </u>																		$\overline{}$		
3.000 A B C D	EFGG	I J K	L M I	N O	P	2 R	ं ।	T L	J. A	. W.	X	Y.	ž þ	A	AC	Min Max	Avg		Color L	egend	
1 0.259 DEP DEES 1.	364 3.257 0.000 0.000 0.000	0 0.346 0.329 0.247	j.345 J.258	281 0.343	3277	.369 931	0 9302	9809 9	320 1	.334 2.29	3 0.196	DB12).335 ()	2013 3.24	9 9336	0 .196 0,36	9 9/302		Over	Range	<u> </u>
2 0,502 0,233 0,273 0,2	2 33) 32232 3.000 3.000 3.000) <u>9203</u> 0.250 0.190).242 <u>J.2</u> 33	0.359 0.152),179 Ş	1.22	1 0.203	9 27 3 9	EO I	239).230	3 3,237	9273).192)	.253).21	3 ILTO).152).35	9 0.255		la Nat	Uteral	
<u>i 3 0390</u> 0.249 0273 02	200 2200 2.000 2.000 2.000) 9£00 92£0 9.225 1	3.232 3.230 :	0.246 0.250	9 2 339	ere pres	9 9,202	5)250))	.000)	.000 0.000	000.0	0.000 C	ງ,207 ຈຼີ	290 127	3 9237).207) E	9 2268				I .
Min : 0.259 0.249 0.273 02	263).257	9203 0.250 0.190	3.232 3.230	0.246 0.152	0.179	265 1.22	1).203	9270 9	300	267 1.238	3,196	9278).192 J	.253 3.21	3 DZOZ				, Not	Used	
Max 0319 0298 0325 1.3	364 0.292	0.346 0.329 0.247	0.345 0.286),359 ~),343 *****	0.277):369 <u>0</u> 131	0.0302	03199	320)	.334 929	3 3.237	DEN2) 335 🛐	200 9,25	3 060	و. برمان میآمد. ماند ماند			Not	Used	
Avg	305[9]277	21319 2290 3.221	0.278 0.258	0295 0.248	3,240	1302 227	749-2624	01288 0	310,5	301(2):26	0.217	9295	3.245 2	268 0.24	5 0.298				0.328	- 0 421	0.421
TMin UT172					<u> </u>					· · · · · · · · · · · · · · · · · · ·	4				-						0.328
TAUE 2020				· · · · · · · · · · · · · · · · · · ·					÷-					····		····· · · · · · · · · · · · · · · · ·			0.262	- 0.328	0.262
INVCIDENCE			: i		<u>!</u>	i	; ;	!				1			<u> </u>				0.090	- 0.262	, ,

.

Page 1

Report Date: 9/19/2007

.

.

0.090

0.000

0.000 - 0.090

Under Range

-.

Win37DLPlur=Pata Grid

18" Line # 408 D/S of SWN-__ - Micro Grid on elbow

File Name :	SWN-38M	Survey Date :	9/19/2007
File Type :	2D Grid	Minimum thickness:	.077" @ 4
File Description :	E/C	Maximum thickness:	, 328" @ K1
Location Note :	IP3	Report No.:	IP2-UT-07-110
Inspector ID :			Page 4 of 5
Robert Allen	Falle		
Obstructions:	A2-C2, valve hand wheel		
		Reviwer:	INE A TERDENING ALLO, LOUIS
<u></u>			
~t· 1	all a straight the second	A REPORT OF A REPORT OF A REPORT OF	The second s

.

,

Over Range	
Not Used	
Not Used	
Not Used	0.421
0.328 - 0.421	0.720
0.262 - 0.328	0.360
0.112 - 0.262	0.202
0.000 - 0.112	0.112
Under Range	0.000
1	

.

.

.

__

0.000	A	8	c	D	E	F	G	н	I	J .	ĸ	Min	Max	Avg
1		0237	0.231	0.176	0.201	0,203	0.177	0.167	0.210	0.254	0.328	0,167	·0.328	0.231
2	0.000	0.000	0.000	0.143	0.175	0.171	0.182	0,184	0.194	. 0,222	0.273	0,143	0.273	0.193
3	0273	0.150	0.146	0,149	0.153	0.187	0.212	0,179	0.185	0.225	0.248	0.146	0.271	0.191
	0200	0.123	0.175	0,160	0.121	0,159	0.149	0,084	0.077	0.231	0.249	0.077	0.999	0.167
	~_ 0.293	0.191	0.121	0.197	0,139	0.209	0.159	0.131	0.156	0.207	0.230	0.121	0.220	0.185
, í	් බළුග	0.258	0.194	0,190	0.213	0.170	0,199	0.191	0.167	° 0.273	0.220	0,167	0.500	0.216
Min	0.273	0.123	0.121	0.143	0.121	0.159	0.149	0.084	0.077	0.207	0.220			
Max	COE0	0207	0.231	0.197	0.213	0.209	- 0.212	0.191	0,210	0.270	0.328	-	-	
Avg	0.293	0.202	0.173	0,169	0.167	0.183	0.180	0.156	0.165	0.236	0.259			1.
TMin	0.077									 			1	
TMax .	0.328	[·				! 							
TAvg	0,198									1				1

.

\sim	· · · · · · · · · · · · · · · · · · ·		\frown
		Supplemental Report Report No	.: IP3-UT-07-110
Enterg	<i>I</i> Y	Page	2 5 of 5
Summary No.:	18" Line # 408	-	
Examiner:	Allen II, Robert E. Jer all R	Level: III-PDI Reviewer: NA held Jeins	Date:
Examiner:	<u>N/A</u>	Level: N/A Site Review: M:: has A JERDENING	Date: 9 19/05
Other:	Ν/Α	Level: N/A ANII Review: N/A	Date:

Comments: Scan of the elbow micro grid showing the areas that are less than .109" thick. These areas are around both through wall leaks and the grid locations H4 and I4. Leak #1 is contained in grid B3-B4-C3-C4, and leak #2 is contained in grid F4-F5-G4-G5.



UT Erosion/Col sion Examination

	Ente	ergy	c /	2			Drocodu			Outage No :	NI/A
				J			Presedure De		NDE-9.05		
	Summa	ary No.:	N//	A			Procedure Re	v.:	<u> </u>	нероп №	123-01-07-049
	Wor	kscope:	BO	P			Work Order N	o.: IP3-C	07-17850	Page:	1 of 3
Code:	ANS	B31.1, 1967	Ed. thru 1	969 Add.	C	at./Item:	N/A	Loc	ation:	32' PAB SW Chas	ie
Drawing	No.:		9321F	27223		Desc	ription: Pipe a	nd weld down s	tream of SWN-38		
System I	D:	Service Wate	r				_				
Compone	ent ID:	SWN-38						Size/Le	ngth: 18" Sch Std.	Thickness/Diamet	er: .375"
Limitation	ns:	Painted surfa	ice		Comp	onent File No.: N	/A		Start Time:	0830 Finish Tin	ne: 1045
[Calibration	Informatic	วก]	Parti	tioning Inform	ation		Component Informati	on
Cali	bration T	hickness (In)	Cal	libration Time:	s / Initials	Component	Begin/Col/Row	Ending/Col/Row	Component Geon	netry: Pip	e & weld
.040)"	N/A	Start:	0830	RDH	M. UPST Ext.	<u>N/A</u>	<u>N/A</u>	Outside Diameter	: <u>18"</u> Gr	id Size: 1"
.100)"	N/A	Verify:	0920	RDH	Main UPST.	N/A	<u> </u>	Max. Thickness:	.340" Min. Thi	ckness: .033"
.200	<u>)"</u>	<u> </u>	Verify:	<u>N/A</u>	N/A	Main	<u> </u>	<u> </u>	Nominal Thicknes	s: .375"	Tmin.: .110"
.300	<u>)" </u>	<u>N/A</u>	Verify:	<u>N/A</u>	<u>N/A</u>	Main DNST.	<u>N/A</u>	<u> </u>	Min. Thickness Lo	ocation: H	6
.400)" 	<u> </u>	Final:	1045	RDH	M. DNST Ext.	<u> </u>	<u>N/A</u>	Max. Thickness L	ocation: A	4
						Branch Branch Evt	<u> </u>	<u>N/A</u>			
Instrume	ent:			_		Diditch Ext.		<u> </u>		_`	
Manufact	urer:	Panamet	rics	Trans	lucer:	_		Reference/Simula	ator Block:	Temp. Tool:	Control Co. Inc.
Model:	-	37DL+	+	- Manuta	acturer:	Panametri	<u>cs</u>	Serial No.:	99-7437	Sorial No :	
Serial No	.: _	0311101	106	- Senan Sizor	212	5/6062	5 MH7	Гуре:	C/S .04"5"		<u> </u>
Gain:	_	59db		- <u>Size</u> , Model:	.312	Preq		Ref./Simulator Bl	ock Temp.: <u>71.7</u>	°F Type	litragel
Range:	_	2"		. # of El	ements:	Dual		Material/Compon	ent Temp.: _ 46	°F Batch No.:	05325
Commer	nts/Obs	structions: Th	e grid ran	ige was fro	om A1 to	K6. No readings	were taken at	A1. A2. A6. B1. I	 K1. K2 or K6.	·	···
Results:		Accept	Rejec	ct	Info []]	Gage ope	erated in thru-	coat mode.			
Examine	r L	evel IIL	n // _	Sig	nature		Date Revie	ewer		Signature	Dat
Herrman	ın, Rot	pert D.	1 cler	t ae	ma	lm 31	27/2007 N	14			
Examine	1	.evel		Sig	nature		Date Site	Review	2 5	Signature	Dat 1. 5/24/0
Other	/ L	evel		Sig	Inature		Date ANII	Review		Signature	Dat
	104							N/A			<u> </u>

Ę С D F 9 E K A, H Ł Ţ ALL THICKNESSES OUTSIDE OF THE LINE ARE > 0.210. AREA OF INTEREST IS 10" x 5.5" 0.202 0.135 0.191 ٥.207 0.224 0.228 0.275 0.250 4 -4 4 -4 4 -0.181 0.144 0.143 0.197 0.190 0.207 0.275 0.224 0.220 4 4 4 4 4 4 .+ ٦ 4 F 2 0.128 0,189 0.235 0.169 0.139 0,181 0,256 0.162 0.182 0.250 1330 + 4 T 1 4 4 -H + 3 0,100 0,155 0.230 0.163 0.128 0,133 0.258 0.206 0.126 .340 0.124 ŧ٢. 4 4 4 ۲. ٦ ۲. 4 L 4 1 4 0.185 0.167 0.109 0,185 0.233 0.142 220,0 0.236 .291 0,221 105,0 7 4 1 7 4 7 7 4 4 L 5 0.208 0.215 0.202 0,185 0.231 0.230 0.206 0.301 0.033 -14 Mar 14 -4 -4 .0.39e-0.403 REPORT No. 183-41-07-6 0,340 0.367. PAGE 2 of 3



ATTACHMENT 5 TO NL-07-120

REPLY TO REQUEST FOR ADDITIONAL INFORMATION REGARDING

INDIAN POINT 3 RELIEF REQUEST 3-43

Entergy Calculation IP-CALC-07-00209, Revision 0 Design Reinforcement Plate for Through Wall Leak Repair D/S SWN-38

> ENTERGY NUCLEAR OPERATIONS, INC INDIAN POINT NUCLEAR GENERATING UNIT NO. 3 DOCKET NO. 50-286

	,							
	NUCLEAR		QUALITY REL	ATED	EN-DC-126	REV. 0		
== Entergy	- Entergy MANAGENIE		NI REFERENCE USE		PAGE 27 OF 32			
10000000000000000000000000000000000000	Er	igineering Ca	alculation Process					
			ا مر	klo				
	NO-2		TIP.	2	1 IP-3			
	10 2			,				
	<u>PS</u>					- <u></u>		
CALCULATION COVER PAGE	(¹⁾ EC #	3176			⁽²⁾ Page 1 of	<u>_8</u>		
(3) Design Basis Calc.] YES 🛛	NO			EC I	Markup		
(5) Calculation No: IP	-CALC-07-0	0209			⁽⁶⁾ Revision	n: 0		
77								
" Title: Design Rein	forcement F	Plate for Th	hrough Wall Lo	eak Repair	r D/S SWN-38			
(B) 0		(9)						
System(s): SWS		Design	w urg (Depart	ment): Ch	vii / Structural			
(10)		Uesign L	ingineering					
Safety Class:		Com	Component/Equipment/Structure Type/Number:					
🕅 Safety / Quality Be	lated	SWN-38						
Augmented Qualit	y Program							
Non-Safety Relate	d							
					<u></u>			
(12) Decument Type: (
Document Type. C	ALC							
(13) Konnerda		, ,						
(Description/Tonical (Codes).							
(Descriptions repical (500C3/.				·····			
		DEV						
<u></u>		nev	12113	1	·····			
(14) Name/Signature/D	ate ⁽¹⁵⁾	Name/Sigr	natyre/Date	⁽¹⁶⁾ Na	ame/Signature/	Date /		
Kai Lo 9-25-07 6C	P. Bow	e 9-26-07 -	KD	R. Drake	9-26-07/ Jak	Start		
Responsible Engine	er 🛛 🖂 De	sian Verifi	er	Sup	ervisor/Appro	val 9/21		
		viewer				[-!		
	Coi	mments At	tached	🗌 🗌 Co	mments Attacl	ned		

	NUCLEAR	QUALITY RELATED	EN-DC-126	REV. 0
≈ Entergy	MANAGEMENI MANUAL	REFERENCE USE	PAGE 27 O	F 32

Engineering Calculation Process

ATTACHMENT 9.3

CALCULATION REFERENCE SHEET

CALCULATION REFERENCE SHEET	CALCULATION NO: IP-CALC-07-00209, REV. 0 Page 2 of 8							
 EC Markups Incorporated: NONE 1, 2. 3. 4. 5. 								
II. Relationships:	Sht	Rev	Input Doc	Output Doc	Impact Y/N	Tracking No.		
1.	 							
2.								
3.								
4.								
1. 2. 3. 4. 5.								
IV. SOFTWARE USED: NO	DNE							
Title:	Vei	rsion/R	elease:	Disk/	CD No			
V. DISK/CDS INCLUDED:	NONE							
Title:	Title:Disk/CD No							
VI. OTHER CHANGES: NONE								

	NUCLEAR	QUALITY RELATED	EN-DC-126	REV. 0			
= Entergy	MANAGEMENI MANUAL	REFERENCE USE	PAGE 27 C)F 32			
Engineering Calculation Process							

Page 3 of 8

Initial i	ssue of Calculation IP-CALC-07-00209.
0	
	· · · · · · · · · · · · · · · · · · ·
·	

	NUCLEAR	QUALITY RELATED	EN-DC-126	REV. 0		
<i>≈ Entergy</i>	MANUAL	REFERENCE USE	PAGE 27 OF 32			
Engineering Calculation Process						

LIST OF EFFECTIVE PAGES

Page 4 of 8

Calculation Number: IP-CALC-07-00209 Revision Number: 0_____

REV. REV. PAGE REV. PAGE PAGE 0

.

ŀ

All

.

,

	NUCLEAR	QUALITY RELATED	EN-DC-126 REV. 0				
<i>≈ Entergy</i>	MANAGEMENT	REFERENCE USE	PAGE 27 OF 32				
Engineering Calculation Process							

TABLE	E OF CO	ONTENTS	PAGE 5 OF 8
		Topic	<u>Page No.</u>
1	Calcul	ation Cover Page	 1
2	Calcul	ation Reference Sheet	 2
3	Record	d of Revisions	 3
4	List of	Effective Pages	 4
5	Table	of Contents	5
6	Calcul	ation Section	 6
	6.1	Background	 6
	6.2	Purpose	 6
	6.3	Method of Analysis	 6
	6.4	Assumptions	 6
	6.5	Design Input	 6
	6.6	References	 6
	6.7	Calculation	 7
	6.8	Results/Conclusions	 8

.

.

	NUCLEAR	QUALITY RELATED	EN-DC-126	REV. 0			
🛎 Entergy	MANAGEMENT	REFERENCE USE	PAGE 27 C	PAGE 27 OF 32			
	Engineering (Calculation Process					

6.0 Calculation Section

Page _6_of _8

6.1 Background

Two through wall leaks and a below minimum wall thickness area were found down-stream of the valve SWN-36 at the region next to the weld toe on Line 408.

6.2 Purpose

A temporary repair is needed to repair the elbow at two leaks and below minimum wall thickness area. It is necessary to design a plate and weld it over the leaked/thinned area.

6.3 Method of analysis

- 1. Based on a four side simple support regular plate with a uniform design pressure of 150 psi acting on it, determine plate thickness required to stay below the allowable stress for the plate material.
- 2. Based on item1, reaction at the simple supported edge can be obtained for the weld stress.
- 3. Determine the transverse shear to be carried by the weld (in the longitudinal direction) in order for the elbow and curved plate to act as one integral piece to resist flexural bending.
- 4. Determine the torsion shear taken by weld along the circumferential direction.
- 5. SRSS the weld stresses to obtain the resultant weld stress and determine the fillet size to ensure the weld stress is below the allowable weld stress.
- 6. Evaluate the pipe stress of a section of uniform wall thickness of 0.2" (minimum pipe thickness outside of the reinforced plate) for design loadings.

6.4 Assumption

- 1. Allowable stress of 15000 psi is based on either a curved section of a 20" elbow of A53 Gr. B seamless material, or A106 Gr B or C, or a rolled plate from A442, A515 or A516 Gr. 60 material.
- 2. Three times the larger reaction from the two adjacent pipe supports is used to design for the transverse shear carried by the weld for the reinforcement plate.

6.5 Design Input

- 1. IP3 Pipe specification TS-MS-027
- 2. Drawing 9321-F-53533
- 3. USAS B31.1, Power Piping Code, 1967.
- 4. Pipe support calculation for SWN-R-524-R & SWN-H&R-525-U

6.6 Reference

- 1. IP3 Pipe specification TS-MS-027
- 2. Drawing 9321-F-53533
- 3. "Formula of Stress and Strain", Roark and Young, 5th edition
- 4. USAS B31.1, Power Piping Code, 1967.
- 5. Pipe support calculation for SWN-R-524-R & SWN-H&R-525-U

P. 7 OF 8

.

6.7 Calculation

Determine reinforcement plate thickness and fillet weld size Pipe thickness beyond the reinforcement plate is greater than 0.25".

		new reinforcement plate
t = plate thickness =	0.5	in
a = plate length in the circumferential direction =	10	in, line from A to J plus 1.5" on each side
b = plate length in the axial direction =	7	in, from line 1 to 6 plus 1.5" from line 1
q = design pressure of piping =	150	psi
w = filet weld size =	0.5	in
Use plate material A442, A515, or A516 Gr. 60, S_h =	15000	psi (or cut from a pipe elbow)
Design plate for uniform pressure:		
Assume 4 sides simple support		[Ref 3, table 26, case 1a]
a/b =	1.42 9	
β =	0.463	
γ=	0.4 8	
σ = plate normal stress = $\beta qb^2/t^2$ =	13612	psi < S _h = 15000 psi
max R = γqb =	504	lb per inch
f_{w1} = weld stress for pressure = R/(0.707w) =	1426	psi
Design plate for bending:		
Plate and exist pipe must act together as a composite, inte	egral secti	ion
with the weld taking the transverse shear.		
f = transverse shear at weld = VAy/(In)		·
For a continuous beam, the resisting shear will be smaller than	the reaction	n at the support
To design for shear, consider the adjacent support reaction.		
Reaction at adjacent support SWN-R-524-R =	2411	lb [Ref. 5]
Design for 3 times the reaction, $V =$ shear =	7233	lb
Determine the distance from the c.g. of new plate to pipe of	cenetrline	for new plate:
t = nominal thickness of new plate =	0.5	in .
R = mean radius to plate =	9.25	in
$L_c \approx$ length of new plate =	10.0	in \iy
$\alpha = 0.5 \left[\frac{L_{a}}{2 \pi R} (360) \right] =$	30.97	degrees a
$\alpha(radian) =$	0.5405	
t/R =	0.0541	
$A = area = \alpha t (2R-t) =$	4.86	in ² [Ref 3, table 1, case 19]
$y_{1\alpha} = R \left[1 - \frac{2\sin\alpha}{3\alpha} \left(1 - \frac{t}{R} + \frac{1}{2 - \frac{t}{R}} \right) \right] =$	0.680	in

P. 8 . F 8

$y =$ distance from c.g. of segment to pipe center = R - $y_{1a} =$	8.570	in
D = outside diameter =	18	in
For moment of inertia calculation, use t =	0.200	in
d = inside diameter = D - 2t =	17.600	in
I = moment of inertia of the pipe = $0.0491[D^4 - d^4] =$	443.1	in ⁴
n = number of welds to carry the transverse shear =	2	
f = transverse shear at weld = VAy/(in) =	340	#/in note: in the longitudinal of the pipe
$f_{w2} = f/(.707w) =$	963	psi
Design weld for torsional shear		
T = torsion at pipe, conservatively use	437248	in-lb, see 0.75i($M_a + M_b$) for value (see below)
R = outside radius = D/2 =	9.0	in
$R_i = inside radius = (R-t) =$	8.80	in
$\tau = 2TR/[\pi(R^4-R_i^4)] =$	4442	psi
$f_{w3} = \tau(t/w)/(.707) =$	2513	psi
$f_{w} = \{f_{w1}^{2} + f_{w2}^{2} + f_{w3}^{2}\}^{0.5} =$	3045	psi
e = efficiency factor for weld =	0.8	
Allowable weld stress is governed by base metal = eS_h =	12000	$psi > f_w = 3045$ psi, o.k.
Verify the repaired condition meeet original de	sign loadin	g requirement.
For original pipe stres	s analysis	,
P = design pressure =	150	psi
D = outside diameter =	18	in
t' = nominal pipe wall thickness =	0.375	in
S' = section modulus =	89.60	in ³
0.75i' = SIF used in stress run = $.75*3.5 = 100$	2.625	at 45 degrees portion of elbow
f'nor = normal stress from stress run =	3120	psi, from PAB-90 inpsection point
f' _{dw+obe} = DW+OBE stress from stress run =	5490	psi
f' _{dw+dbe} = DW+DBE stress from stress run =	6680	psi
$f_p = PD/(4t') =$	1800	psi
f'_{dw} = dead weight stress w/out pressure = $f'_{nor} - f'_p$ =	1320	psi
$0.75iM_a = moment due to DW loading = f_{dw}S' =$	118272	in-lb
Based on wall thinning pipe wall, t =	0.20	in
S based on t =	61	in ³
$PD/(4t) + 0.75iM_a/S =$	5314	$psi < S_n = 15000 psi$
$f'_{dw+obe} = obe pipe stress w/out pressure = f'_{dw+obe} - f_p =$	3690	psi
$0.75i(M_a + M_b)$ = moment due to DW+OBE loading = $f'_{dw+obe}S'$ =	330624	in-lb
$PD/(4t) + 0.75i(M_a + M_b)/S =$	8795	psi < 1.2S _h = 18000 psi
f'_{dbe} = dbe pipe stress w/out pressure = f'_{dw+dbe} - f_p =	4880	psi
$0.75i(M_a+M_b) = moment due to DW+DBE loading = f'_{dw+dbe}S' =$	437248	in-lb

6.8 Conclusion

The new reinforcement plate stress, new fillet weld, and pipe section with reinforcement plate are structurally adequate per B31.1 code and criteria.

 $PD/(4t) + 0.75i(M_a+M_b)/S = 10543$ psi < $1.8S_h = 27000$ psi

ATT. 1, p. 10F2

size 26 Formulas for flat plates with straight boundaries and constant thickness

1

No standard

Case no., shape. and supports Case no., loading Formulas and tabulated specific values icetangular plate; all edges mply supported 1a. Uniform over entire plate (At center) Max $\sigma = \sigma_b = \frac{\beta_0 b^2}{r^2}$ and $\max x = \frac{-\alpha q \delta^4}{Er^3}$ S $\overline{0}$ 1a. Uniform over entire plate (At center) Max $\sigma = \sigma_b = \frac{\beta_0 b^2}{r^2}$ and $\max x = \frac{-\alpha q \delta^4}{Er^3}$ S $\overline{0}$ 1.0 1.2 1.4 1.6 1.8 2.0 3.0 4.0 5.0 ∞ S $\overline{0}$ 0.2874 0.3762 0.4530 0.5172 0.5688 0.6102 0.7134 0.7476 0.7300 σ 0.0444 0.0616 0.0770 0.0996 0.1017 0.1100 0.1417 0.1421 γ 0.420 0.455 0.476 0.499 0.503 0.505 0.502 0.501 0.500 (Ref. 21 for $r = 0.3)$ (At center) Max $\sigma = \frac{3W'}{2\pi r^2} [11 + r) \ln \frac{2b}{\pi r_b^2} + \beta]$ Max $r = \frac{-\alpha W r^2}{\pi r_b^2}$ $Max , r = \frac{-\alpha W r^2}{\pi r_b^2}$ (b. Uniform over small concentric circle of radius r_a (note definition of r_a') $\frac{1.0}{\beta}$	EXTION: The notation y refer to the stresses apressive on the top is the edge of the plate $1.6r_o^2 + t^2 = 0.675t$	for Table 24 applies in directions parallel if loadings are consider e (pounds per inch). if $r_o < 0.5t$ and $r'_o =$	with the following modifications: a and b refer to plate dimensions, and when used to the sides a and b , respectively. σ is a bending stress which is positive when ten ed vertically downward. R is the reaction force normal to the plate surface exerted b r'_o is the equivalent radius of contact for a load concentrated on a very small area r_o if $r_o > 0.5t$	as subscripts for stress, isile on the bottom and by the boundary support and is given by $r'_{o} =$
$S = \frac{S}{1600} \frac{S}{1600} \frac{S}{1600} \frac{1}{1000} \frac{1}{10000} \frac{1}{10000} \frac{1}{10000} \frac{1}{100000} \frac{1}{10000000000000000000000000000000000$	Case no., shape, and supports	Case no., loading	Formulas and rabulated specific values	
1b. Uniform over small concentric circle of radius r_0 (note defini- tion of r'_0) $\frac{\sigma/b}{2\pi r^2} \begin{bmatrix} (1+r) \ln \frac{2b}{2\pi r_b^2} + \beta \end{bmatrix}$ $\frac{Max_F}{Er^3}$ $\frac{a/b}{\beta} \begin{bmatrix} 1.0 & 1.2 & 1.4 & 1.6 & 1.8 & 2.0 & \infty \\ 0.435 & 0.650 & 0.789 & 0.875 & 0.927 & 0.958 & 1.000 \\ a_1 & 0.1267 & 0.1478 & 0.1621 & 0.1715 & 0.1770 & 0.1805 & 0.1851 \end{bmatrix}$	ectangular plate; all edges mply supported S S S S S	la. Uniform over entire plate	$\begin{array}{llllllllllllllllllllllllllllllllllll$	(Ref. 21 for <i>p</i> = 0,3)
		 Uniform over small concentric circle of radius t₀ (note defini- tion of t₀) 	(At center) $Max \sigma = \frac{3W}{2\pi t^2} \left[(1 + r) \ln \frac{2b}{\pi r_b} + \beta \right]$ $Max r = \frac{-\alpha H t^2}{Et^3}$ $\frac{a/b}{\beta} \frac{1.0}{0.435} \frac{1.2}{0.650} \frac{1.4}{0.789} \frac{1.6}{0.875} \frac{1.8}{0.927} \frac{2.0}{0.958} \frac{\infty}{1.000}$ $\frac{1.2}{\alpha} \frac{1.4}{0.1267} \frac{1.6}{0.1478} \frac{1.6}{0.1621} \frac{1.8}{0.1715} \frac{2.0}{0.1770} \frac{\infty}{0.1805} \frac{1.000}{0.1851}$	

CHAP. 10

ART. 10.10]

1c. Uniform over central rectangular atea	(At center	ng s	táx a ≠	≈ 17 ₆ ≈	$\frac{\beta W}{t^2}$	a-h	ere N	≈ 4″1	<i>b</i> ₁											
	× #116			<i>a</i> =	= h			1		,	(⇒)	1.46					a =	= 26		
	1,11	Ð	0.2	0.4	1),6	0.8	1.0	0	0.5	2 0.	.4	0.8	1.2	1.4	0	0,4	0.5	1.2	1.6	2.0
p0	0		1.82	1.38	1.12	0.93	0.76	1.	2.0	1.	55	1.12	0.84	0.75		1.64	1.20	0.97	0.78	0.64
i	0,2	1.82	1.28	1.08	0.90	0.76	0.63		18 1.4 50 54	3 1.) 3 17	23	0.95	0.74	0.64	1.73	1.31	1.03	0.84 0.74	0.68	0.57
	0.6	1.12	0,90	0.72	0.60	0.52	0.43	1.3	0 0.9	1 0.8	82 (0.68	0.53	0.47	1.04	0.90	0.76	0.64	0.54	0.44
	0.8	0.92	0.76	0.62	0.51	0.42	0.36	0.9	0 0.7	6 0.8	58 (8.57	0.45	0.40	0.87	0.76	0.63	0.54	0.44	0.38
	1,0 Í	0.76	0.63	0.52	0.42	0.35	0.30	0.7	5 0 6	2 0.5	57 (0.47	0,38	0.33	0.71	0.61	0.53	0.45	6.38	0.30
	(Values fro	nı ehar	ts of R	ef. 8: 1	= 0.9	.)														
Id. Uniformly increasing Jong length	Max o =	$\frac{Bqb^2}{t^2}$	JIR	m	(x.) ≈	$\frac{-aqb}{El^3}$	+													
	nth	1	1.5	2.0	2.5	3	0.	3.5	4.0											
	BIB	.16	0.26	0,34	0.35	0.4	3 (),47	0.49											
بنبكم	a 0	.022	6.043	0,060	0.07	0 0,0	78 (056	0.091											
a	(Values fr	on cha	as of H	tef. 81	v = 0.	(. ا														
te. Uniformly moreasing along width	Max o =	$\frac{\beta q \hbar^2}{t^2}$	and	uı.	ax y =	$\frac{-nqk}{Et^2}$														

0.38 0.260.32 0.35 0.37 0.35 ₩. þ ₿ ß 0.16 i 0.049 0.056 0.063 0.067 0.069 0.070

386

TABLE 1 Properties of sections (Cont.)

Form of section	Area and distances from centroid to extremities	Moments and products of inertia about central axes	Radii of gyranion about central axes
17. Segment of solid circle (<i>Note:</i> If $\alpha < \frac{\pi}{4}$, use expressions from case 18)	$A = R^{2}(\alpha - \sin \alpha \cos \alpha)$ $y_{1a} = R \left[1 - \frac{2 \sin^{3} \alpha}{3(\alpha - \sin \alpha \cos \alpha)} \right]$ $y_{1b} = R \left[\frac{2 \sin^{3} \alpha}{3(\alpha - \sin \alpha \cos \alpha)} - \cos \alpha \right]$ $y_{2} = R \sin \alpha$	$I_1 = \frac{R^4}{4} \left[\alpha - \sin \alpha \cos \alpha + 2 \sin^3 \alpha \cos \alpha - \frac{16 \sin^6 \alpha}{9(\alpha - \sin \alpha \cos \alpha)} \right]$ $I_2 = \frac{R^4}{12} (3\alpha - 3 \sin \alpha \cos \alpha - 2 \sin^3 \alpha \cos \alpha)$	$r_1 = \frac{R}{2}\sqrt{1 + \frac{2\sin^3 \alpha \cos \alpha}{\alpha - \sin \alpha \cos \alpha} - \frac{16\sin^2 \alpha}{9[\alpha - \sin \alpha \cos \alpha]^2}}$ $r_2 = \frac{R}{2}\sqrt{1 - \frac{2\sin^3 \alpha \cos \alpha}{3(\alpha - \sin \alpha \cos \alpha)}}$
8. Segment of solid circle (.Vote: Do not use if $a > \frac{\pi}{4}$) $\frac{y_{1a}}{1} = \frac{2}{4} = \frac{y_2}{4} = \frac{y_1}{4}$	$\begin{aligned} A &= \frac{2}{3}R^2\alpha^3(1-0.2\alpha^2+0.019\alpha^4) \\ \mathbf{x}_{1\alpha} &= 0.3R\alpha^2(1-0.0976\alpha^2+0.0028\alpha^4) \\ \mathbf{y}_{1b} &= 0.2R\alpha^2(1-0.0619\alpha^2+0.0027\alpha^4) \\ \mathbf{y}_2 &= R\alpha(1-0.1667\alpha^2+0.0083\alpha^4) \end{aligned}$	$l_1 = 0.01143R^4 \alpha^7 (1 - 0.3491 \alpha^2 + 0.0450 \alpha^4)$ $l_2 = 0.1333R^4 \alpha^5 (1 - 0.4762 \alpha^2 + 0.1111 \alpha^4)$.	$r_1 = 0.1309R\alpha^2(1 - 0.0745\alpha^2)$ $r_2 = 0.4472R\alpha(1 - 0.1381\alpha^2 + 0.0184\alpha^4)$



83