



U.S. Nuclear Regulatory Commission  
Page 2


OCT 26 1995

mitigation system (COMS) and as required by the cold shutdown ASME Section XI scheduling requirements and 2) could be stroked in Mode 1 or 2 to determine valve operability provided the appropriate block valve is closed. Revision of this commitment prevents unnecessary stoking of the PORVs.

This commitment meets the requirements in the WBN Technical Specifications and the WBN ASME Section XI program; therefore, TVA considers the revised commitment to be acceptable and in conformance with the intent of the generic letter.

If you should have any questions concerning this matter, please telephone John Vorees at (423) 365-8819.

Sincerely,



R. R. Baron  
Nuclear Assurance  
and Licensing Manager (Acting)

cc: NRC Resident Inspector  
Watts Bar Nuclear Plant  
1260 Nuclear Plant Road  
Spring City, Tennessee 37381

Mr. P. S. Tam, Senior Project Manager  
U.S. Nuclear Regulatory Commission  
One White Flint North  
11555 Rockville Pike  
Rockville, Maryland 20852

U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323