



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381

NOV 01 1995

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of the Application of) Docket Nos. 50-390
Tennessee Valley Authority) 50-391


WATTS BAR NUCLEAR PLANT (WBN) - COMPLETION OF THE CABLE TRAY AND
CABLE TRAY SUPPORTS (CT) CORRECTIVE ACTION PROGRAM (CAP)

The purpose of this letter is to notify NRC that TVA has completed the CT Corrective Action Program as defined in the Watts Bar Unit 1 Nuclear Performance Plan, Volume 4, Revision 1. The stated objectives of the CT CAP have been met.

The enclosure to this letter lists the major elements implemented by the CAP and the resolution of the items identified as open at the time of the CAP implementation inspection.

The documentation package (100 percent book) for this program has been updated and is available for review. If you should have any questions, please contact P. L. Pace at (423) 365-1824.

Sincerely,



R. R. Baron
Nuclear Assurance
and Licensing Manager (Acting)

Enclosure

cc: See page 2

9511070019 951101
PDR ADDCK 05000390
Q PDR

D030

U.S. Nuclear Regulatory Commission
Page 2

NOV 01 1995

cc (Enclosure):

NRC Resident Inspector
Watts Bar Nuclear Plant
1260 Nuclear Plant Road
Spring City, Tennessee 37381

Mr. P. S. Tam, Senior Project Manager
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

ENCLOSURE

Numerous adverse conditions involving the adequacy of structural qualification and configuration records for seismic Category I cable trays, cable tray fittings, and cable tray supports were identified in various Conditions Adverse to Quality (CAQ) documents, Nuclear Regulatory Commission (NRC) violation notices, Design Baseline and Verification Program (DBVP) documents, Vertical Slice Review (VSR) reports and Employee Concern Reports.

The Cable Tray and Cable Tray Supports Corrective Action Program (CAP) was implemented to address these issues and assure structural adequacy and compliance with licensing commitments for Unit 1 and common safety-related cable tray and cable tray supports. The primary corrective actions employed were as follows:

- Complete and document the design basis for cable trays, cable tray fittings/hardware, and cable tray supports.
- Update the design output documents to be consistent with the completed design basis.
- Revise construction, maintenance, and quality assurance procedures, to incorporate design output requirements.
- Develop and implement critical case evaluations of existing installations, with corrective actions as appropriate.

NRC Inspection 50-390, 391/95-69, which ended on November 1, 1995, documents the verification of completion of corrective actions for the CT CAP with the exception of the following documents that were identified as open in the final status report dated October 26, 1995. The required verification and documentation closure for each item is listed including resolution date.

<u>Condition Adverse to Quality</u>	<u>Closure Date</u>
WBP870528SCA	10/28/95
WBP880040SCA	10/28/95
WBP870532	10/27/95
WBP870533	10/28/95
WBP870534	10/25/95
WBP880738SCA	10/21/95

Corrective Action Tracking Documents

11103-WBN-08	10/28/95
80209-WBN-03	10/31/95

Construction Deficiency Report

CDR 390/86-25	10/24/95
---------------	----------

Other Items

NQA Assessment	10/20/95
----------------	----------