

November 6, 2007

LICENSEE: MITSUBISHI HEAVY INDUSTRIES (MHI)
FACILITY: US-APWR STANDARD DESIGN PRE-APPLICATION REVIEW
SUBJECT: SUMMARY OF THE AUGUST 23, 2007 PUBLIC MEETING ON SAFETY
FEATURES AND PLANT DESIGN FEATURES FOR THE US-APWR

On August 23, 2007, a Category 1 public meeting was held between the U.S. Nuclear Regulatory Commission (NRC) staff and representatives of Mitsubishi Heavy Industries (MHI) at NRC Headquarters in Rockville, Maryland. The purpose of the meeting was to discuss plant safety features and plant design concepts for the US-APWR and to obtain feedback from the NRC staff. A list of meeting attendees is provided as Enclosure 1. MHI presented a handout, which is shown in Enclosure 2, and can be accessed through the Agencywide Documents Access and Management System (ADAMS) accession number ML072890316.

Safe Shutdown

MHI began the meeting by discussing and explaining the term "safe shutdown" and how the US-APWR design accomplishes safe shutdown. Specific safety related systems are used to complete and maintain safe shutdown, which are not directly related to the mitigation of accident consequences. MHI explained that while bringing to, and maintaining, the plant in Hot Standby or Cold Shutdown status the safe shutdown systems are required to control reactivity, provide reactor coolant makeup (RCS makeup), control reactor pressure, and remove decay heat. MHI then proceeded to explain how the US-APWR design accomplishes these functions. Reactivity control is accomplished using feed and bleed with the Safety Injection (SI) pumps, and the emergency letdown lines. This design meets SRP 7.4 (NUREG-0800) and uses the same design as the SP-90, an evolutionary pressurized-water reactor (PWR) by Westinghouse. RCS makeup is also provided by the SI pump. This design, once again, mimics Westinghouse SP-90 and meets SRP 7.4. RCS pressure control is similar to current PWRs, except the system is depressurized by a motor operated Safety Depressurization Valve. US-APWR decay heat removal and RCS cooling is similar to current PWRs, except the Steam Generator cooling system has four (4) Emergency Feed Water pumps as opposed to three (3) Auxiliary Feed Water pumps. Two (2) of the four (4) pumps are motor driven, while the other two pumps are turbine driven. The heat removal provided by the residual heat removal system is similar to current PWRs except four (4) trains are used as opposed to two (2).

Next, MHI discussed the safe shutdown support systems, which consist of the Component Cooling Water System (CCWS), the Essential Service Water System (ESWS), and the HVAC systems. The CCWS consists of a four (4) safety train configuration, which is separated into two (2) independent sections, while the ESWS is completely separated into four (4) trains. The Class 1E electrical room HVAC consists of a four (4) safety train configuration, which is separated into two (2) independent sections. The Essential Chilled Water System is also a four (4) train system with one chiller unit and water pump on each train. One expansion tank with a separator tank is shared by two trains. MHI concluded the safe shutdown portion of the presentation by emphasizing that the four (4) train design provides safe shutdown capability with a single failure during online maintenance of one (1) train.

Station Blackout

Station Blackout (SBO) refers to the complete loss of AC electric power to the essential and nonessential switchgear buses. SBO therefore requires the loss of offsite power along with a turbine trip and failure of the onsite emergency AC power system. SBO does not mean the loss of AC power from battery fed inverters. After introducing the concept of a station blackout, MHI explained how the US-APWR will deal with an SBO. Once a blackout occurs, all offsite power and the four (4) Emergency Power Sources (EPS) are lost. The two (2) alternate AC (AAC) power sources and batteries will still be available. A tie-line between the permanent medium voltage bus and the safety medium voltage bus will be manually connected and the needed safety and non-safety loads will be manually restarted. All of these operations can be performed within one hour. The plant can maintain the integrity of the RCP seal and maintain decay heat removal until completion of switching the buses and re-starting the loads, which should occur in less than one hour.

Layout Design

MHI explained that the US-APWR will be designed with robust structures that provide protection from natural phenomena, and provide physical separation for the safe shutdown systems. The design protects against internal floods by placing safety components above the internal flood level in safety buildings designed to withstand external floods. Safety components are also placed in seismic category-I buildings, and the appropriate wall/roof thickness is provided to protect against tornado missiles. Fire protection is provided by installing trains in independent compartments, and assuming that all safety components in a fire area are rendered inoperable.

MHI concluded the public meeting by reiterating that comments and suggestions from the NRC staff would be appreciated, and considered to improve the quality of the Design Control Document (DCD). Members of the public were in attendance, but Public Meeting Feedback forms were not received. Please direct any inquiries to me at 301-415-1626, or bcl1@nrc.gov.

/RA/

Bryce Lehman
US-APWR Projects Branch 1
Division of New Reactor Licensing
Office of New Reactors

Project No. 751

Enclosures:

1. List of Attendees
2. Mitsubishi Handout - US-APWR
9th Pre-Application Review Meeting -
Safety Features (ML072890316)

cc w/encls: See next page

Station Blackout

Station Blackout (SBO) refers to the complete loss of AC electric power to the essential and nonessential switchgear buses. SBO therefore requires the loss of offsite power along with a turbine trip and failure of the onsite emergency AC power system. SBO does not mean the loss of AC power from battery fed inverters. After introducing the concept of a station blackout, MHI explained how the US-APWR will deal with an SBO. Once a blackout occurs, all offsite power and the four (4) Emergency Power Sources are lost. The two (2) alternate AC power sources and batteries will still be available. A tie-line between the permanent medium voltage bus and the safety medium voltage bus will be manually connected and the needed safety and non-safety loads will be manually restarted. All of these operations can be performed within one hour. The plant can maintain the integrity of the RCP seal and maintain decay heat removal until completion of switching the buses and re-starting the loads, which should occur in less than one hour.

Layout Design

MHI explained that the US-APWR will be designed with robust structures that provide protection from natural phenomena, and provide physical separation for the safe shutdown systems. The design protects against internal floods by placing safety components above the internal flood level in safety buildings designed to withstand external floods. Safety components are also placed in seismic category-I buildings, and the appropriate wall/roof thickness is provided to protect against tornado missiles. Fire protection is provided by installing trains in independent compartments, and assuming that all safety components in a fire area are rendered inoperable.

MHI concluded the public meeting by reiterating that comments and suggestions from the NRC staff would be appreciated, and considered to improve the quality of the Design Control Document (DCD). Members of the public were in attendance, but Public Meeting Feedback forms were not received. Please direct any inquiries to me at 301-415-1626, or bcl1@nrc.gov.

/RA/

Bryce Lehman
US-APWR Projects Branch 1
Division of New Reactor Licensing
Office of New Reactors

Project No. 751

Enclosures:

1. List of Attendees
2. Mitsubishi Handout - US-APWR
9th Pre-Application Review Meeting -
Safety Features (ML072890316)

cc w/encls: See next page

DISTRIBUTION: See next page

ADAMS ACCESSION NO: ML072900591 Package: ML072900571

OFFICE	PM: NWE1	NMIP	LA: NWE1
NAME	BLehman*	JCiocco*	KGoldstein
DATE	10/17/2007	11/02/07	11/06/2007

OFFICIAL AGENCY RECORD

Summary of the August 23, 2007 Public Meeting on Safety Features and Plant Design Features
for the US-APWR dated November 6, 2007

Distribution:

PUBLIC	GCranson
Reading File	JCiocco
RidsNroDnrl	JDonoghue
RidsNroDnrlNwe1	NSaltos
BLEhman	PClifford
RidsNroLAKGoldstein	RLandry
RidsOgcMailCenter	SWu
RidsAcrcAcnwMailCenter	SMonarque
RidsRgn2MailCenter	TClark
SCampbell, Region II	TAttard
AMendiola	VKlein
CVan Wert	WWang
DDube	YGene Hsii
EThrom	

Attendees
Public Meeting to Discuss
Safety Feature Topical Reports
August 23, 2007

Name	Affiliation
Alan Levin	Areva
Allen Ho	ETI
Don Woodlan	Luminant
Jenny Weil	McGraw-Hill
Akihiro Wakamatsu	MHI
Akira Nagano	MHI
Hideyuki Teshima	MHI
Hiroshi Hamamoto	MHI
Kaname Shibato	MHI
Kiyoshi Yamauchi	MHI
Masahiko Kaneda	MHI
Masaya Hoshi	MHI
Takayuki Suemura	MHI
Toskimichi Takahashi	MHI
Yasushi Makiho	MHI
Andrew Johnson	MNES
C. K. Paulson	MNES
Masamuri Onozuka	MNES
Masayuki Kambara	MNES
Sherry Bernhoft	MNES
Shinji Kawanago	MNES
Anthony Mendiola	NRC
Chris Van Wert	NRC
Don Dube	NRC
Ed Throm	NRC
Greg Cranson	NRC
Jeffrey Ciocco	NRC
Joe Donoghue	NRC
Nicholas Saltos	NRC
Paul Clifford	NRC
Ralph Landry	NRC
Shih-Liang Wu	NRC
Stephen Monarque	NRC
Theresa Clark	NRC
Tony Attard	NRC
Veronica Klein	NRC
Weidong Wang	NRC
Y. Gene Hsii	NRC
Ryuji Zwasaki	Toshiba
Charles Brinkman	Westinghouse

Enclosure 2

Mitsubishi Handout - US-APWR
9th Pre-Application Review Meeting-
Safety Features

(ML072890316)

cc:

Mr. Glenn H. Archinoff
AECL Technologies
481 North Frederick Avenue
Suite 405
Gaithersburg, MD 20877

Masayuki Kambara
Mitsubishi Nuclear Energy Systems, Inc.
2300 Wilson Blvd.
Suite 300
Arlington, VA 22201-5426

Ms. Michele Boyd
Legislative Director
Energy Program
Public Citizens Critical Mass Energy
and Environmental Program
215 Pennsylvania Avenue, SE
Washington, DC 20003

Masahiko Kaneda
Mitsubishi Heavy Industries, Ltd.
16-5, Konan 2-Chome, Minato-Ku
Tokyo, 108-8215 JAPAN

W. Craig Conklin, Director
Chemical and Nuclear Preparedness &
Protection Division (CNPPD)
Office of Infrastructure Protection
Department of Homeland Security
Washington, DC 20528

Shinji Kawanago
Mitsubishi Nuclear Energy Systems, Inc.
2300 Wilson Blvd.
Suite 300
Arlington, VA 22201-5426

Mr. Marvin Fertel
Senior Vice President
and Chief Nuclear Officer
Nuclear Energy Institute
1776 I Street, NW
Suite 400
Washington, DC 20006-3708

Sirirat Mongkolkarn
Office Administrator
Mitsubishi Nuclear Energy Systems, Inc.
2300 Wilson Boulevard, Suite 300
Arlington, VA 22201-5426

Mr. Ray Ganthner
AREVA, Framatome ANP, Inc.
3315 Old Forest Road
P.O. Box 10935
Lynchburg, VA 24506-0935

Dr. Masanori Onozuka
Mitsubishi Nuclear Energy Systems, Inc.
2300 Wilson Blvd.
Suite 300
Arlington, VA 22201-5426

Mr. Paul Gaukler
Pillsbury, Winthrop, Shaw, Pittman
2300 N Street, NW
Washington, DC 20037

Dr. C. Keith Paulson
Mitsubishi Nuclear Energy Systems, Inc.
300 Oxford Drive, Suite 301
Monroeville, PA 15146

Vanessa E. Quinn, Acting Director
Technological Hazards Division
National Preparedness Directorate
Federal Emergency Management Agency
500 C Street, NW
Washington, DC 20472

Mr. Robert E. Sweeney
IBEX ESI
4641 Montgomery Avenue
Suite 350
Bethesda, MD 20814

Mr. Ed Wallace
General Manager - Projects
PBMR Pty LTD
P. O. Box 9396
Centurion 0046
Republic of South Africa

Mr. Gary Wright, Director
Division of Nuclear Facility Safety
Illinois Emergency Management Agency
1035 Outer Park Drive
Springfield, IL 62704

Email

APH@NEI.org (Adrian Heymer)
awc@nei.org (Anne W. Cottingham)
bennettS2@bv.com (Steve A. Bennett)
bob.brown@ge.com (Robert E. Brown)
BrinkmCB@westinghouse.com (Charles Brinkman)
chris.maslak@ge.com (Chris Maslak)
ck_paulson@mnes-us.com (C Keith Paulson)
ckpaulson@aol.com (C.K. Paulson)
CumminWE@Westinghouse.com (Edward W. Cummins)
cwaltman@roe.com (C. Waltman)
david.hinds@ge.com (David Hinds)
david.lewis@pillsburylaw.com (David Lewis)
DeLaBarreR@state.gov (R. DeLaBarre)
Dennis.Buschbaum@txu.com (Denny Buschbaum)
dlochbaum@UCSUSA.org (David Lochbaum)
dwoodla1@txu.com (Donald Woodlan)
erg-xl@cox.net (Eddie R. Grant)
frankq@hursttech.com (Frank Quinn)
gcesare@enercon.com (Guy Cesare)
greshaja@westinghouse.com (James Gresham)
JAC3@nrc.gov (Jeff Ciocco)
james.beard@gene.ge.com (James Beard)
jcurtiss@winston.com (Jim Curtiss)
jgutierrez@morganlewis.com (Jay M. Gutierrez)
jim.riccio@wdc.greenpeace.org (James Riccio)
JJNesrsta@cpsenergy.com (James J. Nesrsta)
john.o'neil@pillsburylaw.com (John O'Neil)
Joseph.savage@ge.com (Joseph Savage)
Joseph_Hegner@dom.com (Joseph Hegner)
kcrogers@aol.com (K. C. Rogers)
KSutton@morganlewis.com (Kathryn M. Sutton)
kwaugh@impact-net.org (Kenneth O. Waugh)
lynchs@gao.gov (Sarah Lynch - Meeting Notices Only)
Margaret.Bennet@dom.com (Margaret Bennet)
maria.webb@pillsburylaw.com (Maria Webb)
mark.beaumont@wsms.com (Mark Beaumont)
masahiko_kaneda@mhi.co.jp (Masahiko Kaneda)
masanori_onozuka@mnes-us.com (Masanori Onozuka)
masayuki_kambara@mhi.co.jp (Masayuki Kambara)
matias.travieso-diaz@pillsburylaw.com (Matias Travieso-Diaz)
media@nei.org (Scott Peterson)
mike_moran@fpl.com (Mike Moran)
mwetterhahn@winston.com (M. Wetterhahn)
nirsnet@nirs.org (Michael Mariotte)
patriciaL.campbell@ge.com (Patricia L. Campbell)
paul.gaukler@pillsburylaw.com (Paul Gaukler)
Paul@beyondnuclear.org (Paul Gunter)
DC Mitsubishi - US APWR Mailing List

pshastings@duke-energy.com (Peter Hastings)
RJB@NEI.org (Russell Bell)
RKTemple@cpsenergy.com (R.K. Temple)
roberta.swain@ge.com (Roberta Swain)
ronald.hagen@eia.doe.gov (Ronald Hagen)
sandra.sloan@areva.com (Sandra Sloan)
sfrantz@morganlewis.com (Stephen P. Frantz)
shinji_kawanago@mnes-us.com (Shinji Kawanago)
steven.hucik@ge.com (Steven Hucik)
Tansel.Selekler@nuclear.energy.gov (Tansel Selekler)
tom.miller@hq.doe.gov (Tom Miller)
trsmith@winston.com (Tyson Smith)
VictorB@bv.com (Bill Victor)
vijukrp@westinghouse.com (Ronald P. Vijuk)
waraksre@westinghouse.com (Rosemarie E. Waraks)
whorin@winston.com (W. Horin)