(2) <u>Technical Specifications and Environmental Protection Plan</u>

The Technical Specifications contained in Appendix A, as revised through Amendment No. 175, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated in the license. The Corporation shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

(3) Antitrust Conditions

Kansas Gas & Electric Company and Kansas City Power & Light Company shall comply with the antitrust conditions delineated in Appendix C to this license.

(4) <u>Environmental Qualification (Section 3.11, SSER #4, Section 3.11, SSER #5)*</u>

Deleted per Amendment No. 141.

- (5) Fire Protection (Section 9.5.1, SER, Section 9.5.1.8, SSER #5)
 - (a) The Operating Corporation shall maintain in effect all provisions of the approved fire protection program as described in the SNUPPs Final Safety Analysis Report for the facility through Revision 17, the Wolf Creek site addendum through Revision 15, and as approved in the SER through Supplement 5, subject to provisions b and c below.
 - (b) The licensee may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.
 - (c) Deleted.
- (6) <u>Qualification of Personnel (Section 13.1.2, SSER #5, Section 18, SSER</u> #1)

Deleted per Amendment No. 141.

*The parenthetical notation following the title of many license conditions denotes the section of the Safety Evaluation Report and/or its supplements wherein the license condition is discussed.

Amendment No. 175

ACTIONS (continued)

	-
	_
<u> </u>	÷
•	inued

Wolf Creek - Unit 1

Amendment No. 123, 156, 175

ACTIONS (continued)

	CONDITION		REQUIRED ACTION	COMPLETION TIME	
J.	One Main Feedwater Pump trip channel inoperable.	The inop bypasse surveilla channel	perable channel may be ad for up to 2 hours for ance testing of other s.		
		J.1 OR	Place channel in trip.	1 hour	
		J.2	Be in MODE 3.	7 hours	
К.	One channel inoperable.	NOTE One additional channel may be tripped for up to 12 hours for surveillance testing.			
		К.1 <u>OR</u>	Place channel in bypass.	72 hours	
		K.2.1	Be in MODE 3.	78 hours	
		AND			
		K.2.2	Be in MODE 5.	108 hours	

(continued)

Table 3.3.2-1 (page 1 of 5) Engineered Safety Feature Actuation System Instrumentation

	· • • • •			۲۰۰ متر و ووانوسی.			
,		FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE (a)
	Sat	fety Injection			· · · · · · · · · · · · · · · · · · ·		
	a.	Manual Initiation	1,2,3,4	2	В	SR 3.3.2.8	NA
	b.	Automatic Actuation Logic and Actuation Relays	1,2,3,4	2 trains	С	SR 3.3.2.2 SR 3.3.2.4 SR 3.3.2.6 SR 3.3.2.13	NA
	C.	Containment Pressure - High 1	1,2,3	3	D	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9 SR 3.3.2.10	≤ 4.5 psig
	d.	Pressurizer Pressure - Low	1,2,3 ^(b)	4	D	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9 SR 3.3.2.10	≥ 1820 psig
	е.	Steam Line Pressure Low	1,2,3 ^(b)	3 per steam line	D	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9 SR 3.3.2.10	≥ 571 psig ^(C)
	Cor	ntainment Spray					
	а.	Manual Initiation	1,2,3,4	2 per train, 2 trains	В	SR 3.3.2.8	NA
	b.	Automatic Actuation Logic and Actuation Relays	1,2,3,4	2 trains	с	SR 3.3.2.2 SR 3.3.2.4 SR 3.3.2.6	NA
	C.	Containment Pressure High - 3	1,2,3	4	E	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9 SR 3.3.2.10	≤ 28.3 psig

(continued)

(a) The Allowable Value defines the Limiting Safety System Setting. See the Bases for the Trip Setpoints.

(b) Above the P-11 (Pressurizer Pressure) interlock and below P-11 unless the Function is blocked.

(c) Time constants used in the lead/lag controller are $t_1 \ge 50$ seconds and $t_2 \le 5$ seconds.

Wolf Creek - Unit 1

Amendment No. 123, 140

Table 3.3.2-1 (page 2 of 5) Engineered Safety Feature Actuation System Instrumentation

		FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE (a)
3.	Co	ontainment Isolation		. <u> </u>			· · · · · · · · · · · · · · · · · · ·
	a.	Phase A Isolation			:	,	
		(1) Manual Initiation	1,2,3,4	2	В	SR 3.3.2.8	NA
		(2) Automatic Actuation Logic and Actuation Relays	1,2,3,4	2 trains	С	SR 3.3.2.2 SR 3.3.2.4 SR 3.3.2.6 SR 3.3.2.13	NA
		(3) Safety Injection	Refer to Function	1 (Safety Injectio	n) for all initiation f	unctions and requireme	ents.
	b.	Phase B Isolation	•				
		(1) Manual Initiation	1,2,3,4	2 per train, 2 trains	В	SR 3.3.2.8	NA
		(2) Automatic Actuation Logic and Actuation Relays	1,2,3,4	2 trains	С	SR 3.3.2.2 SR 3.3.2.4 SR 3.3.2.6	NA
		(3) Containment Pressure - High 3	1,2,3	4	E	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9 SR 3.3.2.10	≤ 28.3 psig
4.	Ste	am Line Isolation					
	a.	Manual Initiation	1,2 ⁽ⁱ⁾ , 3 ⁽ⁱ⁾	2	F	SR 3.3.2.8	NA
	b.	Automatic Actuation Logic and Actuation Relays (SSPS)	1,2 ⁽ⁱ⁾ , 3 ⁽ⁱ⁾	2 trains	G	SR 3.3.2.2 SR 3.3.2.4 SR 3.3.2.6	NA
	C.	Automatic Actuation Logic (MSFIS)	1,2 ⁽ⁱ⁾ , 3 ⁽ⁱ⁾	2 trains	G	SR 3.3.2.6	NA
	d.	Containment Pressure - High 2	1,2 ⁽ⁱ⁾ , 3 ⁽ⁱ⁾	3	D	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9 SR 3.3.2.10	≤ 18.3 psig
							(continued)

(a) The Allowable Value defines the Limiting Safety System Setting. See the Bases for the Trip Setpoints.

(i) Except when all MSIVs are closed.

Wolf Creek - Unit 1

Amendment No. 123, 175

Table 3.3.2-1 (page 3 of 5) Engineered Safety Feature Actuation System Instrumentation

	FUNCTION	MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE ^(a)
Ste (c	am Line Isolation		,			
e.	Steam Line Pressure	. ,				
	(1) Low	1,2 ⁽ⁱ⁾ ,3 ^{(b)(i)}	3 per steam line	D	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9 SR 3.3.2.10	≥ 571 psig(c)
	(2) Negative Rate - High	3(g)(i)	3 per steam line	D	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9 SR 3.3.2.10	≤ 125 ^(h) psi
Tur Fee	bine Trip and edwater Isolation					
a.	Automatic Actuation Logic and Actuation Relays (SSPS)	1,2 ^(j) ,3 ^(j)	2 trains	G	SR 3.3.2.2 SR 3.3.2.4 SR 3.3.2.6 SR 3.3.2.14	NA
b _. .	Automatic Actuation Logic (MSFIS)	1,2 ⁽ⁱ⁾ ,3(i)	2 trains	G	SR 3.3.2.6	NA
C.	SG Water Level -High High (P-14)	1,2(j)	4 per SG	I	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9 SR 3.3.2.10	≤ 79.7% of Narrow Range Instrument Spa

(continued)

(a) The Allowable Value defines the Limiting Safety System Setting. See the Bases for the Trip Setpoints.

(b) Above the P-11 (Pressurizer Pressure) Interlock and below P-11 unless the Function is blocked.

(c) Time constants used in the lead/lag controller are $t_1 \ge 50$ seconds and $t_2 \le 5$ seconds.

(g) Below the P-11 (Pressurizer Pressure) Interlock; however, may be blocked below P-11 when safety injection on low steam line pressure is not blocked.

(h) Time constant utilized in the rate/lag controller is \geq 50 seconds.

(i) Except when all MSIVs are closed.

(j) Except when all MFIVs are closed.

Wolf Creek - Unit 1

3.3-34

Table 3.3.2-1 (page 4 of 5) Engineered Safety Feature Actuation System Instrumentation

		FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	CONDITIONS	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE ^(a)
6.	Aux	ciliary Feedwater					
	a.	Manual Initiation	1,2,3	1 per pump	0	SR 3.3.2.8	NA
	b.	Automatic Actuation Logic and Actuation Relays (Solid State Protection System)	1,2,3	2 trains	G	SR 3.3.2.2 SR 3.3.2.4 SR 3.3.2.6	NA
	C.	Automatic Actuation Logic and Actuation Relays (Balance of Plant ESFAS)	1,2,3	2 trains	N	SR 3.3.2.3	NA
	d.	SG Water Level Low - Low	1,2,3	4 per SG	D	SR 3.3.2.1 SR 3.3.2.5 SR 3.3.2.9 SR 3.3.2.10	≥ 22.3% of Narrow Range Instrument Span
	e.	Safety Injection	Refer to Function 1 (Safety Injection)	for all initiation fun	ctions and requiremer	nts.
	f.	Loss of Offsite Power	1,2,3	2 trains	Ρ	SR 3.3.2.7 SR 3.3.2.10	NA
	g.	Trip of all Main Feedwater Pumps	1	2 per pump	J ·	SR 3.3.2.8	NA
	h.	Auxiliary Feedwater Pump Suction Transfer on Suction Pressure - Low	1,2,3	3	М	SR 3.3.2.1 SR 3.3.2.9 SR 3.3.2.10 SR 3.3.2.12	≥ 20.53 psia

(continued)

I

I

(a) The Allowable Value defines the Limiting Safety System Setting. See the Bases for the Trip Setpoints.

Amendment No. 123, 136

)