



Pacific Gas and
Electric Company®

Diablo Canyon Power Plant
P. O. Box 56
Avila Beach, CA 93424

Date: October 18, 2007

PG&E Letter DCL-2007-548

Certified/Return Receipt
#7007-0220-0004-6735-9899

California Regional Water Quality Control Board
Central Coast Region
Attn: Monitoring and Reporting Review Section
895 Aerovista, Suite #101
San Luis Obispo, CA 93401-7906

Dear Mr. Briggs:

In accordance with Order 90-09, NPDES No. CA0003751, enclosed is the Third Quarter 2007 Report on Discharge Monitoring at Diablo Canyon Power Plant (Enclosure 1).

Facility Name: Pacific Gas & Electric Company
Diablo Canyon Power Plant

Address: P.O. Box 56
Avila Beach, CA 93424

Contact Person: Bryan Cunningham
Job Title: Supervisor, Environmental Operations
Phone Number: 545-4439

WDR/NPDES Order Number: Order No. 90-09, NPDES No. CA0003751

Type of Report: (check one)

QUARTERLY



ANNUAL



Quarter: (check one):

1st



2nd



3rd



4th



Year:

2007 (Annual Reports for DCPP are Jan-Dec)

Violation(s) (Place an X by the appropriate choice):

No (there are no violations to report)

Yes

Note: A single chlorine TRO exceedance result for a Pathway 001 (OTC Discharge) occurred. The event description is included in Overview Section 5.

IE2S

NRR

Mr. Briggs, CRWQCB

October 18, 2007

Page 2

If Yes is marked (complete a-g):

a) Parameter(s) in Violation:

b) Section(s) of WDR/NPDES

Violated:

c) Reported Value(s)

d) WDR/NPDES

Limit/Condition:

e) Dates of Violation(s)

(reference page of report/data sheet):

f) Explanation of Cause(s):

(attach additional information as needed)

(If "YES", see overview section of attached report)

g) Corrective Action(s):

(attach additional information as needed)

(If "YES", see overview section of attached report)

Mr. Briggs, CRWQCB


October 18, 2007

Page 3

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. The results of the influent and effluent monitoring presented are the observed results of the measurements and analyses required by the monitoring program, and is neither an assertion of the adequacy of any instrument reading or analytical result, nor an endorsement of the appropriateness of any analytical or measurement procedure. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

If you have any questions, please contact Bryan Cunningham at (805) 545-4439.

Sincerely,

A handwritten signature in black ink, appearing to read "JAMES R. BECKER", is written over a horizontal line.

Name: James R. Becker

Title: Vice President - Diablo Canyon Operations and Station Director

2007548/jlk/kmo

PG&E Ltr DCL-2007-548

Mr. Briggs, CRWQCB

October 18, 2007

Page 4

cc: Peter von Langen, CRWQCB
895 Aerovista, #101
San Luis Obispo, CA 93401-7906

California Department of Fish and Game
20 Lower Ragsdale, Suite 100
Monterey, California 93490

Resident Inspector, Michael S. Peck
U.S. Nuclear Regulatory Commission
Diablo Canyon Power Plant 104/5

Regional Administrator
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Dr., Suite 400
Arlington, TX 76011-4005

Director, Division of Reactor Projects
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Dr., Suite 400
Arlington, TX 76011-4005

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Enclosure

ENCLOSURE 1

THIRD QUARTER 2007

**REPORT ON DISCHARGE MONITORING AT
DIABLO CANYON POWER PLANT**

PACIFIC GAS AND ELECTRIC COMPANY

NUCLEAR POWER GENERATION

Third Quarter 2007

REPORT ON

DISCHARGE MONITORING AT

DIABLO CANYON POWER PLANT

(NPDES No. CA0003751)

PACIFIC GAS AND ELECTRIC COMPANY

Third Quarter 2007

REPORT ON DISCHARGE MONITORING AT
DIABLO CANYON POWER PLANT

TABLE OF CONTENTS

	<u>page</u>
<u>OVERVIEW</u>	1
<u>SUMMARY OF MONITORING PROGRAM</u>	
A. <u>Monitoring of Plant Influent and Effluent</u>	1
B. <u>Monitoring of Receiving Waters</u>	2
C. <u>Sodium Bromide Treatment Program</u>	2
 APPENDIX 1: NPDES Discharge Points	
APPENDIX 2: Influent and Effluent Monitoring - July 2007	
APPENDIX 3: Influent and Effluent Monitoring - August 2007	
APPENDIX 4: Influent and Effluent Monitoring - September 2007	
APPENDIX 5: Acute Bioassay, July 26-30, 2007	
APPENDIX 6: Chronic Bioassay, July 26-28, 2007	

OVERVIEW

1. During the third quarter of 2007, discharges occurred from Discharge Paths 001 (once through cooling water), 001B, 001D, 001E, 001F, 001G, 001H, 001J, 001L, 001M, 001N, 001P, 002 through 04, and 013. No discharges occurred from Discharge Paths 001I, 001K, 005 through 012, and 014 through 017. A list of all of the permit discharge pathways, including name and number, is provided in **Appendix 1**.
2. The substances listed in Table B of the 1990 California Ocean Plan were each analyzed for and reported in the permit renewal application for Diablo Canyon submitted in 1994. There have been no changes in the activities conducted at the plant that would have significantly affected the results previously reported in the 1994 renewal application. California Ocean Plan Table B substances that were not analyzed for this quarter were not added to the discharge stream.
3. During the third quarter of 2007, maintenance activities that required draining of closed cooling water systems were performed and are summarized below. PG&E received concurrence from the CCRWQCB in response to letters dated July 19, 1995 (PG&E Letter DCL-95-156), May 23, 1996 (PG&E Letter DCL-96-522), and May 19, 1997 (PG&E Letter DCL-97-533) regarding the use of glutaraldehyde and isothiazolin to control microbiological growth and corrosion in DCPP's closed cooling water systems. Discharges are drained at a flow rate such that the chronic toxicity level would be below the "No Observable Effect Concentration" (NOEC) at NPDES Discharge 001.

Date	System	Volume (gallons)	Glutaraldehyde (mg/l)	Isothiazolin (mg/l)	Total Suspended Solids (mg/l)	Oil & Grease (mg/l)
7/20/07	Unit 1 ICW	48	254	< 0.25	n/a	n/a
8/6/07	Unit 2 ICW	33,214	201	1.93	6.4	2.0
7/12/07 to 8/17/07	Unit 1 ICW	111	175	1.8	n/a	n/a
8/22/07	Unit 1 ICW	3,313	108	1.8	9.8	3.1
9/05/07	Unit 1 ICW	15	246	< 0.25	n/a	n/a

4. Five events affected continuous chlorine monitoring at Discharge 001 during the third quarter. In each case, an engineering evaluation was completed in accordance with PG&E's January 5, 1994 letter as authorized by the CCRWQCB. The event interval, affected monitor, number of affected results, the cause(s), and corrective action(s) are tabulated below. Engineering evaluations use recorded injection rates and condenser waterbox inlet chlorine results to calculate estimates of chlorine concentration for the affected monitor at Discharge 001. These estimates are used to replace results affected by the respective monitor problem as agreed with CCRWQCB staff. Injection rates are set to provide a minimal amount of detectable chlorine at the discharge. Results from the engineering evaluations were all at least 60 µg/L below the applicable 89-µg/L discharge limit.

Interval	Affected Monitor(s)	Number of Affected Readings	Cause	Corrective Actions
6/27/07 to 7/3/07	Unit 1	15 during third quarter reporting period	Shift of monitor calibration after 6/27/07 maintenance	Monitor recalibrated after identification of bias
7/3/07 to 7/11/07	Unit 1	48	Faulty air pump	Pump replaced
8/2/07 to 8/3/07	Unit 1 and Unit 2	6 for each unit	Valve mis-positions	Procedure revised
8/28/07	Unit 2	1	Valve mis-position	Procedure revision
9/14/07 to 9/15/07	Unit 1	2	Sample line blockage	Line flushed

5. On August 14, 2007 the 0000 hours reading on the Unit 1 discharge chlorine monitor reached a maximum of 114 ppb. This value is below the NPDES limit of 200 ppb. However, it is above the calculated effluent limit of 89 ppb from the California Ocean Plan for intermittent 20-minute chemical treatments. Investigation indicates that a strainer at the intake supplying seawater to the injection lines had become significantly fouled with shell debris allowing chemical to accumulate in the line. When the valve was flushed, the accumulated chemical was flushed through the line into the 1-1 conduit resulting in increased levels of chlorine at the discharge. Upon discovery, injection rates were decreased and dechlorination was initiated. The strainer was manually cleaned the following day. Injection seawater supply has returned to normal levels. CCRWQCB staff were notified the afternoon of August 14, 2007.

SUMMARY OF MONITORING PROGRAM

A. Monitoring of Plant Influent and Effluent

1. The results of the July, August, and September 2007 plant influent and effluent monitoring are reported on Discharge Self Monitoring Report (DSMR) forms in **Appendices 2, 3, and 4**, respectively.
2. The laboratory report for one acute bioassay on water sampled from Discharge 001, performed July 26-30, 2007, is included in **Appendix 5**. The bioassay results show that acute toxicity was 0.00 TUa (no mortality).
3. The laboratory report for one chronic bioassay on water sampled from Discharge 001, performed July 26-28, 2007, is included in **Appendix 6**. The bioassay results show that chronic toxicity was 1.0 TUC (no chronic toxicity).

B. Monitoring of Receiving Waters

1. Ecological Studies at Diablo Canyon

Ecological studies in the vicinity of Diablo Cove conducted during the third quarter continued under the Diablo Canyon Receiving Water Monitoring Program (RWMP) as requested in a letter from the Central Coast Regional Water Quality Control Board (CCRWQCB) dated December 9, 1998, and as detailed in a letter (PG&E Letter DCL-99-503) dated January 8, 1999. This program includes tasks from the Ecological Monitoring Program (EMP) with additional stations and increased

sampling frequencies. The RWMP replaces the EMP and the Thermal Effects Monitoring Program (TEMP).

2. In Situ Bioassay

Results of the Mussel Watch Program will be reported to the CCRWQCB directly from the California Department of Fish and Game in the Department's periodic report for this program.

C. Sodium Bromide Treatment Program

Diablo Canyon Power Plant is continuing the use of generic sodium bromide to control macrofouling growth for both Units. Both circulating water conduits of each Unit can be chemically treated simultaneously. Each treated conduit typically receives a twenty-minute injection every four hours (six injections a day) of sodium bromide in combination with sodium hypochlorite (NaOCl). Each injection attempts to achieve a target concentration of 200 parts per billion (ppb) Total Residual Oxidant (TRO) when measured at the inlet waterbox of the condenser. Discharge TRO, measured at the plant outfall, remains below NPDES limitations.

Both conduits of Unit 1 were treated with simultaneous injections of sodium bromide and sodium hypochlorite six times a day throughout the third quarter with brief interruptions for maintenance activities in mid-August and late September.

Both conduits of Unit 2 were treated with simultaneous injections of sodium bromide and sodium hypochlorite six times a day throughout the third quarter with brief interruptions for maintenance activities in mid-August and late September.

APPENDIX 1
DIABLO CANYON POWER PLANT

NPDES DISCHARGE POINTS	
DISCHARGE NUMBER	DESCRIPTION
001	Once-Through Cooling Water
001 A	Firewater Systems
001 B	Auxiliary Salt Water Cooling System
001 C	Discharge Deleted
001 D	Liquid Radioactive Waste Treatment System
001 E	Service Cooling Water System
001 F	Turbine Building Sump
001 G	Make-Up Water System Waste Effluent
001 H	Condensate Demineralizer Regenerant
001 I	Seawater Evaporator Blowdown
001 J	Condensate Pumps Discharge Header Overboard
001 K	Condenser Tube Sheet Leak Detection Dump Tank Overboard
001 L	Steam Generator Blowdown
001 M	Wastewater Holding and Treatment System
001 N	Sanitary Wastewater Treatment System
001 P	Seawater Reverse Osmosis System Blowdown
002	Intake Structure Building Floor Drains
003	Intake Screen Wash
004	Bio Lab and Storm Water Runoff
005, 008, 009, 013, 014, 015	Yard Storm Drains
006, 007, 010, 011, 012	Storm Water Runoff
016	Bio Lab Seawater Supply Pump Valve Drain
017	Seawater Reverse Osmosis System Blowdown Drain

APPENDIX 2
DIABLO CANYON POWER PLANT

Influent and Effluent Monitoring
July 2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 1

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01		YEAR / MO / DAY ENDING 07 / 07 / 31		STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	INFLOW TEMPERATURE DEGREES F METERED CONTINUOUS	EFFLUENT 001 TEMPERATURE DEGREES F METERED CONTINUOUS	DELTA TEMP TEMPERATURE DEGREES F METERED CONTINUOUS	EFFLUENT 001 FLOW MGD RECORDED DAILY	INFLOW pH pH UNITS GRAB MONTHLY	EFFLUENT 001 pH pH UNITS GRAB MONTHLY (**)	EFFLUENT 001P pH pH UNITS GRAB MONTHLY	EFFLUENT 002 pH pH UNITS GRAB MONTHLY	
1	50.2	68.4	18.2	2486					
2	49.8	68.0	18.2	2486					
3	50.3	68.1	17.8	2486					
4	50.0	68.2	18.2	2486					
5	51.5	69.9	18.4	2486					
6	51.6	69.9	18.3	2486					
7	52.0	70.3	18.3	2486					
8	50.9	69.2	18.3	2486					
9	51.8	70.3	18.5	2486					
10	53.7	72.0	18.3	2486					
11	54.3	72.8	18.5	2486					
12	54.8	73.1	18.3	2486	8.1	8.1	2	7.8	
13	53.3	71.6	18.3	2486					
14	52.5	70.8	18.3	2486					
15	52.9	71.2	18.3	2486					
16	53.0	71.4	18.4	2486					
17	52.1	70.5	18.4	2486					
18	52.2	70.4	18.2	2486					
19	51.9	70.1	18.2	2486					
20	51.0	69.3	18.3	2486					
21	51.9	70.0	18.1	2486					
22	53.2	71.5	18.3	2486					
23	54.6	72.9	18.3	2486					
24	53.4	71.7	18.3	2486					
25	53.0	71.2	18.2	2486					
26	52.6	70.9	18.3	2486					
27	52.4	70.7	18.3	2486					
28	53.2	71.3	18.1	2486					
29	53.6	71.6	18.0	2486					
30	53.7	72.1	18.4	2486					
31	54.6	72.9	18.3	2486					
MONTHLY AVG	52.5	70.7	18.3	2486	8.1	8.1	7.8	8.0	
MONTHLY HIGH	54.8	73.1	18.5	2486	8.1	8.1	7.8	8.0	
MONTHLY LOW	49.8	68.0	17.8	2486	8.1	8.1	7.8	8.0	
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MAX 22 = 0 (**)	MAX 2760 = 0	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

** EXCEPT DURING DEMUSSELING.

*** DAILY WHEN DISCHARGING CHEMICAL CLEANING WASTES FROM DISCHARGES 001D, F, I, L, AND/OR M.

PRINCIPAL EXECUTIVE OFFICER	SIGNATURE OF AUTHORIZED AGENT	DATE
JAMES R. BECKER	<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 2

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01		YEAR / MO / DAY ENDING 07 / 07 / 31		STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 003 pH pH UNITS GRAB MONTHLY	EFFLUENT 004 pH pH UNITS GRAB MONTHLY	EFFLUENT 001N OIL & GREASE mg/l COMPOSITE WEEKLY	EFFLUENT 001P OIL & GREASE mg/l GRAB WEEKLY (**)	EFFLUENT 003 OIL & GREASE mg/l GRAB WEEKLY (***)	EFFLUENT 001F OIL & GREASE mg/l GRAB MONTHLY	EFFLUENT 001 T CHLOR RES ug/l GRAB (****) 2 per CYCLE	EFFLUENT 001 CHLORINE USED lbs/day RECORDED MONTHLY	
1									34
2									446
3									32
4									425
5									31
6									403
7									34
8									403
9									29
10									403
11									29
12	8.0	8.0	3	ND(5)					432
13									29
14									461
15									29
16									461
17									29
18									461
19									29
20									497
21									19
22									547
23									19
24									562
25									19
26									562
27									23
28									559
29									20
30									547
31									18
MONTHLY AVG	8.0	8.0	ND(5)	NO	NO	ND(5)	22		545
MONTHLY HIGH	8.0	8.0	ND(5)	DISCHARGE	DISCHARGE	ND(5)	34		518
MONTHLY LOW	8.0	8.0	ND(5)			ND(5)	10		490
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 15 = 0	MO AVG 15 = 0	MO AVG 15 = 0	MO AVG 15 = 0	I MAX 200 = 0		461
TIMES EXCEEDED			D MAX 20 = 0	D MAX 20 = 0	D MAX 20 = 0	D MAX 20 = 0			461
TIMES EXCEEDED									16

REMARKS:
 * NUMBER OF SAMPLES TAKEN DURING THE DAY.
 ** WHEN 001N IS DISCHARGING TO 001P.

*** WHEN 001P IS DISCHARGING TO 003.

**** CONTINUOUS CHLORINE MONITORING USED INSTEAD OF GRAB SAMPLE ANALYSIS

PRINCIPAL EXECUTIVE OFFICER	SIGNATURE OF AUTHORIZED AGENT	DATE
JAMES R. BECKER	<i>Trevor Reber for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 3

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01		YEAR / MO / DAY ENDING 07 / 07 / 31		STATE CODE 06	NPDES PERMIT # CA0003751		
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFF 001N=>003 TOTL COLIFORM MPN/100ml GRAB 4 TIMES/WEEK	EFF 001N=>003 FECAL COLIFORM MPN/100ml GRAB 4 TIMES/WEEK		mg/l 1st FLTR	EFFLUENT 001D SUSPENDED SOLIDS mg/l 2nd FLTR GRAB MONTHLY	mg/l NET	mg/l 1st FLTR	EFFLUENT 001F SUSPENDED SOLIDS mg/l 2nd FLTR GRAB MONTHLY	mg/l NET
1				*		*			
2									
3				2 < 2		2	ND(5)		
4									
5									
6									
7									
8									
9									
10				4 < 3		4 < 5	ND(5)	2 13	2 < 2 2 12
11									
12				2 3		2	ND(5)		
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									
23									
24				2 28	2	2	26		
25									
26									
27									
28									
29									
30									
31									
MONTHLY AVG	NO DISCHARGE	NO DISCHARGE			**< 5				12
MONTHLY HIGH					51				13
MONTHLY LOW					ND(5)				11
TIMES EXCEEDED	80% SMPLS>1K	MEAN>200 =	NO LIMIT	NO LIMIT	MO AVG 30 = 0	NO LIMIT	NO LIMIT	MO AVG 30 = 0	
TIMES EXCEEDED		90 % SMPLS>400			D MAX 100 = 0				
TIMES EXCEEDED	I MAX >10K							D MAX 100 = 0	

REMARKS:
 * NUMBER OF SAMPLES TAKEN DURING THE DAY.
 ** FLOW-WEIGHTED AVERAGES REPORTED.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Reber for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 4

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01			YEAR / MO / DAY ENDING 07 / 07 / 31			STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.		EFFLUENT 001G SUSPENDED SOLIDS mg/l 1st FLTR GRAB MONTHLY			EFFLUENT 001H SUSPENDED SOLIDS mg/l 2nd FLTR GRAB MONTHLY						
1		*		*	*		*	*		*	
2						<	2	<	2		ND(5)
3											
4											
5											
6											
7											
8											
9											
10											
11											
12		< 2			ND(5)						
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											
29											
30											
31											
MONTHLY AVG				ND(5)				ND(5)			
MONTHLY HIGH				ND(5)				ND(5)			
MONTHLY LOW				ND(5)				ND(5)			
TIMES EXCEEDED		NO LIMIT	NO LIMIT	MO AVG 30=0 D MAX 100 = 0	NO LIMIT	NO LIMIT	NO LIMIT	MO AVG 30=0 D MAX 100 = 0			
TIMES EXCEEDED											
TIMES EXCEEDED											

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 5

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01		YEAR / MO / DAY ENDING 07 / 07 / 31		STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.		EFFLUENT 001I SUSPENDED SOLIDS mg/l 1st FLTR • GRAB MONTHLY	mg/l NET		EFFLUENT 001J SUSPENDED SOLIDS mg/l 1st FLTR GRAB MONTHLY	mg/l NET			
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									
MONTHLY AVG		NO DISCHARGE				NO DISCHARGE			
MONTHLY HIGH									
MONTHLY LOW									
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 30 = 0 MAX 100 = 0	NO LIMIT	NO LIMIT	MO AVG 30 = 0 MAX 100 = 0			
TIMES EXCEEDED									
TIMES EXCEEDED									

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT <i>Trevor Rebek for Bryan Cunningham</i>	DATE 10/18/2007
---	--------------------

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 6

FACILITY I.D.		YEAR / MO / DAY BEGINNING 07 / 07 / 01			YEAR / MO / DAY ENDING 07 / 07 / 31			STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.		EFFLUENT 001K SUSPENDED SOLIDS mg/l 1st FLTR mg/l 2nd FLTR GRAB MONTHLY			EFFLUENT 001L SUSPENDED SOLIDS mg/l 1st FLTR mg/l 2nd FLTR GRAB MONTHLY						
1	*	*	*	*	*	*	*				
2											
3											
4											
5											
6											
7											
8											
9											
10											
11					2 < 2			2	ND(5)		
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											
29											
30											
31											
MONTHLY AVG					NO DISCHARGE			ND(5)			
MONTHLY HIGH								ND(5)			
MONTHLY LOW								ND(5)			
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 30 = 0	NO LIMIT	NO LIMIT	MO AVG 30 = 0					
TIMES EXCEEDED			D MAX 100 = 0								
TIMES EXCEEDED						D MAX 100 = 0					

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 7

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01			YEAR / MO / DAY ENDING 07 / 07 / 31			STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.		EFFLUENT 001M SUSPENDED SOLIDS mg/l 1st FLTR	GRAB MONTHLY	mg/l NET	EFFLUENT 001N SUSPENDED SLDS mg/l COMPOSITE WEEKLY	mg/l 1st FLTR	EFFLUENT 001P SUSPENDED SOLIDS mg/l 2nd FLTR GRAB MONTHLY	mg/l NET			
1											
2											
3											
4											
5						ND(5)					
6											
7											
8											
9											
10											
11											
12						12	9	4	5		
13											
14											
15											
16											
17											
18						24					
19											
20		7	< 2	7							
21											
22											
23											
24						45					
25											
26											
27											
28											
29											
30											
31											
MONTHLY AVG				7	20			5			
MONTHLY HIGH				7	45			5			
MONTHLY LOW				7	ND(5)			5			
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 30 = 0 D MAX 100 = 0	MO AVG 60 = 0 D MAX 100 = 0	NO LIMIT	NO LIMIT	MO AVG 30 = 0 D MAX 100 = 0				
TIMES EXCEEDED											
TIMES EXCEEDED											

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT <i>Trevor Rebelt for Bryan Cunningham</i>	DATE 10/18/2007
--	--------------------

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 8

FACILITY I.D. 3402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01			YEAR / MO / DAY ENDING 07 / 07 / 31			STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.		EFFLUENT 002 SUSPENDED SOLIDS mg/l 1st FLTR mg/l 2nd FLTR GRAB MONTHLY			EFFLUENT 003 SUSPENDED SOLIDS mg/l 1st FLTR mg/l 2nd FLTR GRAB MONTHLY						
1		*		*	*		*	*		*	
2											
3											
4											
5											
6											
7											
8											
9											
10											
11											
12	2	<	2	2	<	2	2	ND(5)	2	5	2
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											
29											
30											
31											
MONTHLY AVG								ND(5)		5	
MONTHLY HIGH								ND(5)		6	
MONTHLY LOW								ND(5)		5	
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 30 = 0	NO LIMIT	NO LIMIT	MO AVG 30 = 0					
TIMES EXCEEDED			D MAX 100 = 0			D MAX 100 = 0					
TIMES EXCEEDED											

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 9

FACILITY I.D.		YEAR / MO / DAY BEGINNING 07 / 07 / 01		YEAR / MO / DAY ENDING 07 / 07 / 31		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.		EFFLUENT 003 SUSPENDED SOLIDS mg/1 1st FLTR mg/1 2nd FLTR GRAB WEEKLY WHEN 001N & 001P => 003		EFFLUENT 001N SETTL SOLIDS m/l GRAB WEEKLY	EFFLUENT 001 T CHROMIUM ug/l GRAB MONTHLY	EFFLUENT 001 COPPER ug/l GRAB MONTHLY	EFFLUENT 001 NICKEL ug/l GRAB MONTHLY	EFFLUENT 001 ZINC ug/l GRAB MONTHLY
1								
2								
3								
4								
5					ND(0.1)			
6								
7								
8								
9								
10								
11								
12					ND(0.1)	ND(10)	ND(10)	ND(10)
13								
14								
15								
16								
17								
18					ND(0.1)			
19								
20								
21								
22								
23								
24					ND(0.1)			
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG		NO DISCHARGE		ND(0.1)	ND(10)	ND(10)	ND(10)	ND(10)
MONTHLY HIGH		NO DISCHARGE		ND(0.1)	ND(10)	ND(10)	ND(10)	ND(10)
MONTHLY LOW		NO DISCHARGE		ND(0.1)	ND(10)	ND(10)	ND(10)	ND(10)
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 30 = 0 D MAX 100 = 0	MO AVG 1.0 = 0 D MAX 3.0 = 0	6M-MED 10 = 0 D MAX 40 = 0	6M-MED 10 = 0 D MAX 50 = 0	6M-MED 30 = 0 D MAX 100 = 0	6M-MED 70 = 0 D MAX 380 = 0
TIMES EXCEEDED					I MAX 100 = 0	I MAX 140 = 0	I MAX 260 = 0	I MAX 990 = 0
TIMES EXCEEDED								

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebelfor Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 1

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01		YEAR / MO / DAY ENDING 07 / 07 / 31		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	INFLOW T CHROMIUM ug/l GRAB JA/AP/JUL/OCT	INFLOW COPPER ug/l GRAB JA/AP/JUL/OCT	INFLOW NICKEL ug/l GRAB JA/AP/JUL/OCT	INFLOW AMMONIA (N) ug/l GRAB JA/AP/JUL/OCT	EFFLUENT 001 AMMONIA (N) ug/l GRAB JA/AP/JUL/OCT	EFFLUENT 001D OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001G OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001H OIL & GREASE mg/l GRAB JA/AP/JUL/OCT
1	*	*	*	*	*	*	*	*
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12	ND(10)	ND(10)	10	ND(200)	ND(200)	2 < 5	ND(5)	ND(5)
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG	ND(10)	ND(10)	10	ND(200)	ND(200)	** < 5	ND(5)	ND(5)
MONTHLY HIGH	ND(10)	ND(10)	10	ND(200)	ND(200)	8	ND(5)	ND(5)
MONTHLY LOW	ND(10)	ND(10)	10	ND(200)	ND(200)	ND(5)	ND(5)	ND(5)
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	6M-MED 3060 = 0 D MAX 12240 = 0 I MAX 30600 = 0	MO AVG 15 = 0 D MAX 20 = 0	MO AVG 15 = 0 D MAX 20 = 0	MO AVG 15 = 0 D MAX 20 = 0
TIMES EXCEEDED								
TIMES EXCEEDED								

REMARKS:
* NUMBER OF SAMPLES TAKEN DURING THE DAY.
** FLOW-WEIGHTED AVERAGE RESULT REPORTED.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebiffé for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 2

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01		YEAR / MO / DAY ENDING 07 / 07 / 31		STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001I OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001J OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001K OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001L OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001M OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001P OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 002 OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 003 OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12							ND(5)	2	ND(5)
13									ND(5)
14									
15									
16									
17									
18					2	ND(5)			
19						ND(5)			
20							ND(5)		
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									
MONTHLY AVG	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE	ND(5)	ND(5)	ND(5)	ND(5)	ND(5)	ND(5)
MONTHLY HIGH				ND(5)	ND(5)	ND(5)	ND(5)	ND(5)	ND(5)
MONTHLY LOW				ND(5)	ND(5)	ND(5)	ND(5)	ND(5)	ND(5)
TIMES EXCEEDED	MO AVG 15 = 0	MO AVG 15 = 0	MO AVG 15 = 0	MO AVG 15 = 0					
TIMES EXCEEDED	D MAX 20 = 0	D MAX 20 = 0	D MAX 20 = 0	D MAX 20 = 0					
TIMES EXCEEDED									

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 3

FACILITY I.D. 3 402003001		YEAR / MO / DAY 07 / 07 / 01		YEAR / MO / DAY 07 / 07 / 31		STATE CODE 06	NPDES PERMIT # CA0003751
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 004 OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001 TOX CONCEN TU GRAB JA/AP/JUL/OCT	EFFLUENT 001D CADMIUM ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H CADMIUM ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L CADMIUM ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F CADMIUM ug/l 1 WEEK COMP JA/AP/JUL/OCT	
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12	ND(5)						
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25		0.00					
26							
27							
28							
29							
30							
31							
MONTHLY AVG	ND(5)	0.00	ND(10)	ND(10)	ND(10)	ND(10)	
MONTHLY HIGH	ND(5)	0.00	ND(10)	ND(10)	ND(10)	ND(10)	
MONTHLY LOW	ND(5)	0.00	ND(10)	ND(10)	ND(10)	ND(10)	
TIMES EXCEEDED	MO AVG 15 = 0 D MAX 20 = 0 6M-MED 0.26=0		NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	
TIMES EXCEEDED							
TIMES EXCEEDED							

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT <i>Trevor Rebely for Bryan Cunningham</i>	DATE 10/18/2007
--	--------------------

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 4

FACILITY I.D. 3402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01		YEAR / MO / DAY ENDING 07 / 07 / 31		STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D CHROMIUM ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H T CHROMIUM ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L T CHROMIUM ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F 1 WEEK COMP JA/AP/JUL/OCT	EFFLUENT 001D COPPER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H COPPER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L COPPER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F COPPER ug/l 1 WEEK COMP JA/AP/JUL/OCT	
1									
2		ND(10)							
3				ND(10)					
4			2 < 10						
5				ND(10)					
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									
MONTHLY AVG	ND(10)	< 10		ND(10)	ND(10)	ND(10)	< 10	ND(10)	ND(10)
MONTHLY HIGH	ND(10)	18		ND(10)	ND(10)	ND(10)	18	ND(10)	ND(10)
MONTHLY LOW	ND(10)	ND(10)		ND(10)	ND(10)	ND(10)	ND(10)	ND(10)	ND(10)
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT
TIMES EXCEEDED									
TIMES EXCEEDED									

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 5

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01		YEAR / MO / DAY ENDING 07 / 07 / 31		STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D LEAD ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H LEAD ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L LEAD ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F 1 WEEK COMP JA/AP/JUL/OCT	EFFLUENT 001D MERCURY ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H MERCURY ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L MERCURY ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F MERCURY ug/l 1 WEEK COMP JA/AP/JUL/OCT	
1									
2		ND(10)							
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									
MONTHLY AVG	ND(10)	ND(10)	ND(10)	ND(10)	ND(0.20)	< 0.20	ND(0.20)	ND(0.20)	ND(0.20)
MONTHLY HIGH	ND(10)	ND(10)	ND(10)	ND(10)	ND(0.20)	0.21	ND(0.20)	ND(0.20)	ND(0.20)
MONTHLY LOW	ND(10)	ND(10)	ND(10)	ND(10)	ND(0.20)	ND(0.20)	ND(0.20)	ND(0.20)	ND(0.20)
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT
TIMES EXCEEDED									
TIMES EXCEEDED									

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 6

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01		YEAR / MO / DAY ENDING 07 / 07 / 31		STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D NICKEL ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H NICKEL ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L NICKEL ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F NICKEL ug/l 1 WEEK COMP JA/AP/JUL/OCT	EFFLUENT 001D SILVER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H SILVER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L SILVER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F SILVER ug/l 1 WEEK COMP JA/AP/JUL/OCT	
1									
2		ND(10)							
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									
MONTHLY AVG	ND(10)	< 10	ND(10)	ND(10)	ND(10)	ND(10)	ND(10)	ND(10)	ND(10)
MONTHLY HIGH	ND(10)	10	ND(10)	ND(10)	ND(10)	ND(10)	ND(10)	ND(10)	ND(10)
MONTHLY LOW	ND(10)	ND(10)	ND(10)	ND(10)	ND(10)	ND(10)	ND(10)	ND(10)	ND(10)
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT
TIMES EXCEEDED									
TIMES EXCEEDED									

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebello for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 7

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01		YEAR / MO / DAY ENDING 07 / 07 / 31		STATE CODE 06	NPDES PERMIT # CA0003751
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D ZINC ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H ZINC ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L ZINC ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F ZINC ug/l 1 WEEK COMP JA/AP/JUL/OCT			
1							
2		43		ND(10)			
3				ND(10)			
4			2				
5						ND(10)	
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
MONTHLY AVG	43	ND(10)	ND(10)	ND(10)			
MONTHLY HIGH	43	ND(10)	ND(10)	ND(10)			
MONTHLY LOW	43	ND(10)	ND(10)	ND(10)			
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT			
TIMES EXCEEDED							
TIMES EXCEEDED							

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 8

FACILITY I.D. 3402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01		YEAR / MO / DAY ENDING 07 / 07 / 31		STATE CODE 06	NPDES PERMIT # CA0003751
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D COPPER mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001F COPPER mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001I COPPER mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001L COPPER mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001M COPPER mg/l 24-HR COMP. METAL CLNG		
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
MONTHLY AVG	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE		
MONTHLY HIGH							
MONTHLY LOW							
TIMES EXCEEDED	MO AVG 1 = 0						
TIMES EXCEEDED	D MAX 1 = 0						
TIMES EXCEEDED							

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 9

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01		YEAR / MO / DAY ENDING 07 / 07 / 31		STATE CODE 06	NPDES PERMIT # CA0003751
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D IRON mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001F IRON mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001I IRON mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001L IRON mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001M IRON mg/l 24-HR COMP. METAL CLNG		
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
MONTHLY AVG	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE		
MONTHLY HIGH							
MONTHLY LOW							
TIMES EXCEEDED	MO AVG 1 = 0 D MAX 1 = 0	MO AVG 1 = 0 D MAX 1 = 0	MO AVG 1 = 0 D MAX 1 = 0	MO AVG 1 = 0 D MAX 1 = 0	MO AVG 1 = 0 D MAX 1 = 0		
TIMES EXCEEDED							
TIMES EXCEEDED							

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebek for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD*
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (A) 1

FACILITY I.D. 3.402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01		YEAR / MO / DAY ENDING 07 / 07 / 31		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001 TITANIUM ug/l GRAB OCTOBER	INFLOWNT ARSENIC ug/l GRAB OCTOBER	EFFLUENT ARSENIC ug/l GRAB OCTOBER	INFLOWNT CADMIUM ug/l GRAB OCTOBER	EFFLUENT 001 CADMIUM ug/l GRAB OCTOBER	INFLOWNT LEAD ug/l GRAB OCTOBER	EFFLUENT 001 LEAD ug/l GRAB OCTOBER	INFLOWNT ZINC ug/l GRAB OCTOBER
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								ND(10)
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG							**	ND(10)
MONTHLY HIGH							ND(10)	
MONTHLY LOW							ND(10)	
TIMES EXCEEDED	NO LIMIT	NO LIMIT	6M-MED 30 = 0 D MAX 150 = 0 I MAX 400 = 0	NO LIMIT	6M-MED 10 = 0 D MAX 20 = 0 I MAX 50 - 0	NO LIMIT	6M-MED 10 = 0 D MAX 40 = 0 I MAX 100 = 0	NO LIMIT
TIMES EXCEEDED								
TIMES EXCEEDED								

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

** INFLOWNT ANALYSIS PERFORMED FOR COMPARISON TO EFFLUENTS.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebello for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (A) 2

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01		YEAR / MO / DAY ENDING 07 / 07 / 31		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	INFLOW MERCURY ug/l GRAB OCTOBER	EFFLUENT 001 MERCURY ug/l GRAB OCTOBER	INFLOW SILVER ug/l GRAB OCTOBER	EFFLUENT 001 SILVER ug/l GRAB OCTOBER	INFLOW CYANIDE ug/l GRAB OCTOBER	EFFLUENT 001 CYANIDE ug/l GRAB OCTOBER	INFLOW PHENOLIC CMP ug/l (NONCL) GRAB OCTOBER	EFFLUENT 001 PHENOLIC CMP ug/l (NONCL) GRAB OCTOBER
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG								
MONTHLY HIGH								
MONTHLY LOW								
TIMES EXCEEDED	NO LIMIT	6M-MED 0.2=0	NO LIMIT	6M-MED 2.9=0	NO LIMIT	6M-MED 30=0	NO LIMIT	6M-MED 150=0
TIMES EXCEEDED		DMAX 0.8 = 0		DMAX 13.6=0		DMAX 100=0		DMAX 610= 0
TIMES EXCEEDED		IMAX 2 = 0		IMAX 35= 0		IMAX 260=0		IMAX 1530=0

REMARKS: • NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebek for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (A) 3

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01		YEAR / MO / DAY ENDING 07 / 07 / 31		STATE CODE 06	NPDES PERMIT # CA0003751
STATION ANALYSIS UNITS SMPL TYPE FREQ.	INFLUENT CHLOR PHENOL ug/l GRAB OCTOBER	EFFLUENT 001 CHLOR PHENOL ug/l GRAB OCTOBER	EFFLUENT 001D LITHIUM mg/l GRAB OCTOBER	EFFLUENT 001D BORON mg/l GRAB OCTOBER	EFFLUENT 001D HYDRAZINE mg/l GRAB OCTOBER	EFFLUENT 005 OIL & GREASE mg/l GRAB OCTOBER	EFFLUENT 008 OIL & GREASE mg/l GRAB OCTOBER
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
MONTHLY AVG							
MONTHLY HIGH							
MONTHLY LOW							
TIMES EXCEEDED	NO LIMIT	6M-MED 10=0	NO LIMIT	NO LIMIT	NO LIMIT	MO AVG 15=0	MO AVG 15=0
TIMES EXCEEDED		DMAX 20=0				DMAX 20=0	DMAX 20=0
TIMES EXCEEDED		IMAX 50=0					

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT <i>Trevor Rebel for Bryan Cunningham</i>	DATE 10/18/2007
---	--------------------

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (A) 4

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01		YEAR / MO / DAY ENDING 07 / 07 / 31		STATE CODE 06	NPDES PERMIT # CA0003751
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 009 OIL & GREASE mg/l GRAB OCTOBER	EFFLUENT 013 OIL & GREASE mg/l GRAB OCTOBER	EFFLUENT 015 OIL & GREASE mg/l GRAB OCTOBER	EFFLUENT 016 OIL & GREASE mg/l GRAB OCTOBER	EFFLUENT 017 OIL & GREASE mg/l GRAB OCTOBER	INFLUENT PCB'S ug/l GRAB OCTOBER	EFFLUENT 001 PCB'S ug/l GRAB OCTOBER
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
MONTHLY AVG							
MONTHLY HIGH							
MONTHLY LOW							
TIMES EXCEEDED	MO AVG 15=0 DMAX 20=0	MO AVG 15=0 DMAX20=0	NO LIMIT	NO LIMIT			
TIMES EXCEEDED							
TIMES EXCEEDED							

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebef for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (A) 5

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01		YEAR / MO / DAY ENDING 07 / 07 / 31		STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001N SLUDGE MOISTURE % GRAB OCTOBER	EFFLUENT 001N SLUDGE TOT KJDL N mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE AMMONIA (N) mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE NITRATE (N) mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE TOT PHOSPHS mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE pH pH units GRAB OCTOBER	EFFLUENT 001N SLUDGE OIL & GREASE mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE BORON mg/kg GRAB OCTOBER	
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									
MONTHLY AVG									
MONTHLY HIGH									
MONTHLY LOW									
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	
TIMES EXCEEDED									
TIMES EXCEEDED									

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (A) 6

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 07 / 01		YEAR / MO / DAY ENDING 07 / 07 / 31		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001N SLUDGE CADMIUM mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE COPPER mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE CHROMIUM mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE LEAD mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE NICKEL mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE MERCURY mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE ZINC mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE VOLUME tons OCTOBER
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG								
MONTHLY HIGH								
MONTHLY LOW								
TIMES EXCEEDED	10xSTLC=0	10xSTLC=0	10xSTLC=0	10xSTLC=0	10xSTLC=0	10xSTLC=0	10xSTLC=0	
TIMES EXCEEDED	10 mg/kg=0	250 mg/kg=0	50 mg/kg=0	50 mg/kg=0	200 mg/kg=0	2 mg/kg=0	2500 mg/kg=0	
TIMES EXCEEDED	TTLC>100=0	TTLC>2500=0	TTLC>500=0	TTLC>1000=0	TTLC>2000=0	TTLC>20=0	TTLC>5000=0	

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

APPENDIX 3

DIABLO CANYON POWER PLANT

Influent and Effluent Monitoring

August 2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 1

FACILITY I.D. 3 402003001		YEAR / MO / DAY 07 / 08 / 01		YEAR / MO / DAY 07 / 08 / 31		STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	INFLOW TEMPERATURE DEGREES F METERED CONTINUOUS	EFFLUENT 001 TEMPERATURE DEGREES F METERED CONTINUOUS	DELTA TEMP TEMPERATURE DEGREES F METERED CONTINUOUS	EFFLUENT 001 FLOW MGD RECORDED DAILY	INFLOW pH pH UNITS GRAB MONTHLY	EFFLUENT 001 pH pH UNITS GRAB MONTHLY (**)	EFFLUENT 001P pH pH UNITS GRAB MONTHLY	EFFLUENT 002 pH pH UNITS GRAB MONTHLY	
1	54.6	73.0	18.4	2486					*
2	55.1	73.4	18.3	2486					*
3	55.1	73.5	18.4	2486					*
4	55.3	73.9	18.6	2486					*
5	55.5	74.0	18.5	2486					*
6	54.5	73.0	18.5	2486					*
7	54.2	72.6	18.4	2486					*
8	53.5	72.0	18.5	2486					*
9	53.3	71.4	18.1	2486					*
10	53.7	69.6	15.9	2486					*
11	54.4	68.2	13.8	1950					*
12	54.2	65.0	10.8	2384					*
13	54.1	64.4	10.3	2486					*
14	52.9	63.3	10.4	2486					*
15	51.8	61.7	9.9	2486					*
16	51.3	60.9	9.6	2486					*
17	50.7	60.4	9.7	2486					*
18	52.0	66.9	14.9	2486					*
19	52.1	70.8	18.7	2486					*
20	53.2	72.3	19.1	2486					*
21	53.2	72.0	18.8	2486					*
22	53.8	72.5	18.7	2486	7.9	7.9	2	7.6	2
23	54.3	73.2	18.9	2486					*
24	54.7	73.4	18.7	2486					*
25	55.1	73.6	18.5	2486					*
26	54.8	73.3	18.5	2486					*
27	54.4	72.8	18.4	2486					*
28	54.8	73.3	18.5	2486					*
29	54.8	73.4	18.6	2486					*
30	54.1	72.7	18.6	2486					*
31	54.9	73.6	18.7	2486					*
MONTHLY AVG	53.9	70.5	16.6	2465	7.9	7.9	7.6	7.8	
MONTHLY HIGH	55.5	74.0	19.1	2486	7.9	7.9	7.6	7.8	
MONTHLY LOW	50.7	60.4	9.6	1950	7.9	7.9	7.6	7.8	
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MAX 22 = 0 (**)	MAX 2760 = 0	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT
TIMES EXCEEDED									
TIMES EXCEEDED									

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

** EXCEPT DURING DEMUSSELING.

*** DAILY WHEN DISCHARGING CHEMICAL CLEANING WASTES FROM DISCHARGES 001D, F, I, L, AND/OR M.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebaf for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 2

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 08 / 01		YEAR / MO / DAY ENDING 07 / 08 / 31		STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 003 pH pH UNITS GRAB MONTHLY	EFFLUENT 004 pH pH UNITS GRAB MONTHLY	EFFLUENT 001N OIL & GREASE mg/l COMPOSITE WEEKLY	EFFLUENT 001P OIL & GREASE mg/l GRAB WEEKLY (**)	EFFLUENT 003 OIL & GREASE mg/l GRAB WEEKLY (**)	EFFLUENT 001F OIL & GREASE mg/l GRAB MONTHLY	EFFLUENT 001 T CHLOR RES ug/l GRAB (***) 2 per CYCLE	EFFLUENT 001 CHLORINE USED lbs/day RECORDED MONTHLY	
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									
21									
22	7.9	8.0	< 5						
23									
24									
25									
26									
27									
28									
29									
30									
31									
MONTHLY AVG	7.9	8.0	< 5	NO DISCHARGE	NO DISCHARGE	ND(5)	16	596	
MONTHLY HIGH	7.9	8.0	6			ND(5)	114	706	
MONTHLY LOW	7.9	8.0	ND(5)			ND(5)	< 10	410	
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 15 = 0 D MAX 20 = 0	MO AVG 15 = 0 D MAX 20 = 0	MO AVG 15 = 0 D MAX 20 = 0	MO AVG 15 = 0 D MAX 20 = 0	I MAX 200 = 0	NO LIMIT	
TIMES EXCEEDED									
TIMES EXCEEDED									

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

** WHEN 001N IS DISCHARGING TO 001P.

*** WHEN 001P IS DISCHARGING TO 003.

**** CONTINUOUS CHLORINE MONITORING USED INSTEAD OF GRAB SAMPLE ANALYSIS

PRINCIPAL EXECUTIVE OFFICER	SIGNATURE OF AUTHORIZED AGENT	DATE
JAMES R. BECKER	<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 3

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 08 / 01			YEAR / MO / DAY ENDING 07 / 08 / 31			STATE CODE 06		NPDES PERMIT # CA0003751				
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFF 001N=>003 TOTL COLIFORM MPN/100ml GRAB 4 TIMES/WEEK	EFF 001N=>003 FECAL COLIFORM MPN/100ml GRAB 4 TIMES/WEEK			EFFLUENT 001D SUSPENDED SOLIDS mg/l 1st FLTR GRAB MONTHLY			mg/l NET		EFFLUENT 001F SUSPENDED SOLIDS mg/l 2nd FLTR GRAB MONTHLY			mg/l NET	
1			*	*					*			*		
2														
3				2 < 2				2	ND(5)					
4														
5														
6														
7														
8														
9														
10														
11														
12														
13														
14				2 19 2				3 2	15					
15														
16				2 < 2				2	ND(5)					
17				< 2				2	ND(5)					
18														
19														
20														
21				2 < 2				2	ND(5)					
22				2 22	2 < 2	2	2	2	20	2	16	2	6	2 10
23														
24														
25														
26														
27														
28														
29														
30														
31														
MONTHLY AVG	NO DISCHARGE	NO DISCHARGE			**< 5									10
MONTHLY HIGH					21									10
MONTHLY LOW					ND(5)									9
TIMES EXCEEDED	80% SMPLS>1K	MEAN>200 =	NO LIMIT	NO LIMIT	MO AVG 30 = 0	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	MO AVG 30 = 0				
TIMES EXCEEDED	90 % SMPLS>400				D MAX 100 = 0					D MAX 100 = 0				
TIMES EXCEEDED	I MAX>10K													

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.
** FLOW-WEIGHTED AVERAGES REPORTED.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebek for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 4

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 08 / 01			YEAR / MO / DAY ENDING 07 / 08 / 31			STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.		EFFLUENT 001G SUSPENDED SOLIDS mg/l 1st FLTR GRAB MONTHLY			EFFLUENT 001H SUSPENDED SOLIDS mg/l 2nd FLTR GRAB MONTHLY						
1			*		*			7	7	ND(5)	
2											
3											
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22	< 2				ND(5)						
23											
24											
25											
26											
27											
28											
29											
30											
31											
MONTHLY AVG				ND(5)				ND(5)			
MONTHLY HIGH				ND(5)				ND(5)			
MONTHLY LOW				ND(5)				ND(5)			
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 30=0 D MAX 100 = 0	NO LIMIT	NO LIMIT	NO LIMIT	MO AVG 30=0 D MAX 100 = 0				
TIMES EXCEEDED											
TIMES EXCEEDED											

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT <i>Trevor Rebel for Bryan Cunningham</i>	DATE 10/18/2007
---	--------------------

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 5

FACILITY I.D.		YEAR / MO / DAY BEGINNING 07 / 08 / 01			YEAR / MO / DAY ENDING 07 / 08 / 31			STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.		EFFLUENT 001I SUSPENDED SOLIDS mg/l 1st FLTR GRAB MONTHLY			EFFLUENT 001J SUSPENDED SOLIDS mg/l 2nd FLTR GRAB MONTHLY						
1		*			*					*	
2											
3											
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16						< 2			ND(5)		
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											
29											
30											
31											
MONTHLY AVG					NO DISCHARGE				ND(5)		
MONTHLY HIGH									ND(5)		
MONTHLY LOW									ND(5)		
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 30 = 0 MAX 100 = 0	NO LIMIT	NO LIMIT	MO AVG 30 = 0 MAX 100 = 0					
TIMES EXCEEDED											
TIMES EXCEEDED											

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebello for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 6

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 08 / 01			YEAR / MO / DAY ENDING 07 / 08 / 31			STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.		EFFLUENT 001K SUSPENDED SOLIDS mg/1 1st FLTR mg/1 2nd FLTR GRAB MONTHLY			EFFLUENT 001L SUSPENDED SOLIDS mg/1 1st FLTR mg/1 2nd FLTR GRAB MONTHLY						
1											
2											
3											
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22					2 < 2			2	ND(5)		
23											
24											
25											
26											
27											
28											
29											
30											
31											
MONTHLY AVG					NO DISCHARGE			ND(5)			
MONTHLY HIGH								ND(5)			
MONTHLY LOW								ND(5)			
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 30 = 0 D MAX 100 = 0	NO LIMIT	NO LIMIT	NO LIMIT	MO AVG 30 = 0 D MAX 100 = 0				
TIMES EXCEEDED											
TIMES EXCEEDED											

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebek for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 7

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 08 / 01			YEAR / MO / DAY ENDING 07 / 08 / 31			STATE CODE 06		NPDES PERMIT # CA0003751		
STATION ANALYSIS UNITS SMPL TYPE FREQ.		EFFLUENT 001M SUSPENDED SOLIDS mg/1 1st FLTR mg/1 2nd FLTR GRAB MONTHLY			EFFLUENT 001N SUSPENDED SLDs mg/1 COMPOSITE WEEKLY			EFFLUENT 001P SUSPENDED SOLIDS mg/1 1st FLTR mg/1 2nd FLTR GRAB MONTHLY			mg/1 NET	
1	*			*		*		*		*		
2							11					
3												
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												
21												
22												
23												
24												
25												
26												
27												
28												
29												
30												
31							17					
MONTHLY AVG								12				ND(5)
MONTHLY HIGH								17				ND(5)
MONTHLY LOW								8				ND(5)
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 30 = 0	MO AVG 60 = 0	NO LIMIT	NO LIMIT						MO AVG 30 = 0
TIMES EXCEEDED			D MAX 100 = 0									D MAX 100 = 0
TIMES EXCEEDED												

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebek for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 8

FACILITY I.D.	YEAR / MO / DAY			YEAR / MO / DAY			STATE CODE	NPDES PERMIT #
	BEGINNING	07 / 08 / 01	ENDING	07 / 08 / 31			06	CA0003751
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 002 SUSPENDED SOLIDS mg/l 1st FLTR GRAB MONTHLY			EFFLUENT 003 SUSPENDED SOLIDS mg/l 2nd FLTR GRAB MONTHLY				
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22	2 < 2	2 < 2	2	ND(5)	2 < 2	2 < 2	2	ND(5)
23								
24								
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG				ND(5)			ND(5)	
MONTHLY HIGH				ND(5)			ND(5)	
MONTHLY LOW				ND(5)			ND(5)	
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 30 = 0 D MAX 100 = 0	NO LIMIT	NO LIMIT	MO AVG 30 = 0 D MAX 100 = 0		
TIMES EXCEEDED								
TIMES EXCEEDED								

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 9

FACILITY I.D. 3 402003001	YEAR / MO / DAY BEGINNING 07 / 08 / 01			YEAR / MO / DAY ENDING 07 / 08 / 31			STATE CODE 06	NPDES PERMIT # CA0003751
	STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 003 SUSPENDED SOLIDS mg/1 1st FLTR mg/1 2nd FLTR GRAB WEEKLY WHEN 001N & 001P => 003	EFFLUENT 001N SETTL SOLIDS m/1 GRAB WEEKLY	EFFLUENT 001 T CHROMIUM ug/1 GRAB MONTHLY	EFFLUENT 001 COPPER ug/1 GRAB MONTHLY	EFFLUENT 001 NICKEL ug/1 GRAB MONTHLY		
1	*	*	*	*	*	*	*	*
2					ND(0.1)			
3					ND(0.1)			
4					ND(0.1)			
5					ND(0.1)			
6					ND(0.1)			
7					ND(0.1)			
8					ND(0.1)			
9					ND(0.1)			
10					ND(0.1)			
11					ND(0.1)			
12					ND(0.1)			
13					ND(0.1)			
14					ND(0.1)			
15					ND(0.1)			
16					ND(0.1)			
17					ND(0.1)			
18					ND(0.1)			
19					ND(0.1)			
20					ND(0.1)			
21					ND(0.1)			
22					ND(0.1)	ND(10)	ND(10)	ND(10)
23								ND(10)
24								
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG	NO DISCHARGE			ND(0.1)	ND(10)	ND(10)	ND(10)	ND(10)
MONTHLY HIGH	NO			ND(0.1)	ND(10)	ND(10)	ND(10)	ND(10)
MONTHLY LOW	DISCHARGE			ND(0.1)	ND(10)	ND(10)	ND(10)	ND(10)
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 30 = 0 D MAX 100 = 0	MO AVG 1.0 = 0 D MAX 3.0 = 0	6M-MED 10 = 0 D MAX 40 = 0	6M-MED 10 = 0 D MAX 50 = 0	6M-MED 30 = 0 D MAX 100 = 0	6M-MED 70 = 0 D MAX 380 = 0
TIMES EXCEEDED					I MAX 100 = 0	I MAX 140 = 0	I MAX 260 = 0	I MAX 990 = 0
TIMES EXCEEDED								

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebek for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 1

FACILITY I.D.		YEAR / MO / DAY BEGINNING 07 / 08 / 01		YEAR / MO / DAY ENDING 07 / 08 / 31		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	INFLUENT T CHROMIUM ug/l GRAB JA/AP/JUL/OCT	INFLUENT COPPER ug/l GRAB JA/AP/JUL/OCT	INFLUENT NICKEL ug/l GRAB JA/AP/JUL/OCT	INFLUENT AMMONIA (N) ug/l GRAB JA/AP/JUL/OCT	EFFLUENT 001 AMMONIA (N) ug/l GRAB JA/AP/JUL/OCT	EFFLUENT 001D OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001G OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001H OIL & GREASE mg/l GRAB JA/AP/JUL/OCT
1	*	*	*	*	*	*	*	*
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22	ND(10)	ND(10)	ND(10)					
23								
24								
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG	ND(10)	ND(10)	ND(10)		** < 5			
MONTHLY HIGH	ND(10)	ND(10)	ND(10)		5			
MONTHLY LOW	ND(10)	ND(10)	ND(10)		ND(5)			
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	6M-MED 3060 = 0 D MAX 12240 = 0 I MAX 30600 = 0	MO AVG 15 = 0 D MAX 20 = 0	MO AVG 15 = 0 D MAX 20 = 0	MO AVG 15 = 0 D MAX 20 = 0
TIMES EXCEEDED								
TIMES EXCEEDED								

REMARKS:
 * NUMBER OF SAMPLES TAKEN DURING THE DAY.
 ** FLOW-WEIGHTED AVERAGE RESULT REPORTED.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 2

FACILITY I.D. 3402003001		YEAR / MO / DAY BEGINNING 07 / 08 / 01		YEAR / MO / DAY ENDING 07 / 08 / 31		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001I OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001J OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001K OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001L OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001M OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001P OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 002 OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 003 OIL & GREASE mg/l GRAB JA/AP/JUL/OCT
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG	ND(5)							
MONTHLY HIGH	ND(5)							
MONTHLY LOW	ND(5)							
TIMES EXCEEDED	MO AVG 15 = 0	MO AVG 15 = 0	MO AVG 15 = 0					
TIMES EXCEEDED	D MAX 20 = 0	D MAX 20 = 0	D MAX 20 = 0					
TIMES EXCEEDED								

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebelt for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 3

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 08 / 01		YEAR / MO / DAY ENDING 07 / 08 / 31		STATE CODE 06	NPDES PERMIT # CA0003751
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 004 OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001 TOX CONCEN TU GRAB JA/AP/JUL/OCT	EFFLUENT 001D CADMIUM ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H CADMIUM ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L CADMIUM ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F CADMIUM ug/l 1 WEEK COMP JA/AP/JUL/OCT	
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
MONTHLY AVG							
MONTHLY HIGH							
MONTHLY LOW							
TIMES EXCEEDED	MO AVG 15 = 0	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT		
TIMES EXCEEDED	D MAX 20 = 0						
TIMES EXCEEDED	6M-MED 0.26=0						

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 4

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 08 / 01		YEAR / MO / DAY ENDING 07 / 08 / 31		STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D CHROMIUM ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H T CHROMIUM ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L T CHROMIUM ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F T CHROMIUM ug/l 1 WEEK COMP JA/AP/JUL/OCT	EFFLUENT 001D COPPER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H COPPER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L COPPER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F COPPER ug/l 1 WEEK COMP JA/AP/JUL/OCT	
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									
MONTHLY AVG									
MONTHLY HIGH									
MONTHLY LOW									
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	
TIMES EXCEEDED									
TIMES EXCEEDED									

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebelt for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 5

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 08 / 01		YEAR / MO / DAY ENDING 07 / 08 / 31		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D LEAD ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H LEAD ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L LEAD ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F LEAD ug/l 1 WEEK COMP JA/AP/JUL/OCT	EFFLUENT 001D MERCURY ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H MERCURY ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L MERCURY ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F MERCURY ug/l 1 WEEK COMP JA/AP/JUL/OCT
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG								
MONTHLY HIGH								
MONTHLY LOW								
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT
TIMES EXCEEDED								
TIMES EXCEEDED								

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebek for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 6

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 08 / 01		YEAR / MO / DAY ENDING 07 / 08 / 31		STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D NICKEL ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H NICKEL ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L NICKEL ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F NICKEL ug/l 1 WEEK COMP JA/AP/JUL/OCT	EFFLUENT 001D SILVER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H SILVER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L SILVER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F SILVER ug/l 1 WEEK COMP JA/AP/JUL/OCT	
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									
MONTHLY AVG									
MONTHLY HIGH									
MONTHLY LOW									
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT
TIMES EXCEEDED									
TIMES EXCEEDED									

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebek for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 7

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 08 / 01		YEAR / MO / DAY ENDING 07 / 08 / 31		STATE CODE 06	NPDES PERMIT # CA0003751
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D ZINC ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H ZINC ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L ZINC ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F ZINC ug/l 1 WEEK COMP JA/AP/JUL/OCT			
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
MONTHLY AVG							
MONTHLY HIGH							
MONTHLY LOW							
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT			
TIMES EXCEEDED							
TIMES EXCEEDED							

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 8

FACILITY I.D.		YEAR / MO / DAY BEGINNING 07 / 08 / 01		YEAR / MO / DAY ENDING 07 / 08 / 31		STATE CODE 06	NPDES PERMIT # CA0003751
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D COPPER mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001F COPPER mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001I COPPER mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001L COPPER mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001M COPPER mg/l 24-HR COMP. METAL CLNG		
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
MONTHLY AVG	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE		
MONTHLY HIGH							
MONTHLY LOW							
TIMES EXCEEDED	MO AVG 1 = 0						
TIMES EXCEEDED	D MAX 1 = 0						
TIMES EXCEEDED							

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 9

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 08 / 01		YEAR / MO / DAY ENDING 07 / 08 / 31		STATE CODE 06	NPDES PERMIT # CA0003751
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D IRON mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001F IRON mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001I IRON mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001L IRON mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001M IRON mg/l 24-HR COMP. METAL CLNG		
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
MONTHLY AVG	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE		
MONTHLY HIGH							
MONTHLY LOW							
TIMES EXCEEDED	MO AVG 1 = 0						
TIMES EXCEEDED	D MAX 1 = 0						
TIMES EXCEEDED							

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebek for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (A) 1

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 08 / 01		YEAR / MO / DAY ENDING 07 / 08 / 31		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001 TITANIUM ug/l GRAB OCTOBER	INFLOWNT ARSENIC ug/l GRAB OCTOBER	EFFLUENT ARSENIC ug/l GRAB OCTOBER	INFLOWNT CADMIUM ug/l GRAB OCTOBER	EFFLUENT 001 CADMIUM ug/l GRAB OCTOBER	INFLOWNT LEAD ug/l GRAB OCTOBER	EFFLUENT 001 LEAD ug/l GRAB OCTOBER	INFLOWNT ZINC ug/l GRAB OCTOBER
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG							** ND(10)	
MONTHLY HIGH							ND(10)	
MONTHLY LOW							ND(10)	
TIMES EXCEEDED	NO LIMIT	NO LIMIT	6M-MED 30 = 0 D MAX 150 = 0 I MAX 400 = 0	NO LIMIT	6M-MED 10 = 0 D MAX 20 = 0 I MAX 50 - 0	NO LIMIT	6M-MED 10 = 0 D MAX 40 = 0 I MAX 100 = 0	NO LIMIT
TIMES EXCEEDED								
TIMES EXCEEDED								

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

** INFLOWNT ANALYSIS PERFORMED FOR COMPARISON TO EFFLUENTS.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (A) 2

FACILITY I.D.		YEAR / MO / DAY BEGINNING 07 / 08 / 01		YEAR / MO / DAY ENDING 07 / 08 / 31		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	INFLUENT MERCURY ug/l GRAB OCTOBER	EFFLUENT 001 MERCURY ug/l GRAB OCTOBER	INFLUENT SILVER ug/l GRAB OCTOBER	EFFLUENT 001 SILVER ug/l GRAB OCTOBER	INFLUENT CYANIDE ug/l GRAB OCTOBER	EFFLUENT 001 CYANIDE ug/l GRAB OCTOBER	INFLUENT PHENOLIC CMP ug/l (NONCL) GRAB OCTOBER	EFFLUENT 001 PHENOLIC CMP ug/l (NONCL) GRAB OCTOBER
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG								
MONTHLY HIGH								
MONTHLY LOW								
TIMES EXCEEDED	NO LIMIT	6M-MED 0.2=0	NO LIMIT	6M-MED 2.9=0	NO LIMIT	6M-MED 30=0	NO LIMIT	6M-MED 150=0
TIMES EXCEEDED		DMAX 0.8 = 0		DMAX 13.6=0		DMAX 100=0		DMAX 610= 0
TIMES EXCEEDED		IMAX 2 = 0		IMAX 35= 0		IMAX 260=0		IMAX 1530=0

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (A) 3

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 08 / 01		YEAR / MO / DAY ENDING 07 / 08 / 31		STATE CODE 06	NPDES PERMIT # CA0003751
STATION ANALYSIS UNITS SMPL TYPE FREQ.	INFLOWNT CHLOR PHENOL ug/l GRAB OCTOBER	EFFLUENT 001 CHLOR PHENOL ug/l GRAB OCTOBER	EFFLUENT 001D LITHIUM mg/l GRAB OCTOBER	EFFLUENT 001D BORON mg/l GRAB OCTOBER	EFFLUENT 001D HYDRAZINE mg/l GRAB OCTOBER	EFFLUENT 005 OIL & GREASE mg/l GRAB OCTOBER	EFFLUENT 008 OIL & GREASE mg/l GRAB OCTOBER
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
MONTHLY AVG							
MONTHLY HIGH							
MONTHLY LOW							
TIMES EXCEEDED	NO LIMIT	6M-MED 10=0	NO LIMIT	NO LIMIT	NO LIMIT	MO AVG 15=0	MO AVG 15=0
TIMES EXCEEDED		DMAX 20=0				DMAX 20=0	DMAX 20=0
TIMES EXCEEDED		IMAX 50=0					

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebet for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (A) 4

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 08 / 01		YEAR / MO / DAY ENDING 07 / 08 / 31		STATE CODE 06	NPDES PERMIT # CA0003751
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 009 OIL & GREASE mg/l GRAB OCTOBER	EFFLUENT 013 OIL & GREASE mg/l GRAB OCTOBER	EFFLUENT 015 OIL & GREASE mg/l GRAB OCTOBER	EFFLUENT 016 OIL & GREASE mg/l GRAB OCTOBER	EFFLUENT 017 OIL & GREASE mg/l GRAB OCTOBER	INFLOW PCB'S ug/l GRAB OCTOBER	EFFLUENT 001 PCB'S ug/l GRAB OCTOBER
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
MONTHLY AVG							
MONTHLY HIGH							
MONTHLY LOW							
TIMES EXCEEDED	MO AVG 15=0	NO LIMIT	NO LIMIT				
TIMES EXCEEDED	DMAX 20=0						
TIMES EXCEEDED							

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (A) 5

FACILITY I.D.		YEAR / MO / DAY BEGINNING 07 / 08 / 01		YEAR / MO / DAY ENDING 07 / 08 / 31		STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001N SLUDGE MOISTURE % GRAB OCTOBER	EFFLUENT 001N SLUDGE TOT KJLDL N mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE AMMONIA (N) mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE NITRATE (N) mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE TOT PHOSPHS mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE pH pH units GRAB OCTOBER	EFFLUENT 001N SLUDGE OIL & GREASE mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE BORON mg/kg GRAB OCTOBER	
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									
MONTHLY AVG									
MONTHLY HIGH									
MONTHLY LOW									
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	
TIMES EXCEEDED									
TIMES EXCEEDED									

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebelt for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (A) 6

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 08 / 01		YEAR / MO / DAY ENDING 07 / 08 / 31		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001N SLUDGE CADMIUM mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE COPPER mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE CHROMIUM mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE LEAD mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE NICKEL mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE MERCURY mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE ZINC mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE VOLUME tons OCTOBER
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG								
MONTHLY HIGH								
MONTHLY LOW								
TIMES EXCEEDED	10xSTLC=0	10xSTLC=0	10xSTLC=0	10xSTLC=0	10xSTLC=0	10xSTLC=0	10xSTLC=0	
TIMES EXCEEDED	10 mg/kg=0	250 mg/kg=0	50 mg/kg=0	50 mg/kg=0	200 mg/kg=0	2 mg/kg=0	2500 mg/kg=0	
TIMES EXCEEDED	TTLCL>100=0	TTLCL>2500=0	TTLCL>500=0	TTLCL>1000=0	TTLCL>2000=0	TTLCL>20=0	TTLCL>5000=0	

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

APPENDIX 4

DIABLO CANYON POWER PLANT

Influent and Effluent Monitoring

September 2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 1

FACILITY I.D. 3402003001		YEAR / MO / DAY BEGINNING 07 / 09 / 01		YEAR / MO / DAY ENDING 07 / 09 / 30		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	INFLUENT TEMPERATURE DEGREES F METERED CONTINUOUS	EFFLUENT 001 TEMPERATURE DEGREES F METERED CONTINUOUS	DELTA TEMP TEMPERATURE DEGREES F METERED CONTINUOUS	EFFLUENT 001 FLOW MGD RECORDED DAILY	INFLUENT pH pH UNITS GRAB MONTHLY	EFFLUENT 001 pH pH UNITS GRAB MONTHLY (**)	EFFLUENT 001P pH pH UNITS GRAB MONTHLY	EFFLUENT 002 pH pH UNITS GRAB MONTHLY
1	53.6	72.3	18.7	2486				
2	54.0	72.7	18.7	2486				
3	52.9	71.5	18.6	2486				
4	51.6	70.2	18.6	2486				
5	52.5	71.2	18.7	2486				
6	55.3	74.1	18.8	2486				
7	56.5	74.9	18.4	2486				
8	55.9	74.4	18.5	2486				
9	55.6	74.2	18.6	2486				
10	55.2	73.8	18.6	2486				
11	54.1	72.8	18.7	2486				
12	53.7	72.3	18.6	2486				
13	54.1	72.6	18.5	2486				
14	52.9	71.4	18.5	2486				
15	52.7	71.2	18.5	2486				
16	53.6	72.2	18.6	2486				
17	53.7	72.5	18.8	2486				
18	53.7	72.4	18.7	2486				
19	54.0	72.6	18.6	2486				
20	53.6	71.8	18.2	2486				
21	55.6	74.5	18.9	2486				
22	55.4	74.3	18.9	2486				
23	55.9	74.7	18.8	2486				
24	56.9	75.4	18.5	2486	8.1	8.1	2	7.8
25	56.9	75.6	18.7	2486			2	8.1
26	57.1	76.0	18.9	2486				
27	57.0	76.1	19.1	2486				
28	56.9	75.8	18.9	2486				
29	56.1	74.9	18.8	2486				
30	55.2	74.2	19.0	2486				
31								
MONTHLY AVG	54.7	73.4	18.7	2486	8.1	8.1	7.8	8.1
MONTHLY HIGH	57.1	76.1	19.1	2486	8.1	8.1	7.8	8.1
MONTHLY LOW	51.6	70.2	18.2	2486	8.1	8.1	7.8	8.1
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MAX 22 = 0 (**)	MAX 2760 = 0	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT

REMARKS:

- * NUMBER OF SAMPLES TAKEN DURING THE DAY.
- ** EXCEPT DURING DEMUSSELING.
- *** DAILY WHEN DISCHARGING CHEMICAL CLEANING WASTES FROM DISCHARGES 001D, F, I, L, AND/OR M.

PRINCIPAL EXECUTIVE OFFICER	SIGNATURE OF AUTHORIZED AGENT	DATE
JAMES R. BECKER	<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 2

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 09 / 01		YEAR / MO / DAY ENDING 07 / 09 / 30		STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 003 pH pH UNITS GRAB MONTHLY	EFFLUENT 004 pH pH UNITS GRAB MONTHLY	EFFLUENT 001N OIL & GREASE mg/l COMPOSITE WEEKLY	EFFLUENT 001P OIL & GREASE mg/l GRAB WEEKLY (**)	EFFLUENT 003 OIL & GREASE mg/l GRAB WEEKLY (***)	EFFLUENT 001F OIL & GREASE mg/l GRAB MONTHLY	EFFLUENT 001 T CHLOR RES ug/l GRAB (****) 2 per CYCLE	EFFLUENT 001 CHLORINE USED lbs/day RECORDED MONTHLY	
1									
2							11	706	
3							11	706	
4							16	706	
5							23	706	
6							23	691	
7							< 10	677	
8							< 10	677	
9							< 10	677	
10							13	706	
11							14	749	
12				3	ND(5)		20	749	
13				3	ND(5)		26	691	
14				3	ND(5)		34	634	
15				3	ND(5)		37	619	
16				3	ND(5)		31	619	
17				3	ND(5)		28	619	
18				3	ND(5)		28	600	
19				3	ND(5)		21	562	
20				3	ND(5)		19	562	
21				3	ND(5)		19	562	
22				3	ND(5)		18	562	
23				3	ND(5)		13	562	
24	8.1	8.1	ND(5)	NO DISCHARGE	NO DISCHARGE	5	< 10	394	
25							< 10	653	
26							16	691	
27							16	720	
28							16	734	
29							16	734	
30							14	734	
31									
MONTHLY AVG	8.1	8.1	ND(5)	NO DISCHARGE	NO DISCHARGE	5	16	656	
MONTHLY HIGH	8.1	8.1	ND(5)			5	37	749	
MONTHLY LOW	8.1	8.1	ND(5)			5	< 10	394	
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 15 = 0 D MAX 20 = 0	MO AVG 15 = 0 D MAX 20 = 0	MO AVG 15 = 0 D MAX 20 = 0	MO AVG 15 = 0 D MAX 20 = 0	I MAX 200 = 0	NO LIMIT	
TIMES EXCEEDED									
TIMES EXCEEDED									

REMARKS:

- * NUMBER OF SAMPLES TAKEN DURING THE DAY.
- ** WHEN 001N IS DISCHARGING TO 001P.
- *** WHEN 001P IS DISCHARGING TO 003.
- **** CONTINUOUS CHLORINE MONITORING USED INSTEAD OF GRAB SAMPLE ANALYSIS

PRINCIPAL EXECUTIVE OFFICER	SIGNATURE OF AUTHORIZED AGENT	DATE
JAMES R. BECKER	<i>Trevor Rebek for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 3

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 09 / 01		YEAR / MO / DAY ENDING 07 / 09 / 30		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFF 001N=>003 TOTL COLIFORM MPN/100ml GRAB 4 TIMES/WEEK	EFF 001N=>003 FECAL COLIFORM MPN/100ml GRAB 4 TIMES/WEEK		EFFLUENT 001D SUSPENDED SOLIDS mg/l 1st FLTR GRAB MONTHLY	mg/l NET		EFFLUENT 001F SUSPENDED SOLIDS mg/l 2nd FLTR GRAB MONTHLY	mg/l NET
1	*	*	*	*	*	*	*	*
2				< 2				
3						ND(5)	2	20
4							2	< 2
5						ND(5)	2	2
6						ND(5)		20
7								
8								
9								
10								
11								
12				< 2				
13				2 < 2				
14						2		
15						ND(5)		
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG	NO DISCHARGE	NO DISCHARGE		"< 5				20
MONTHLY HIGH				54				20
MONTHLY LOW				ND(5)				20
TIMES EXCEEDED	80% SMPLS>1K	MEAN>200 = 90 % SMPLS>400	NO LIMIT	NO LIMIT	MO AVG 30 = 0 D MAX 100 = 0	NO LIMIT	NO LIMIT	MO AVG 30 = 0 D MAX 100 = 0
TIMES EXCEEDED		I MAX>10K						
TIMES EXCEEDED								

REMARKS:
* NUMBER OF SAMPLES TAKEN DURING THE DAY.
** FLOW-WEIGHTED AVERAGES REPORTED.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebello for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 4

FACILITY I.D.		YEAR / MO / DAY BEGINNING 07 / 09 / 01			YEAR / MO / DAY ENDING 07 / 09 / 30			STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.		EFFLUENT 001G SUSPENDED SOLIDS mg/l 1st FLTR mg/l 2nd FLTR GRAB MONTHLY			EFFLUENT 001H SUSPENDED SOLIDS mg/l 1st FLTR mg/l 2nd FLTR GRAB MONTHLY						
1											
2											
3											
4	< 2				ND(5)		< 2	< 2	ND(5)		
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											
29											
30											
31											
MONTHLY AVG				ND(5)				ND(5)			
MONTHLY HIGH				ND(5)				ND(5)			
MONTHLY LOW				ND(5)				ND(5)			
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 30=0 D MAX 100 = 0	NO LIMIT	NO LIMIT	NO LIMIT	MO AVG 30=0 D MAX 100 = 0				
TIMES EXCEEDED											
TIMES EXCEEDED											

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebell for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 5

FACILITY I.D.		YEAR / MO / DAY BEGINNING		YEAR / MO / DAY ENDING		STATE CODE		NPDES PERMIT #	
STATION ANALYSIS UNITS SMPL TYPE FREQ.		EFFLUENT 001I SUSPENDED SOLIDS mg/l 1st FLTR GRAB MONTHLY	mg/l NET		EFFLUENT 001J SUSPENDED SOLIDS mg/l 2nd FLTR GRAB MONTHLY	mg/l NET			
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									
MONTHLY AVG		NO DISCHARGE				NO DISCHARGE			
MONTHLY HIGH									
MONTHLY LOW									
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 30 = 0 MAX 100 = 0	NO LIMIT	NO LIMIT	MO AVG 30 = 0 MAX 100 = 0			
TIMES EXCEEDED									
TIMES EXCEEDED									

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebef for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 6

FACILITY I.D.		YEAR / MO / DAY			YEAR / MO / DAY			STATE CODE		NPDES PERMIT #	
3 402003001		BEGINNING	07 / 09 / 01	ENDING	07 / 09 / 30			06		CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.		EFFLUENT 001K SUSPENDED SOLIDS mg/l 1st FLTR GRAB MONTHLY			EFFLUENT 001L SUSPENDED SOLIDS mg/l 2nd FLTR GRAB MONTHLY						
1						2	<	2		2	ND(5)
2											
3											
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											
29											
30											
31											
MONTHLY AVG		NO DISCHARGE						ND(5)			
MONTHLY HIGH								ND(5)			
MONTHLY LOW								ND(5)			
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 30 = 0	NO LIMIT	NO LIMIT	NO LIMIT	MO AVG 30 = 0				
TIMES EXCEEDED			D MAX 100 = 0				D MAX 100 = 0				
TIMES EXCEEDED											

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebet for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 7

FACILITY I.D. 3 402003001	YEAR / MO / DAY BEGINNING 07 / 09 / 01			YEAR / MO / DAY ENDING 07 / 09 / 30			STATE CODE 06	NPDES PERMIT # CA0003751
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001M SUSPENDED SOLIDS mg/1 1st FLTR GRAB MONTHLY	EFFLUENT 001N SUSPENDED SLDS mg/1 NET COMPOSITE WEEKLY	EFFLUENT 001P SUSPENDED SOLIDS mg/1 1st FLTR GRAB MONTHLY	EFFLUENT 001P SUSPENDED SOLIDS mg/1 2nd FLTR GRAB MONTHLY	mg/1 NET			
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11	3	< 2	ND(5)					
12				14				
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG		ND(5)	12			ND(5)		
MONTHLY HIGH		ND(5)	14			ND(5)		
MONTHLY LOW		ND(5)	10			ND(5)		
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 30 = 0 D MAX 100 = 0	MO AVG 60 = 0	NO LIMIT	NO LIMIT	MO AVG 30 = 0 D MAX 100 = 0	
TIMES EXCEEDED								
TIMES EXCEEDED								

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebet for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 8

FACILITY I.D.	YEAR / MO / DAY BEGINNING 07 / 09 / 01			YEAR / MO / DAY ENDING 07 / 09 / 30			STATE CODE	NPDES PERMIT #
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 002 SUSPENDED SOLIDS mg/l 1st FLTR GRAB MONTHLY			EFFLUENT 003 SUSPENDED SOLIDS mg/l 1st FLTR GRAB MONTHLY				
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24	2	2	2	< 2	2	ND(5)	2	5
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG				ND(5)				5
MONTHLY HIGH				ND(5)				5
MONTHLY LOW				ND(5)				ND(5)
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 30 = 0	NO LIMIT	NO LIMIT	MO AVG 30 = 0		
TIMES EXCEEDED			D MAX 100 = 0					
TIMES EXCEEDED								

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (M) 9

FACILITY I.D.		YEAR / MO / DAY BEGINNING 07 / 09 / 01		YEAR / MO / DAY ENDING 07 / 09 / 30		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.		EFFLUENT 003 SUSPENDED SOLIDS mg/l 1st FLTR mg/l 2nd FLTR mg/l NET GRAB WEEKLY WHEN 001N & 001P => 003		EFFLUENT 001N SETTL. SOLIDS ml/l GRAB WEEKLY	EFFLUENT 001 T CHROMIUM ug/l GRAB MONTHLY	EFFLUENT 001 COPPER ug/l GRAB MONTHLY	EFFLUENT 001 NICKEL ug/l GRAB MONTHLY	EFFLUENT 001 ZINC ug/l GRAB MONTHLY
1								
2								
3								
4								
5					ND(0.1)			
6					ND(0.1)			
7					ND(0.1)			
8					ND(0.1)			
9					ND(0.1)			
10					ND(0.1)			
11					ND(0.1)			
12					ND(0.1)			
13					ND(0.1)			
14					ND(0.1)			
15					ND(0.1)			
16					ND(0.1)			
17					ND(0.1)			
18					ND(0.1)			
19					ND(0.1)			
20					ND(0.1)			
21					ND(0.1)			
22					ND(0.1)			
23					ND(0.1)			
24					ND(0.1)	ND(10)	ND(10)	ND(10)
25					ND(0.1)	ND(10)	ND(10)	ND(10)
26					ND(0.1)	ND(10)	ND(10)	ND(10)
27					ND(0.1)	ND(10)	ND(10)	ND(10)
28					ND(0.1)	ND(10)	ND(10)	ND(10)
29					ND(0.1)	ND(10)	ND(10)	ND(10)
30					ND(0.1)	ND(10)	ND(10)	ND(10)
31					ND(0.1)	ND(10)	ND(10)	ND(10)
MONTHLY AVG		NO DISCHARGE		ND(0.1)	ND(10)	ND(10)	ND(10)	ND(10)
MONTHLY HIGH		NO DISCHARGE		ND(0.1)	ND(10)	ND(10)	ND(10)	ND(10)
MONTHLY LOW		NO DISCHARGE		ND(0.1)	ND(10)	ND(10)	ND(10)	ND(10)
TIMES EXCEEDED	NO LIMIT	NO LIMIT	MO AVG 30 = 0 D MAX 100 = 0	MO AVG 1.0 = 0 D MAX 3.0 = 0	6M-MED 10 = 0 D MAX 40 = 0	6M-MED 10 = 0 D MAX 50 = 0	6M-MED 30 = 0 D MAX 100 = 0	6M-MED 70 = 0 D MAX 380 = 0
TIMES EXCEEDED					I MAX 100 = 0	I MAX 140 = 0	I MAX 260 = 0	I MAX 990 = 0
TIMES EXCEEDED								

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebek for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 1

FACILITY I.D. 3 402003001		YEAR / MO / DAY 07 / 09 / 01		YEAR / MO / DAY 07 / 09 / 30		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	INFLOW T CHROMIUM ug/l GRAB JA/AP/JUL/OCT	INFLOW COPPER ug/l GRAB JA/AP/JUL/OCT	INFLOW NICKEL ug/l GRAB JA/AP/JUL/OCT	INFLOW AMMONIA (N) ug/l GRAB JA/AP/JUL/OCT	EFFLUENT 001 AMMONIA (N) ug/l GRAB JA/AP/JUL/OCT	EFFLUENT 001D OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001G OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001H OIL & GREASE mg/l GRAB JA/AP/JUL/OCT
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24	ND(10)	ND(10)	10				8	
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG	ND(10)	ND(10)	10				8	
MONTHLY HIGH	ND(10)	ND(10)	10				8	
MONTHLY LOW	ND(10)	ND(10)	10				8	
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	6M-MED 3060 = 0 D MAX 12240 = 0 I MAX 30600 = 0	MO AVG 15 = 0 D MAX 20 = 0	MO AVG 15 = 0 D MAX 20 = 0	MO AVG 15 = 0 D MAX 20 = 0
TIMES EXCEEDED								
TIMES EXCEEDED								

REMARKS:
 * NUMBER OF SAMPLES TAKEN DURING THE DAY.
 ** FLOW-WEIGHTED AVERAGE RESULT REPORTED.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebek for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 2

FACILITY I.D. 3402003001		YEAR / MO / DAY BEGINNING 07 / 09 / 01		YEAR / MO / DAY ENDING 07 / 09 / 30		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001I OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001J OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001K OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001L OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001M OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001P OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 002 OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 003 OIL & GREASE mg/l GRAB JA/AP/JUL/OCT
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG					ND(5)			
MONTHLY HIGH					ND(5)			
MONTHLY LOW					ND(5)			
TIMES EXCEEDED	MO AVG 15 = 0	MO AVG 15 = 0	MO AVG 15 = 0					
TIMES EXCEEDED	D MAX 20 = 0	D MAX 20 = 0	D MAX 20 = 0					
TIMES EXCEEDED								

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebello for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 3

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 09 / 01		YEAR / MO / DAY ENDING 07 / 09 / 30		STATE CODE: 06	NPDES PERMIT # CA0003751
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 004 OIL & GREASE mg/l GRAB JA/AP/JUL/OCT	EFFLUENT 001 TOX CONCEN TU GRAB JA/AP/JUL/OCT	EFFLUENT 001D CADMIUM ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H CADMIUM ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L CADMIUM ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F CADMIUM ug/l 1 WEEK COMP JA/AP/JUL/OCT	
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
MONTHLY AVG							
MONTHLY HIGH							
MONTHLY LOW							
TIMES EXCEEDED	MO AVG 15 = 0	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT		
TIMES EXCEEDED	D MAX 20 = 0						
TIMES EXCEEDED	6M-MED 0.26=0						

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebek for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 4

FACILITY I.D.		YEAR / MO / DAY BEGINNING 07 / 09 / 01		YEAR / MO / DAY ENDING 07 / 09 / 30		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D CHROMIUM ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H T CHROMIUM ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L T CHROMIUM ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F T CHROMIUM ug/l 1 WEEK COMP JA/AP/JUL/OCT	EFFLUENT 001D COPPER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H COPPER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L COPPER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F COPPER ug/l 1 WEEK COMP JA/AP/JUL/OCT
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG								
MONTHLY HIGH								
MONTHLY LOW								
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT
TIMES EXCEEDED								
TIMES EXCEEDED								

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 5

FACILITY I.D. 3 402003001		YEAR / MO / DAY 07 / 09 / 01		YEAR / MO / DAY 07 / 09 / 30		STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D LEAD ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H LEAD ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L LEAD ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F 1 WEEK COMP JA/AP/JUL/OCT	EFFLUENT 001D LEAD ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H MERCURY ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L MERCURY ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F MERCURY ug/l 1 WEEK COMP JA/AP/JUL/OCT	EFFLUENT 001F MERCURY ug/l 1 WEEK COMP JA/AP/JUL/OCT
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									
MONTHLY AVG									
MONTHLY HIGH									
MONTHLY LOW									
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT
TIMES EXCEEDED									
TIMES EXCEEDED									

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebelfor Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 6

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 09 / 01		YEAR / MO / DAY ENDING 07 / 09 / 30		STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D NICKEL ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H NICKEL ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L NICKEL ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F NICKEL ug/l 1 WEEK COMP JA/AP/JUL/OCT	EFFLUENT 001D SILVER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H SILVER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L SILVER ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F SILVER ug/l 1 WEEK COMP JA/AP/JUL/OCT	
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									
MONTHLY AVG									
MONTHLY HIGH									
MONTHLY LOW									
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	
TIMES EXCEEDED									
TIMES EXCEEDED									

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 7

FACILITY I.D. 3 402003001	YEAR / MO / DAY BEGINNING 07 / 09 / 01	YEAR / MO / DAY ENDING 07 / 09 / 30	STATE CODE 06	NPDES PERMIT # CA0003751
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D ZINC ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001H ZINC ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001L ZINC ug/l QTRLY COMP JA/AP/JUL/OCT	EFFLUENT 001F ZINC ug/l 1 WEEK COMP JA/AP/JUL/OCT
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				
MONTHLY AVG				
MONTHLY HIGH				
MONTHLY LOW				
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT
TIMES EXCEEDED				
TIMES EXCEEDED				

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebelt for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 8

FACILITY I.D.		YEAR / MO / DAY BEGINNING		YEAR / MO / DAY ENDING		STATE CODE	NPDES PERMIT #
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D COPPER mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001F COPPER mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001I COPPER mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001L COPPER mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001M COPPER mg/l 24-HR COMP. METAL CLNG		
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
MONTHLY AVG	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE		
MONTHLY HIGH							
MONTHLY LOW							
TIMES EXCEEDED	MO AVG 1 = 0						
TIMES EXCEEDED	D MAX 1 = 0						
TIMES EXCEEDED							

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebelt for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (Q) 9

FACILITY I.D.		YEAR / MO / DAY BEGINNING		YEAR / MO / DAY ENDING		STATE CODE	NPDES PERMIT #
3 402003001		07 / 09 / 01		07 / 09 / 30		06	CA0003751
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001D IRON mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001F IRON mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001I IRON mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001L IRON mg/l 24-HR COMP. METAL CLNG	EFFLUENT 001M IRON mg/l 24-HR COMP. METAL CLNG		
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
MONTHLY AVG	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE	NO DISCHARGE		
MONTHLY HIGH							
MONTHLY LOW							
TIMES EXCEEDED	MO AVG 1 = 0						
TIMES EXCEEDED	D MAX 1 = 0						
TIMES EXCEEDED							

REMARKS: • NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebely for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (A) 1

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 09 / 01		YEAR / MO / DAY ENDING 07 / 09 / 30		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001 TITANIUM ug/l GRAB OCTOBER	INFLOWNT ARSENIC ug/l GRAB OCTOBER	EFFLUENT ARSENIC ug/l GRAB OCTOBER	INFLOWNT CADMIUM ug/l GRAB OCTOBER	EFFLUENT 001 CADMIUM ug/l GRAB OCTOBER	INFLOWNT LEAD ug/l GRAB OCTOBER	EFFLUENT 001 LEAD ug/l GRAB OCTOBER	INFLOWNT ZINC ug/l GRAB OCTOBER
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								ND(10)
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG								ND(10)
MONTHLY HIGH								ND(10)
MONTHLY LOW								ND(10)
TIMES EXCEEDED	NO LIMIT	NO LIMIT	6M-MED 30 = 0 D MAX 150 = 0 I MAX 400 = 0	NO LIMIT	6M-MED 10 = 0 D MAX 20 = 0 I MAX 50 - 0	NO LIMIT	6M-MED 10 = 0 D MAX 40 = 0 I MAX 100 = 0	NO LIMIT
TIMES EXCEEDED								
TIMES EXCEEDED								

REMARKS:
* NUMBER OF SAMPLES TAKEN DURING THE DAY.
** INFLOWNT ANALYSIS PERFORMED FOR COMPARISON TO EFFLUENTS.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebelt for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (A) 2

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 09 / 01		YEAR / MO / DAY ENDING 07 / 09 / 30		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	INFLUENT MERCURY ug/l GRAB OCTOBER	EFFLUENT 001 MERCURY ug/l GRAB OCTOBER	INFLUENT SILVER ug/l GRAB OCTOBER	EFFLUENT 001 SILVER ug/l GRAB OCTOBER	INFLUENT CYANIDE ug/l GRAB OCTOBER	EFFLUENT 001 CYANIDE ug/l GRAB OCTOBER	INFLUENT PHENOLIC CMP ug/l (NONCL) GRAB OCTOBER	EFFLUENT 001 PHENOLIC CMP ug/l (NONCL) GRAB OCTOBER
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG								
MONTHLY HIGH								
MONTHLY LOW								
TIMES EXCEEDED	NO LIMIT	6M-MED 0.2=0	NO LIMIT	6M-MED 2.9=0	NO LIMIT	6M-MED 30=0	NO LIMIT	6M-MED 150=0
TIMES EXCEEDED		DMAX 0.8 = 0		DMAX 13.6=0		DMAX 100=0		DMAX 610= 0
TIMES EXCEEDED		IMAX 2 = 0		IMAX 35= 0		IMAX 260=0		IMAX 1530=0

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebek for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (A) 3

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 09 / 01		YEAR / MO / DAY ENDING 07 / 09 / 30		STATE CODE 06	NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	INFLOW CHLOR PHENOL ug/l GRAB OCTOBER	EFFLUENT 001 CHLOR PHENOL ug/l GRAB OCTOBER	EFFLUENT 001D LITHIUM mg/l GRAB OCTOBER	EFFLUENT 001D BORON mg/l GRAB OCTOBER	EFFLUENT 001D HYDRAZINE mg/l GRAB OCTOBER	EFFLUENT 005 OIL & GREASE mg/l GRAB OCTOBER	EFFLUENT 008 OIL & GREASE mg/l GRAB OCTOBER	
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
MONTHLY AVG								
MONTHLY HIGH								
MONTHLY LOW								
TIMES EXCEEDED	NO LIMIT	6M-MED 10=0	NO LIMIT	NO LIMIT	NO LIMIT	MO AVG 15=0	MO AVG 15=0	
TIMES EXCEEDED		DMAX 20=0				DMAX 20=0	DMAX 20=0	
TIMES EXCEEDED		IMAX 50=0						

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebek for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (A) 4

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 09 / 01		YEAR / MO / DAY ENDING 07 / 09 / 30		STATE CODE 06	NPDES PERMIT # CA0003751
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 009 OIL & GREASE mg/l GRAB OCTOBER	EFFLUENT 013 OIL & GREASE mg/l GRAB OCTOBER	EFFLUENT 015 OIL & GREASE mg/l GRAB OCTOBER	EFFLUENT 016 OIL & GREASE mg/l GRAB OCTOBER	EFFLUENT 017 OIL & GREASE mg/l GRAB OCTOBER	INFLUENT PCB'S ug/l GRAB OCTOBER	EFFLUENT 001 PCB'S ug/l GRAB OCTOBER
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
MONTHLY AVG							
MONTHLY HIGH							
MONTHLY LOW							
TIMES EXCEEDED	MO AVG 15=0	NO LIMIT	NO LIMIT				
TIMES EXCEEDED	DMAX 20=0						
TIMES EXCEEDED							

REMARKS: NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebello for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (A) 5

FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 09 / 01		YEAR / MO / DAY ENDING 07 / 09 / 30		STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001N SLUDGE MOISTURE % GRAB OCTOBER	EFFLUENT 001N SLUDGE TOT KJLDL N mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE AMMONIA (N) mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE NITRATE (N) mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE TOT PHOSPHS mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE pH pH units GRAB OCTOBER	EFFLUENT 001N SLUDGE OIL & GREASE mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE BORON mg/kg GRAB OCTOBER	
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									
MONTHLY AVG									
MONTHLY HIGH									
MONTHLY LOW									
TIMES EXCEEDED	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	NO LIMIT	
TIMES EXCEEDED									
TIMES EXCEEDED									

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebel for Bryan Cunningham</i>	10/18/2007

CALIFORNIA REGIONAL WATER QUALITY
CONTROL BOARD
CENTRAL COAST REGION
895 AEROVISTA PLACE, SUITE 101
SAN LUIS OBISPO, CA 93401

DISCHARGE SELF MONITORING REPORT

PACIFIC GAS AND ELECTRIC CO.
DIABLO CANYON NUCLEAR POWER PLANT
PO BOX 56
AVILA BEACH, CALIF 93424

PAGE: (A) 6


FACILITY I.D. 3 402003001		YEAR / MO / DAY BEGINNING 07 / 09 / 01		YEAR / MO / DAY ENDING 07 / 09 / 30		STATE CODE 06		NPDES PERMIT # CA0003751	
STATION ANALYSIS UNITS SMPL TYPE FREQ.	EFFLUENT 001N SLUDGE CADMIUM mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE COPPER mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE CHROMIUM mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE LEAD mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE NICKEL mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE MERCURY mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE ZINC mg/kg GRAB OCTOBER	EFFLUENT 001N SLUDGE VOLUME tons OCTOBER	
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									
MONTHLY AVG									
MONTHLY HIGH									
MONTHLY LOW									
TIMES EXCEEDED	10xSTLC=0	10xSTLC=0	10xSTLC=0	10xSTLC=0	10xSTLC=0	10xSTLC=0	10xSTLC=0		
TIMES EXCEEDED	10 mg/kg=0	250 mg/kg=0	50 mg/kg=0	50 mg/kg=0	200 mg/kg=0	2 mg/kg=0	2500 mg/kg=0		
TIMES EXCEEDED	TTLC>100=0	TTLC>2500=0	TTLC>500=0	TTLC>1000=0	TTLC>2000=0	TTLC>20=0	TTLC>5000=0		

REMARKS: * NUMBER OF SAMPLES TAKEN DURING THE DAY.

PRINCIPAL EXECUTIVE OFFICER
JAMES R. BECKER

SIGNATURE OF AUTHORIZED AGENT	DATE
<i>Trevor Rebello for Bryan Cunningham</i>	10/18/2007

APPENDIX 5
DIABLO CANYON POWER PLANT
Acute Bioassay
July 26-30, 2007



ORIGINAL

RECEIVED

OCT 15 2007

ENV. OPS.

TOXICITY TESTING • OCEANOGRAPHIC RESEARCH

August 1, 2007

Ms. Vicki Ziegler
FGL Environmental
P.O. Box 272
Santa Paula, CA 93061

Dear Ms. Ziegler:

We are pleased to present the enclosed bioassay report. The test was conducted under guidelines prescribed in *Guidelines for Performing Static Acute Fish Bioassays in Municipal and Industrial Waste Waters* as provided to us by Frederic R. Kopperdahl, Fish and Wildlife Water Pollution Control Laboratory, Department of Fish and Game. Results were as follows:

CLIENT: FGL Environmental
SAMPLE I.D.: DCPP Discharge 001 Acute
DATE RECEIVED: 25 July - 07
ABC LAB. NO.: FGL0707.134

ACUTE ABALONE SURVIVAL BIOASSAY

LC50 = 100 % Survival in 100 % Sample
TUA = 0.00

Yours very truly,

Thomas (Tim) Mikel
Laboratory Director

-96 Hr Survival

Start Date: 7/26/2007 Test ID: FGL0707134 Sample ID: CA0000000
 End Date: 7/30/2007 Lab ID: CAABC Sample Type: EFF3-Power Plant
 Sample Date: 7/25/2007 Protocol: KOP 76-Kopperdahl Test Species: HR-Haliotis rufescens
 Comments: DCPP Discharge 001 Acute (708300)

Conc-%	1	2
N Control	1.0000	1.0000
100	1.0000	1.0000

Transform: Arcsin Square Root

Conc-%	Mean	N-Mean	Isotonic					Mean	N-Mean
			Mean	Min	Max	CV%	N		
N Control	1.0000	1.0000	1.4120	1.4120	1.4120	0.000	2	1.0000	1.0000
100	1.0000	1.0000	1.4120	1.4120	1.4120	0.000	2	1.0000	1.0000


Auxiliary Tests**Statistic****Critical****Skew****Kurt**

Normality of the data set cannot be confirmed

Equality of variance cannot be confirmed

Linear Interpolation (200 Resamples)


Point	%	SD	95% CL(Exp)	Skew
IC05	>100			
IC10	>100			
IC15	>100			
IC20	>100			
IC25	>100			
IC40	>100			
IC50	>100			



-96 Hr Survival

Start Date:	7/26/2007	Test ID:	FGL0707134	Sample ID:	CA0000000
End Date:	7/30/2007	Lab ID:	CAABC	Sample Type:	EFF3-Power Plant
Sample Date:	7/25/2007	Protocol:	KOP 76-Kopperdahl	Test Species:	HR-Haliotis rufescens
Comments:	DCPP Discharge 001 Acute (708300)				

Dose-Response Plot



-96 Hr Survival

Start Date: 7/26/2007 Test ID: FGL0707134 Sample ID: CA0000000
 End Date: 7/30/2007 Lab ID: CAABC Sample Type: EFF3-Power Plant
 Sample Date: 7/25/2007 Protocol: KOP 76-Kopperdahl Test Species: HR-Haliotis rufescens
 Comments: DCPP Discharge 001 Acute (708300)

Auxiliary Data Summary

Conc-%	Parameter	Mean	Min	Max	SD	CV%	N
N Control	Temp C	14.27	14.00	15.30	0.54	5.17	10
		14.12	14.00	14.50	0.20	3.20	10
100	pH	7.84	7.80	8.00	0.07	3.37	10
		7.78	7.70	7.80	0.04	2.64	10
N Control	DO mg/L	7.42	7.00	7.60	0.23	6.53	10
		7.57	7.30	7.70	0.16	5.34	10
100	Salinity ppt	34.00	34.00	34.00	0.00	0.00	10
		35.00	35.00	35.00	0.00	0.00	10
N Control		0.00	0.00	0.00	0.00	0.00	0
		0.00	0.00	0.00	0.00	0.00	0
100		0.00	0.00	0.00	0.00	0.00	0
		0.00	0.00	0.00	0.00	0.00	0
N Control		0.00	0.00	0.00	0.00	0.00	0
		0.00	0.00	0.00	0.00	0.00	0
100		0.00	0.00	0.00	0.00	0.00	0



Subcontract Chain of Custody

CLIENT DETAILS:

Phone: Santa Paula, CA 93060 (805) 659-0910 Fax: (805) 525-4172
Project: 7-110 Contact Person:

Project: 703300

Digitized by srujanika@gmail.com

REPORT INFORMATION:

Rush Analysis: 5 days 4 days 3 days 2 days 24 hours

Electronic Data Transfer: YES / NO

If yes, To: State Client Other _____

REMARKS:

SAMPLING:

Sampler(s)

Larry

CUSTODY:

Relinquished by:

Date: 7/25/07

Time: 1545

Relinquished by:

Date: _____ Time: _____

Time:

• 111

~~5~~ *Shahrukh*)

Date: 1/1


Time: 1-145

Received by:

APPENDIX 6
DIABLO CANYON POWER PLANT
Chronic Bioassay
July 26-28, 2007



ORIGINAL



TOXICITY TESTING • OCEANOGRAPHIC RESEARCH

August 1, 2007

Ms. Vicki Ziegler
FGL Environmental
P.O. Box 272
Santa Paula, CA 93060

Dear Ms. Ziegler:

We are pleased to present the enclosed bioassay report. The test was conducted under guidelines prescribed in *Short-Term Methods for Measuring the Chronic Toxicity of Effluents and Receiving Waters to West Coast Marine and Estuarine Organisms, EPA-R-95/136*. Results were as follows:


CLIENT: FGL Environmental
SAMPLE I.D.: DCPP Discharge 001 Chronic
DATE RECEIVED: 25 July - 07
ABC LAB. NO.: FGL0707.135

CHRONIC ABALONE LARVAL DEVELOPMENT BIOASSAY

NOEC = 100.00 %
TUC = 1.00

IC25 = >100.00 %
IC50 = >100.00 %

Yours very truly,


Thomas (Tim) Mikel
Laboratory Director

Absolute Larval Development Test-Proportion No.

Start Date: 7/26/2007 Test ID: FGL0707135 Sample ID: CA0000000
 End Date: 7/28/2007 Lab ID: CAABC Sample Type: EFF1-POTW
 Sample Date: 7/25/2007 Protocol: MBP 90-Anderson et al. Test Species: HR-Haliotis rufescens
 Comments: DCPP Discharge 001 Chronic (708300)

Conc-%	1	2	3	4	5
N Control	1.0000	1.0000	1.0000	1.0000	1.0000
10	1.0000	1.0000	1.0000	1.0000	1.0000
18	1.0000	1.0000	1.0000	1.0000	1.0000
32	1.0000	1.0000	1.0000	1.0000	1.0000
56	1.0000	1.0000	1.0000	1.0000	1.0000
100	1.0000	1.0000	1.0000	1.0000	1.0000

Conc-%	Transform: Arcsin Square Root						Rank	1-Tailed	Isotonic			
	Mean	N-Mean	Mean	Min	Max	CV%			Sum	Critical	Mean	N-Mean
N Control	1.0000	1.0000	1.5208	1.5208	1.5208	0.000	5				1.0000	1.0000
10	1.0000	1.0000	1.5208	1.5208	1.5208	0.000	5	27.50	16.00		1.0000	1.0000
18	1.0000	1.0000	1.5208	1.5208	1.5208	0.000	5	27.50	16.00		1.0000	1.0000
32	1.0000	1.0000	1.5208	1.5208	1.5208	0.000	5	27.50	16.00		1.0000	1.0000
56	1.0000	1.0000	1.5208	1.5208	1.5208	0.000	5	27.50	16.00		1.0000	1.0000
100	1.0000	1.0000	1.5208	1.5208	1.5208	0.000	5	27.50	16.00		1.0000	1.0000

Auxiliary Tests

Shapiro-Wilk's Test indicates normal distribution ($p > 0.01$) Statistic 1 Critical 0.9

Equality of variance cannot be confirmed


Hypothesis Test (1-tail, 0.05) NOEC LOEC ChV TU

Steel's Many-One Rank Test 100 >100 1

Treatments vs N Control

Linear Interpolation (200 Resamples)


Point	%	SD	95% CL(Exp)	Skew
IC05	>100			
IC10	>100			
IC15	>100			
IC20	>100			
IC25	>100			
IC40	>100			
IC50	>100			



Abalone Larval Development Test-Proportion Normal

Start Date: 7/26/2007 Test ID: FGL0707135 Sample ID: CA0000000
End Date: 7/28/2007 Lab ID: CAABC Sample Type: EFF1-POTW
Sample Date: 7/25/2007 Protocol: MBP 90-Anderson et al. Test Species: HR-Haliotis rufescens
Comments: DCPP Discharge 001 Chronic (708300)

Dose-Response Plot



Abalone Larval Development Test-Proportion No.

Start Date: 7/26/2007 Test ID: FGL0707135 Sample ID: CA0000000
 End Date: 7/28/2007 Lab ID: CAABC Sample Type: EFF1-POTW
 Sample Date: 7/25/2007 Protocol: MBP 90-Anderson et al. Test Species: HR-Haliotis rufescens
 Comments: DCPP Discharge 001 Chronic (708300)

Conc-%	Parameter	Auxiliary Data Summary					
		Mean	Min	Max	SD	CV%	N
N Control	Temp C	15.55	15.50	15.60	0.07	1.71	2
10		15.55	15.50	15.60	0.07	1.71	2
18		15.55	15.50	15.60	0.07	1.71	2
32		15.55	15.50	15.60	0.07	1.71	2
56		15.55	15.50	15.60	0.07	1.71	2
100		15.55	15.50	15.60	0.07	1.71	2
N Control	pH	7.65	7.60	7.70	0.07	3.48	2
10		7.60	7.50	7.70	0.14	4.95	2
18		7.60	7.50	7.70	0.14	4.95	2
32		7.60	7.50	7.70	0.14	4.95	2
56		7.60	7.50	7.70	0.14	4.95	2
100		7.70	7.70	7.70	0.00	0.00	2
N Control	DO mg/L	6.05	4.20	7.90	2.62	26.74	2
10		6.15	4.40	7.90	2.47	25.58	2
18		6.15	4.40	7.90	2.47	25.58	2
32		6.00	4.10	7.90	2.69	27.32	2
56		6.05	4.10	8.00	2.76	27.45	2
100		6.20	4.30	8.10	2.69	26.44	2
N Control	Salinity ppt	34.00	34.00	34.00	0.00	0.00	2
10		34.00	34.00	34.00	0.00	0.00	2
18		34.00	34.00	34.00	0.00	0.00	2
32		34.00	34.00	34.00	0.00	0.00	2
56		34.00	34.00	34.00	0.00	0.00	2
100		34.00	34.00	34.00	0.00	0.00	2



ORIGINAL

RECEIVED
OCT 15 2007
ENV. OPS.

TOXICITY TESTING • OCEANOGRAPHIC RESEARCH

CHRONIC ABALONE DEVELOPMENT BIOASSAY

DATE: 26 July - 07


STANDARD TOXICANT: Zinc

NOEC = 56.00 ug/l

IC25 = 67.00 ug/l

IC50 = 78.00 ug/l

Yours very truly,


Thomas (Tim) Mikel
Laboratory Director

All Larval Development Test-Proportion No.							
Start Date:	7/26/2007	Test ID:	ABS072607	Sample ID:	REF-Ref Toxicant		
End Date:	7/28/2007	Lab ID:	ABC LABS	Sample Type:	ZNSO-Zinc sulfate		
Sample Date:	7/26/2007	Protocol:	MBP 90-Anderson et al.	Test Species:	HR-Haliotis rufescens		
Comments:	Standard Toxicant						


Conc-ug/L	1	2	3	4	5
Control	1.0000	1.0000	1.0000	1.0000	1.0000
18	1.0000	1.0000	1.0000	1.0000	1.0000
32	1.0000	1.0000	1.0000	1.0000	1.0000
56	1.0000	1.0000	1.0000	1.0000	1.0000
100	0.0000	0.0000	0.0000	0.0000	0.0000
180	0.0000	0.0000	0.0000	0.0000	0.0000

Conc-ug/L	Transform: Arcsin Square Root						Rank Sum	1-Tailed Critical	Isotonic		
	Mean	N-Mean	Mean	Min	Max	CV%			Mean	N-Mean	
Control	1.0000	1.0000	1.5208	1.5208	1.5208	0.000	5		1.0000	1.0000	
18	1.0000	1.0000	1.5208	1.5208	1.5208	0.000	5	27.50	17.00	1.0000	1.0000
32	1.0000	1.0000	1.5208	1.5208	1.5208	0.000	5	27.50	17.00	1.0000	1.0000
56	1.0000	1.0000	1.5208	1.5208	1.5208	0.000	5	27.50	17.00	1.0000	1.0000
100	0.0000	0.0000	0.0500	0.0500	0.0500	0.000	5		0.0000	0.0000	
180	0.0000	0.0000	0.0500	0.0500	0.0500	0.000	5		0.0000	0.0000	

Auxiliary Tests	Statistic	Critical	Skew	Kurt
Shapiro-Wilk's Test indicates normal distribution ($p > 0.01$)	1	0.868		
Equality of variance cannot be confirmed				
Hypothesis Test (1-tail, 0.05)	NOEC	LOEC	ChV	TU
Steel's Many-One Rank Test	56	100	74.8331	


Treatments vs Control

Linear Interpolation (200 Resamples)				
Point	ug/L	SD	95% CL(Exp)	Skew
IC05	58.200	0.000	58.200	-1.0076
IC10	60.400	0.000	60.400	1.0076
IC15	62.600	0.000	62.600	-1.0076
IC20	64.800	0.000	64.800	1.0076
IC25	67.000	0.000	67.000	#DIV/0!
IC40	73.600	0.000	73.600	-1.0076
IC50	78.000	0.000	78.000	#DIV/0!



All One Larval Development Test-Proportion Normal			
Start Date:	7/26/2007	Test ID:	ABS072607
End Date:	7/28/2007	Lab ID:	ABC LABS
Sample Date:	7/26/2007	Protocol:	MBP 90-Anderson et al.
Comments:	Standard Toxicant	Sample ID:	REF-Ref Toxicant
		Sample Type:	ZNSO-Zinc sulfate
		Test Species:	HR-Haliotis rufescens

Dose-Response Plot



A. One Larval Development Test-Proportion Normal								
Start Date:	7/26/2007	Test ID:	ABS072607	Sample ID:	REF-Ref Toxicant			
End Date:	7/28/2007	Lab ID:	ABC LABS	Sample Type:	ZNSO-Zinc sulfate			
Sample Date:	7/26/2007	Protocol:	MBP 90-Anderson et al.		Test Species:	HR-Haliotis rufescens		
Comments:	Standard Toxicant							
Auxiliary Data Summary								
Conc-ug/L	Parameter	Mean	Min	Max	SD	CV%		
Control	Temp C	15.55	15.50	15.60	0.07	1.71		
18		15.55	15.50	15.60	0.07	1.71		
32		15.55	15.50	15.60	0.07	1.71		
56		15.55	15.50	15.60	0.07	1.71		
100		15.55	15.50	15.60	0.07	1.71		
180		15.55	15.50	15.60	0.07	1.71		
Control	pH	7.65	7.60	7.70	0.07	3.48		
18		7.65	7.60	7.70	0.07	3.48		
32		7.65	7.60	7.70	0.07	3.48		
56		7.65	7.60	7.70	0.07	3.48		
100		7.65	7.60	7.70	0.07	3.48		
180		7.65	7.60	7.70	0.07	3.48		
Control	DO mg/L	6.05	4.20	7.90	2.62	26.74		
18		6.00	4.10	7.90	2.69	27.32		
32		6.00	4.10	7.90	2.69	27.32		
56		6.00	4.10	7.90	2.69	27.32		
100		6.00	4.10	7.90	2.69	27.32		
180		6.00	4.10	7.90	2.69	27.32		
Control	Salinity ppt	34.00	34.00	34.00	0.00	0.00		
18		34.00	34.00	34.00	0.00	0.00		
32		34.00	34.00	34.00	0.00	0.00		
56		34.00	34.00	34.00	0.00	0.00		
100		34.00	34.00	34.00	0.00	0.00		
180		34.00	34.00	34.00	0.00	0.00		



Subcontract Chain of Custody

CLIENT DETAILS:

Client: FGL Environmental
Address: 853 Corporation Street
Santa Paula, CA 93061

Phone: (805) 659-0910 Fax: (805) 525-4172
Project: 716300 Contact Person:

Project _____ 100% _____

REPORT INFORMATION:

Rush Analysis: 5 days 4 days 3 days 2 days 24 hours

Electronic Data Transfer: YES / NO

If yes, To: State _____ Client _____ Other _____

REMARKS:

SAMPLING:

Sampler(

(3) LARRY

CUSTODY:

Relinquished by

Received by

Date: 7/25/07

Date: 1/2

Time: 1545

Time: 1545

Relinquished by:

Received by:

Date: _____ Time: _____

Date: _____ Time: _____

Temp. @ 17.2°C