



**DEPARTMENT OF VETERANS AFFAIRS**  
**Veterans Health Administration**  
**National Health Physics Program**  
**2200 Fort Roots Drive**  
**North Little Rock, AR 72114**

OCT 22 2007

In Reply Refer To: 598/115HP/NLR

Cassandra F. Frazier  
Division of Nuclear Material Safety  
Nuclear Regulatory Commission (NRC), Region III  
2443 Warrenville Road, Suite 210  
Lisle, Illinois 60532-4352

Dear Ms. Frazier:

In reference to NRC License 03-23853-01VA, we are enclosing closeout survey documentation related to Building 72 at the VA Medical Center, Hampton, Virginia, for your review. Principal activities under the license have ceased in this building; therefore, we are requesting that Building 72 be released for unrestricted use.

As supporting information for review and approval of this request, we enclose the following documents:

- Enclosure 1 Historical Site Assessment and Final Status Survey Report for the Veterans Administration Facility, Building 72, in Hampton Virginia
- Enclosure 2 Additional Information Provided by the Permittee to the National Health Physics Program (NHPP)
- Enclosure 3 Annotated Versions of Attachments 5.0 and 7.0 of Enclosure 1 to This Letter
- Enclosure 4 Additional Comments on Enclosure 1 by NHPP Reviewer with Permittee Responses
- Enclosure 5 Additional Facility Details


RECEIVED OCT 25 2007

Page 2

We believe these documents provide information consistent with 10 CFR 30.36 criteria to evaluate this separate building for a decommissioning action, and we conclude that the survey results and assessment comply with the radiological dose criteria in 10 CFR 20.1402 for an unrestricted release.

If you have any questions or comments, please contact Thomas E. Huston, Ph.D., VHA National Health Physics Program, at (501) 257-1578.

Sincerely,

  
E. Lynn McGuire  
Director, National Health Physics Program

Enclosures

Area Classification: 3  
 Building/Area: Room 108  
 Floor/Elevation: Floor  
 Survey Unit/Grid: Bathroom/shower  
 Surface: ceramic tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	30	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
ceramic tile β floor	1.24k cpm	2.48k cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 1.41k cpm  
 Smears taken - see map for location  
 12C on sink and 13C on floor of shower - No positive activity detected


**Comments:**

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document

Technician/Surveyor: Byron Bland *Byron Bland* Date: 4/11/2007  
 Name Signature  
 Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W. Moon* Date: 4/11/2007  
 Name Signature

Room  
107





Area Classification: 3  
 Building/Area: Room 107  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: ceramic tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	35%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
ceramic tile β floor	1.24k cpm	2.48k cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 1.41k cpm  
 Smears taken - see map for location  
 14C on floor - No positive activity detected

No activity found in excess of the RG 1.86 (1974) clean-up guidelines


**Attach survey map to this document**

Technician/Surveyor: Byron Bland *Byron Bland*  
 Name Signature

Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W Moon*  
 Name Signature

Date: 4/11/2007



**Survey Requirements**

Area Classification: 3  
 Building/Area: Room 105  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	30%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile	618 cpm	1236 cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift

**Comments:**


Highest scan level seen in this room was 729 cpm  
 Smears taken - see map for location  
 6C through 9C on floor and 5C on floor drain - No positive activity detected

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

**Attach survey map to this document**

Technician/Surveyor: Byron Bland *Byron Bland* Date: 4/11/2007  
 Name Signature  
 Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W. Moon* Date: 4/11/2007  
 Name Signature

Sink in room 104



Area Classification: 3  
 Building/Area: Room 104  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: ceramic tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	25%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
ceramic tile β floor	1.24k cpm	2.48k cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift

**Comments:**


Highest scan level seen in this room was 1.58k cpm  
 Smears taken - see map for location  
 99B on floor - No positive activity detected  
 Initial survey 30C in sink drain - positive activity detected at 226 dpm/100 cm<sup>2</sup> H-3 and 195 dpm/100 cm<sup>2</sup> C-14  
 Follow-up Investigational survey of sink (39C through 42C) - No positive activity detected 3-24-07


No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document


Technician/Surveyor: Byron Bland *Byron Bland* Date: 4/11/2007  
 Name Signature  
 Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W. Moon* Date: 4/11/2007  
 Name Signature

# Room 104





*Room 128*





Area Classification: 3  
 Building/Area: Room 128 & 103  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: ceramic tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	30%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
ceramic tile β floor	1.24k cpm	2.48k cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 1.69k cpm  
 Smears taken - see map for location  
 46B through 53B, 57B & 58B - No positive activity detected  
 Floor Drains 59B & 60B - No positive activity detected

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document

Technician/Surveyor: Byron Bland  
 Name


*Byron Bland*  
 Signature

Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP  
 Name

*Joseph W. Moon*  
 Signature

Date: 4/11/2007



Room 102

Area Classification: 3  
 Building/Area: Room 102  
 Floor/Elevation: Floor  
 Survey Unit/Grid: Utility Room  
 Surface: sealed concrete  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	35%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
sealed concrete	929 cpm	1.86k cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 872 cpm  
 Smears taken - see map for location  
 69B & 72B on floor - No positive activity detected  
 66B in sink drain - No positive activity detected

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

**Attach survey map to this document**

Technician/Surveyor: Byron Bland  
 Name

*Byron Bland*  
 Signature


Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP  
 Name

*Joseph W. Moon*  
 Signature

Date: 4/11/2007

# Room 101



Area Classification: 3  
 Building/Area: Room 101  
 Floor/Elevation: Floor  
 Survey Unit/Grid: Feed Room  
 Surface: sealed concrete  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	30%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
sealed concrete	929 cpm	1.86k cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 1.0k cpm  
 Smears taken - see map for location  
 64B on floor and 62B on floor drain - No positive activity detected

**Comments:**

No activity found in excess of the RG 1.86 (1974) clean-up guidelines


**Attach survey map to this document**

Technician/Surveyor: Byron Bland *Byron Bland*  
 Name Signature

Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W Moon*  
 Name Signature

Date: 4/11/2007



Room 100

Area Classification: 3  
 Building/Area: Room 100  
 Floor/Elevation: Floor  
 Survey Unit/Grid: Autoclave Room  
 Surface: sealed concrete  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	30%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
sealed concrete	929 cpm	1.86k cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 1.1k cpm  
 Smears taken - see map for location  
 63B on floor and 61B on floor drain - No positive activity detected

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

**Attach survey map to this document**

Technician/Surveyor: Byron Bland *Byron Bland*  
 Name Signature

Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W Moon*  
 Name Signature

Date: 4/11/2007

Final 8/13/2007

**Attachment 1**  
**Individual Survey Area Results and Maps**



**Historical Site Assessment and Final Status Survey Report  
for the Veterans Administration Facility  
Building 72 in Hampton, Virginia**

**1.0 Historical Site Assessment**

The Hampton, Virginia Veterans Administration is the fourth oldest facility in the VA health care system, established just after the Civil War (in 1870) as a National Home for Volunteer Soldiers and Sailors. Building 72 was added to the facility in 1908 and was originally used as Dining Room for soldiers.

The first recorded use of radioactive materials at the Hampton, Virginia facility in 1961 was conducted under the authority of the Atomic Energy Commission (AEC). Under the Atomic Energy Act of 1954, the AEC had responsibility for the development and production of nuclear weapons and for both the development and the safety regulation of the civilian uses of nuclear materials. The Energy Reorganization Act of 1974 split these functions, assigning to one agency, now the Department of Energy, the responsibility for the development and production of nuclear weapons, promotion of nuclear power, and other energy-related work, and established the Nuclear Regulatory Commission for regulation of the civilian uses of nuclear materials. Over the next few years, the NRC developed its system of licensing and assumed regulatory authority over the research activities conducted by the Veterans Administration (VA). Materials Permits at the various VA facilities were organized under a single Broad Scope NRC License which is now administered from the North Little Rock, Arkansas VA facility.

The use of radioactive materials at the Hampton, Virginia facility has since been conducted under the authority of Materials Permit # 45-07569-01 now in its 82<sup>nd</sup> amended form.

**1.1 Building Description**

Building 72 was converted into a research building in 1974. The East end of the building is a single floor brick enclosure with an extensive wooden frame attic space capped with a slate roof and underlain by a dirt floor crawl space about three feet in height. This section of the building (presumably the former main dining hall) consists of laboratory facilities, administrative office spaces and a library. Fume hoods in the laboratory spaces are operated under a negative pressure gradient and generally are found to be filtered prior to entering the attic space. The fume hoods are exhausted through independent ventilation ducts/fan housings to the exterior of the roofing material. Sinks in the laboratories in this section of the building are drained to the crawl space area with piping typical of laboratory settings where corrosive materials are utilized and are often composed of lead. A system of floor drains was also installed in the laboratory spaces which drain to the crawl space area. There does not appear to be any type of hold-up tank system for the general neutralization of laboratory liquid wastes or the monitoring of hazardous liquid discharge. The liquid effluents of the building discharge to the sanitary sewerage system. The flooring is generally composed of a wood overlain by linoleum tiling in the halls and laboratory spaces and medium duty wall to wall carpeting in office and library spaces.

The West end of Building 72 (presumably the former kitchen and clean-up areas) is also a single floor brick enclosure but with a less expansive attic space. Several areas of the west end of the building appear to be additions of considerable age. This end of the building is underlain

by a cellar space of approximately five feet in height that houses the major utility equipment. This cellar space has recently been remediated for asbestos insulation on the piping and a low density concrete floor was poured over the original cellar floor surface. Access to the crawl space under the east end of the building (an opening of approximately 2.5 x 3 feet) is located here on the east wall of the cellar under the west end of the building. The flooring of the west end of the building is a mixture of ceramic tile, linoleum tiles, and a plastiform and/or linoleum sheeting applied over concrete or wooden substrate. The rooms in the west end of the building appear to have been designed to house animal studies, and consist of a series of wards and laboratories and support rooms containing incubators and sterilization chambers as well as bathroom facilities. The central area of the west end of the building appears to be composed of a series of isolation chambers/rooms connected to a common hallway with an adjacent decontamination room containing a large walk-in washdown chamber and laboratory complex.

An elevated enclosed wooden platform along the south side of the east end of Building 72 accessed by the main central hallway appears to have been the radioactive waste storage and processing area for the building. The far western end of this platform was isolated from the remainder of the platform and was apparently the location of a fire in the building. From the exterior, burned areas of the wooden siding surrounding a ventilation fan housing were observed and the view through a small window though obscured indicated that the space contained rubble scattered upon the floor. This space had no apparent access and was not able to be entered. A similar elevated enclosed wooden platform on the northern side of the east end of Building 72 connects to an adjacent larger building of unknown usage to the north.

A current floor plan of Building 72 was obtained from the Engineering Department of the Hampton, Virginia VA facility and a request was made for any existing maintenance or filter media change out frequencies or historical information concerning the fume hoods in Building 72.

## 1.2 Findings: Historical Usage of Radioactive Materials in Building 72

It is presumed that radioactive materials were not introduced to Building 72 until after the conversion of the building to a research facility in 1974. [Specific information on the applications for amendment to Materials Permit # 45-07569-01 which may help refine this information has been requested from the broad License administrator and is forthcoming.]

An interview with the current Radiation Safety Officer, Dr. Tapan K. Chaudhuri, was conducted on February 22, 2007. Dr. Chaudhuri provided a copy of the current Material Permit (Amendment 82) as well as copies of a series of *Health Physicist Assessments* spanning the time frame between 1998 and 2001 for review as documentation of the activities in Building 72 involving the use of radioactive material. These reports appear to be quarterly summaries of the activities of researchers in Building 72 by the Health and Safety staff of the Hampton VA facility. The reports were submitted to the facility Radiation Safety Officer for review. Each report would detail the active authorized users, the status of the building radioactive source inventory (including any additions or disposals) and whether any iodinations had been performed during the quarter by the researchers. Dr. Chaudhuri also provided a comprehensive list of authorized users of radioactive materials in Building 72 and the radionuclides which they were authorized to utilize in their studies and which radionuclides were actually used by these individuals. This list is reproduced below:

Researchers:

Richard Atkinson, M.D. – 12/1/86-11/27/93 – used H-3  
Paul Aravich, Ph.D. – 7/1/87 -4/8/90- used I-125  
Thomas Lauterio, Ph.D. – 4/8/90 – 1/8/94. used I-131, H-3.  
Jerome Seyer Ph.D., 7/21/96 – 10/30/04, used H-3, S-35, P-32.  
Steven Gentry, M.D. – 1991-1995, used H-3.

This list was compared to the current Materials Permit, the information contained in the quarterly assessment reports reviewed and a physical inspection of Building 72 with the following items being noted:

- The current Materials Permit lists these specific radionuclides under section 6 E through J as "storage only pending disposal and decommissioning", but also lists item 6 F as carbon-14 which is not cited on the list above as a radionuclide used in Building 72. Dr. Chaudhuri was asked about the usage of C-14 in Building 72 when a note in the Health Physics Assessment for the first quarter of 2001 mentioned a pick-up by a disposal company of 5 barrels of radioactive trash labeled as tritium (H-3) and Carbon-14. Dr. Chaudhuri reaffirmed that he had no knowledge of any historical usage of Carbon-14 by any of the researchers in Building 72.
- Laboratory and/or office spaces in the east end of Building 72 are labeled with some of these researchers names and radioactive material labels on fume hoods, drawers; and storage spaces within these laboratories are generally consistent with this usage. Some lead pig type casks in room 113D and the 2" lead bricks located in both rooms 113c and 113D are more commonly used to store/transport/shield high energy gamma emitting radionuclides but most likely were used to shield the often significant bremsstrahlung radiations coincident to common usage of phosphorus-32. One small container in room 113C was labeled as having contained manganese-54 but may have been transferred to Building 72 solely as a lead container after the Mn-54 was removed
- No overt evidence of historical usage of radioactive materials was found in the west end of Building 72 (beyond the double door access which separate the two sections of the building) in the form of radioactive material labels, shielding materials, equipment or laboratory notes within the rooms. This is consistent with anecdotal information concerning the building
- Although it is clear that monthly radioactive material inventory logs were kept for Building 72, these logs were not available for review nor were they located during visual inspections of any of the rooms. From the information contained in the summary quarterly *Health Physics Assessment* reports, the tracking of reduction of radioactive material inventory by decay in storage was not implemented over the period of usage.
- The types and quantities of loose radioactive material used in the building with the exception of tritium (H-3) were of relatively short half-life and mostly disposed of during a clean-up evolution in the first quarter of 2001, which was the last recorded documentation of usage and disposal in the building. The sealed sources that were present in the building (I-129, Cs-137 and Ni-63 rod or calibration/check sources) were either disposed of at that time or subsequently transferred to the inventory of the main hospital building and nuclear medicine laboratory (Eu-152 source).

- The last quarterly *Health Physics Assessment* report available for review (dated September 18, 2001) was still listing 180  $\mu\text{Ci}$  of H-3 and an undetermined, but minor, quantity of Sulfur-35, as well as noting the presence of a Cs-137 sealed check source in the building but exempt from inclusion on the formal inventory. The previous quarterly *Health Physics Assessment* report (dated July 12, 2001) noted that this material was scheduled to be disposed of in October of 2001.
- No waste disposal manifests were available for review but their existence is inferred from statements on the last quarterly *Health Physics Assessment* report (dated September 18, 2001). The last manifest noted was dated 2/12/01 (Manifest 01311) and listed three entries of H-3 waste in the amount of 37mBq each.
- The waste processing area on the elevated enclosed wooden platform on the south side of the East end of Building 72 was populated with various containers for the storage of red bag waste as well as an open 30 gallon drum half full of liquid (presumably mop water from rad labs) and some empty and unassembled cardboard boxes (with mold infestation) labeled for use as radioactive material. A container of absorbent material was also found.
- The sink in room 113D was taped over and noted to be "out of service-do not use" due to a broken drain line. The cabinet below the sink was open and contained approximately  $\frac{1}{2}$  inch of liquid covering the floor space of the cabinet. There was also evidence that the floor may have been coated with a water resistant barrier at some point (although it appeared well degraded). A bottle of "Isoclean" was also on the floor of this cabinet and presumably the liquid resident in the space.

### 1.3 Conclusions

Based on the identified past usage and documented inventory, the presence of remaining and residual radioactive material was expected to be minimal in Building 72. The activity, if present, should have been confined to the east end of the Building 72 and located primarily as tritium residue on laboratory surfaces. These surfaces include, but are not limited to, refrigerator and fume hood floors, fume hood filtration media, radioactive material storage drawer in room 113C, and the sink bowls and drains utilized for disposal of radioactive materials by discharge to the sanitary sewerage system (as noted in quarterly *Health Physics Assessment* reports). The possibility of contamination in the decontamination liquid residue found under the broken sink in room 113D and in the radioactive material labeled drum in the waste processing area was considered because of general nature and location.

On the basis of the radioactive materials authorized for use at the facility, carbon-14 and tritium were the only two radionuclides that were considered as potential contaminants. All other listed authorized radionuclides have short half-lives and will have decayed away to undetectable levels as of March of 2007.

In consideration of the nature of the materials observed in the laboratories of room 113 (lead container marked Mn-54) and two inch lead blocks spread about the lab, a cursory survey for the presence of gamma emitting radionuclides was also considered prudent.

## 2.0 Final Status Survey Design

### 2.1 Radiological Hazard Assessment and Survey Strategy

Based on the conclusions of the Historical Site Assessment, the Final Status Survey (FSS) of Building 72 focused on the detection of tritium (H-3) and carbon-14 (C-14) contamination on surfaces and floors of the specific laboratories, where radioactive materials were known to have been used. These areas, for the purpose of this survey were subjected to a rigorous evaluation with 100% of the accessible floor areas and horizontal surfaces being assessed for residual contamination. Other areas were evaluated under a graded approach, consistent with MARSSIM guidance. Accessible floor areas were surveyed with a 20% or greater coverage of total floor area and biased sampling was conducted targeting floor drains and sink drains.

Smear surveys for loose surface contamination were conducted in each room of the facility for the initial survey. The initial surveys represented wide area smears to determine the general presence of non-fixed surface contamination. Should any transferable surface contamination be detected, a second series of smear surveys were conducted as an investigatory process to determine the actual levels of transferable contamination in units appropriate to comparison with the clean-up standard.

### 2.2 Site Clean-up Criteria

For the release of this facility, the approach was no detectable levels of residual contamination using past acceptance criteria for unrestricted release as found in U.S. NRC Regulatory Guide 1.86 (See Attachment 2). The applicable criterion is set forth in Table 1 "Acceptable Surface Contamination Levels" of this Guide. Specifically, for the radionuclides of concern (C-14 and H-3), these criteria are those listed for beta-gamma emitters. The criterion is 5000 dpm/100cm<sup>2</sup> averaged over no more than 1 square meter with no area in excess of 15,000 dpm/100cm<sup>2</sup>. In addition, no area may contain removable contamination in excess of 1000 dpm/100cm<sup>2</sup> as determined by dry smear count evaluated over no more than 100 cm<sup>2</sup>.

### 2.3 Survey Instrumentation

Thin windowed portable gas flow proportional counters were selected for the floor and horizontal surface assessment. The proportional detectors are of two different sizes, a large area probe (771 cm<sup>2</sup>) used in conjunction with a scanning floor monitor unit which scans at a fixed rate of approximately 2.5 inches/second and a hand held probe of an area more appropriate to direct comparisons with the clean-up standard (126 cm<sup>2</sup>). If contamination is detected with the floor monitoring unit, the smaller probe will be used to evaluate the contamination levels for comparison with the clean-up criterion.

Specifically, the two proportional counters used are:

Ludlum Model 43-37-1 gas flow proportional detector (SN PR145081) 771 cm<sup>2</sup> thin window (8 mg/cm<sup>2</sup> mylar) coupled with a Ludlum Model 2350-1 (SN 129408) data logger, and

Ludlum Model 43-68 gas flow proportional detector (SN PR148454) 126 cm<sup>2</sup> thin window (8 mg/cm<sup>2</sup> mylar) coupled with a Ludlum Model 2350-1 (SN 129408) data logger

This type of detector is particularly sensitive to pure beta emitting radionuclides such as C-14. These detectors were calibrated and efficiencies established for C-14 at around 18% (See Attachment 3). This type of detector is not particularly sensitive to H-3 due to the very low energy beta emission. Essentially, beta particles from H-3 cannot penetrate even the thin window of these detectors. Therefore, the monitoring for H-3 contamination was performed by smear survey evaluation. While it is possible for H-3 to be present as fixed contamination on surfaces, the mobile nature of this radionuclide makes it also most likely that a fraction will also be present as non-fixed and available for smear survey identification. A liquid scintillation counter was utilized for the evaluation of the smear sample media by a qualified independent vendor service.

The smears utilized for the survey were the special type which dissolves completely into the liquid scintillation cocktail so that light transmission is not impaired in the counting vials by the smear media. The smears were evaluated at three energy bands corresponding to the energies of the radionuclides of concern -- a low energy band for H-3, mid-energy for C-14/S-35, and an upper energy band for P-32 and other radionuclides, which would include common beta/gamma emitting radionuclides. In addition to liquid scintillation counting of smears, a general area survey for gamma emitting radionuclides was conducted using a 1" x 1" NaI(Tl) detector.

## 2.4 Evaluations

Background levels and check source response were verified prior to the commencement of surface monitoring or surveying and periodically during the evaluation period as well as at the completion of daily activities to assure that the instruments were performing with the efficiency determined during calibration. Background measurements for the various types of media present were established so that appropriate background levels could be subtracted from the direct measurements.

If no C-14 contamination was detected by direct measurement survey or smear evaluations, no H-3 detected by smear evaluations, and no elevated gamma levels were detected; then these initial screening surveys were considered sufficient for final assessment. If investigations of areas were necessary due to detection of the presence of radioactive materials during the initial survey phase, then specific levels of contamination were evaluated by performance of additional surveys and smears.

## **3.0 Initial Radiological Survey**

### 3.1 Conduct of the Initial Radiological Survey

The initial survey of Building 72 was conducted on February 22<sup>nd</sup> and February 23<sup>rd</sup> of 2007. Each room of the facility was evaluated with the floor monitor at the percentages established by the survey design. In addition, two hundred and thirty smear samples were obtained over the entire building with some being biased samples of every floor drain and sink drain in the facility. The locations of the smear samples were documented of a plat drawing of Building 72 obtained from the onsite Engineering group (See Attachment 4).

The smear samples were individually packaged to prevent cross-contamination if any were found to be present and were sent to Radiation Service Organization (RSO, Inc.) of Laurel

Maryland for evaluation on February 26, 2007. RSO, Inc evaluated the samples with a Packard Model 5300 Liquid Scintillation Counter (See Attachment 5).

### 3.2 Findings

Evidence of facility contamination was detected with the floor monitor in rooms 113 (two locations) and 113B (one location). These locations were further evaluated using the hand held proportional counter and these areas were found to have maximum contamination levels of 3500 cpm/126 cm<sup>2</sup> and 4500 cpm/126 cm<sup>2</sup> in Room 113 and a level of 6200 cpm/126 cm<sup>2</sup> in room 113B. Assuming that the contamination is primarily C-14, the levels in room 113 are above the NRC Regulatory Guide 1.86 criterion for beta-gamma emitting radionuclides at 12,500 dpm/100 cm<sup>2</sup> (3500 cpm/126 cm<sup>2</sup>) and 16,750 dpm/100 cm<sup>2</sup> (4500 cpm/126 cm<sup>2</sup>). The floor location in room 113B is also above the NRC Regulatory Guide 1.86 criterion at 24,250 dpm/100 cm<sup>2</sup>.

Smears of these three contaminated floor areas were obtained and evaluated with the initial smear sets (smear samples 26C through 28C). None of these smears were in excess of the NRC Regulatory Guide 1.86 criterion for removable beta-gamma emitting radionuclides with the highest in the identified floor contamination areas being 17 dpm/100cm<sup>2</sup>.

An additional area of surface contamination was found on the sink surface in room 113B directly between the two faucets at 8500 cpm/126 cm<sup>2</sup> (36,500 dpm/100cm<sup>2</sup>). A smear of this area (smear sample 29C) returned a removable contamination level of 23 dpm/100cm<sup>2</sup>.

The other smear samples taken in room 113B before the floor contamination was discovered (smear samples 10B sink drain and 12B floor drain) also showed indication of removable surface contamination at 230 dpm/100 cm<sup>2</sup> and 52 dpm/100 cm<sup>2</sup>. Smear sample 21B taken near the exit door from the Room 113 complex indicated a removable contamination level of 15 dpm/100 cm<sup>2</sup>.

Four other smear samples gave a positive indication of removable contamination. Smear sample 31B was taken beneath the sink in room 113D and indicated 11 dpm/100 cm<sup>2</sup>. Smear sample 40B was taken as a large area smear on the inner surfaces of the refrigerator/freezer in Room 113C and indicated 124 dpm/100 cm<sup>2</sup> in the H-3 channel and 47 dpm/100 cm<sup>2</sup> in the C-14 channel. Smear sample 41B was taken on the floor in room 125 and indicated 64 dpm/100 cm<sup>2</sup> in the H-3 channel and 22 dpm/100 cm<sup>2</sup> in the C-14 channel. The final smear indicating removable contamination (30C) was taken in the sink drain in the women's bathroom (room 104) and indicated 226 dpm/100 cm<sup>2</sup> in the H-3 channel and 195 dpm/100 cm<sup>2</sup> in the C-14 channel.

### 3.3 Evaluation of Initial Survey Results

Based on the findings of the initial survey, seven distinct areas were targeted for follow-up investigational surveys. These areas are identified below:

- The sink bowl and drain in Room 104 (Women's Bathroom). This area was not anticipated to have been contaminated.
- Room 125 NW corner to verify presence of removable contamination. This area was not anticipated to have been contaminated.

- Room 113B removable contamination indications on floor drain and sink drain smears.
- Room 113 fixed floor contamination locations (obtain wax build-up scrapings to determine if contamination is removable).
- Room 113C a more comprehensive evaluation of refrigerator surfaces to possibly isolate the contamination location.
- Room 114 Fume Hood (very low indication but rad sticker on side of hood warrants further investigation).
- Room 113D under "out of order" sink

These areas were identified for detailed follow-up investigational surveys to better define the areas indicating positive contamination results to assist in defining any needed remediation activities. The direct measurement surveys of the remainder of the laboratory bench tops and other horizontal surfaces above floor level in Rooms 112 and 124 and the Room 113 laboratory complex were deferred until the follow-up survey tasking.

#### **4.0 Follow-up Investigational Survey**

##### **4.1 Conduct of the Follow-up Survey**

The radiological survey team returned on March 21<sup>st</sup> and March 22<sup>nd</sup> of 2007 to conduct follow-up investigational surveys on areas identified to be impacted by the findings of the initial surveys performed on February 22<sup>nd</sup> and 23<sup>rd</sup> of 2007. Additional surveys included smears for removable contamination with smears submitted to RSO, Inc for counting on March 26<sup>th</sup> 2007 and the results reported on March 27<sup>th</sup>, 2007 (See Attachment 6).

##### **4.2 Investigational Survey Details**

An additional 36 smear samples (31C through 67C) for surface areas and 3 swabs for drains were obtained in the targeted investigation areas. A general gamma activity survey was conducted with a Ludlum Model 19  $\mu$ R meter. All remaining above floor horizontal laboratory surfaces in the designated comprehensive survey areas were evaluated with the 126 cm<sup>2</sup> thin-window, gas flow proportional detector (Rooms 112 and 124 as well as the remaining above floor level horizontal surfaces in the Room 113 laboratory complex).

##### **4.3 Findings**

The following summarize the survey results:

- The sink in the women's bathroom was evaluated with four smears and 2 swabs (on surfaces inside the drain). No evidence of removable contamination was found on any of the survey media.
- The Northwest corner Room 125 was evaluated with five smear samples. No evidence of removable contamination was found on any of the survey media.
- The Fume hood in room 114 was investigated by taking two smear samples on each vertical surface (one high and one low) as well as direct measurements with the hand held proportional counter detector. Smears 31C through 38C returned no evidence of



removable contamination and the direct measurements were indistinguishable from the background count rate.

- No evidence of contaminated surfaces was found in rooms 124 or 112 during the addition direct measurements of the above floor horizontal surfaces.
- Three additional contaminated areas were identified on the above floor horizontal surfaces within the room 113 complex. In room 113A, a direct measurement of the speed concentrator lid was 7500 cpm/100cm<sup>2</sup> (33,000 dpm/100cm<sup>2</sup>). A smear sample of the concentrator lid (49C) returned a removable contamination level of 1147 dpm/100 cm<sup>2</sup> of H-3 and 1318 dpm/100 cm<sup>2</sup> of C-14. In room 113D, an additional hot spot was identified on the left front top of the bench top of the sink surface of 2900 cpm/100cm<sup>2</sup> (11,500 dpm/100cm<sup>2</sup>). A smear sample (67C) of this location returned no evidence of removable surface contamination.
- An additional hot spot was identified on top of the decontamination sink in room 113B with a direct measurement of 321,000 cpm/100 cm<sup>2</sup> (1,340,000 dpm/100cm<sup>2</sup>) a smear sample of this location returned removable contamination of 3998 dpm/100cm<sup>2</sup> in the H-3 channel and 5389 dpm/100cm<sup>2</sup> in the C-14 channel. Smears of the known two hot spots on the sink top surface and vertical surface of the sink confirm removable contamination in excess of the clean-up guidelines. The smear survey of the floor drain and swabs within the floor drain do not confirm the presence of removable contamination.
- The refrigerator/freezer in room 113C returned positive but low-level indications of removable surface contamination in two of the twelve smear samples obtained. The left bottom drawer returned H-3 activity of 30 dpm/100 cm<sup>2</sup> and C-14 activity of 14 dpm/100 cm<sup>2</sup>. The floor of the freezer returned H-3 activity of 107 dpm/100 cm<sup>2</sup> and C-14 activity of 20 dpm/100 cm<sup>2</sup>. The top shelf of the freezer door returned H-3 activity of 51 dpm/100 cm<sup>2</sup> and C-14 activity of 8 dpm/100 cm<sup>2</sup>. The next to bottom shelf of the refrigerator door returned H-3 activity of 63 dpm/100 cm<sup>2</sup> and no apparent C-14 activity. None of the areas of the refrigerator freezer were contaminated above the Regulatory Guide 1.86 guideline of 1000 dpm/100 cm<sup>2</sup>.

#### 4.4 Delineation of Areas Confirmed to be Contaminated (Results)

All areas of Building 72 with the exception of the Room 113 complex were free of detectable contamination both fixed and removable. No beta emitters or gamma emitting radionuclides above background levels were identified.

Within the Room 113 complex, areas of the Room 113 floor marked as having fixed contamination were above the Regulatory Guide 1.86 guideline but the radioactive material appears to be fixed. In room 113D, the top of the sink contained an area of fixed contamination in excess of the guideline. In Room 113C, the refrigerator/freezer contained removable contamination below the guideline. In room 113A, the speed concentrator unit was contaminated above the guidelines for both removable and direct measurements of C-14 and H-3. In room 113B, a small area of floor was contaminated above the guideline and the top of the sink benchtop was contaminated above the guidelines.

#### 4.5 Recommendations for Remediation

The following remediation actions were recommended and taken:

- Discard the Speed concentrator in Room 113A as radioactive waste.
- Remove portions of the sinktop in rooms 113B and 113D identified as contaminated and discard as radioactive waste.
- Decontaminate/remove as radioactive waste contaminated sections of the refrigerator/freezer in room 113C.
- Remove portions of the flooring identified to be contaminated and discard as radioactive material.

#### 5.0 Remediation

Chesapeake Nuclear Services returned to the facility on June 28<sup>th</sup>, 2007, to remediate the areas recommended in Section 4.5 and to perform surveys to demonstrate that all surfaces identified as contaminated during the Follow-up survey of March 21<sup>st</sup> and 22<sup>nd</sup>, 2007, were either removed from the facility or otherwise met the facility clean-up criteria as described in Section 2.2. Arrangements were made with licensed radioactive waste broker RSO, Inc of Laurel, MD to package and remove the debris that resulted from the remediation effort. Post remediation surveys were conducted with a Ludlum Model 2360 attached to the 125 cm<sup>2</sup> thin window gas-flow proportional detector used for the follow-up surveys on March 21<sup>st</sup> and 22<sup>nd</sup>, 2007 to demonstrate that all facility surfaces remaining met the facility clean-up criteria. Swipe surveys were also conducted of surfaces that had undergone remediation or were suspected to possibly have been impacted by the remediation process.

- Speed Concentrator in Room 113A. Based on the results of the Follow-up survey, the benchtop surface in room 113A was not impacted by the presence of internal contamination within the speed concentrator. The speed concentrator was removed and discarded as radioactive waste.
- Sinktop and Floor surfaces in Room 113B: Major impacted portions of the sinktop were partitioned and carefully removed to prevent transfer of loose surface contamination to otherwise non-impacted surfaces. Following removal of the known contaminated sections of the sinktop, additional surveys were conducted to locate any additional areas that might require remediation. During these measurements, the faucet plumbing fixture on the right side of the sink was found to be contaminated but due to geometric considerations, it was difficult to determine at what levels. Decontamination of the fixture was attempted but was unsuccessful. A decision was made to remove the fixture and discard it as radioactive waste. A portion of the wooden framework beneath the sinktop was observed to be water stained and due to its location beneath the contaminated portion of the sinktop was surveyed for residual contamination. Although no contamination was measurable with the proportional detector, this section of wooden truss was removed and discarded as radioactive waste due to the high probability of contamination set into the wooden fibers. The areas of linoleum tile identified as contaminated in Room 113B were removed and discarded as radioactive waste.
- Refrigerator Internal Surfaces in Room 113C: Two decontamination passes were performed with Windex and Bounty paper towels on the internal surfaces of the refrigerator/freezer in Room 113C. The decontamination media was discarded as

radioactive waste. The contamination levels of this refrigerator were not detectable with the proportional counter during the Follow-up surveys but were only measurable by smear survey.

- Sinktop in Room 113D: The impacted section of the sinktop in Room 113D was removed and discarded as radioactive waste.
- Floor surfaces in Room 113: The two areas of linoleum tile identified as impacted during the Follow-up surveys of March 21<sup>st</sup> and 22<sup>nd</sup>, 2007 were removed and discarded as radioactive waste.

## 6.0 Final Status Survey

### 6.1 Conduct of the Final Status Survey

Following the completion of all remediation tasks and in-process surveys, the container of radioactive waste sealed and removed from the facility. A radioactive waste manifest was prepared and forwarded to the facility RSO for approval and certification statement signature. Final measurements and smear surveys were then conducted of the remediated floor surfaces, the internal surfaces of the refrigerator/freezer and the sink/benchttop or floor surfaces nearest those surfaces removed during the remediation.

### 6.2 Results of the Final Status Survey

No detectable contamination was measured above background with the 125 cm<sup>2</sup> proportional detector on any of the remediated floor surfaces in Rooms 113 or 113B. No detectable contamination was measured above background on the remaining sinktop surfaces in Room 113D. A small residual sinktop surface of approximately 400 cm<sup>2</sup> located in Room 113B at the top of the remaining wooden framework of the sink (right rear) was found to have residual contamination below the clean-up criteria at 3,600 dpm/100 cm<sup>2</sup> and a total activity around 5 nCi (C-14). A smear of this area was obtained to assess the loose surface contamination status. No other surfaces were found to contain residual contamination by direct measurement. The results of the smears taken of the interior of the refrigerator in Room 113C and of the remaining residually contaminated surface in Room 113B as well as remediated floor surfaces and areas near the removed sinktop surface were all found to be free of loose surface contamination (Attachment 7.0).

### 6.3 Analysis of the Final Status Survey Results

The remediation of the identified contaminated areas/equipment was completed; all identified areas with elevated levels were remediated to below Regulatory Guide 1.86 clean-up criteria. RSO, Inc. of Laurel, MD, took possession the waste for disposal – 211 lbs, 4.1 cubic feet containing 0.9 mCi C-14 and 0.001 mCi H-3.

The facility clean-up criteria as established in Section 2.2 requires that all surfaces be less than 5000 dpm/100cm<sup>2</sup> averaged over no more than 1 square meter with no area in excess of

15,000 dpm/100cm<sup>2</sup>. The remaining residually contaminated surface is significantly less than 1 square meter (0.04 square meters) and yet still meets the clean-up criteria for average fixed contamination. The remaining residually contaminated surface at 3600 dpm/100cm<sup>2</sup> is a small fraction (< 0.25) of the maximum residual contamination clean-up criteria for a 100 cm<sup>2</sup> sized area. NRC's default surface contamination level corresponding to 25 mrem/yr is 3.7E+06 dpm/100 cm<sup>2</sup> (NUREG-1757). So, leaving in-place does not pose an issue for the unconditional release of the site. Additionally, the piece is below the 10 CFR 30 exempt concentration value for C-14 of  $8 \times 10^{-3}$  uCi/ml and the exempt total activity level of 100 uCi.

The hypothetical dose to a member of the public from the unconditional release of the facility is much less than 1 mrem per year and well below the 25 mrem per year decommissioning criteria of 10 CFR 20.

# Table of Contents

<b>1.0</b>	<b>Historical Site Assessment</b>	
1.1.	Building Description	1
1.2.	Findings: Historical usage of Radioactive Materials in Building 72	2
1.3.	Conclusion	4
<b>2.0</b>	<b>Final Status Survey Design</b>	
2.1.	Radiological Hazard Assessment and Survey Strategy	5
2.2.	Site clean-up criteria	5
2.3.	Survey instrumentation	5
2.4.	Evaluations	6
<b>3.0</b>	<b>Initial Radiological Survey</b>	
3.1.	Conduct of the Initial Radiological Survey	6
3.2.	Findings	7
3.3.	Evaluation of Initial Survey Results	7
<b>4.0</b>	<b>Follow-up Investigational Survey</b>	
4.1.	Conduct of follow-up survey	8
4.2.	Investigational Survey Details	8
4.3.	Findings	8
4.4.	Delineation of Areas Confirmed to be Contaminated (Results)	9
4.5.	Recommendations for Remediation	10
<b>5.0</b>	<b>Remediation</b>	10
<b>6.0</b>	<b>Final Status Survey</b>	
6.1.	Conduct of Final Status Survey	11
6.2.	Results of Final Status Survey	11
6.3.	Analysis of Final Status Survey Results	11

## **Attachments**

1.0	Individual Survey Area Results and Maps
2.0	Regulatory Guide 1.86 (1974)
3.0	Instrumentation Calibration Record
4.0	Large Area Survey Map Initial Survey
5.0	Initial Smear Survey Results
6.0	Follow-up Smear Survey Results
7.0	Final Status Survey Smear Results
8.0	Radioactive Waste Shipment Manifest

**Historical Site Assessment and Final Status Survey Report  
for the Veterans Administration Facility  
Building 72 in Hampton, Virginia**

**Final Report**

**8/13/2007**

**Surveys Performed by:**

**Joseph W. Moon, CHP  
and  
Byron W. Bland**



**Chesapeake Nuclear Services**

788 Sonne Drive  
Annapolis MD 21401  
410.266.9174 voice  
410.266.5811 fax  
[www.chesnuc.com](http://www.chesnuc.com)

**Enclosure 1**

Historical Site Assessment and Final Status Survey Report for the Veterans administration  
Facility Building 72 in Hampton Virginia

(Prepared: August 13, 2007)

Area Classification: 3  
 Building/Area: Room 119  
 Floor/Elevation: Floor  
 Survey Unit/Grid: Copy Room  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/22/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	30%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile β Floor	618 cpm	1236 cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/22/2007	1400	bwb
End:	2/22/2007	1655	bwb

Note: Source checks required at beginning and end of shift

**Comments:**


Highest scan level seen in this room was 750 cpm  
 Smears taken - see map for location  
 44A - No positive activity detected  
  
 No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document

Technician/Surveyor: Byron Bland *Byron Bland* Date: 4/11/2007  
 Name Signature  
 Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W. Moon* Date: 4/11/2007  
 Name Signature



Room 118



42A - Sink drain

43A - Bench top

Area Classification: 3  
 Building/Area: Room 118  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/22/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	35%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile β Floor	618 cpm	1236 cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/22/2007	1400	bwb
End:	2/22/2007	1655	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 760 cpm  
 Smears taken - see map for location  
 40A through 43A - No positive activity detected  
  
 No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document

Technician/Surveyor: Byron Bland  
 Name

*Byron Bland*  
 Signature


Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP  
 Name

*Joseph W. Moon*  
 Signature

Date: 4/11/2007

Room 117



Area Classification: 3  
 Building/Area: Room 117  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/22/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	40%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile β Floor	618 cpm	1236 cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/22/2007	1400	bwb
End:	2/22/2007	1655	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 849 cpm  
 Smears taken - see map for location  
 38A and 39A - No positive activity detected  
  
 No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document

Technician/Surveyor: Byron Bland *Byron Bland*  
 Name Signature


Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W. Moon*  
 Name Signature

Date: 4/11/2007

# Room 116A

- Fume Hood
- 35A - Floor
- 36A - Walls
- 37A - Exhaust



Area Classification: 3  
 Building/Area: Rooms 116 and 116A  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/22/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	25%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile β Floor	618 cpm	1236 cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/22/2007	1400	bwb
End:	2/22/2007	1655	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this survey area was 772 cpm  
 Smears taken - see map for location  
 Room 116 - 33A - No positive activity detected  
 Room 116A - 34A through 37A - No positive activity detected

Room 116A Fume Hood is detached (not connected to any ventilation system) odor of VOC's in room  
 Note: Radiation Symbol on Fume Hood - should be removed

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

**Attach survey map to this document**

Technician/Surveyor: Byron Bland  
 Name

*Byron Bland*  
 Signature


Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP  
 Name


*Joseph W Moon*  
 Signature

Date: 4/11/2007

Room 116




*Room 115A*





*Room 115*



Area Classification: 3  
 Building/Area: Rooms 115 and 115A  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/22/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	45%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile β Floor	618 cpm	1236 cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/22/2007	1400	bwb
End:	2/22/2007	1655	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 792 cpm  
 Smears taken - see map for location  
 Room 115 31A - No positive activity detected  
 Room 115A 32A - No positive activity detected  
  
 No activity found in excess of the RG 1.86 (1974) clean-up guidelines


**Attach survey map to this document**

Technician/Surveyor: Byron Bland *Byron Bland* Date: 4/11/2007  
 Name Signature  
 Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W. Moon* Date: 4/11/2007  
 Name Signature

# Room 114

Fume Hood  
10A - exhaust  
1A - Floor  
2A - Walls

8A - Top of bench  
7A - In sink  
9A - Top of bench



Area Classification: 3  
 Building/Area: Room 114  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/22/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	40%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile β Floor	618 cpm	1236 cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/22/2007	1400	bwb
End:	2/22/2007	1655	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 867 cpm  
 Smears taken - see map for location  
 1A through 10A  
 Highest positive smear 2A @ 14 dpm/100 cm<sup>2</sup> in C-14 channel on Fume Hood walls  
 No positive activity detected on any other smear  
*Investigation of positive result on 3/22/07*  
 Static Measurements of Fume Hood walls and glass with 126 cm<sup>2</sup> probe - no detectable activity above background  
 Additional smears taken 3/22/07 2 on each vertical surface one of upper surface and one of lower surface  
 31C through 38C all less than 10 dpm/100 cm<sup>2</sup> in C-14 channel

Note: Radiation Symbol on side of Fume Hood - should be removed  
 No activity found in excess of the RG 1.86 (1974) clean-up guidelines

**Attach survey map to this document**

Technician/Surveyor: Byron Bland  
 Name

*Byron Bland*  
 Signature


Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP  
 Name

*Joseph W. Moon*  
 Signature

Date: 4/11/2007

# Room 113D



## Fume hood

26B - floor  
27B - Walls  
28B - exhaust  
23B - in fume hood  
drain

---

30B - Sink drain  
31B - Under sink  
29B - Bench top

**Survey Requirements**

Area Classification: 1  
 Building/Area: Room 113D  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
β scan 126 cm<sup>2</sup> probe  
γ scan μR meter  
 Date/Time: 2/23/2007 and 3/22/2007

	Beta	Gamma
Floor	100%	as required
Wall		
Working Surfaces	100%	100%
Actual surveyed	100%	100%

Beta Scan Speed: 2.5 inches/sec  
 Beta Scan Height: 1/2 inch  
 γ Scan Speed: \_\_\_\_\_  
 γ Scan Height: 1/2 inch

**Instrument Information**

	β Floor	β hand held	γ μR meter
Floor Monitor ID Number:	1	2	Ludlum
Logger Model:	2350-1	2350-1	
Logger Serial Number:	149408	149408	
Cal Due Date:	10/22/2007	10/22/2007	9/19/2007
Detector Model:	43-37-1	43-68	Model 19
Detector Serial Number:	PR145081	PR148454	182679

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile	618 cpm	1236 cpm	
Lab bench β Hand	239 cpm	478 cpm	
μR/hr γ exposure rate	8-15 μR/hr	30 μR/hr	

**Source Checks**

	Prior	Date	Time	Initials
β Floor		2/23/2007	921	bwb
	End:	2/23/2007	1630	bwb
β hand	Prior:	3/22/2007	905	bwb
	End:	3/22/2007	1315	bwb

Note: Source checks required at beginning and end of shift


**Comments:**

Highest scan level seen in this room with the floor monitor was 680 cpm  
 Highest hand held measurement was on the front left sink top at 2900 cpm/100cm<sup>2</sup> (11,500 dpm/100cm<sup>2</sup>).  
 Smears taken - see map for location  
 Smears 22B through 33B - No positive activity detected on floor, the fume hood interior or bench top surfaces  
 A smear sample (67C) of the contaminated sink top location returned no evidence of removable surface contamination.  
 A smear taken of the liquid below the sink (31B) showed minimal positive activity.

Activity found in excess of the RG 1.86 (1974) clean-up guidelines only on the sink top location  
 This activity is fixed and not removable

Attach survey map to this document

Technician/Surveyor: <u>Byron Bland</u>	<u><i>Byron Bland</i></u>	Date: <u>4/11/2007</u>
Name	Signature	
Supervisor/Reviewer: <u>Joseph W. Moon, CHP</u>	<u><i>Joseph W. Moon</i></u>	Date: <u>4/11/2007</u>
Name	Signature	



113C

38B - In sink drain

40B - Taken in fridge / freezer

Area Classification: 1  
 Building/Area: Room 113C  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
β scan 126 cm<sup>2</sup> probe  
γ scan μR meter  
 Date/Time: 2/23/2007 and 3/22/2007

**Survey Requirements**

	Beta	Gamma
Floor	100%	as required
Wall		
Working Surfaces	100%	100%
Actual surveyed	100%	100%

Beta Scan Speed: 2.5 inches/sec  
 Beta Scan Height: 1/2 inch  
 γ Scan Speed: \_\_\_\_\_  
 γ Scan Height: 1/2 inch

Floor Monitor ID Number: 1      β Floor      β hand held      γ μR meter  
 Logger Model: 2350-1      2350-1      Ludlum  
 Logger Serial Number: 149408      149408  
 Cal Due Date: 10/22/2007      10/22/2007      9/19/2007  
 Detector Model: 43-37-1      43-68      Model 19  
 Detector Serial Number: PR145081      PR148454      182679

**Instrument Information**

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile	618 cpm	1236 cpm	
Lab bench β Hand	239 cpm	478 cpm	
μR/hr γ exposure rate	8-15 μR/hr	30 μR/hr	

**Source Checks**

	Date	Time	Initials
β Floor	Prior: 2/23/2007	921	bwb
	End: 2/23/2007	1630	bwb
β hand	Prior: 3/22/2007	905	bwb
	End: 3/22/2007	1315	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room with the floor monitor was 775 cpm  
 Highest hand held measurement was background  
 Smears taken - see map for location  
 Smears 34B through 39B - No positive activity detected on floor or bench top surfaces  
 Smear 40B taken in the refrigerator/freezer showed positive indication of activity  
 Follow-up investigation of the refrigerator/freezer showed positive activity at a maximum  
 H-3 activity of 107 dpm/100 cm<sup>2</sup> and C-14 activity of 20 dpm/100 cm<sup>2</sup>.  
 The refrigerator/freezer activity is not fixed and does not exceed the clean-up guideline for removable contamination

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document

Technician/Surveyor: Byron Bland      *Byron Bland*  
 Name      Signature


Supervisor/Reviewer: Joseph W. Moon, CHP      *Joseph W. Moon*  
 Name      Signature

Date: 4/11/2007

Date: 4/11/2007



# Room 113B



Direct measurements of contaminated surfaces with a model 43-58 proportional hand held detector directly on the areas shown on the map where smears were obtained

### Location Measurement

43C	1,340,000 dpm/100cpm <sup>2</sup>
44C	8500 dpm/100cpm <sup>2</sup>
45C	21,750 dpm/100cpm <sup>2</sup>
46C	BKG
48C	14,600 dpm/100cpm <sup>2</sup>

Area Classification: 1  
 Building/Area: Room 113B  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
β scan 126 cm<sup>2</sup> probe  
γ scan μR meter  
 Date/Time: 2/23/2007 and 3/22/2007

**Survey Requirements**

	Beta	Gamma
Floor	100%	as required
Wall		
Working Surfaces	100%	100%
Actual surveyed	100%	100%

Beta Scan Speed: 2.5 inches/sec  
 Beta Scan Height: 1/2 inch  
 γ Scan Speed: \_\_\_\_\_  
 γ Scan Height: 1/2 inch

**Instrument Information**

	β Floor	β hand held	γ μR meter
Floor Monitor ID Number:	1	2	Ludlum
Logger Model:	2350-1	2350-1	
Logger Serial Number:	149408	149408	
Cal Due Date:	10/22/2007	10/22/2007	9/19/2007
Detector Model:	43-37-1	43-68	Model 19
Detector Serial Number:	PR145081	PR148454	182679

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile	618 cpm	1236 cpm	
Lab bench β Hand	239 cpm	478 cpm	
μR/hr γ exposure rate	8-15 μR/hr	30 μR/hr	

**Source Checks**

	Date	Time	Initials
β Floor	Prior: 2/23/2007	921	bwb
	End: 2/23/2007	1630	bwb
β hand	Prior: 3/22/2007	905	bwb
	End: 3/22/2007	1315	bwb



**Comments:**

*Initial Survey 2/23/07*


Note: Source checks required at beginning and end of shift

One floor region was detected as contaminated above the Investigation level by the floor monitor  
 Highest hand held measurement of this floor area was 6.2k cpm/126 cm<sup>2</sup> (24,250 dpm/100 cm<sup>2</sup>)  
 Two areas were found to be contaminated on the decon sink top during the initial survey.  
 The highest reading of these two was 8500 cpm/126 cm<sup>2</sup> between the faucets  
 Smears taken - see map for location  
 Floor smears in Room 113B 5B through 8B & 28C (floor hot spot) - No positive activity detected  
 Smear samples 12B (floor drain) and 10B (right sink drain) indicated positive activity  
*Follow-up Survey 3/22/07*  
 Highest μR meter measurement seen in this room was background  
 Highest hand held measurement found on the above floor level horizontal surfaces  
 was 321,000 cpm/100 cm<sup>2</sup> (1,340,000 dpm/100cm<sup>2</sup>) on the right rear side of the decon sink top.  
 Decon sink smear of highest contaminated areas (43C) was 3998 dpm/100cm<sup>2</sup> in the H-3 channel  
 and 5389 dpm/100cm<sup>2</sup> in the C-14 channel. Other sink top smears (44C, 45C & 48C) confirm activity in excess  
 of clean-up guideline. Floor drain smear (47C) - No positive activity detected

**Attach survey map to this document**

Technician/Surveyor: Byron Bland  Date: 4/11/2007  
 Name Signature  
 Supervisor/Reviewer: Joseph W. Moon, CHF  Date: 4/11/2007  
 Name Signature

# Room 113B



- 11B - Bench top
- 12B - Floor drain
- 10B - In sink drain
- 9B - In sink drain
- 29C - Between faucets

Area Classification: 1  
 Building/Area: Room 113A  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
β scan 126 cm<sup>2</sup> probe  
γ scan μR meter  
 Date/Time: 2/23/2007 and 3/22/2007

**Survey Requirements**

	Beta	Gamma
Floor	100%	as required
Wall		
Working Surfaces	100%	100%
Actual surveyed	100%	100%

Beta Scan Speed: 2.5 inches/sec  
 Beta Scan Height: 1/2 inch  
 γ Scan Speed: \_\_\_\_\_  
 γ Scan Height: 1/2 inch

Floor Monitor ID Number: β Floor 1 β hand held 2 γ μR meter Ludlum  
 Logger Model: 2350-1 2350-1  
 Logger Serial Number: 149408 149408  
 Cal Due Date: 10/22/2007 10/22/2007 9/19/2007  
 Detector Model: 43-37-1 43-68 Model 19  
 Detector Serial Number: PR145081 PR148454 182679

**Instrument Information**

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile	618 cpm	1236 cpm	
Lab bench β Hand	239 cpm	478 cpm	
μR/hr γ exposure rate	8-15 μR/hr	30 μR/hr	

**Source Checks**

	Prior	Date	Time	Initials
β Floor		2/23/2007	921	bwb
	End:	2/23/2007	1630	bwb
β hand	Prior:	3/22/2007	905	bwb
	End:	3/22/2007	1315	bwb

Note: Source checks required at beginning and end of shift


**Comments:**

Highest scan level seen in this room with the floor monitor was 700 cpm  
 Highest hand held measurement was 7500 cpm/100cm<sup>2</sup> (33,000 dpm/100cm<sup>2</sup>) on the lid of the speed concentrator.  
 Smears taken - see map for location  
 Smears 1B through 4B no positive activity detected on floor or bench top surfaces  
 Smear on lid of speed concentrator (49C) returned a removable contamination level of 1147 dpm/100 cm<sup>2</sup> of H-3 and 1318 dpm/100 cm<sup>2</sup> of C-14.  
 Activity was detected in excess of the RG 1.86 (1974) clean-up guidelines on a piece of equipment (Speed concentrator) on a bench top in the room. This activity exceeds the removable as well as the total activity limitation.

Attach survey map to this document

Technician/Surveyor: Byron Bland *Byron Bland* Date: 4/11/2007  
 Name Signature  
 Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W. Moon* Date: 4/11/2007  
 Name Signature

# Room 113A



4B - On bench

Area Classification: 1  
 Building/Area: Room 113  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
β scan 126 cm<sup>2</sup> probe  
γ scan μR meter  
 Date/Time: 2/23/2007 and 3/22/2007

**Survey Requirements**

	Beta	Gamma
Floor	100%	as required
Wall		
Working Surfaces	100%	100%
Actual surveyed	100%	100%

Beta Scan Speed: 2.5 inches/sec  
 Beta Scan Height: 1/2 inch  
 γ Scan Speed: \_\_\_\_\_  
 γ Scan Height: 1/2 inch

Floor Monitor ID Number: 1 2 Ludlum  
 Logger Model: 2350-1 2350-1  
 Logger Serial Number: 149408 149408  
 Cal Due Date: 10/22/2007 10/22/2007 9/19/2007  
 Detector Model: 43-37-1 43-68 Model 19  
 Detector Serial Number: PR145081 PR148454 182679

**Instrument Information**

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile	618 cpm	1236 cpm	
Lab bench β Hand	239 cpm	478 cpm	
μR/hr γ exposure rate	8-15 μR/hr	30 μR/hr	

**Source Checks**

	Date	Time	Initials
β Floor	Prior: 2/23/2007	921	bwb
	End: 2/23/2007	1630	bwb
β hand	Prior: 3/22/2007	905	bwb
	End: 3/22/2007	1315	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Two floor regions were detected as contaminated above the Investigation level by the floor monitor  
 Highest hand held measurement of these two floor areas was 4500 cpm/126 cm<sup>2</sup> (16,750 dpm/100cm<sup>2</sup>)  
 Highest μR meter measurement seen in this room was background  
 Smears taken - see map for location  
 Floor smears in Room 113 13B through 21B - No positive activity detected except 21B (15 dpm/100cm<sup>2</sup>)

Floor activity was detected in excess of the RG 1.86 (1974) clean-up guidelines  
 This activity appears to be fixed into the floor surface


Attach survey map to this document

Technician/Surveyor: Byron Bland *Byron Bland*  
 Name Signature


Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W. Moon*  
 Name Signature


Date: 4/11/2007



*Room 112A*







Area Classification: 1  
 Building/Area: Rooms 112 and 112A  
 Floor/Elevation: Floor  
 Survey Unit/Grid: Rad Lab and Office  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
β scan 126 cm<sup>2</sup> probe  
γ scan μR meter  
 Date/Time: 2/23/2007 and 3/22/2007

**Survey Requirements**

	Beta	Gamma
Floor	100%	as required
Wall		
Working Surfaces	100%	100%
Actual surveyed	100%	100%

Beta Scan Speed: 2.5 inches/sec  
 Beta Scan Height: 1/2 inch  
 γ Scan Speed: \_\_\_\_\_  
 γ Scan Height: 1/2 inch

Floor Monitor ID Number: β Floor 1 β hand held 2 γ μR meter Ludlum  
 Logger Model: 2350-1 2350-1  
 Logger Serial Number: 149408 149408  
 Cal Due Date: 10/22/2007 10/22/2007 9/19/2007  
 Detector Model: 43-37-1 43-68 Model 19  
 Detector Serial Number: PR145081 PR148454 182679

**Instrument Information**

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile	618 cpm	1236 cpm	
Lab bench β Hand	239 cpm	478 cpm	
μR/hr γ exposure rate	8-15 μR/hr	30 μR/hr	

**Source Checks**

	Date	Time	Initials
β Floor	Prior: 2/23/2007	921	bwb
	End: 2/23/2007	1630	bwb
β hand	Prior: 3/22/2007	905	bwb
	End: 3/22/2007	1315	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest Floor Monitor scan level seen in this room was 787β cpm  
 Highest hand held scan level seen in this room was background  
 Highest μR meter measurement seen in this room was background  
 Smears taken - see map for location

Sink drains in Room 112 - 84A through 87A and 90A - No positive activity detected  
 Floor drain in Room 112 - 88A - No positive activity detected  
 Floor smear in Room 112 - 91A through 100A - No positive activity detected  
 Floor smear in Room 112A - 89A - - No positive activity detected  
 No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document


Technician/Surveyor: Byron Bland *Byron Bland*  
 Name Signature

Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W Moon*  
 Name Signature

Date: 4/11/2007

Room 111



Fume Hood            25C - in sink  
21C - floor  
22C - walls  
23C - exhaust

Area Classification: 3  
 Building/Area: Room 111  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	35%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile	618 cpm	1236 cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift


**Comments:**

Highest scan level seen in this room was 701 cpm  
 Smears taken - see map for location  
 16C through 20C on floor and 25C on sink drains - No positive activity detected  
 21C through 23C on Fume Hood internals - No positive activity detected

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document

Technician/Surveyor: Byron Bland *Byron Bland* Date: 4/11/2007  
 Name Signature  
 Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W Moon* Date: 4/11/2007  
 Name Signature



Area Classification: 3  
 Building/Area: Room 110  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: sealed concrete  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	40%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
sealed concrete	929 cpm	1.86k cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 923 cpm  
 Smears taken - see map for location  
 88B & 89B on floor and 87B on floor drain - No positive activity detected

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document

Technician/Surveyor: Byron Bland  
 Name

*Byron Bland*  
 Signature


Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP  
 Name

*Joseph W. Moon*  
 Signature

Date: 4/11/2007

Room 109



Area Classification: 3  
 Building/Area: Room 109  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	30%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile	618 cpm	1236 cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 810 cpm  
 Smears taken - see map for location  
 10C on floor and 11C on floor drain - No positive activity detected

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

**Attach survey map to this document**

Technician/Surveyor: Byron Bland *Byron Bland*  
 Name Signature

Date: 4/11/2007


Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W Moon*  
 Name Signature

Date: 4/11/2007



Room 108

12c - In sink



Area Classification: 3  
 Building/Area: Rooms 120, 120A & 120B  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/22/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	35%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile β Floor	618 cpm	1236 cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/22/2007	1400	bwb
End:	2/22/2007	1655	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 720 cpm  
 Smears taken - see map for location  
 45A through 48A - No positive activity detected  
 Carpeted floor surfaces  
 Note: partitions delineating closet space Room 120C no longer present  
  
 No activity found in excess of the RG 1.86 (1974) clean-up guidelines

**Attach survey map to this document**


Technician/Surveyor: Byron Bland *Byron Bland*  
 Name Signature

Date: 4/11/2007


Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W Moon*  
 Name Signature

Date: 4/11/2007


*Room 119*



Room 120



Room 120A



Area Classification: 3  
 Building/Area: Room 121  
 Floor/Elevation: Floor  
 Survey Unit/Grid: Non-Rad Lab  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	30%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile β Floor	618 cpm	1236 cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	921	bwb
End:	2/23/2007	1630	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 760 cpm  
 Smears taken - see map for location  
 49A through 60A - No positive activity detected  
  
 No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document


Technician/Surveyor: Byron Bland *Byron Bland*  
 Name Signature

Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W Moon*  
 Name Signature

Date: 4/11/2007

Room 120B



Area Classification: 3  
 Building/Area: Rooms 123, 123A and 123B  
 Floor/Elevation: Floor  
 Survey Unit/Grid: Non-Rad Lab/Darkroom/Office  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	30%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile β Floor	618 cpm	1236 cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 665 cpm  
 Smears taken - see map for location  
 Floor Smears room 123 were 61A through 65A - No positive activity detected  
 Floor Smear from room 123A (Darkroom) was 66A - No positive activity detected  
 Floor Smear from room 123B (Office) was 71A - No positive activity detected  
 Floor Drain smears in room 123 were 67A and 68A - No positive activity detected  
 Sink Drain smears from rooms 123 and 123A were 69A and 70A - No positive activity detected

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

**Attach survey map to this document**

Technician/Surveyor: Byron Bland *Byron Bland*  
 Name Signature

Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W. Moon*  
 Name Signature


Date: 4/11/2007




Room 121

Fume Hood  
57A - Floor, 58A - Walls, 59A - ahoust


53A - In sink drain  
54A - In sink  
55A - In sink





- 67A - Floor drain
- 68A - Floor drain
- 69A - Sink drain


Room 123A




70A - Sink drain




Room 123B





Room 124A



100% scan of accessible floor area

Area Classification: 3  
 Building/Area: Room 125  
 Floor/Elevation: Floor  
 Survey Unit/Grid: Office  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	30%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile	618 cpm	1236 cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift

**Comments:**


Highest scan level seen in this room was 817 cpm  
 Smears taken - see map for location  
 Initial survey 41B through 44B on floor and 45B on floor drain - No positive activity detected except 41B (124 dpm/100cm<sup>2</sup> for H-3 and 47 dpm/100cm<sup>2</sup> for C-14)  
 Investigational survey 50C through 54C - No positive activity detected

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document

Technician/Surveyor: Byron Bland *Byron Bland* Date: 4/11/2007  
 Name Signature  
 Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W. Moon* Date: 4/11/2007  
 Name Signature





Area Classification: 3  
 Building/Area: Room 127  
 Floor/Elevation: Floor  
 Survey Unit/Grid: Ward  
 Surface: sealed concrete  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	35%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
sealed concrete	929 cpm	1.86k cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift


**Comments:**

Highest scan level seen in this room was 950 cpm  
 Smears taken - see map for location  
 67B & 68B on floor and 66B on floor drain - No positive activity detected  
 65B in sink drain - No positive activity detected

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document

Technician/Surveyor: Byron Bland *Byron Bland* Date: 4/11/2007  
 Name Signature  
 Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W Moon* Date: 4/11/2007  
 Name Signature



Room 127

65B - In sink

Area Classification: 3  
 Building/Area: Room 129  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: sealed concrete  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	30%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
sealed concrete	929 cpm	1.86k cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift


**Comments:**

Highest scan level seen in this room was 840 cpm  
 Smears taken - see map for location  
 73B & 78B on floor and 83B on floor drain- No positive activity detected

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

**Attach survey map to this document**

Technician/Surveyor: Byron Bland *Byron Bland* Date: 4/11/2007  
 Name Signature  
 Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W Moon* Date: 4/11/2007  
 Name Signature



*Room 129*

Area Classification: 3  
 Building/Area: Room 130  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: sealed concrete  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	25%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
sealed concrete	929 cpm	1.86k cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 921 cpm  
 Smears taken - see map for location  
 74B & 79B on floor and 84B on floor drain- No positive activity detected

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document

Technician/Surveyor: Byron Bland  
 Name


*Byron Bland*  
 Signature

Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP  
 Name

*Joseph W. Moon*  
 Signature

Date: 4/11/2007



*Room 130*

Area Classification: 3  
 Building/Area: Room 131  
 Floor/Elevation: Floor  
 Survey Unit/Grid:  
 Surface: sealed concrete  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	30%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
sealed concrete	929 cpm	1.86k cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift

**Comments:**


Highest scan level seen in this room was 945 cpm  
 Smears taken - see map for location  
 75B & 80B on floor and 85B on floor drain- No positive activity detected

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

**Attach survey map to this document**

Technician/Surveyor: Byron Bland *Byron Bland* Date: 4/11/2007  
 Name Signature  
 Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W. Moon* Date: 4/11/2007  
 Name Signature





*Room 131*

Area Classification: 3  
 Building/Area: Room 132  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: sealed concrete  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	30%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
sealed concrete	929 cpm	1.86k cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift


**Comments:**

Highest scan level seen in this room was 981 cpm  
 Smears taken - see map for location  
 76B & 81B on floor and 86B on floor drain- No positive activity detected

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document

Technician/Surveyor: Byron Bland *Byron Bland* Date: 4/11/2007  
 Name Signature  
 Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W Moon* Date: 4/11/2007  
 Name Signature



Room 132

Area Classification: 3  
 Building/Area: Room 133  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: sealed concrete  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	40%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
sealed concrete	929 cpm	1.86k cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 940 cpm  
 Smears taken - see map for location  
 77B, 82B, & 96B on floor - No positive activity detected  
 97B on the sink drain - No positive activity detected

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document

Technician/Surveyor: Byron Bland  
 Name


*Byron Bland*  
 Signature

Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP  
 Name

*Joseph W. Moon*  
 Signature

Date: 4/11/2007



*Room 133*

97B - In sink

Area Classification: 3  
 Building/Area: Room 134  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: sealed concrete  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	35%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
sealed concrete	929 cpm	1.86k cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 857 cpm  
 Smears taken - see map for location  
 91B, 92B 95B on floor - No positive activity detected  
 93B on sink top and 94B on sink drain - No positive activity detected  
 98B on the walk-in decon booth - No positive activity detected

**Comments:**

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document

Technician/Surveyor: Byron Bland  
 Name


*Byron Bland*  
 Signature

Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP  
 Name

*Joseph W. Moon*  
 Signature

Date: 4/11/2007



94B - In sink

Area Classification: 3  
 Building/Area: 135  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: sealed concrete  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	35%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
sealed concrete	929 cpm	1.86k cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 1.01k cpm  
 Smears taken - see map for location  
 90B on floor - No positive activity detected

**Comments:**

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document

Technician/Surveyor: Byron Bland  
 Name

*Byron Bland*  
 Signature


Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP  
 Name

*Joseph W. Moon*  
 Signature

Date: 4/11/2007





*Room135*

Area Classification: 3  
 Building/Area: Room 136  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	30%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile β Floor	618 cpm	1236 cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1630	bwb

Note: Source checks required at beginning and end of shift

**Comments:**


Highest scan level seen in this room was 970 cpm  
 Smears taken - see map for location  
 11A through 13A - No positive activity detected

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

**Attach survey map to this document**

Technician/Surveyor: Byron Bland *Byron Bland* Date: 4/11/2007  
 Name Signature  
 Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W. Moon* Date: 4/11/2007  
 Name Signature

Room 136



Area Classification: 3  
 Building/Area: Room 137  
 Floor/Elevation: Floor  
 Survey Unit/Grid: Rad Waste processing  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/22/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	20%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile β Floor	618 cpm	1236 cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/22/2007	1400	bwb
End:	2/22/2007	1655	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 1.09k cpm  
 Smears taken - see map for location  
 Floor smears 20A through 23A - No positive activity detected  
 smear 24A dipped in liquid standing in uncovered 30 gallon Radwaste drum  
 smear 25A taken on 5 -6 crushed moldy cardboard boxes marked for Rad waste usage (presumed unused)  
 No positive activity detected on smears 24A or 25A

Note: materials marked with radioactive material labels should be removed from this room and disposed prior to demolition of building

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

**Attach survey map to this document**


Technician/Surveyor: Byron Bland *Byron Bland*  
 Name Signature

Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W. Moon*  
 Name Signature

Date: 4/11/2007

Room 137



Area Classification: 3  
 Building/Area: Hall C-1  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/22/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	30%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile β Floor	618 cpm	1236 cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/22/2007	1400	bwb
End:	2/22/2007	1655	bwb

Note: Source checks required at beginning and end of shift

**Comments:**


Highest scan level seen in this room was 776 cpm  
 Smears taken - see map for location  
 14A and 15A - No positive activity detected

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

**Attach survey map to this document**

Technician/Surveyor: Byron Bland *Byron Bland* Date: 4/11/2007  
 Name Signature  
 Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W. Moon* Date: 4/11/2007  
 Name Signature

Hall C-1



Area Classification: 3  
 Building/Area: C-2  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/22/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	30%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile β Floor	618 cpm	1236 cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/22/2007	1400	bwb
End:	2/22/2007	1655	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 776 cpm  
 Smears taken - see map for location  
 16A through 19A - No positive activity detected


No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document

Technician/Surveyor: Byron Bland *Byron Bland* Date: 4/11/2007  
 Name Signature  
 Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W. Moon* Date: 4/11/2007  
 Name Signature



Hall C-2



**Survey Requirements**

Area Classification: 3  
 Building/Area: C-3  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/22/2007

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	30%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile β Floor	618 cpm	1236 cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/22/2007	1400	bwb
End:	2/22/2007	1655	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 803 cpm  
 Smears taken - see map for location  
 26A through 30A - No positive activity detected  
  
 No activity found in excess of the RG 1.86 (1974) clean-up guidelines

Attach survey map to this document


Technician/Surveyor: Byron Bland *Byron Bland*  
 Name Signature

Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W. Moon*  
 Name Signature

Date: 4/11/2007

Hall C-3



Area Classification: 3  
 Building/Area: Hall C-4/C-5  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: covered floor  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	35%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
covered wood	828 cpm	1.65k cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Highest scan level seen in this room was 1.04k cpm  
 Smears taken - see map for location  
 54B through 56B & 100B on floor - No positive activity detected

No activity found in excess of the RG 1.86 (1974) clean-up guidelines

**Attach survey map to this document**


Technician/Surveyor: Byron Bland *Byron Bland*  
 Name Signature

Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W. Moon*  
 Name Signature

Date: 4/11/2007

Hall C-4



Area Classification: 3  
 Building/Area: Hall C-6  
 Floor/Elevation: Floor  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: 8 inch tile  
 Survey Type: β scan 771 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007

**Survey Requirements**

	Beta	Gamma
Floor	20%	
Wall		
Ceiling		
Actual surveyed	40%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-37-1  
 Detector Serial Number: PR145081

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
8 inch tile β Floor	618 cpm	1236 cpm	

**Source Checks**

	Date	Time	Initials
Prior:	2/23/2007	925	bwb
End:	2/23/2007	1635	bwb

Note: Source checks required at beginning and end of shift


**Comments:**

Highest scan level seen in this room was 720 cpm  
 Smears taken - see map for location  
 15C on floor and 24C in sink drain - No positive activity detected


**Comments:**

No activity found in excess of the RG 1.86 (1974) clean-up guidelines


**Attach survey map to this document**

Technician/Surveyor: Byron Bland   
 Name Signature

Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP   
 Name Signature

Date: 4/11/2007



Area Classification: 1  
 Building/Area: All class 1 areas  
 Floor/Elevation: \_\_\_\_\_  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: all surfaces  
 Survey Type: γ general area  
 Date/Time: 3/22/2007

**Survey Requirements**

	Beta	Gamma
Floor		
Wall		
Ceiling		
Class 1 areas		100%

**Instrument Information**

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: \_\_\_\_\_  
 Logger Serial Number: \_\_\_\_\_  
 Cal Due Date: 9/20/2007 9/19/2007  
 Detector Model: Model 19 model 19  
 Detector Serial Number: 180302 182679

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
All material	8-15 μR/hr	30 μR/hr	

**Source Checks**

	Date	Time	Initials
Prior:	<u>2/22/2007</u>	<u>820</u>	<u>bwb</u>
End:	<u>2/22/2007</u>	<u>1200</u>	<u>bwb</u>

Note: Source checks required at beginning and end of shift


**Comments:**

No elevated levels were detected except for in rooms 137 and 136 but when verified with off site background materials it was determined that the leaves seen in these two rooms were in fact background

Attach survey map to this document


Technician/Surveyor: Byron Bland *Byron Bland* Date: 4/11/2007  
 Name Signature  
 Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W. Moon* Date: 4/11/2007  
 Name Signature






*Hall C-6*

Room 136



Room 137



Area Classification: 1  
 Building/Area: Room 113,a,b,c,d  
 Floor/Elevation: All objects in rooms  
 Survey Unit/Grid: \_\_\_\_\_  
 Surface: misc above floor  
 Survey Type: β scan 126 cm<sup>2</sup> probe  
 Date/Time: 2/23/2007 and 3/22/2007

**Survey Requirements**

	Beta	Gamma
Floor		
Wall		
Ceiling		
Material in rooms	100%	

**Instrument Information**

Floor Monitor ID Number: \_\_\_\_\_  
 Alpha/Beta Scan Speed: 2.5 inches/sec  
 Alpha/Beta Scan Height: 1/2 inch  
 Gamma Scan Speed: \_\_\_\_\_  
 Gamma Scan Height: \_\_\_\_\_

MARSS Inst ID: \_\_\_\_\_  
 Logger Model: 2350-1  
 Logger Serial Number: 149408  
 Cal Due Date: 10/22/2007  
 Detector Model: 43-68  
 Detector Serial Number: Pr148454

**Background Information**

Material	Bkgd Level	Invest. Level	Alarm Level
Misc	225β cpm	450β cpm	

**Source Checks**

	Date	Time	Initials
Prior:	3/22/2007	905	bwb
End:	3/22/2007	1200	bwb

Note: Source checks required at beginning and end of shift

**Comments:**

Mesureable levels of contamination were found in rooms 113B on the lab sink and in room 113D on the edge of the sink.


Attach survey map to this document

Technician/Surveyor: Byron Bland *Byron Bland*  
 Name Signature


Date: 4/11/2007

Supervisor/Reviewer: Joseph W. Moon, CHP *Joseph W. Moon*  
 Name Signature


Date: 4/11/2007




*Room 113A*



*Room 113B*






113C




# Room 113D



---

**Attachment 2.0**  
**U. S. NRC Regulatory Guide 1.86 (1974)**



U.S. ATOMIC ENERGY COMMISSION

June 1974

# REGULATORY GUIDE

DIRECTORATE OF REGULATORY STANDARDS

## REGULATORY GUIDE 1.86

### TERMINATION OF OPERATING LICENSES FOR NUCLEAR REACTORS

#### A. INTRODUCTION

Section 50.51, "Duration of license, renewal," of 10 CFR Part 50, "Licensing of Production and Utilization Facilities," requires that each license to operate a production and utilization facility be issued for a specified duration. Upon expiration of the specified period, the license may be either renewed or terminated by the Commission. Section 50.82, "Applications for termination of licenses," specifies the requirements that must be satisfied to terminate an operating license, including the requirement that the dismantlement of the facility and disposal of the component parts not be inimical to the common defense and security or to the health and safety of the public. This guide describes methods and procedures considered acceptable by the Regulatory staff for the termination of operating licenses for nuclear reactors. The Advisory Committee on Reactor Safeguards has been consulted concerning this guide and has concurred in the regulatory position.

#### B. DISCUSSION

When a licensee decides to terminate his nuclear reactor operating license, he may, as a first step in the process, request that his operating license be amended to restrict him to possess but not operate the facility. The advantage to the licensee of converting to such a possession-only license is reduced surveillance requirements in that periodic surveillance of equipment important to the safety of reactor operation is no longer required. Once this possession-only license is issued, reactor operation is not permitted. Other activities related to cessation of operations such as unloading fuel from the reactor and placing it in storage (either onsite or offsite) may be continued.

A licensee having a possession-only license must retain, with the Part 50 license, authorization for special nuclear material (10 CFR Part 70, "Special Nuclear Material"), byproduct material (10 CFR Part 30, "Rules of General Applicability to Licensing of Byproduct Material"), and source material (10 CFR Part 40, "Licensing of Source Material"), until the fuel, radioactive components, and sources are removed from the facility. Appropriate administrative controls and facility requirements are imposed by the Part 50 license and the technical specifications to assure that proper surveillance is performed and that the reactor facility is maintained in a safe condition and not operated.

A possession-only license permits various options and procedures for decommissioning, such as mothballing, entombment, or dismantling. The requirements imposed depend on the option selected.

Section 50.82 provides that the licensee may dismantle and dispose of the component parts of a nuclear reactor in accordance with existing regulations. For research reactors and critical facilities, this has usually meant the disassembly of a reactor and its shipment offsite, sometimes to another appropriately licensed organization for further use. The site from which a reactor has been removed must be decontaminated, as necessary, and inspected by the Commission to determine whether unrestricted access can be approved. In the case of nuclear power reactors, dismantling has usually been accomplished by shipping fuel offsite, making the reactor inoperable, and disposing of some of the radioactive components.

Radioactive components may be either shipped off-site for burial at an authorized burial ground or secured

---

#### USAEC REGULATORY GUIDES

Regulatory Guides are issued to describe and make available to the public methods acceptable to the AEC Regulatory staff of implementing specific parts of the Commission's regulations, to delineate techniques used by the staff in evaluating specific problems or postulated accidents, or to provide guidance to applicants. Regulatory Guides are not substitutes for regulations and compliance with them is not required. Methods and solutions different from those set out in the guides will be acceptable if they provide a basis for the findings requisite to the issuance or continuance of a permit or license by the Commission.

Published guides will be revised periodically, as appropriate, to accommodate comments and to reflect new information or experience.

Copies of published guides may be obtained by request indicating the divisions desired to the U.S. Atomic Energy Commission, Washington, D.C. 20545, Attention: Director of Regulatory Standards. Comments and suggestions for improvements in these guides are encouraged and should be sent to the Secretary of the Commission, U.S. Atomic Energy Commission, Washington, D.C. 20545, Attention: Chief, Public Proceedings Staff.

The guides are issued in the following ten broad divisions:

- |                                   |                        |
|-----------------------------------|------------------------|
| 1. Power Reactors                 | 6. Products            |
| 2. Research and Test Reactors     | 7. Transportation      |
| 3. Fuels and Materials Facilities | 8. Occupational Health |
| 4. Environmental and Siting       | 9. Antitrust Review    |
| 5. Materials and Plant Protection | 10. General            |

on the site. Those radioactive materials remaining on the site must be isolated from the public by physical barriers or other means to prevent public access to hazardous levels of radiation. Surveillance is necessary to assure the long term integrity of the barriers. The amount of surveillance required depends upon (1) the potential hazard to the health and safety of the public from radioactive material remaining on the site and (2) the integrity of the physical barriers. Before areas may be released for unrestricted use, they must have been decontaminated or the radioactivity must have decayed to less than prescribed limits (Table I).

The hazard associated with the retired facility is evaluated by considering the amount and type of remaining contamination, the degree of confinement of the remaining radioactive materials, the physical security provided by the confinement, the susceptibility to release of radiation as a result of natural phenomena, and the duration of required surveillance.

### C. REGULATORY POSITION

#### 1. APPLICATION FOR A LICENSE TO POSSESS BUT NOT OPERATE (POSSESSION-ONLY LICENSE)

A request to amend an operating license to a possession-only license should be made to the Director of Licensing, U.S. Atomic Energy Commission, Washington, D.C. 20545. The request should include the following information:

- a. A description of the current status of the facility.
- b. A description of measures that will be taken to prevent criticality or reactivity changes and to minimize releases of radioactivity from the facility.
- c. Any proposed changes to the technical specifications that reflect the possession-only facility status and the necessary disassembly/retirement activities to be performed.
- d. A safety analysis of both the activities to be accomplished and the proposed changes to the technical specifications.
- e. An inventory of activated materials and their location in the facility.

#### 2. ALTERNATIVES FOR REACTOR RETIREMENT

Four alternatives for retirement of nuclear reactor facilities are considered acceptable by the Regulatory staff. These are:

- a. **Mothballing.** Mothballing of a nuclear reactor facility consists of putting the facility in a state of protective storage. In general, the facility may be left intact except that all fuel assemblies and the radioactive

fluids and waste should be removed from the site. Adequate radiation monitoring, environmental surveillance, and appropriate security procedures should be established under a possession-only license to ensure that the health and safety of the public is not endangered.

- b. **In-Place Entombment.** In-place entombment consists of sealing all the remaining highly radioactive or contaminated components (e.g., the pressure vessel and reactor internals) within a structure integral with the biological shield after having all fuel assemblies, radioactive fluids and wastes, and certain selected components shipped offsite. The structure should provide integrity over the period of time in which significant quantities (greater than Table I levels) of radioactivity remain with the material in the entombment. An appropriate and continuing surveillance program should be established under a possession-only license.

- c. **Removal of Radioactive Components and Dismantling.** All fuel assemblies, radioactive fluids and waste, and other materials having activities above accepted unrestricted activity levels (Table I) should be removed from the site. The facility owner may then have unrestricted use of the site with no requirement for a license. If the facility owner so desires, the remainder of the reactor facility may be dismantled and all vestiges removed and disposed of.

- d. **Conversion to a New Nuclear System or a Fossil Fuel System.** This alternative, which applies only to nuclear power plants, utilizes the existing turbine system with a new steam supply system. The original nuclear steam supply system should be separated from the electric generating system and disposed of in accordance with one of the previous three retirement alternatives.

#### 3. SURVEILLANCE AND SECURITY FOR THE RETIREMENT ALTERNATIVES WHOSE FINAL STATUS REQUIRES A POSSESSION-ONLY LICENSE

A facility which has been licensed under a possession-only license may contain a significant amount of radioactivity in the form of activated and contaminated hardware and structural materials. Surveillance and commensurate security should be provided to assure that the public health and safety are not endangered.

- a. Physical security to prevent inadvertent exposure of personnel should be provided by multiple locked barriers. The presence of these barriers should make it extremely difficult for an unauthorized person to gain access to areas where radiation or contamination levels exceed those specified in Regulatory Position C.4. To prevent inadvertent exposure, radiation areas above 5 mR/hr, such as near the activated primary system of a power plant, should be appropriately marked and should not be accessible except by cutting of welded closures or the disassembly and removal of substantial structures

and/or shielding material. Means such as a remote-readout intrusion alarm system should be provided to indicate to designated personnel when a physical barrier is penetrated. Security personnel that provide access control to the facility may be used instead of the physical barriers and the intrusion alarm systems.

b. The physical barriers to unauthorized entrance into the facility, e.g., fences, buildings, welded doors, and access openings, should be inspected at least quarterly to assure that these barriers have not deteriorated and that locks and locking apparatus are intact.

c. A facility radiation survey should be performed at least quarterly to verify that no radioactive material is escaping or being transported through the containment barriers in the facility. Sampling should be done along the most probable path by which radioactive material such as that stored in the inner containment regions could be transported to the outer regions of the facility and ultimately to the environs.

d. An environmental radiation survey should be performed at least semiannually to verify that no significant amounts of radiation have been released to the environment from the facility. Samples such as soil, vegetation, and water should be taken at locations for which statistical data has been established during reactor operations.

e. A site representative should be designated to be responsible for controlling authorized access into and movement within the facility.

f. Administrative procedures should be established for the notification and reporting of abnormal occurrences such as (1) the entrance of an unauthorized person or persons into the facility and (2) a significant change in the radiation or contamination levels in the facility or the offsite environment.

g. The following reports should be made:

(1) An annual report to the Director of Licensing, U.S. Atomic Energy Commission, Washington, D.C. 20545, describing the results of the environmental and facility radiation surveys, the status of the facility, and an evaluation of the performance of security and surveillance measures.

(2) An abnormal occurrence report to the Regulatory Operations Regional Office by telephone within 24 hours of discovery of an abnormal occurrence. The abnormal occurrence will also be reported in the annual report described in the preceding item.

h. Records or logs relative to the following items should be kept and retained until the license is terminated, after which they may be stored with other plant records:

- (1) Environmental surveys;
- (2) Facility radiation surveys,
- (3) Inspections of the physical barriers, and
- (4) Abnormal occurrences.

#### 4. DECONTAMINATION FOR RELEASE FOR UNRESTRICTED USE

If it is desired to terminate a license and to eliminate any further surveillance requirements, the facility should be sufficiently decontaminated to prevent risk to the public health and safety. After the decontamination is satisfactorily accomplished and the site inspected by the Commission, the Commission may authorize the license to be terminated and the facility abandoned or released for unrestricted use. The licensee should perform the decontamination using the following guidelines:

a. The licensee should make a reasonable effort to eliminate residual contamination.

b. No covering should be applied to radioactive surfaces of equipment or structures by paint, plating, or other covering material until it is known that contamination levels (determined by a survey and documented) are below the limits specified in Table I. In addition, a reasonable effort should be made (and documented) to further minimize contamination prior to any such covering.

c. The radioactivity of the interior surfaces of pipes, drain lines, or ductwork should be determined by making measurements at all traps and other appropriate access points, provided contamination at these locations is likely to be representative of contamination on the interior of the pipes, drain lines, or ductwork. Surfaces of premises, equipment, or scrap which are likely to be contaminated but are of such size, construction, or location as to make the surface inaccessible for purposes of measurement should be assumed to be contaminated in excess of the permissible radiation limits.

d. Upon request, the Commission may authorize a licensee to relinquish possession or control of premises, equipment, or scrap having surfaces contaminated in excess of the limits specified. This may include, but is not limited to, special circumstances such as the transfer of premises to another licensed organization that will continue to work with radioactive materials. Requests for such authorization should provide:

(1) Detailed, specific information describing the premises, equipment, scrap, and radioactive contaminants and the nature, extent, and degree of residual surface contamination.

(2) A detailed health and safety analysis indicating that the residual amounts of materials on surface areas, together with other considerations such as the prospective use of the premises, equipment, or scrap, are unlikely to result in an unreasonable risk to the health and safety of the public.

e. Prior to release of the premises for unrestricted use, the licensee should make a comprehensive radiation survey establishing that contamination is within the limits specified in Table I. A survey report should be filed with the Director of Licensing, U.S. Atomic Energy Commission, Washington, D.C. 20545, with a copy to the Director of the Regulatory Operations Regional Office having jurisdiction. The report should be filed at least 30 days prior to the planned date of abandonment. The survey report should:

(1) Identify the premises;

(2) Show that reasonable effort has been made to reduce residual contamination to as low as practicable levels;

(3) Describe the scope of the survey and the general procedures followed; and

(4) State the finding of the survey in units specified in Table I.

After review of the report, the Commission may inspect the facilities to confirm the survey prior to granting approval for abandonment.

## 5. REACTOR RETIREMENT PROCEDURES

As indicated in Regulatory Position C.2, several alternatives are acceptable for reactor facility retirement. If minor disassembly or "mothballing" is planned, this could be done by the existing operating and maintenance procedures under the license in effect. Any planned actions involving an unreviewed safety question

or a change in the technical specifications should be reviewed and approved in accordance with the requirements of 10 CFR §50.59.

If major structural changes to radioactive components of the facility are planned, such as removal of the pressure vessel or major components of the primary system, a dismantlement plan including the information required by §50.82 should be submitted to the Commission. A dismantlement plan should be submitted for all the alternatives of Regulatory Position C.2 except mothballing. However, minor disassembly activities may still be performed in the absence of such a plan, provided they are permitted by existing operating and maintenance procedures. A dismantlement plan should include the following:

a. A description of the ultimate status of the facility

b. A description of the dismantling activities and the precautions to be taken.

c. A safety analysis of the dismantling activities including any effluents which may be released.

d. A safety analysis of the facility in its ultimate status.

Upon satisfactory review and approval of the dismantling plan, a dismantling order is issued by the Commission in accordance with §50.82. When dismantling is completed and the Commission has been notified by letter, the appropriate Regulatory Operations Regional Office inspects the facility and verifies completion in accordance with the dismantlement plan. If residual radiation levels do not exceed the values in Table I, the Commission may terminate the license. If these levels are exceeded, the licensee retains the possession-only license under which the dismantling activities have been conducted or, as an alternative, may make application to the State (if an Agreement State) for a byproduct materials license.

TABLE I

## ACCEPTABLE SURFACE CONTAMINATION LEVELS

NUCLIDE <sup>a</sup>	AVERAGE <sup>b c</sup>	MAXIMUM <sup>b d</sup>	REMOVABLE <sup>b e</sup>
U-nat, U-235, U-238, and associated decay products	5,000 dpm $\alpha$ /100 cm <sup>2</sup>	15,000 dpm $\alpha$ /100 cm <sup>2</sup>	1,000 dpm $\alpha$ /100 cm <sup>2</sup>
Transuranics, Ra-226, Ra-228, Th-230, Th-228, Pa-231, Ac-227, I-125, I-129	100 dpm/100 cm <sup>2</sup>	300 dpm/100 cm <sup>2</sup>	20 dpm/100 cm <sup>2</sup>
Th-nat, Th-232, Sr-90, Ra-223, Ra-224, U-232, I-126, I-131, I-133	1000 dpm/100 cm <sup>2</sup>	3000 dpm/100 cm <sup>2</sup>	200 dpm/100 cm <sup>2</sup>
Beta-gamma emitters (nuclides with decay modes other than alpha emission or spontaneous fission) except Sr-90 and others noted above.	5000 dpm $\beta$ - $\gamma$ /100 cm <sup>2</sup>	15,000 dpm $\beta$ - $\gamma$ /100 cm <sup>2</sup>	1000 dpm $\beta$ - $\gamma$ /100 cm <sup>2</sup>

<sup>a</sup>Where surface contamination by both alpha- and beta-gamma-emitting nuclides exists, the limits established for alpha- and beta-gamma-emitting nuclides should apply independently.

<sup>b</sup>As used in this table, dpm (disintegrations per minute) means the rate of emission by radioactive material as determined by correcting the counts per minute observed by an appropriate detector for background, efficiency, and geometric factors associated with the instrumentation.

<sup>c</sup>Measurements of average contaminant should not be averaged over more than 1 square meter. For objects of less surface area, the average should be derived for each such object.

<sup>d</sup>The maximum contamination level applies to an area of not more than 100 cm<sup>2</sup>.

<sup>e</sup>The amount of removable radioactive material per 100 cm<sup>2</sup> of surface area should be determined by wiping that area with dry filter or soft absorbent paper, applying moderate pressure, and assessing the amount of radioactive material on the wipe with an appropriate instrument of known efficiency. When removable contamination on objects of less surface area is determined, the pertinent levels should be reduced proportionally and the entire surface should be wiped.

Final 8/13/2007

**Attachment 3.0  
Instrument Calibration Records**



RSO, Inc.  
P.O. Box 1450  
Laurel, MD 20725  
(301) 953-2482

RSO Job No. 7040

# Certificate of Calibration

ISSUED TO: Chesapeake Nuclear Services  
788 Sonne Dr.  
Annapolis, MD 21401

INSTRUMENT: LUDLUM  
MODEL: 2360  
TYPE: DATA LOGGER  
SN: 141321

CONTACT: Stewart Bland  
PHONE: (410) 266-9174

PO NO: Credit Card

RSO, Inc. certifies that on 02/15/2007 the above described instrument was calibrated using a radioactive source to determine the efficiency for a specific radionuclide(s) and using electronically generated pulse for the linearity. Pulsed using Ludlum 500-2, S/N 159110.

The results are tabulated below. Calibration is traceable to NIST.

### Calibration Data

	RANGE	EXPECTED	OBSERVED	C.F.
X	1	100	100 cpm	1.00
		400	400 cpm	1.00
X	10	1000	1000 cpm	1.00
		4000	4000 cpm	1.00
X	100	10000	10000 cpm	1.00
		40000	40000 cpm	1.00
X	1000	100000	100000 cpm	1.00
		400000	400000 cpm	1.00
C.F. AVERAGE				1.00

Probe type(s) Probe1: PROPORTIONAL Probe2: Probe3:

MODEL	SER#	WINDOW	GEOMETRY	VOLT	ISOTOPE 1	EFF.(%)	ISOTOPE 2	EFF.(%)	ISOTOPE 3	EFF.(%)	ISOTOPE 4	EFF.(%)
43-68	PR148454	FIXED	CONTACT	1658	Tc99	17	C14	20				

### INSTRUMENT CHECKS

1 mR/hr CHECK: N/A  
BATTERY CHECK: NORMAL  
CHECK SOURCE 1: N/A READING:  
CHECK SOURCE 2: N/A READING:

### ENVIRONMENTAL

TEMP: 24 °C  
PRESS: 759 mmHg  
HUMID: 23 %

THE SUGGESTED RECALIBRATION DATE FOR THIS INSTRUMENT IS **02/15/2008**

Calibrated By:

*Dorsey Austin*  
Dorsey Austin

Reviewed By:

*RSE*

Cal Date: 02/15/2007

Maryland License MD-33-021-01

4380

RSO, Inc.  
P.O. Box 1450  
Laurel, MD 20725  
(301) 953-2482

RSO Job No. 7040

# Certificate of Calibration

ISSUED TO: Chesapeake Nuclear Services  
788 Sonne Dr.  
Annapolis, MD 21401

INSTRUMENT: LUDLUM  
MODEL: 2360  
TYPE: DATA LOGGER  
SN: 141311

CONTACT: Stewart Bland  
PHONE: (410) 266-9174

PO NO: Credit Card

RSO, Inc. certifies that on 02/15/2007 the above described instrument was calibrated using a radioactive source to determine the efficiency for a specific radionuclide(s) and using electronically generated pulse for the linearity. Pulsed using Ludlum 500-2, S/N 159110.

The results are tabulated below. Calibration is traceable to NIST.

### Calibration Data

	RANGE	EXPECTED	OBSERVED	C.F.
X	1	100	103 cpm	0.97
		400	400 cpm	1.00
X	10	1000	1000 cpm	1.00
		4000	4000 cpm	1.00
X	100	10000	10000 cpm	1.00
		40000	40000 cpm	1.00
X	1000	100000	100280 cpm	1.00
		400000	400000 cpm	1.00
			C.F. AVERAGE	1.00

Probe type(s)    Probe1: PROPORTIONAL                      Probe2:                      Probe3:

MODEL	SER#	WINDOW	GEOMETRY	VOLT	ISOTOPE 1	EFF.(%)	ISOTOPE 2	EFF.(%)	ISOTOPE 3	EFF.(%)	ISOTOPE 4	EFF.(%)
43-68	PR148454	FIXED	CONTACT	1658	Tc99	18	C14	20				

### INSTRUMENT CHECKS

1 mR/hr CHECK: N/A  
BATTERY CHECK: NORMAL  
CHECK SOURCE 1: N/A    READING:  
CHECK SOURCE 2: N/A    READING:

### ENVIRONMENTAL

TEMP: 23°C  
PRESS: 759 mmHg  
HUMID: 24 %

THE SUGGESTED RECALIBRATION DATE FOR THIS INSTRUMENT IS 02/15/2008

Calibrated By:

*Stewart Bland*  
Dorsey Austin

Reviewed By:

*RAG*


Cal Date: 02/15/2007

Maryland License MD-33-021-01

4381

---

**Attachment 4.0**  
**Large Area Survey Map Initial Survey**



- C Centrifuge
- DW Dishwasher
- FL Flycatcher Locker
- WC Water Fountain
- H HEATING UNIT
- FH FUME HOOD
- F Refrigerator
- B LAB BENCH WORK SURFACE
- S SINK
- FC File Cabinets
- PC Portable Cabinet
- X Floor Drain
- T Toilet
- F Freezer
- T Tile Floor 8x8x1/2 V Vinyl Roll Guide on Concrete
- C Carpet Floor
- S Sealed Concrete
- CT Ceramic Tile Red 6"x6" ceramic
- SW Solid Wood
- INC Incubator/oven
- CTL Little ceramic tiles 3/4"x3/4" Rm 104 only

- 4 Ash Can Absorbent kl 2x2 liter
- 3 Red Ash Can
- 2 Red Waste Can Boxes
- 1 Red Waste 35 gal water 24A dipped in no liquid
- \* 5 or 6 old milled crushed red waste 25A on cardboard surfaces
- Boxes (cardboard) present under

ONE H<sub>2</sub>O Fluoride Gas Tank  
 O<sub>2</sub> Oxygen Tank

Note 39B taken inside Bench Drawer  
 Rm 113C Top Right  
 (color) Reductive Waste Store for Decay  
 (with hasp lock)

Sink Drains in  
 Rm 129 1C  
 Rm 130 2C  
 Rm 131 3C  
 Rm 132 4C

⊗ indicates smear taken in/on  
 floor or sink drain

Swipes on Hot Spots in Rm 113 3500pm 26C  
 4500pm 27C  
 Rm 113B 6200pm 28C  
 Sink in Rm 113B 8500pm 29C

30C Womens Restroom 104 Sink Drain

FLOOR PLAN

BUILDING 72

SCALE: 1/4" = 1'-0"

RM #	ACTIVITY/OCCUPANT	SUPT
10A	VACANT	NA
10B	VACANT	NA
10C	VACANT	NA
10D	VACANT	NA
10E	VACANT	NA
10F	VACANT	NA
10G	VACANT	NA
10H	VACANT	NA
10I	VACANT	NA
10J	VACANT	NA
10K	VACANT	NA
10L	VACANT	NA
10M	VACANT	NA
10N	VACANT	NA
10O	VACANT	NA
10P	VACANT	NA
10Q	VACANT	NA
10R	VACANT	NA
10S	VACANT	NA
10T	VACANT	NA
10U	VACANT	NA
10V	VACANT	NA
10W	VACANT	NA
10X	VACANT	NA
10Y	VACANT	NA
10Z	VACANT	NA
11A	VACANT	NA
11B	VACANT	NA
11C	VACANT	NA
11D	VACANT	NA
11E	VACANT	NA
11F	VACANT	NA
11G	VACANT	NA
11H	VACANT	NA
11I	VACANT	NA
11J	VACANT	NA
11K	VACANT	NA
11L	VACANT	NA
11M	VACANT	NA
11N	VACANT	NA
11O	VACANT	NA
11P	VACANT	NA
11Q	VACANT	NA
11R	VACANT	NA
11S	VACANT	NA
11T	VACANT	NA
11U	VACANT	NA
11V	VACANT	NA
11W	VACANT	NA
11X	VACANT	NA
11Y	VACANT	NA
11Z	VACANT	NA
12A	VACANT	NA
12B	VACANT	NA
12C	VACANT	NA
12D	VACANT	NA
12E	VACANT	NA
12F	VACANT	NA
12G	VACANT	NA
12H	VACANT	NA
12I	VACANT	NA
12J	VACANT	NA
12K	VACANT	NA
12L	VACANT	NA
12M	VACANT	NA
12N	VACANT	NA
12O	VACANT	NA
12P	VACANT	NA
12Q	VACANT	NA
12R	VACANT	NA
12S	VACANT	NA
12T	VACANT	NA
12U	VACANT	NA
12V	VACANT	NA
12W	VACANT	NA
12X	VACANT	NA
12Y	VACANT	NA
12Z	VACANT	NA
13A	VACANT	NA
13B	VACANT	NA
13C	VACANT	NA
13D	VACANT	NA
13E	VACANT	NA
13F	VACANT	NA
13G	VACANT	NA
13H	VACANT	NA
13I	VACANT	NA
13J	VACANT	NA
13K	VACANT	NA
13L	VACANT	NA
13M	VACANT	NA
13N	VACANT	NA
13O	VACANT	NA
13P	VACANT	NA
13Q	VACANT	NA
13R	VACANT	NA
13S	VACANT	NA
13T	VACANT	NA
13U	VACANT	NA
13V	VACANT	NA
13W	VACANT	NA
13X	VACANT	NA
13Y	VACANT	NA
13Z	VACANT	NA
14A	VACANT	NA
14B	VACANT	NA
14C	VACANT	NA
14D	VACANT	NA
14E	VACANT	NA
14F	VACANT	NA
14G	VACANT	NA
14H	VACANT	NA
14I	VACANT	NA
14J	VACANT	NA
14K	VACANT	NA
14L	VACANT	NA
14M	VACANT	NA
14N	VACANT	NA
14O	VACANT	NA
14P	VACANT	NA
14Q	VACANT	NA
14R	VACANT	NA
14S	VACANT	NA
14T	VACANT	NA
14U	VACANT	NA
14V	VACANT	NA
14W	VACANT	NA
14X	VACANT	NA
14Y	VACANT	NA
14Z	VACANT	NA
15A	VACANT	NA
15B	VACANT	NA
15C	VACANT	NA
15D	VACANT	NA
15E	VACANT	NA
15F	VACANT	NA
15G	VACANT	NA
15H	VACANT	NA
15I	VACANT	NA
15J	VACANT	NA
15K	VACANT	NA
15L	VACANT	NA
15M	VACANT	NA
15N	VACANT	NA
15O	VACANT	NA
15P	VACANT	NA
15Q	VACANT	NA
15R	VACANT	NA
15S	VACANT	NA
15T	VACANT	NA
15U	VACANT	NA
15V	VACANT	NA
15W	VACANT	NA
15X	VACANT	NA
15Y	VACANT	NA
15Z	VACANT	NA
16A	VACANT	NA
16B	VACANT	NA
16C	VACANT	NA
16D	VACANT	NA
16E	VACANT	NA
16F	VACANT	NA
16G	VACANT	NA
16H	VACANT	NA
16I	VACANT	NA
16J	VACANT	NA
16K	VACANT	NA
16L	VACANT	NA
16M	VACANT	NA
16N	VACANT	NA
16O	VACANT	NA
16P	VACANT	NA
16Q	VACANT	NA
16R	VACANT	NA
16S	VACANT	NA
16T	VACANT	NA
16U	VACANT	NA
16V	VACANT	NA
16W	VACANT	NA
16X	VACANT	NA
16Y	VACANT	NA
16Z	VACANT	NA
17A	VACANT	NA
17B	VACANT	NA
17C	VACANT	NA
17D	VACANT	NA
17E	VACANT	NA
17F	VACANT	NA
17G	VACANT	NA
17H	VACANT	NA
17I	VACANT	NA
17J	VACANT	NA
17K	VACANT	NA
17L	VACANT	NA
17M	VACANT	NA
17N	VACANT	NA
17O	VACANT	NA
17P	VACANT	NA
17Q	VACANT	NA
17R	VACANT	NA
17S	VACANT	NA
17T	VACANT	NA
17U	VACANT	NA
17V	VACANT	NA
17W	VACANT	NA
17X	VACANT	NA
17Y	VACANT	NA
17Z	VACANT	NA
18A	VACANT	NA
18B	VACANT	NA
18C	VACANT	NA
18D	VACANT	NA
18E	VACANT	NA
18F	VACANT	NA
18G	VACANT	NA
18H	VACANT	NA
18I	VACANT	NA
18J	VACANT	NA
18K	VACANT	NA
18L	VACANT	NA
18M	VACANT	NA
18N	VACANT	NA
18O	VACANT	NA
18P	VACANT	NA
18Q	VACANT	NA
18R	VACANT	NA
18S	VACANT	NA
18T	VACANT	NA
18U	VACANT	NA
18V	VACANT	NA
18W	VACANT	NA
18X	VACANT	NA
18Y	VACANT	NA
18Z	VACANT	NA
19A	VACANT	NA
19B	VACANT	NA
19C	VACANT	NA
19D	VACANT	NA
19E	VACANT	NA
19F	VACANT	NA
19G	VACANT	NA
19H	VACANT	NA
19I	VACANT	NA
19J	VACANT	NA
19K	VACANT	NA
19L	VACANT	NA
19M	VACANT	NA
19N	VACANT	NA
19O	VACANT	NA
19P	VACANT	NA
19Q	VACANT	NA
19R	VACANT	NA
19S	VACANT	NA
19T	VACANT	NA
19U	VACANT	NA
19V	VACANT	NA
19W	VACANT	NA
19X	VACANT	NA
19Y	VACANT	NA
19Z	VACANT	NA
20A	VACANT	NA
20B	VACANT	NA
20C	VACANT	NA
20D	VACANT	NA
20E	VACANT	NA
20F	VACANT	NA
20G	VACANT	NA
20H	VACANT	NA
20I	VACANT	NA
20J	VACANT	NA
20K	VACANT	NA
20L	VACANT	NA
20M	VACANT	NA
20N	VACANT	NA
20O	VACANT	NA
20P	VACANT	NA
20Q	VACANT	NA
20R	VACANT	NA
20S	VACANT	NA
20T	VACANT	NA
20U	VACANT	NA
20V	VACANT	NA
20W	VACANT	NA
20X	VACANT	NA
20Y	VACANT	NA
20Z	VACANT	NA

Final 8/13/2007

**Attachment 5.0  
Initial Smear Survey Results**



Radiation Service Organization

March 7, 2007

Chesapeake Nuclear  
Attn: Stewart Bland  
788 Sonne Dr.  
Annapolis, MD 21401

Dear Mr. Bland,

Enclosed please find the results for the wipe tests received on February 26, 2007. The wipe tests were analyzed using Liquid Scintillation and Gamma Counters. An individual data print out for each analysis process is attached for your review. The only elevated activity indicated on the analysis reports were as follows:

Wipe test group B1-B100 found 3 wipe tests exceeding 100 but less than 300 dpm.  
Wipe test group C1-C30 found 1 wipe test exceeding 100 but less than 300 dpm.

All other results indicated activity levels below 50 dpm which included the gamma test results.

If you have any questions please do not hesitate to call me at (301) 953-2482 ext. 305 or by e-mail [james.dean@rsoinc.com](mailto:james.dean@rsoinc.com).

Sincerely,

James W. Dean  
Manager, Radiation Safety Services – Radiation Safety Officer

JWD:11P

Enclosure

NIH

Assay Definition- A1-A100

Assay Description:  
CHESAPEAKE NUCLEAR

REVIEWED BY:  
JD 2/28/07

Assay Type: DPM (Triple)

Report Name: Report1

Output Data Path: C:\Packard\Tricarb\Results\NIH\Triple Lable DPM

Raw Results Path: C:\Packard\Tricarb\Results\NIH\Triple Lable DPM\20070227\_0946.results

Assay File Name: C:\Packard\TriCarb\Assays\Triple Lable DPM.lsa

Count Conditions-

Nuclide: Triple Label

Quench Indicator: tSIE/AEC

External Std Terminator (sec): 0.5 2s%

Pre-Count Delay (min): 0.00

Quench Sets:

Low Energy: 3H-TOL-7-17-06

Mid Energy: 14C-TOL-07-17-06

High Energy: 32P-UG-02-28-05

Count Time (min): 5.00

Count Mode: Normal

Assay Count Cycles: 1

Repeat Sample Count: 1

#Vials/Sample: 1

Calculate % Reference: Off

Background Subtract: On - 1st Vial

Low CPM Threshold: Off

2 Sigma % Terminator: Off

Regions	LL	UL	Bkg Subtract
A	0.0	12.0	1st Vial
B	12.0	156.0	1st Vial
C	156.0	2000.0	1st Vial

Count Corrections-

Static Controller: On

Luminescence Correction: On

Colored Samples: On

Heterogeneity Monitor: n/a

Coincidence Time (nsec): 18

Delay Before Burst (nsec): 75

Half Life-

Half Life Correction: Off

Regions	Half Life	Units	Reference Date	Reference Time
A				
B				
C				

Cycle 1 Results

S#	Time	CPMA	CPMB	CPMC	DPM1	DPM2	DPM3	SIS	tSIE	LUM
1	10.00	5	8	6	0	0	0	53.33	565.99	2
2	5.00	6	12	1	10	14	1	50.09	507.24	1
3	5.00	2	5	-1	3	6	-1	78.46	512.01	1
4	5.00	1	1	1	2	1	1	66.19	476.71	1
5	5.00	3	3	2	5	3	3	49.74	467.57	1
6	5.00	5	4	2	8	4	2	60.15	573.07	0
7	5.00	1	5	0	1	5	-0	75.54	427.61	1
8	5.00	0	0	2	1	-0	3	164.69	462.19	1
9	5.00	1	3	1	2	4	1	1.62	306.19	4

*LD*

10	5.00	0	1	1	0	1	2	84.37	411.28	1
11	5.00	3	2	-1	5	2	-2	43.92	479.24	1
12	5.00	-0	3	2	-1	3	3	103.07	466.05	1
13	5.00	-1	1	0	-3	1	-0	0.00	426.18	2
14	5.00	-3	2	1	-6	2	1	0.00	425.05	2
15	5.00	1	2	0	2	3	0	76.50	463.16	1
16	5.00	-1	3	-0	-3	4	-0	162.91	474.31	1
17	5.00	3	2	2	6	2	3	37.19	470.20	1
18	5.00	-1	3	3	-3	3	3	121.02	435.72	1
19	5.00	-1	2	2	-2	2	2	70.56	412.71	1
20	5.00	-1	3	1	-2	3	1	131.99	463.25	1
21	5.00	-1	3	1	-4	4	2	75.56	443.58	1
22	5.00	-2	0	-1	-5	1	-1	0.00	385.77	2
23	5.00	-2	4	-1	-9	6	-1	50.56	300.45	4
24	5.00	-1	2	0	-4	3	0	0.00	336.11	1
25	5.00	1	4	-0	0	5	-0	48.35	476.27	1
26	5.00	-2	5	2	-6	6	2	77.54	401.47	1
27	5.00	-1	1	1	-2	1	2	191.16	464.66	3
28	5.00	-1	4	-0	-3	4	-0	121.77	450.80	1
29	5.00	1	1	0	1	1	-0	85.65	444.69	1
30	5.00	-2	1	1	-4	2	1	0.00	434.83	2
31	5.00	-1	1	3	-2	1	4	0.00	457.58	3
32	5.00	-2	3	1	-5	4	1	165.62	440.46	1
33	5.00	1	2	2	2	1	2	42.15	473.72	1
34	5.00	-1	3	1	-3	3	1	94.86	445.94	1
35	5.00	0	1	1	0	1	1	26.39	467.69	1
36	5.00	1	2	4	2	1	4	49.53	478.99	1
37	5.00	0	2	2	-0	2	2	58.39	495.99	1
38	5.00	3	4	-1	4	4	-1	73.24	582.81	1
39	5.00	1	-0	-1	1	-0	-1	202.71	530.46	1
40	5.00	-1	2	-1	-2	3	-1	154.80	477.57	1
41	5.00	-0	3	1	-2	4	2	145.75	474.29	1
42	5.00	-0	0	1	-0	-0	1	0.00	450.80	1
43	5.00	-1	3	1	-3	4	1	164.44	482.72	1
44	5.00	-1	3	1	-2	3	2	106.80	482.94	1
45	5.00	1	1	2	2	0	2	92.63	469.04	3
46	5.00	2	1	1	4	1	2	41.37	468.06	2
47	5.00	-0	3	0	-2	4	-0	68.89	444.83	1
48	5.00	1	3	1	1	4	1	30.16	468.23	2
49	5.00	1	2	1	2	2	1	49.21	449.88	1
50	5.00	-0	1	-0	-1	2	-0	0.00	437.52	3
51	5.00	-2	2	1	-5	2	2	221.76	361.44	3
52	5.00	0	1	3	0	1	4	69.25	467.47	1
53	5.00	-0	1	1	-1	1	1	0.00	464.38	3
54	5.00	-1	0	3	-1	-0	4	0.00	410.80	2
55	5.00	0	3	1	-0	4	1	33.72	456.61	9
56	5.00	1	5	-0	2	5	-0	52.90	463.19	1
57	5.00	3	3	1	5	3	2	58.61	503.89	1
58	5.00	-0	5	3	-2	5	3	78.08	428.75	2
59	5.00	-0	2	3	-1	1	4	345.52	470.79	1
60	5.00	1	2	2	1	2	2	148.95	531.00	1
61	5.00	1	4	3	1	4	3	35.79	422.45	2
62	5.00	-1	2	0	-3	2	-0	235.67	424.77	1
63	5.00	-0	2	1	-0	2	1	189.44	448.19	3
64	5.00	-0	1	1	-1	2	1	9.18	444.92	3
65	5.00	1	3	1	0	3	1	43.93	444.11	2
66	5.00	1	-0	1	2	-1	2	0.00	470.64	1
67	5.00	-0	2	2	-1	2	2	45.66	445.41	1
68	5.00	0	4	-0	-1	5	-0	52.53	485.27	2
69	5.00	1	3	1	1	3	1	44.72	493.74	1
70	5.00	-1	1	2	-2	1	2	0.00	359.14	1
71	5.00	-2	1	2	-4	1	2	0.00	493.28	3



NIH

72	5.00	-1	1	1	-2	1	1	0.00	443.49	3
73	5.00	-1	3	1	-3	3	1	92.85	489.84	3
74	5.00	2	2	1	4	2	1	67.75	500.40	1
75	5.00	-0	4	-0	-1	5	-0	45.08	447.97	1
76	5.00	-0	-1	-0	-1	-1	-0	0.00	474.57	2
77	5.00	2	5	0	3	5	0	46.56	451.32	2
78	5.00	1	2	2	2	2	2	95.41	506.63	1
79	5.00	2	7	-0	3	8	-1	59.05	528.17	1
80	5.00	1	4	-2	-0	6	-2	95.06	501.81	1
81	5.00	1	2	0	2	2	0	96.76	493.99	2
82	5.00	0	5	2	-1	6	2	65.41	440.00	1
83	5.00	-0	2	2	-1	2	2	72.39	462.11	1
84	5.00	1	0	1	3	0	1	80.30	481.03	1
85	5.00	2	1	1	4	1	2	54.60	475.36	1
86	5.00	-0	2	1	-1	3	1	61.02	455.60	3
87	5.00	1	5	1	-0	6	1	70.80	470.08	2
88	5.00	1	-0	-1	2	-0	-1	335.18	476.39	1
89	5.00	-2	1	2	-4	0	3	0.00	495.81	2
90	5.00	1	2	3	1	2	4	73.47	387.85	1
91	5.00	-0	0	1	-1	0	1	0.00	444.24	2
92	5.00	1	1	4	2	1	5	0.00	419.76	1
93	5.00	-1	3	1	-2	3	1	125.54	448.79	1
94	5.00	-0	2	3	-2	2	4	97.02	449.34	1
95	5.00	2	1	0	4	1	0	7.35	502.13	1
96	5.00	0	3	2	-0	4	2	99.12	435.06	1
97	5.00	2	2	0	5	2	0	32.94	440.45	1
98	5.00	-0	5	2	-3	6	3	62.61	462.34	2
99	5.00	1	2	1	2	2	1	11.40	488.29	1
100	5.00	-1	2	0	-3	2	0	120.26	439.24	1
101	5.00	0	1	3	0	0	4	117.61	522.56	1

CHESAPEAKE NUCLEAR  
 Count Time(minutes): 1.00  
 Assay Type: CPM  
 Background Subtract: IPA Bkg  
 Outlier: 5.0 FLAG  
 %Spillup: 0.00  
 %Spilldown: 0.00  
 Screening: OFF

REVIEWED BY:  
*JD* 2/28/07

	Window A	Window B	Window C
Nuclide:	I-125 15 - 75 keV	Co-57 75 - 165 keV	MAN 15 - 2000 keV
Bkg:	24.7	29.2	229
Sigma:	0.00	0.00	2.00
LCR:	0	0	0
Half Life(hours):	0.00	0.00	
Multiplier:	1.0000		
%CV Flag Limit:	0.00	0.00	

S#	A:CPM	A:%SIG	B:CPM	B:%SIG	C:CPM	C:%SIG
1	0.0		0.0		0.0	
2	0.0		0.0		0.0	
3	0.0		0.0		0.0	
4	4.3	48.5	5.8	41.5	20.7	22.0
5	0.0		0.0		0.0	
6	2.3	66.5	10.8	30.4	25.7	19.7
7	2.3	66.5	0.8	112	0.0	
8	3.3	55.4	6.8	38.3	19.7	22.5
9	0.0		0.0		11.7	29.2
10	11.3	29.8	0.0		8.7	33.9
(24A) 11	0.0		3.8	51.3	1.7	76.7

EDITDATA.D07 Archived to C:\ARCH\ARCH07D.183  
 C:\DATA\P7DATA Copied to C:\DATA\ARCH07A.183

26 Feb 07 14:19:18 Packard Model 5003 COBRA SN: 424559

PROTOCOL # 7  
 SWIPES  
 CHESAPEAKE NUCLEAR  
 COUNT TIME 1.00 Minutes

	Window A		Window B		Window C	
LLD:	15 keV		75 keV		15 keV	
ULD:	75 keV		165 keV		2000 keV	
EFF:	79 %		85 %		70 %	
Sample #	A:CPM	A:DPM	B:CPM	B:DPM	C:CPM	C:DPM
1	0	0	0	0	0	0
2	0	0	0	0	0	0
3	0	0	0	0	0	0
4	4	5	6	7	21	30
5	0	0	0	0	0	0

7  
6  
9  
10  
(24A) 11

2  
3  
0  
11  
0

3  
4  
0  
14  
0

1  
7  
0  
0  
4

1  
8  
0  
0  
4

9  
20  
12  
9  
2

0  
28  
17  
12  
2

LD

Assay Definition- *BI- B100*

REVIEWED BY:  
*JD* 2/28/07

Assay Description:  
CHESAPEAKE NUCLEAR

Assay Type: DPM (Triple)  
Report Name: Report1  
Output Data Path: C:\Packard\Tricarb\Results\Default\Triple Lable DPM  
Raw Results Path: C:\Packard\Tricarb\Results\Default\Triple Lable  
DPM\20070227\_2036.results  
Assay File Name: C:\Packard\TriCarb\Assays\Triple Lable DPM.lsa

Count Conditions-

Nuclide: Triple Label  
Quench Indicator: tSIE/AEC  
External Std Terminator (sec): 0.5 2s%  
Pre-Count Delay (min): 0.00

Quench Sets:  
Low Energy: 3H-TOL-7-17-06  
Mid Energy: 14C-TOL-07-17-06  
High Energy: 32P-UG-02-28-05

Count Time (min): 5.00  
Count Mode: Normal  
Assay Count Cycles: 1 Repeat Sample Count: 1  
#Vials/Sample: 1 Calculate % Reference: Off

Background Subtract: On - 1st Vial  
Low CPM Threshold: Off  
2 Sigma % Terminator: Off

Regions	LL	UL	Bkg Subtract
A	0.0	12.0	1st Vial
B	12.0	156.0	1st Vial
C	156.0	2000.0	1st Vial

Count Corrections-

Static Controller: On Luminescence Correction: On  
Colored Samples: On Heterogeneity Monitor: n/a  
Coincidence Time (nsec): 18 Delay Before Burst (nsec): 75

Half Life-

Half Life Correction: Off

Regions	Half Life	Units	Reference Date	Reference Time
A				
B				
C				

Cycle 1 Results

S#	Time	CPMA	CPMB	CPMC	DPM1	DPM2	DPM3	SIS	tSIE	LUM
1	10.00	5	9	7	0	0	0	58.17	508.25	1
2	5.00	-1	3	1	-3	4	1	55.31	412.81	1
3	5.00	-0	2	-2	-2	3	-2	24.80	341.97	1
4	5.00	0	1	-1	-0	2	-1	122.67	421.97	1
5	5.00	0	2	1	1	2	1	36.35	413.85	1
6	5.00	-0	1	-1	-1	2	-1	72.87	399.09	0
7	5.00	-0	-1	0	-0	-1	0	0.00	446.69	2
8	5.00	1	5	1	0	5	1	47.45	425.83	2

*JD*

9	5.00	3	2	-0	7	2	-0	19.43	434.03	0
10	5.00	142	206	-2	281	230	-3	30.40	409.51	0
11	5.00	8	3	-1	16	2	-1	18.35	473.41	1
12	5.00	51	50	0	110	52	0	28.44	407.61	0
13	5.00	1	3	-1	3	4	-2	13.19	377.05	1
14	5.00	-1	2	0	-2	3	0	105.23	434.40	1
15	5.00	-0	4	0	-1	5	0	83.34	460.97	1
16	5.00	6	3	1	11	3	1	33.28	523.38	1
17	5.00	1	1	-2	1	1	-2	64.50	486.01	1
18	5.00	-1	5	-1	-3	6	-1	5.34	349.32	1
19	5.00	1	1	0	2	1	0	24.07	432.31	1
20	5.00	2	1	-0	4	1	-0	0.00	438.26	0
21	5.00	3	13	-1	4	15	-1	52.15	474.39	1
22	5.00	1	1	1	2	1	1	78.77	483.19	1
23	5.00	3	1	-0	6	1	-0	42.17	503.43	1
24	5.00	0	2	-1	-0	3	-1	33.62	494.81	1
25	5.00	2	2	-2	4	2	-2	49.92	467.97	1
26	5.00	-1	3	-1	-4	4	-1	113.45	442.71	1
27	5.00	3	1	-2	8	1	-3	19.30	463.06	1
28	5.00	1	-1	-1	2	-1	-1	0.00	468.02	1
29	5.00	1	0	0	2	-0	0	0.00	470.18	1
30	5.00	0	4	-1	-1	5	-1	146.34	511.65	1
31	5.00	7	10	-1	12	11	-1	28.84	484.54	1
32	5.00	0	-0	1	1	-1	1	0.00	417.74	6
33	5.00	2	4	-0	2	4	-0	51.23	450.98	1
34	5.00	1	2	-2	1	3	-2	94.08	519.56	1
35	5.00	1	2	-0	1	2	-0	57.04	472.85	1
36	5.00	1	3	-1	1	4	-1	87.59	502.18	1
37	5.00	1	3	-0	2	3	-0	54.79	446.92	1
38	5.00	0	2	-0	-0	2	-0	0.00	438.78	1
39	5.00	-0	1	-0	-0	1	-0	84.06	389.94	1
40	5.00	62	46	0	124	47	0	23.22	476.51	0
41	5.00	29	21	-1	64	22	-1	21.87	407.33	0
42	5.00	2	3	0	2	3	0	51.82	521.94	1
43	5.00	1	1	2	2	0	3	0.00	435.47	0
44	5.00	0	-0	-1	1	0	-1	0.00	443.59	1
45	5.00	0	-2	0	2	-2	0	0.00	478.42	0
46	5.00	-0	6	1	-3	7	1	57.52	464.18	1
47	5.00	1	-1	-1	2	-1	-1	0.00	447.53	1
48	5.00	-1	2	0	-3	2	0	474.48	517.93	1
49	5.00	0	1	-0	-0	1	-0	0.00	450.99	1
50	5.00	1	1	-2	2	1	-2	122.44	428.73	1
51	5.00	-1	1	-4	-2	3	-5	63.13	464.40	1
52	5.00	-1	3	-1	-4	4	-1	0.00	415.69	1
53	5.00	0	1	0	1	1	0	140.84	441.55	1
54	5.00	-1	2	-1	-3	3	-1	0.00	427.46	1
55	5.00	2	-0	0	4	-1	0	0.00	447.01	1
56	5.00	-2	1	1	-5	2	1	0.00	491.88	2
57	5.00	-1	2	-1	-2	3	-1	203.66	440.31	1
58	5.00	0	0	1	1	-0	1	0.00	450.53	1
59	5.00	1	5	-3	1	7	-4	54.76	434.20	1
60	5.00	1	1	-1	2	1	-1	45.40	458.36	1
61	5.00	0	5	-1	-1	6	-1	68.51	493.39	1
62	5.00	-0	2	-1	-1	3	-1	0.00	459.26	1
63	5.00	1	1	-1	2	2	-2	67.41	517.56	1
64	5.00	0	2	-1	-0	2	-1	13.34	441.37	1
65	5.00	0	2	-1	-0	3	-1	83.79	505.13	1
66	5.00	1	1	-0	1	1	-0	93.19	450.49	1
67	5.00	-0	2	-1	-1	3	-1	134.52	466.33	1
68	5.00	-0	1	-1	-1	1	-1	0.00	440.87	1
69	5.00	1	-1	-0	2	-2	-0	0.00	472.70	2
70	5.00	-1	1	-1	-2	1	-1	0.00	425.86	1

71	5.00	0	2	-1	-1	3	-1	87.94	428.66	1
72	5.00	1	3	-1	0	4	-1	71.82	499.38	0
73	5.00	0	-1	-2	1	-1	-2	0.00	411.42	2
74	5.00	0	-2	-2	2	-3	-2	0.00	533.90	2
75	5.00	1	1	1	1	1	1	0.00	450.96	1
76	5.00	2	0	-1	4	0	-1	0.00	504.50	0
77	5.00	-0	-2	3	-0	-3	4	0.00	447.94	2
78	5.00	1	0	-0	2	0	-0	0.00	426.97	0
79	5.00	1	-0	-1	3	-0	-1	57.46	456.95	1
80	5.00	1	0	-0	3	-0	-0	95.80	472.18	1
81	5.00	3	1	-1	5	2	-1	46.91	486.01	1
82	5.00	1	0	-1	3	0	-1	115.79	516.21	1
83	5.00	-0	-1	2	-0	-1	3	0.00	459.62	2
84	5.00	1	1	-2	3	1	-2	0.00	448.96	3
85	5.00	-1	2	-3	-3	4	-4	73.83	449.59	1
86	5.00	-0	3	-1	-1	3	-1	152.77	472.92	3
87	5.00	-1	1	-1	-2	2	-1	19.66	464.82	1
88	5.00	0	4	-1	-0	5	-1	99.37	457.58	1
89	5.00	0	1	1	0	1	2	167.56	472.50	1
90	5.00	-0	4	2	-2	5	2	124.60	464.35	2
91	5.00	1	-0	1	2	-0	1	0.00	546.07	1
92	5.00	-1	1	3	-3	1	3	0.00	478.54	3
93	5.00	2	1	1	5	0	1	9.28	472.60	2
94	5.00	1	2	2	1	2	2	74.00	453.37	1
95	5.00	0	1	-1	0	1	-1	16.18	451.53	3
96	5.00	3	0	2	6	-1	3	57.03	498.04	1
97	5.00	1	2	2	3	1	3	13.89	479.78	1
98	5.00	2	-1	-2	4	-1	-2	0.00	503.45	1
99	5.00	1	-0	3	2	-2	4	0.00	448.46	3
100	5.00	0	1	-1	-0	1	-1	137.03	452.35	3
101	5.00	0	3	-1	-1	4	-1	54.32	441.07	0

CHESAPEAKE NUCLEAR

Count Time(minutes): 1.00  
 Assay Type: CPM  
 Background Subtract: IPA Bkg  
 Outlier: 5.0 FLAG  
 %Spillup: 0.00  
 %Spilldown: 0.00  
 Screening: OFF

REVIEWED BY:  
*JD* 2/28/07

	Window A		Window B		Window C	
Nuclide:	1-125	15 - 75 keV	Co-57	75 - 165 keV	MAN	15 - 2000 keV
Bkg:	24.7		29.2		229	
Sigma:	0.00		0.00		2.00	
LCR:	0		0		0	
Half Life(hours):	0.00		0.00			
Multiplier:	1.0000					
%CV Flag Limit:	0.00		0.00			

SN	A:CPM	A:%SIG	B:CPM	B:%SIG	C:CPM	C:%SIG
1	1.3	89.1	0.0		0.0	
2	0.3	196	5.8	41.5	1.7	76.7
3	0.0		0.0		10.7	30.6
4	0.0		1.3	74.5	0.0	
5	2.3	66.5	22.6	20.9	33.7	17.2
6	0.0		2.8	59.8	39.7	15.9
7	0.0		0.8	112	4.7	46.1
8	5.3	43.6	6.8	38.3	15.7	25.2
9	5.3	43.6	7.8	35.8	24.7	20.1
10	10.3	31.2	5.8	41.5	38.7	16.1
(31B) 11	0.0		0.0		0.0	

EDITDATA.D07 Archived to C:\ARCH\ARCH07D.185  
 C:\DATA\P7DATA Copied to C:\DATA\ARCH07A.185

26 Feb 07 14:41:17 Packard Model 5003 COBRA SN: 424559

PROTOCOL # 7  
 SWIPES  
 CHESAPEAKE NUCLEAR  
 COUNT TIME 1.00 Minutes

	Window A		Window B		Window C	
LLD:	15 keV		75 keV		15 keV	
ULD:	75 keV		165 keV		2000 keV	
EFF:	79 %		65 %		70 %	
Sample #	A:CPM	A:DPM	B:CPM	B:DPM	C:CPM	C:DPM
1	1	2	0	0	0	0
2	0	0	6	7	2	2
3	0	0	0	0	11	15
4	0	0	2	2	0	0
5	2	3	23	27	34	48

	7	0	0	1	1	5	7
	8	5	7	7	8	16	22
	9	5	7	8	9	25	35
	10	10	13	6	7	39	55
(31B)	11	0	0	0	0	0	10

22

0  
0  
1



NIH

Assay Definition- C1-C30

Assay Description: CHESAPEAKE NUCLEAR

REVIEWED BY: JD 2/28/07

Assay Type: DPM (Triple)

Report Name: Report1

Output Data Path: C:\Packard\Tricarb\Results\NIH\Triple Lable DPM

Raw Results Path: C:\Packard\Tricarb\Results\NIH\Triple Lable DPM\20070228\_0727.results

Assay File Name: C:\Packard\TriCarb\Assays\Triple Lable DPM.lsa

Count Conditions-

Nuclide: Triple Label

Quench Indicator: tSIE/AEC

External Std Terminator (sec): 0.5 2s%

Pre-Count Delay (min): 0.00

Quench Sets:

Low Energy: 3H-TOL-7-17-06

Mid Energy: 14C-TOL-07-17-06

High Energy: 32P-UG-02-28-05

Count Time (min): 5.00

Count Mode: Normal

Assay Count Cycles: 1

Repeat Sample Count: 1

#Vials/Sample: 1

Calculate % Reference: Off

Background Subtract: On - 1st Vial

Low CPM Threshold: Off

2 Sigma % Terminator: Off

Regions	LL	UL	Bkg Subtract
A	0.0	12.0	1st Vial
B	12.0	156.0	1st Vial
C	156.0	2000.0	1st Vial

Count Corrections-

Static Controller: On

Luminescence Correction: On

Colored Samples: On

Heterogeneity Monitor: n/a

Coincidence Time (nsec): 18

Delay Before Burst (nsec): 75

Half Life-

Half Life Correction: Off

Regions	Half Life	Units	Reference Date	Reference Time
A				
B				
C				

Cycle 1 Results

S#	Time	CPMA	CPMB	CPMC	DPM1	DPM2	DPM3	SIS	tSIE	LUM
1	10.00	5	8	6	0	0	0	57.03	557.01	1
2	5.00	0	1	0	-0	1	0	94.29	462.46	1
3	5.00	0	3	1	-0	4	2	23.18	445.34	1
4	5.00	-1	5	2	-3	6	3	68.50	498.42	2
5	5.00	0	0	-1	0	1	-1	67.14	536.01	1
6	5.00	-1	2	1	-3	2	2	165.05	401.30	3
7	5.00	-1	1	2	-4	1	2	0.00	453.80	2
8	5.00	0	2	-0	0	3	-0	4.01	466.14	1
9	5.00	0	2	1	0	3	1	49.20	447.97	0

NIH

10	5.00	-1	3	-0	-2	3	-0	14.28	435.11	0
11	5.00	-1	0	-0	-3	1	-0	0.00	467.48	2
12	5.00	2	1	1	4	1	1	68.81	496.99	1
13	5.00	2	3	2	4	3	2	24.20	494.78	1
14	5.00	-2	2	0	-4	3	0	291.31	485.55	1
15	5.00	-0	3	-1	-1	4	-1	98.21	526.58	1
16	5.00	0	1	2	0	1	3	100.05	473.52	1
17	5.00	-1	3	1	-3	4	1	15.83	409.92	1
18	5.00	0	3	0	-0	4	0	43.64	419.27	1
19	5.00	0	2	1	-0	3	2	88.34	508.49	1
20	5.00	-2	4	1	-6	5	1	109.70	469.81	1
21	5.00	1	1	1	1	1	1	26.30	493.88	0
22	5.00	-0	5	2	-2	5	2	81.71	457.87	1
23	5.00	-0	3	1	-2	3	1	82.78	485.97	1
24	5.00	0	2	0	0	2	0	131.77	525.48	1
25	5.00	-0	0	1	-0	-0	2	0.00	365.34	1
26	5.00	-0	4	0	-2	4	0	60.47	400.52	1
27	5.00	0	8	2	-2	10	2	49.10	436.35	1
28	5.00	4	15	1	5	17	1	51.71	443.39	1
29	5.00	12	20	0	21	23	-0	37.18	451.32	0
30	5.00	124	176	0	226	195	-1	37.13	474.19	0
31	5.00	-0	4	0	-1	4	0	56.09	451.11	1

Protocol #: 7

SWIPES 1C-30C

User : Lab Technician

CHESAPEAKE NUCLEAR

Count Time(minutes): 1.00  
 Assay Type: CPM  
 Background Subtract : IPA Bkg  
 Outlier: 5.0 FLAG  
 %Spillup: 0.00  
 %Spilldown: 0.00  
 Screening: OFF

REVIEWED BY:  
*JD* 2/28/07

	Window A		Window B		Window C	
Nuclide:	I-125	15 - 75 keV	Co-57	75 - 165 keV	MAN	15 - 2000 keV
Bkg:	24.7		29.2		229	
Sigma:	0.00		0.00		2.00	
LCR:	0		0		0	
Half Life(hours):	0.00		0.00			
Multiplier:	1.0000					
%CV Flag Limit:	0.00		0.00			

S#	A:CPM	A:%SIG	B:CPM	B:%SIG	C:CPM	C:%SIG
1	0.0		2.8	59.8	0.0	
2	0.0		0.0		0.0	
3	0.0		0.8	112	0.0	

EDITDATA.D07 Archived to C:\ARCH\ARCH07D.184  
 C:\DATA\NP7DATA Copied to C:\DATA\ARCH07A.184

26 Feb 07 14:35:40 Packard Model 5003 COBRA SN: 424559

-----  
 PROTOCOL # 7  
 SWIPES  
 CHESAPEAKE NUCLEAR  
 COUNT TIME 1.00 Minutes  
 -----

	Window A		Window B		Window C	
LLD:	15 keV		75 keV		15 keV	
ULD:	75 keV		165 keV		2000 keV	
EFF:	79 %		85 %		70 %	
Sample #	A:CPM	A:DPM	B:CPM	B:DPM	C:CPM	C:DPM
1	0	0	3	3	0	0
2	0	0	0	0	0	0
3	0	0	1	1	0	0

Final 8/13/2007

**Attachment 6.0**  
**Follow-up Smear Survey Results**



Radiation Service Organization

March 27, 2007

Chesapeake Nuclear  
Attn: Stewart Bland  
788 Sonne Dr.  
Annapolis, MD 21401

Dear Mr. Bland,

Enclosed please find the results for the wipe tests received on March 26, 2007. The wipe tests were analyzed using Liquid Scintillation, Gamma Counters and Gamma Spectroscopy. An individual data print out for each analysis process is attached for your review. The only elevated activity indicated on the analysis reports were as follows:

Wipe test group 3C to 67C (37 wipe tests) found 3 wipe tests exceeding 100 and 2 wipe tests exceeding 1,000 dpm. Please review attached beta-gamma LSC data results for activity concentrations.

Analysis of swabs 5, 6 & 8 found no activity exceeding 10 dpm.  
Please review attached beta-gamma LSC data results for activity concentrations.

Wipe tests were Gamma counted and analysis results indicated all activity levels below 50 dpm. Please review attached gamma data results for activity concentrations.

Gamma spec analysis of scrapings received within 7 small bags found no spectrum outside of normal background.

If you have any questions please do not hesitate to call me at (301) 953-2482 ext. 305 or by e-mail [james.dean@rsoinc.com](mailto:james.dean@rsoinc.com).

Sincerely,

James W. Dean  
Manager, Radiation Safety Services – Radiation Safety Officer

Enclosure



CHESAPEAKE NUCLEAR  
Count Time: minutes: 1.00  
Assay Type: CPM  
Background Subtract: IPA Bkg  
Outlier: 5.0 FLAG  
%Spillup: 0.00  
%Spilldown: 0.00  
Screening: OFF

REVIEWED BY:  
*JD* 3/27/07

	Window A	Window B	Window C
Nuclide:	I-125 15 - 75 keV	Co-57 75 - 165 keV	MAN 15 - 2000 keV
Bkg:	23.1	26.7	210
Sigma:	0.00	0.00	2.00
LCR:	0	0	0
Half Life(hours):	0.00	0.00	
Multiplier:	1.0000		
%CV Flag Limit:	0.00	0.00	

S#	A:CPM	A:%SIG	B:CPM	B:%SIG	C:CPM	C:%SIG
1	1.4	72.2	0.0		0.0	
2	9.9	31.8	2.3	65.4	6.2	40.2
3	3.9	50.5	3.3	54.7	15.2	25.6
4	0.0		3.3	54.7	20.2	22.2
5	0.0		3.3	54.7	21.2	21.7
6	11.9	29.0	6.3	39.7	41.2	15.6
7	0.0		0.3	171	6.2	40.2


EDITDATA.D07 Archived to C:\ARCH\ARCH07\D.191  
C:\DATA\NP7DATA Copied to C:\DATA\ARCH07A.191

26 Mar 07 14:10:59 Packard Model 5003 CUBRA SN: 424559

PROTOCOL # 7  
SWIPES  
CHESAPEAKE NUCLEAR  
COUNT TIME 1.00 Minutes

Sample #	Window A		Window B		Window C	
	A:CPM	A:DPM	B:CPM	B:DPM	C:CPM	C:DPM
1	0	0	0	0	0	0
2	10	10	2	3	6	9
3	4	4	3	4	15	22
4	0	0	3	4	20	29
5	0	0	3	4	11	16
6	12	15	6	7	41	58
7	0	0	0	0	6	9

NIH

<p>REVIEWED BY:</p>  <p>3/27/07</p>
--

Assay Definition-

Assay Description:  
CHEASAPEAKE NUCLEAR

Assay Type: DPM (Triple)

Report Name: Report1

Output Data Path: C:\Packard\Tricarb\Results\NIH\Triple Lable DPM

Raw Results Path: C:\Packard\Tricarb\Results\NIH\Triple Lable DPM\20070326\_1554.results

Assay File Name: C:\Packard\TriCarb\Assays\Triple Lable DPM.lsa

Count Conditions-

Nuclide: Triple Label

Quench Indicator: tSIE/AEC

External Std Terminator (sec): 0.5 2s%

Pre-Count Delay (min): 0.00

Quench Sets:

Low Energy: 3H-TOL-7-17-06

Mid Energy: 14C-TOL-07-17-06

High Energy: 32P-UG-02-28-05

Count Time (min): 5.00

Count Mode: Normal

Assay Count Cycles: 1

Repeat Sample Count: 1

#Vials/Sample: 1

Calculate % Reference: Off

Background Subtract: On - 1st Vial

Low CPM Threshold: Off

2 Sigma % Terminator: Off

Regions	LL	UL	Bkg Subtract
A	0.0	12.0	1st Vial
B	12.0	156.0	1st Vial
C	156.0	2000.0	1st Vial

Count Corrections-

Static Controller: On

Luminescence Correction: On

Colored Samples: On

Heterogeneity Monitor: n/a

Coincidence Time (nsec): 18

Delay Before Burst (nsec): 75

Half Life-

Half Life Correction: Off

Regions	Half Life	Units	Reference Date	Reference Time
A				
B				
C				

Cycle 1 Results

S#	Time	CPMA	CPMB	CPMC	DPM1	DPM2	DPM3	SIS	tSIE	LUM
BKG-1	10.00	6	11	6	0	0	0	68.71	527.52	2
*1	2 5.00	1	-2	3	2	-3	3	0.00	490.83	4
	3 5.00	1	-2	-1	4	-2	-1	0.00	497.42	4
	4 5.00	0	1	1	0	1	.2	0.00	481.85	2
	5 5.00	1	0	2	2	-0	3	0.00	505.94	2
	6 5.00	0	0	1	1	-0	1	0.00	497.94	2
	7 5.00	1	7	3	0	7	4	47.92	456.63	2
	8 5.00	1	2	1	1	3	2	0.00	502.96	2
	9 5.00	0	4	3	-0	4	3	17.25	464.03	2



NIH

10	5.00	0	1	2	0	1	2	0.00	470.50	2
11	5.00	-1	1	1	-2	2	1	0.00	473.34	3
12	5.00	0	2	2	-0	2	2	0.00	422.26	2
13	5.00	-1	-1	5	-2	-2	6	0.00	498.13	3
14	5.00	2426	4726	5	3998	5389	-16	41.30	482.06	0
15	5.00	100	162	3	168	182	3	41.74	518.21	0
16	5.00	129	168	3	237	184	3	35.88	481.58	0
17	5.00	5	5	2	11	5	3	4.24	408.48	1
18	5.00	0	4	2	-1	5	2	40.89	407.03	2
19	5.00	9	12	4	16	12	4	23.53	457.51	1
20	5.00	649	1164	1	1147	1318	-3	37.46	447.54	0
21	5.00	-0	3	2	-2	3	2	0.00	420.95	1
22	5.00	3	1	1	7	1	2	0.00	446.18	2
23	5.00	1	5	-0	-0	6	-0	45.66	432.58	2
24	5.00	-1	1	1	-2	1	1	0.00	397.77	1
25	5.00	1	1	3	3	0	3	0.00	464.81	2
26	5.00	9	3	-1	18	3	-1	8.11	490.25	1
27	5.00	14	13	-2	30	14	-2	12.92	395.32	1
28	5.00	1	0	2	3	-0	2	0.00	496.22	2
29	5.00	26	2	1	63	-2	1	0.00	408.92	1
30	5.00	3	3	0	5	4	0	0.00	487.01	2
31	5.00	6	2	1	12	1	1	0.00	488.62	2
32	5.00	5	0	2	10	-1	2	0.00	500.78	2
33	5.00	24	9	-1	51	8	-1	14.71	485.19	1
34	5.00	44	22	1	107	20	1	13.43	369.64	0
35	5.00	10	5	-2	20	6	-2	22.25	521.84	1
36	5.00	4	3	1	7	3	2	31.37	487.86	3
37	5.00	17	10	3	32	9	3	18.44	541.92	1
#37 38	5.00	2	2	2	4	2	2	1.42	507.76	2
#5 39	5.00	1	-3	0	4	-4	0	0.00	535.89	3
#6 40	5.00	3	3	3	6	3	4	29.67	515.97	2
#8 41	5.00	3	-2	3	6	-4	3	0.00	524.08	2

\*\*\*\*\*  
\*\*\*\*\* GAMMA SPECTRUM ANALYSIS \*\*\*\*\*  
\*\*\*\*\*

Report Generated On : 3/26/07 12:30:12 PM  
Sample Title : Soil  
Spectrum Description :  
Sample Identification : CHESAPEAKE NUC  
Sample Type : Sol  
Sample Geometry : Marinelli Beaker  
Peak Locate Threshold : 3.00  
Peak Locate Range (in channels) : 50 - 8192  
Peak Area Range (in channels) : 50 - 8192  
Identification Energy Tolerance : 1.000 keV  
Sample Size : 1.000E+000 Grams  
Sample Taken On : 3/26/07 12:15:06 PM  
Acquisition Started : 3/26/07 12:15:06 PM  
Live Time : 900.0 seconds  
Real Time : 900.1 seconds

REVIEWED BY:  
*JD* 3/27/07

Energy Calibration Used Done On : 1/25/07  
Efficiency Calibration Used Done On : 1/23/07

*Jim*

*I put these 7 small bags of scrappings  
into a beaker & counted. Let me know  
if you need additional info.*

*Rich*  
3/26/07

\*\*\*\*\*  
\*\*\*\*\* N U C L I D E I D E N T I F I C A T I O N R E P O R T \*\*\*\*\*  
\*\*\*\*\*

Sample Title: Soil  
Nuclide Library Used: C:\GENIE2K\CAMFILES\NORMPLUS.NLB

..... IDENTIFIED NUCLIDES .....

Nuclide Name	Id Confidence	Energy (keV)	Yield (%)	Activity (pCi/Gram)	Activity Uncertainty
--------------	---------------	--------------	-----------	---------------------	----------------------

\* = Energy line found in the spectrum.  
@ = Energy line not used for Weighted Mean Activity  
Energy Tolerance : 1.000 keV  
Nuclide confidence index threshold = 0.30  
Errors quoted at 2.000 sigma

\*\*\*\*\*  
 \* INTERFERENCE CORRECTED REPORT \*\*\*\*\*  
 \*\*\*\*\*

Nuclide Name	Nuclide Id Confidence	Wt mean Activity (pCi/Gram)	Wt mean Activity Uncertainty
--------------	--------------------------	--------------------------------	---------------------------------

? = nuclide is part of an undetermined solution  
 X = nuclide rejected by the interference analysis  
 @ = nuclide contains energy lines not used in Weighted Mean Activity

Errors quoted at 2.000 sigma

\*\*\*\*\* UNIDENTIFIED PEAKS \*\*\*\*\*

Peak Locate Performed on: 3/26/07 12:30:11 PM  
 Peak Locate From Channel: 50  
 Peak Locate To Channel: 8192

Peak No.	Energy (keV)	Peak Size in Counts per Second	Peak CPS % Uncertainty
1	26.35	1.5569E-001	25.45

M = First peak in a multiplet region  
 m = Other peak in a multiplet region  
 F = Fitted singlet

Errors quoted at 2.000 sigma

Final 8/13/2007

**Attachment 7.0**  
**Final Status Survey Smear Results**



Radiation Service Organization

July 10, 2007

Chesapeake Nuclear  
Attn: Stewart Bland  
788 Sonne Dr.  
Annapolis, MD 21401

Dear Mr. Bland,

Enclosed please find the results of the 10 wipe tests received on July 2, 2007. The wipe tests were analyzed using Liquid Scintillation (LSC) counting technology. An LSC individual data results print out denoting each analysis result is attached for your review. The results of the first sample are for background determination. The wipe test analysis begins with sample location #2. Wipe test results were background deducted presenting net results. Reported analytical data indicates all activity levels below 50 dpm.

If you have any questions please do not hesitate to call me at (301) 953-2482 ext. 305 or by e-mail [james.dean@rsoinc.com](mailto:james.dean@rsoinc.com).

Sincerely,

James W. Dean  
Manager, Radiation Safety Services – Radiation Safety Officer

Enclosure

July 2, 2007

Stewart Bland  
Chesapeake Nuclear Services, Inc.  
788 Sonne Dr.  
Annapolis, MD 21401  
USA

Dear Stewart:

The ten swipes delivered to RSO Inc. were found to be < 50dpm. The final results will be sent to you with the invoice.

Sincerely,

A handwritten signature in black ink, appearing to read "Richard Emmons", with a long horizontal flourish extending to the right.

Mr. Richard Emmons  
Laboratory Technician

Assay Definition-

Assay Description:  
CHESAPEAKE NUCLEAR

REVIEWED BY:  
*JD* 7/06/07

Assay Type: DPM (Triple)  
Report Name: Report1  
Output Data Path: C:\Packard\Tricarb\Results\Default\Triple Lable DPM  
Raw Results Path: C:\Packard\Tricarb\Results\Default\Triple Lable  
DPM\20070702\_1238.results  
Assay File Name: C:\Packard\TriCarb\Assays\Triple Lable DPM.lsa

Count Conditions-

Nuclide: Triple Label  
Quench Indicator: tSIE/AEC  
External Std Terminator (sec): 0.5 2s%  
Pre-Count Delay (min): 0.00  
Quench Sets:  
Low Energy: 3H-TOL-7-17-06  
Mid Energy: 14C-TOL-07-17-06  
High Energy: 32P-UG-02-28-05  
Count Time (min): 1.00  
Count Mode: Normal  
Assay Count Cycles: 1 Repeat Sample Count: 1  
#Vials/Sample: 1 Calculate % Reference: Off

Background Subtract: On - 1st Vial  
Low CPM Threshold: Off  
2 Sigma % Terminator: Off

Regions	LL	UL	Bkg Subtract
A	0.0	12.0	1st Vial
B	12.0	156.0	1st Vial
C	156.0	2000.0	1st Vial

Count Corrections-

Static Controller: On Luminescence Correction: On  
Colored Samples: On Heterogeneity Monitor: n/a  
Coincidence Time (nsec): 18 Delay Before Burst (nsec): 75

Half Life-

Half Life Correction: Off

Regions	Half Life	Units	Reference Date	Reference Time
A				
B				
C				

Cycle 1 Results

S#	Time	CPMA	CPMB	CPMC	DPM1	DPM2	DPM3	SIS	tSIE	LUM
1	10.00	7	8	8	0	0	0	53.73	524.81	2
2	1.00	8	21	-2	10	25	-3	57.54	556.93	0
3	1.00	1	6	-1	-1	7	-2	101.77	552.25	0
4	1.00	3	3	-2	5	3	-3	71.39	556.11	0
5	1.00	5	5	-2	8	6	-3	31.53	544.69	0
6	1.00	-2	2	-3	-5	4	-4	587.91	480.71	0
7	1.00	-3	1	5	-8	1	6	0.00	424.99	0
8	1.00	6	10	-0	9	12	-0	33.38	563.77	0



9	1.00	14	6	-4	27	6	-5	22.48	529.99	0
10	1.00	4	2	-2	7	2	-3	64.25	531.70	0
11	1.00	-2	5	-1	-6	6	-2	120.79	547.00	0

*JD 7/2/07*

Final 8/13/2007

**Attachment 8.0**  
**Radioactive Waste Shipment Manifest**

FORM 540

Radiation Service Organization, Inc.

**UNIFORM LOW-LEVEL RADIOACTIVE  
WASTE MANIFEST  
SHIPPING PAPER**

5. SHIPPER - NAME AND FACILITY

VA Medical Center  
100 Emancipation Drive  
Hampton, VA 23667

SHIPPER I.D. NUMBER

NA

COLLECTOR

PROCESSOR

GENERATOR TYPE

(Specify) M

TELEPHONE NUMBER

(Include Area Code)

(810)873-4814

7. FORM 540 AND 540A

PAGE 1 OF

1 PAGE(S)

FORM 541 AND 541A

1 PAGE(S)

FORM 542 AND 542A

None PAGE(S)

ADDITIONAL INFORMATION

None PAGE(S)

8. MANIFEST NUMBER

(Use this number on all continuation pages)

15882

1. EMERGENCY TELEPHONE NUMBER

(Include Area Code)

1-800-424-9300

ORGANIZATION

Chemtrac

NA

SHIPMENT NUMBER

15882

CONTACT

Joe Moon

6. CARRIER - Name and Address

RSC, Inc.  
5204 Minnick Road  
Laurel, MD 20707

Truck #: 98233

Trailer #: N/A

EPA I.D. NUMBER

MDD-08-927-8869

SHIPPING DATE

06/28/2007

TELEPHONE

(Include Area Code)

(301)963-2482

9. CONSIGNEE - Name and Facility

RSC, Inc.  
5204 Minnick Road  
Laurel, MD 20707

SIGNATURE - Authorized consignee acknowledging waste receipt

*David Wellner*

CONTACT

David Wellner

TELEPHONE

(Include Area Code)

(301)963-2482

DATE

6-28-07

2. IS THIS AN "EXCLUSIVE USE" SHIPMENT?

YES

NO

3. TOTAL NUMBER OF PACKAGES IDENTIFIED ON THIS MANIFEST

1

4. DOES EPA REGULATED WASTE REQUIRING A MANIFEST ACCOMPANY THIS SHIPMENT?

YES

NO

EPA MANIFEST NUMBER

CONTACT

David Wellner

SIGNATURE - Authorized carrier acknowledging waste receipt

*David Wellner*

DATE

6-28-07

10. CERTIFICATION  
This is to certify that the herein-named materials are properly classified, described, packaged, marked, and labeled and are in proper condition for transportation according to the applicable regulations of the Department of Transportation. This also certifies that the materials are classified, packaged, marked, and labeled and are in proper condition for transportation and disposal as described in accordance with the requirements of 10 CFR Parts 20 and 61, or equivalent state regulations.

AUTHORIZED SIGNATURE

*DCU*

TITLE

MD R-SO

DATE

6/28/07

11. U.S. DEPARTMENT OF TRANSPORTATION DESCRIPTION (including proper shipping name, hazard class, UN ID number, and any additional information)

Radioactive material, excepted package-limited quantity of material, 7, UN 2910

12. DOT LABEL "RADIOACTIVE"

NA

13. TRANSPORT INDEX

NA

14. PHYSICAL AND CHEMICAL FORM

Solid Labware, Tiles

15. INDIVIDUAL RADIONUCLIDES

C-14 H-3

16. TOTAL PACKAGE ACTIVITY MBq mCi

3.3337E+01

9.0100E-01

17. LSA/SCO CLASS

NA

18. TOTAL WEIGHT OR VOLUME (Use appropriate units)

85 LBS; 4.1 FT3

211

19. IDENTIFICATION NUMBER OF PACKAGE

58181

FOR CONSIGNEE USE ONLY

TENNESSEE "LICENSE FOR DELIVERY" NO \_\_\_\_\_

SOUTH CAROLINA TRANSPORT PERMIT NO \_\_\_\_\_

US ECOLOGY GENERATOR NO \_\_\_\_\_

US ECOLOGY PERMIT NO \_\_\_\_\_

20.

Dr. Chadhuri VA contact  
757-722-9961 Ext. 3528

FORM 541

Radiation Service Organization, Inc.

# UNIFORM LOW-LEVEL RADIOACTIVE WASTE MANIFEST

## CONTAINER AND WASTE DESCRIPTION

Additional Nuclear Regulatory Commission (NRC) Requirements for Control, Transfer and Disposal of Radioactive Waste

### 1. MANIFEST TOTALS

NUMBER OF PACKAGES/DISPOSAL CONTAINERS	NET WASTE VOLUME	NET WASTE WEIGHT	SPECIAL NUCLEAR MATERIAL (grams)				SOURCE (kg)
			U-233	U-235	Pu	Total	
1	m3 0.1161	kg 38.5554	NP	NP	NP	NP	
	ft3 4.1000	lb 85.0000					
ACTIVITY							
ALL NUCLIDES		TRITIUM	C-14	Tc-99	I-129		
MBq	3.3337E+01	3.7000E-02	3.3300E+01	NP	NP	(kg) NA	
mCi	9.0100E-01	1.0000E-03	9.0000E-01	NP	NP	(lbs) NA	

2. MANIFEST NUMBER

15882

3. PAGE 1 OF 1 PAGE(S)

4. SHIPPER NAME  
VA Medical Center

SHIPMENT ID NUMBER

NA

### DISPOSAL CONTAINER DESCRIPTION

### WASTE DESCRIPTION FOR EACH WASTE TYPE IN CONTAINER

5. CONTAINER IDENTIFICATION NUMBER/GENERATOR ID NUMBER	6. CONTAINER DESCRIPTION (See Note 1) PROCESS REQUESTED (See Note 1A) BURIAL/DISPOSITION (See Note 2A)	7. VOLUME (m3) (ft3)	8. WASTE AND CONTAINER WEIGHT (kg) (lb)	9. SURFACE RADIATION LEVEL (mSv/hr) (mrem/hr)	10. SURFACE CONTAMINATION (MBq/100 cm2) (dpm/100cm2)		11. PHYSICAL DESCRIPTION (See Note 2)		12. APPROXIMATE WASTE VOLUME(S) IN CONTAINER (m3) (FT3)	13. SOLIDIFICATION OR STABILIZATION MEDIA (See Note 3)	14. CHEMICAL DESCRIPTION CHEMICAL FORM/ CHELATING AGENT	15. RADIOLOGICAL DESCRIPTION INDIVIDUAL RADIONUCLIDES AND ACTIVITY (MBq) AND CONTAINER TOTAL OR CONTAINER TOTAL ACTIVITY AND RADIONUCLIDE PERCENT	16. WASTE CLASSIFICATION AS-Class A Stable AU-Class A Unstable B-Class B C-Class C			
					ALPHA	BETA-GAMMA	WASTE DESCRIPTION	WASTE DESCRIPTION								
56161/VAMC	4 C E	0.1161	38.5554	2.0000E-04	<1.6700E-06	<1.6700E-06	33		0.1161	NA	Labware, Ties/NP	NP	C-14 H-3 Subtotal Total	3.3300E+01 3.7000E-02 3.3337E+01 3.3337E+01	9.0000E-01 1.0000E-03 9.0100E-01 9.0100E-01	AU
		4.1000	85.0000	2.0000E-02	<1.0000E+02	<1.0000E+02			4.1000							
Shipment Totals		0.1161	38.5554										3.3337E+01	9.0100E-01		
		4.1000	85.0000													

Note 1: Container Description Codes. For containers/waste requiring disposal in approved structural overpacks the numerical code must be followed by "OP."

- |                               |   |
|-------------------------------|---|
| 1. Wooden Box or Crate        | 9. Demineralizer                                  |
| 2. Metal Box                  | 10. Gas Cylinder                                  |
| 3. Plastic Drum or Pail       | 11. Bulk, Unpackaged Waste                        |
| 4. Metal Drum or Pail         | 12. Unpackaged Components                         |
| 5. Metal Tank or Liner        | 13. High Integrity Container                      |
| 6. Concrete Tank or Liner     | 19. Other. Describe in Item 6, or additional page |
| 7. Polyethylene Tank or Liner |   |
| 8. Fiberglass Tank or Liner   |   |

Note 1A: Process Requested

- |    |                         |
|----|-------------------------|
| C  | Compaction              |
| SR | Steam Reforming         |
| DI | Direct Incineration     |
| SI | Sort & Incinerate       |
| D  | Decon                   |
| G  | Green is Clean          |
| M  | Metal Melt              |
| T  | Trans-Ship              |
| LJ | Liquid for Incineration |
| OI | Oil for Incineration    |
| O  | Other (describe)        |

Note 2: Waste Descriptor Codes. (Choose up to three which predominate by volume.)

- |                            |                                  |  |
|----------------------------|----------------------------------|--|
| 20. Charcoal               | 29. Demolition Rubble            | 38. Evaporator Bottoms/Sludges/Concentrates        |
| 21. Incinerator Ash        | 30. Cation Ion-exchange Media    | 39. Compactible Trash                              |
| 22. Soil                   | 31. Anion Ion-exchange Media     | 40. Noncompactible Trash                           |
| 23. Gas                    | 32. Mixed Bed Ion-exchange Media | 41. Animal Carcass                                 |
| 24. Oil                    | 33. Contaminated Equipment       | 42. Biological Material (except animal carcass)    |
| 25. Aqueous Liquid         | 34. Organic Liquid (except oil)  | 43. Activated Material                             |
| 26. Filter Media           | 35. Glassware or Labware         | 59. Other. Describe in Item 11, or additional page |
| 27. Mechanical Filter      | 36. Sealed Source/Device         |  |
| 28. EPA or State Hazardous | 37. Paint or Plating             |  |

Note 2A: Burial/Disposition Site

- |    |                           |
|----|---------------------------|
| B  | Barnwell Waste Management |
| E  | Envirocare                |
| R  | Richland, WA              |
| PR | Process and Return        |
| O  | Other                     |

Note 3: Solidification and Stabilization Media Codes. (Choose up to three which predominate by volume. For media meeting disposal site structural stability requirements, the numerical code must be followed by "-S-" and the media vendor and brand name must also be identified in Item 13. Code 100=NONE REQUIRED)

- |                    |  |
|--------------------|--|
| 90. Cement         | 94. Vinyl Ester Styrene                            |
| 91. Concrete       | 99. Other. Describe in Item 13, or additional page |
| 92. Bitumen        |  |
| 93. Vinyl Chloride | 100. None Required                                 |

**Enclosure 2**

Additional Information Provided by Permittee to the National Health Physics Program

The National Health Physics Program (NHPP) issued a request for information (RFI) to the permittee based on an NHPP review of the report included as **Enclosure 1**. This enclosure (**Enclosure 2**) documents that request and the permittee's response. Information referenced as *attached* in permittee responses are provided at the end of this enclosure.

NHPP Request Item 1

Attachment 3 of the report only includes instrument calibration records for two Ludlum 43-68 probes. Please provide calibration records (showing efficiencies traceable to NIST) for the other instruments used: Ludlum Model 43-37-1, Ludlum Model 19, Liquid Scintillation Counters (wipes), and Gamma Counters (wipes).

Permittee Response to Item 1

The requested calibration records are **attached**. Please note the documentation of efficiency for the Ludlum 43-68 detector with a different cable was reported by email from RSO, Inc.; a complete re-calibration was not deemed necessary, but we did re-establish the efficiency for C-14.

NHPP Request Item 2

Wipe data (Attachments 5.0 and 6.0) need better identification. Please provide Attachments 5.0 and 6.0 with sample results that are more clearly labeled with the sample field IDs.

Permittee Response to Item 2

The number designation used by RSO, Inc., for the smear analysis reflects an incremental increase by one (1) from the number designation denoted on the survey forms. The reason for this is that the first sample designation (i.e., analysis #1) is used for establishing the system background. A cross comparison between the RSO, Inc., smear analysis numbers and those as designated on the survey forms are **attached [as Enclosure 3]**.

NHPP Request Item 3

Provide additional discussion on how/where background was established for the various surface scanning detection instruments and surveyed media. The report provides different background levels for different detector probes and different media: "sealed concrete," "ceramic tile," and "8-inch tile."

Permittee Response to Item 3

The backgrounds for the various survey media that composed the facility flooring were taken in non-impacted areas of the building. This approach is allowed by MARSSIM, where it may be difficult to find locations/facilities away from the facility under evaluation for obtaining suitable backgrounds. Additionally, when evaluating the identified elevated areas, additional consideration was given to observed increase in relative instrument response. For example, for the decontamination sink in Room 113B the left side of the surface was found to be not impacted; i.e., levels consistent with those for other non-impacted areas throughout the facility. Also once the right side of the lab table surface was broken up, we verified the background on the bottom surface of a slab that was also non-impacted. For the Lab table surface in Room 113C, the right side of the sink table was not impacted, so that was used as an indication of background for the impacted left-side surface.

NHPP Request Item 4

Provide the height above floor at which the exposure rate measurements (using Ludlum Model 19 meter) were made (1 meter is normally used). Also, the report does not include any discussion of exposure rate results in Rooms 113A, 113C, and 113D; please provide this information.

Permittee Response to Item 4

There were not chest-height gamma dose rates taken in the facility. Review of the detailed radionuclide inventory maintained for Building 72 by the VAHA RSO and his staff show no use or storage of loose gamma-emitting substances that would still be present in the facility (short-lived I-131 was used in Building 72). The gamma measurements made were all near surfaces that would most likely have exhibited long-lived gamma activity had any actually been used (e.g., hood Sink drains in the Rooms 113 Lab Complex and any other area where small or large lead pigs were found in source storage drawer). No indications of elevated gamma-emitting radionuclides were found in any part of Building 72. These surveys were precautionary in nature since one of the abandoned pigs in Room 113D was marked "Mn-54" but not as part of an official label.

NHPP Request Item 5

Comments in Attachment 1 for Room 137 mention standing liquid material in a 30-gallon drum marked as "radioactive material." Describe what was done with this material. (Has it been removed from the building/properly disposed?)

Permittee Response to Item 5

The 30-gallon drum with the standing liquid was sampled (wetted smear) during the initial survey evolution and found to be non-contaminated. Upon return for the follow-up survey, the liquid had evaporated and no sediment was observed in the bottom of the drum. The "Radioactive" Symbol on the drum was removed, as were other radioactive symbols throughout the facility.

NHPP Request Item 6

The report mentions an inaccessible area adjacent to Room 137. The inaccessible area is closed off by a wall and may have suffered fire damage in the past. No surveys were able to be performed in the area, and the radiological status of this area is unknown. Provide justification for not surveying this area for unrestricted release (i.e., certify no radioactive materials were ever used in the area) or provide survey data for the area.

Permittee Response to Item 6

The Head of Research Service [at permittee facility] has confirmed that radioactive materials were never used in the inaccessible area adjacent to Room 137.

**RSO, Inc.**  
 P.O. Box 1450  
 Laurel, MD 20725  
 (301) 953-2482

# Certificate of Calibration

RSO Job No. 6994

ISSUED TO: **Chesapeake Nuclear Services**  
 788 Sonne Dr.  
 Annapolis, MD 21401

INSTRUMENT: **COBOLUM**  
 MODEL: **2350-1**  
 TYPE: **DATA LOGGER**  
 SN: **129408**

CONTACT: **Stewart Bland**  
 PHONE: (410) 266-9174

PO NO: **Credit Card**

RSO, Inc. certifies that on **01/26/2007** the above described instrument was calibrated using a radioactive source to determine the efficiency for a specific radionuclide(s) and using electronically generated pulse for the linearity. Pulsed using Luthium 500-2, S/N 159110.

The results are tabulated below. Calibration is traceable to NIST.

### Calibration Data

RANGE	EXPECTED	OBSERVED	C.E.
AUTO	100	102 cpm	0.98
	400	400 cpm	1.00
RANGING	1000	1000 cpm	1.00
	4000	4000 cpm	1.00
SCALE	10000	10000 cpm	1.00
	40000	39900 cpm	1.00
	100000	100000 cpm	1.00
	400000	399000 cpm	1.00
		<b>C.F. AVERAGE</b>	<b>1.00</b>

Probe type(s) Probe1: **PROPORTIONAL** Probe2: **PROPORTIONAL** Probe3: **PROPORTIONAL**

MODEL	SER#	WINDOW	GEOMETRY	VOLT	ISOTOPE 1 EFF. (%)	ISOTOPE 2 EFF. (%)	ISOTOPE 3 EFF. (%)	ISOTOPE 4 EFF. (%)
43-37-1	PR145081	FIXED	CONTACT	1780	Tc99 21	C14 18		
43-68	PR144456	FIXED	CONTACT	1780	Tc99 20	C14 19		
43-68	PR144454	FIXED	CONTACT	1780	Tc99 20	C14 19		

Note: Window = OFF; Threshold = 30 (0mV).

### INSTRUMENT CHECKS

Leak/Rate CHECK: **N/A**  
 BATTERY CHECK: **NORMAL**  
 CHECK SOURCE 1: **N/A** READING:  
 CHECK SOURCE 2: **N/A** READING:

### ENVIRONMENTAL

TEMP: **21°C**  
 PRESS: **760 mmHg**  
 HUMID: **27%**

THE SUGGESTED RECALIBRATION DATE FOR THIS INSTRUMENT IS **01/26/2008**

Calibrated By:

*Stewart Bland*  
 Stewart Bland

Reviewed By:

*ROE*

Cal Date: **01/26/2007**

Maryland License MD 33-021-01

4235



RSO, Inc.  
P.O. Box 1450  
Laurel, MD 20725  
(301) 953-2482

RSO Job No. 6793

# Certificate of Calibration

ISSUED TO: Chesapeake Nuclear Services  
788 Sonne Dr.  
Annapolis, MD 21401

INSTRUMENT: LUDLUM  
MODEL: 19  
TYPE: MICRO R  
SN: 182679

CONTACT: Stewart Beard  
PHONE: (410) 266-9174

PO NO: Credit Card

RSO, Inc. certifies that on 09/19/2006 the above described instrument was calibrated in a known radiation field using 137 Cs (662 keV) beam calibrator (J.L. Shepherd Model 28-6A, S/N 10056). Electronically pulsed using Ludlum 500-2, S/N 159110.

The results are tabulated below. Calibration is traceable to NIST.

### Calibration Data

RANGE	EXPECTED	OBSERVED	C.F.
25	5	5 • uR/hr	1.00
	20	20 • uR/hr	1.00
50	10	10 • uR/hr	1.00
	40	40 • uR/hr	1.00
250	50	50 • uR/hr	1.00
	200	200 • uR/hr	1.00
500	100	100 • uR/hr	1.00
	400	400 • uR/hr	1.00
5000	1000	1000 uR/hr	1.00
	4000	4000 uR/hr	1.00
C.F. AVERAGE			1.00

• Electronically pulsed.

Probe type(s) Probe1: SCINTILLATOR Probe2: Probe3:  
 MODEL SER# WINDOW GEOMETRY VOLT ISOTOPE 1 EFF.(%) ISOTOPE 2 EFF.(%) ISOTOPE 3 EFF.(%) ISOTOPE 4 EFF.(%)  
 INTERNAL NONE FRONT 752

### INSTRUMENT CHECKS

1 mR/hr CHECK: N/A  
 BATTERY CHECK: NORMAL  
 CHECK SOURCE 1: N/A READING:  
 CHECK SOURCE 2: N/A READING:

### ENVIRONMENTAL

TEMP: 24°C  
 PRESS: 754 mmHg  
 HUMID: 47 %

THE SUGGESTED RECALIBRATION DATE FOR THIS INSTRUMENT IS 09/19/2007

Calibrated By:

*Richard S. Sizemore*  
 Richard S. Sizemore

Reviewed By:

*[Signature]*

Cal Date: 09/19/2006

Maryland License MD-33-021-01

14819

**From:** Dorsey Austin [DorseyA@RSOInc.com]  
**Sent:** Wednesday, July 18, 2007 10:22 AM  
**To:** 'J Stewart Bland'  
**Subject:** RE: Ludlum 2360 w/43-68 probe Efficiency

Stewart,  
I checked the efficiency of your Ludlum 43-68 probe SN PR148454 using the three foot cable and found the efficiency for C-14 to be 11%.  
Both meter and detector were in calibration at the time the test was performed.  
Dorsey Austin  
1-888-723-5463  
dorseya@rsoinc.com

**From:** J Stewart Bland [mailto:jsbland@chesnuc.com]  
**Sent:** Tuesday, July 17, 2007 4:16 PM  
**To:** dorseya@rsoinc.com  
**Cc:** jwmoon@verizon.net; bwbland@aol.com  
**Subject:** Ludlum 2360 w/43-68 probe Efficiency

Dorsey,  
During an instrument check of our Ludlum 2360 with a 43-68 probe (# PR148454) performed for Byron Bland, you provided a C-14 detection efficiency of 11% for the use of the 3 foot detector cable. Will you please formally document this efficiency. An email transmittal should be sufficient for our records.  
Thanks.

J Stewart Bland, CHP



**Chesapeake Nuclear Services**

788 Sonne Drive  
Annapolis, MD 21401  
voice: 410-266-9174  
fax: 410-266-5811

**Enclosure 3**

Annotated Version of Attachments 5.0 and 7.0 in Enclosure 1 to This Letter

(Facility response to NHPP comments in Enclosure 2, Item 2)



Radiation Service Organization

March 7, 2007

Chesapeake Nuclear  
Attn: Stewart Bland  
788 Sonne Dr.  
Annapolis, MD 21401

*Annotated in response for  
additional information*

*JW Moon 9-5-07*

*St Bland 10-5-07*

Dear Mr. Bland,

Enclosed please find the results for the wipe tests received on February 26, 2007. The wipe tests were analyzed using Liquid Scintillation and Gamma Counters. An individual data print out for each analysis process is attached for your review. The only elevated activity indicated on the analysis reports were as follows:

Wipe test group B1-B100 found 3 wipe tests exceeding 100 but less than 300 dpm.  
Wipe test group C1-C30 found 1 wipe test exceeding 100 but less than 300 dpm.

All other results indicated activity levels below 50 dpm which included the gamma test results.

If you have any questions please do not hesitate to call me at (301) 953-2482 ext. 305 or by e-mail [james.dean@rsoinc.com](mailto:james.dean@rsoinc.com).

Sincerely,

James W. Dean  
Manager, Radiation Safety Services – Radiation Safety Officer

JWD:11P

Enclosure

NIH

Assay Definition- A1-A100

REVIEWED BY: JD 2/28/07

Assay Description: CHESAPEAKE NUCLEAR

Assay Type: DPM (Triple)

Report Name: Report1

Output Data Path: C:\Packard\Tricarb\Results\NIH\Triple Lable DPM

Raw Results Path: C:\Packard\Tricarb\Results\NIH\Triple Lable DPM\20070227\_0946.results

Assay File Name: C:\Packard\TriCarb\Assays\Triple Lable DPM.lsa

Count Conditions-

Nuclide: Triple Label

Quench Indicator: tSIE/AEC

External Std Terminator (sec): 0.5 2s%

Pre-Count Delay (min): 0.00

Quench Sets:

Low Energy: 3H-TOL-7-17-06

Mid Energy: 14C-TOL-07-17-06

High Energy: 32P-UG-02-28-05

Count Time (min): 5.00

Count Mode: Normal

Assay Count Cycles: 1

Repeat Sample Count: 1

#Vials/Sample: 1

Calculate % Reference: Off

Background Subtract: On - 1st Vial

Low CPM Threshold: Off

2 Sigma % Terminator: Off

Regions	LL	UL	Bkg Subtract
A	0.0	12.0	1st Vial
B	12.0	156.0	1st Vial
C	156.0	2000.0	1st Vial

Count Corrections-

Static Controller: On

Luminescence Correction: On

Colored Samples: On

Heterogeneity Monitor: n/a

Coincidence Time (nsec): 18

Delay Before Burst (nsec): 75

Half Life-

Half Life Correction: Off

Regions	Half Life	Units	Reference Date	Reference Time
A				
B				
C				

Cycle 1 Results

S#	Time	CPMA	CPMB	CPMC	DPM1	DPM2	DPM3	SIS	tSIE	LUM	
Bkg	1	10.00	5	8	6	0	0	0	53.33	565.99	2
A-1	2	5.00	6	12	1	10	14	1	50.09	507.24	1
	3	5.00	2	5	-1	3	6	-1	78.46	512.01	1
	4	5.00	1	1	1	2	1	1	66.19	476.71	1
	5	5.00	3	3	2	5	3	3	49.74	467.57	1
	6	5.00	5	4	2	8	4	2	60.15	573.07	0
	7	5.00	1	5	0	1	5	-0	75.54	427.61	1
	8	5.00	0	0	2	1	-0	3	164.69	462.19	1
A-8	9	5.00	1	3	1	2	4	1	1.62	306.19	4

Protocol# 1 - Triple Lable DPM.lsa

User: NIH

NIH

LD

A9	10	5.00	0	1	1	0	1	2	84.37	411.28	1
↓	11	5.00	3	2	-1	5	2	-2	43.92	479.24	1
	12	5.00	-0	3	2	-1	3	3	103.07	466.05	1
	13	5.00	-1	1	0	-3	1	-0	0.00	426.18	2
	14	5.00	-3	2	1	-6	2	1	0.00	425.05	2
	15	5.00	1	2	0	2	3	0	76.50	463.16	1
	16	5.00	-1	3	-0	-3	4	-0	162.91	474.31	1
	17	5.00	3	2	2	6	2	3	37.19	470.20	1
	18	5.00	-1	3	3	-3	3	3	121.02	435.72	1
	19	5.00	-1	2	2	-2	2	2	70.56	412.71	1
	20	5.00	-1	3	1	-2	3	1	131.99	463.25	1
	21	5.00	-1	3	1	-4	4	2	75.56	443.58	1
	22	5.00	-2	0	-1	-5	1	-1	0.00	385.77	2
	23	5.00	-2	4	-1	-9	6	-1	50.56	300.45	4
	24	5.00	-1	2	0	-4	3	0	0.00	336.11	1
	25	5.00	1	4	-0	0	5	-0	48.35	476.27	1
	26	5.00	-2	5	2	-6	6	2	77.54	401.47	1
	27	5.00	-1	1	1	-2	1	2	191.16	464.66	3
	28	5.00	-1	4	-0	-3	4	-0	121.77	450.80	1
	29	5.00	1	1	0	1	1	-0	85.65	444.69	1
	30	5.00	-2	1	1	-4	2	1	0.00	434.83	2
	31	5.00	-1	1	3	-2	1	4	0.00	457.58	3
	32	5.00	-2	3	1	-5	4	1	165.62	440.46	1
	33	5.00	1	2	2	2	1	2	42.15	473.72	1
	34	5.00	-1	3	1	-3	3	1	94.86	445.94	1
	35	5.00	0	1	1	0	1	1	26.39	467.69	1
	36	5.00	1	2	4	2	1	4	49.53	478.99	1
	37	5.00	0	2	2	-0	2	2	58.39	495.99	1
	38	5.00	3	4	-1	4	4	-1	73.24	582.81	1
	39	5.00	1	-0	-1	1	-0	-1	202.71	530.46	1
	40	5.00	-1	2	-1	-2	3	-1	154.80	477.57	1
	41	5.00	-0	3	1	-2	4	2	145.75	474.29	1
	42	5.00	-0	0	1	-0	-0	1	0.00	450.80	1
	43	5.00	-1	3	1	-3	4	1	164.44	482.72	1
	44	5.00	-1	3	1	-2	3	2	106.80	482.94	1
	45	5.00	1	1	2	2	0	2	92.63	469.04	3
	46	5.00	2	1	1	4	1	2	41.37	468.06	2
	47	5.00	-0	3	0	-2	4	-0	68.89	444.83	1
	48	5.00	1	3	1	1	4	1	30.16	468.23	2
	49	5.00	1	2	1	2	2	1	49.21	449.88	1
	50	5.00	-0	1	-0	-1	2	-0	0.00	437.52	3
	51	5.00	-2	2	1	-5	2	2	221.76	361.44	3
	52	5.00	0	1	3	0	1	4	69.25	467.47	1
	53	5.00	-0	1	1	-1	1	1	0.00	464.38	3
	54	5.00	-1	0	3	-1	-0	4	0.00	410.80	2
	55	5.00	0	3	1	-0	4	1	33.72	456.61	9
	56	5.00	1	5	-0	2	5	-0	52.90	463.19	1
	57	5.00	3	3	1	5	3	2	58.61	503.89	1
	58	5.00	-0	5	3	-2	5	3	78.08	428.75	2
	59	5.00	-0	2	3	-1	1	4	345.52	470.79	1
	60	5.00	1	2	2	1	2	2	148.95	531.00	1
	61	5.00	1	4	3	1	4	3	35.79	422.45	2
	62	5.00	-1	2	0	-3	2	-0	235.67	424.77	1
	63	5.00	-0	2	1	-0	2	1	189.44	448.19	3
	64	5.00	-0	1	1	-1	2	1	9.18	444.92	3
	65	5.00	1	3	1	0	3	1	43.93	444.11	2
	66	5.00	1	-0	1	2	-1	2	0.00	470.64	1
	67	5.00	-0	2	2	-1	2	2	45.66	445.41	1
	68	5.00	0	4	-0	-1	5	-0	52.53	485.27	2
	69	5.00	1	3	1	1	3	1	44.72	493.74	1
↓	70	5.00	-1	1	2	-2	1	2	0.00	359.14	1
A70	71	5.00	-2	1	2	-4	1	2	0.00	493.28	3

NIH

User: NIH

A-71	72	5.00	-1	1	1	-2	1	1	0.00	443.49	3
	73	5.00	-1	3	1	-3	3	1	92.85	489.84	3
↓	74	5.00	2	2	1	4	2	1	67.75	500.40	1
	75	5.00	-0	4	-0	-1	5	-0	45.08	447.97	1
	76	5.00	-0	-1	-0	-1	-1	-0	0.00	474.57	2
	77	5.00	2	5	0	3	5	0	46.56	451.32	2
	78	5.00	1	2	2	2	2	2	95.41	506.63	1
	79	5.00	2	7	-0	3	8	-1	59.05	528.17	1
	80	5.00	1	4	-2	-0	6	-2	95.06	501.81	1
	81	5.00	1	2	0	2	2	0	96.76	493.99	2
	82	5.00	0	5	2	-1	6	2	65.41	440.00	1
	83	5.00	-0	2	2	-1	2	2	72.39	462.11	1
	84	5.00	1	0	1	3	0	1	80.30	481.03	1
	85	5.00	2	1	1	4	1	2	54.60	475.36	1
	86	5.00	-0	2	1	-1	3	1	61.02	455.60	3
	87	5.00	1	5	1	-0	6	1	70.80	470.08	2
	88	5.00	1	-0	-1	2	-0	-1	335.18	476.39	1
	89	5.00	-2	1	2	-4	0	3	0.00	495.81	2
	90	5.00	1	2	3	1	2	4	73.47	387.85	1
	91	5.00	-0	0	1	-1	0	1	0.00	444.24	2
	92	5.00	1	1	4	2	1	5	0.00	419.76	1
	93	5.00	-1	3	1	-2	3	1	125.54	448.79	1
	94	5.00	-0	2	3	-2	2	4	97.02	449.34	1
	95	5.00	2	1	0	4	1	0	7.35	502.13	1
	96	5.00	0	3	2	-0	4	2	99.12	435.06	1
	97	5.00	2	2	0	5	2	0	32.94	440.45	1
	98	5.00	-0	5	2	-3	6	3	62.61	462.34	2
↓	99	5.00	1	2	1	2	2	1	11.40	488.29	1
A-100	100	5.00	-1	2	0	-3	2	0	120.26	439.24	1
	101	5.00	0	1	3	0	0	4	117.61	522.56	1

CHESAPEAKE NUCLEAR  
 Count Time(minutes): 1.00  
 Assay Type: CPM  
 Background Subtract : IPA Bkg  
 Outlier: 5.0 FLAG  
 %Spillup: 0.00  
 %Spilldown: 0.00  
 Screening: OFF

REVIEWED BY:  
*JD* 2/28/07

	Window A	Window B	Window C
Nuclide:	I-125 15 - 75 keV	Co-57 75 - 165 keV	MAN 15 - 2000 keV
Bkg:	24.7	29.2	229
Sigma:	0.00	0.00	2.00
LCR:	0	0	0
Half Life(hours):	0.00	0.00	
Multiplier:	1.0000		
%CV Flag Limit:	0.00	0.00	

*← Composite gamma*

S#	A:CPM	A:%SIG	B:CPM	B:%SIG	C:CPM	C:%SIG
1	0.0		0.0		0.0	
2	0.0		0.0		0.0	
3	0.0		0.0		0.0	
4	4.3	48.5	5.8	41.5	20.7	22.0
5	0.0		0.0		0.0	
6	2.3	66.5	10.8	30.4	25.7	19.7
7	2.3	66.5	0.8	112	0.0	
8	3.3	55.4	6.8	38.3	19.7	22.5
9	0.0		0.0		11.7	29.2
10	11.3	29.8	0.0		8.7	33.9
(24A) 11	0.0		3.8	51.3	1.7	76.7

EDITDATA.D07 Archived to C:\ARCH\ARCH07D.183  
 C:\DATA\P7DATA Copied to C:\DATA\ARCH07A.183

26 Feb 07 14:19:18 Packard Model 5003 COBRA SN: 424559

PROTOCOL # 7  
 SWIPES  
 CHESAPEAKE NUCLEAR  
 COUNT TIME 1.00 Minutes

Sample #	Window A		Window B		Window C	
	A:CPM	A:DPM	B:CPM	B:DPM	C:CPM	C:DPM
1	0	0	0	0	0	0
2	0	0	0	0	0	0
3	0	0	0	0	0	0
4	4	5	6	7	21	30
5	0	0	0	0	0	0



6  
7  
8  
9  
10  
11  
(24A)

2  
2  
3  
0  
11  
0

3  
3  
4  
0  
14  
0

11  
1  
7  
0  
0  
4

13  
1  
8  
0  
0  
4

26  
9  
20  
12  
9  
2

37  
0  
28  
17  
12  
2

LD

Assay Definition- *BI- B100*

REVIEWED BY:  
*JD 2/28/07*

Assay Description:  
CHESAPEAKE NUCLEAR

Assay Type: DPM (Triple)  
Report Name: Report1  
Output Data Path: C:\Packard\Tricarb\Results\Default\Triple Lable DPM  
Raw Results Path: C:\Packard\Tricarb\Results\Default\Triple Lable  
DPM\20070227\_2036.results  
Assay File Name: C:\Packard\TriCarb\Assays\Triple Lable DPM.lsa

Count Conditions-

Nuclide: Triple Label  
Quench Indicator: tSIE/AEC  
External Std Terminator (sec): 0.5 2s%  
Pre-Count Delay (min): 0.00  
Quench Sets:  
Low Energy: 3H-TOL-7-17-06  
Mid Energy: 14C-TOL-07-17-06  
High Energy: 32P-UG-02-28-05  
Count Time (min): 5.00  
Count Mode: Normal  
Assay Count Cycles: 1 Repeat Sample Count: 1  
#Vials/Sample: 1 Calculate % Reference: Off

Background Subtract: On - 1st Vial  
Low CPM Threshold: Off  
2 Sigma % Terminator: Off

Regions	LL	UL	Bkg Subtract
A	0.0	12.0	1st Vial
B	12.0	156.0	1st Vial
C	156.0	2000.0	1st Vial

Count Corrections-

Static Controller: On Luminescence Correction: On  
Colored Samples: On Heterogeneity Monitor: n/a  
Coincidence Time (nsec): 18 Delay Before Burst (nsec): 75

Half Life-

Half Life Correction: Off

Regions	Half Life	Units	Reference Date	Reference Time
A				
B				
C				

Cycle 1 Results


S#	Time	CPMA	CPMB	CPMC	DPM1	DPM2	DPM3	SIS	tSIE	LUM
<i>Bkg</i> 1	10.00	5	9	7	0	0	0	58.17	508.25	1
<i>B-1</i> 2	5.00	-1	3	1	-3	4	1	55.31	412.81	1
<i>↓</i> 3	5.00	-0	2	-2	-2	3	-2	24.80	341.97	1
4	5.00	0	1	-1	-0	2	-1	122.67	421.97	1
5	5.00	0	2	1	1	2	1	36.35	413.85	1
6	5.00	-0	1	-1	-1	2	-1	72.87	399.09	0
7	5.00	-0	-1	0	-0	-1	0	0.00	446.69	2
<i>R-7</i> 8	5.00	1	5	1	0	5	1	47.45	425.83	2

*JD*

B8	9	5.00	3	2	-0	7	2	-0	19.43	434.03	0
↓	10	5.00	142	206	-2	281	230	-3	30.40	409.51	0
	11	5.00	8	3	-1	16	2	-1	18.35	473.41	1
	12	5.00	51	50	0	110	52	0	28.44	407.61	0
	13	5.00	1	3	-1	3	4	-2	13.19	377.05	1
	14	5.00	-1	2	0	-2	3	0	105.23	434.40	1
	15	5.00	-0	4	0	-1	5	0	83.34	460.97	1
	16	5.00	6	3	1	11	3	1	33.28	523.38	1
	17	5.00	1	1	-2	1	1	-2	64.50	486.01	1
	18	5.00	-1	5	-1	-3	6	-1	5.34	349.32	1
	19	5.00	1	1	0	2	1	0	24.07	432.31	1
	20	5.00	2	1	-0	4	1	-0	0.00	438.26	0
	21	5.00	3	13	-1	4	15	-1	52.15	474.39	1
	22	5.00	1	1	1	2	1	1	78.77	483.19	1
	23	5.00	3	1	-0	6	1	-0	42.17	503.43	1
	24	5.00	0	2	-1	-0	3	-1	33.62	494.81	1
	25	5.00	2	2	-2	4	2	-2	49.92	467.97	1
	26	5.00	-1	3	-1	-4	4	-1	113.45	442.71	1
	27	5.00	3	1	-2	8	1	-3	19.30	463.06	1
	28	5.00	1	-1	-1	2	-1	-1	0.00	468.02	1
	29	5.00	1	0	0	2	-0	0	0.00	470.18	1
	30	5.00	0	4	-1	-1	5	-1	146.34	511.65	1
	31	5.00	7	10	-1	12	11	-1	28.84	484.54	1
	32	5.00	0	-0	1	1	-1	1	0.00	417.74	6
	33	5.00	2	4	-0	2	4	-0	51.23	450.98	1
	34	5.00	1	2	-2	1	3	-2	94.08	519.56	1
	35	5.00	1	2	-0	1	2	-0	57.04	472.85	1
	36	5.00	1	3	-1	1	4	-1	87.59	502.18	1
	37	5.00	1	3	-0	2	3	-0	54.79	446.92	1
	38	5.00	0	2	-0	-0	2	-0	0.00	438.78	1
	39	5.00	-0	1	-0	-0	1	-0	84.06	389.94	1
	40	5.00	62	46	0	124	47	0	23.22	476.51	0
	41	5.00	29	21	-1	64	22	-1	21.87	407.33	0
	42	5.00	2	3	0	2	3	0	51.82	521.94	1
	43	5.00	1	1	2	2	0	3	0.00	435.47	0
	44	5.00	0	-0	-1	1	0	-1	0.00	443.59	1
	45	5.00	0	-2	0	2	-2	0	0.00	478.42	0
	46	5.00	-0	6	1	-3	7	1	57.52	464.18	1
	47	5.00	1	-1	-1	2	-1	-1	0.00	447.53	1
	48	5.00	-1	2	0	-3	2	0	474.48	517.93	1
	49	5.00	0	1	-0	-0	1	-0	0.00	450.99	1
	50	5.00	1	1	-2	2	1	-2	122.44	428.73	1
	51	5.00	-1	1	-4	-2	3	-5	63.13	464.40	1
	52	5.00	-1	3	-1	-4	4	-1	0.00	415.69	1
	53	5.00	0	1	0	1	1	0	140.84	441.55	1
	54	5.00	-1	2	-1	-3	3	-1	0.00	427.46	1
	55	5.00	2	-0	0	4	-1	0	0.00	447.01	1
	56	5.00	-2	1	1	-5	2	1	0.00	491.88	2
	57	5.00	-1	2	-1	-2	3	-1	203.66	440.31	1
	58	5.00	0	0	1	1	-0	1	0.00	450.53	1
	59	5.00	1	5	-3	1	7	-4	54.76	434.20	1
	60	5.00	1	1	-1	2	1	-1	45.40	458.36	1
	61	5.00	0	5	-1	-1	6	-1	68.51	493.39	1
	62	5.00	-0	2	-1	-1	3	-1	0.00	459.26	1
	63	5.00	1	1	-1	2	2	-2	67.41	517.56	1
	64	5.00	0	2	-1	-0	2	-1	13.34	441.37	1
	65	5.00	0	2	-1	-0	3	-1	83.79	505.13	1
	66	5.00	1	1	-0	1	1	-0	93.19	450.49	1
	67	5.00	-0	2	-1	-1	3	-1	134.52	466.33	1
	68	5.00	-0	1	-1	-1	1	-1	0.00	440.87	1
	69	5.00	1	-1	-0	2	-2	-0	0.00	472.70	2
B69	70	5.00	-1	1	-1	-2	1	-1	0.00	425.86	1

B70	71	5.00	0	2	-1	-1	3	-1	87.94	428.66	1
↓	72	5.00	1	3	-1	0	4	-1	71.82	499.38	0
	73	5.00	0	-1	-2	1	-1	-2	0.00	411.42	2
	74	5.00	0	-2	-2	2	-3	-2	0.00	533.90	2
	75	5.00	1	1	1	1	1	1	0.00	450.96	1
	76	5.00	2	0	-1	4	0	-1	0.00	504.50	0
	77	5.00	-0	-2	3	-0	-3	4	0.00	447.94	2
	78	5.00	1	0	-0	2	0	-0	0.00	426.97	0
	79	5.00	1	-0	-1	3	-0	-1	57.46	456.95	1
	80	5.00	1	0	-0	3	-0	-0	95.80	472.18	1
	81	5.00	3	1	-1	5	2	-1	46.91	486.01	1
	82	5.00	1	0	-1	3	0	-1	115.79	516.21	1
	83	5.00	-0	-1	2	-0	-1	3	0.00	459.62	2
	84	5.00	1	1	-2	3	1	-2	0.00	448.96	3
	85	5.00	-1	2	-3	-3	4	-4	73.83	449.59	1
	86	5.00	-0	3	-1	-1	3	-1	152.77	472.92	3
	87	5.00	-1	1	-1	-2	2	-1	19.66	464.82	1
	88	5.00	0	4	-1	-0	5	-1	99.37	457.58	1
	89	5.00	0	1	1	0	1	2	167.56	472.50	1
	90	5.00	-0	4	2	-2	5	2	124.60	464.35	2
	91	5.00	1	-0	1	2	-0	1	0.00	546.07	1
	92	5.00	-1	1	3	-3	1	3	0.00	478.54	3
	93	5.00	2	1	1	5	0	1	9.28	472.60	2
	94	5.00	1	2	2	1	2	2	74.00	453.37	1
	95	5.00	0	1	-1	0	1	-1	16.18	451.53	3
	96	5.00	3	0	2	6	-1	3	57.03	498.04	1
	97	5.00	1	2	2	3	1	3	13.89	479.78	1
	98	5.00	2	-1	-2	4	-1	-2	0.00	503.45	1
	99	5.00	1	-0	3	2	-2	4	0.00	448.46	3
	100	5.00	0	1	-1	-0	1	-1	137.03	452.35	3
B100	101	5.00	0	3	-1	-1	4	-1	54.32	441.07	0

CHESAPEAKE NUCLEAR  
 Count Time(minutes): 1.00  
 Assay Type: CPM  
 Background Subtract: IPA Bkg  
 Outlier: 5.0 FLAG  
 %Spillue: 0.00  
 %Spilldown: 0.00  
 Screening: OFF

REVIEWED BY:  
 2/28/07

	Window A		Window B		Window C	
Nuclide:	I-125	15 - 75 keV	Co-57	75 - 165 keV	MAN	15 - 2000 keV
Bkg:	14.7		29.2		229	
Sigma:	0.00		0.00		2.00	
LCR:	0		0		0	
Half Life(hours):	0.00		0.00			
Multiplier:	1.0000					
%CV Flag Limit:	0.00		0.00			

SN	A		B		C	
	CPM	%SIG	CPM	%SIG	CPM	%SIG
1	1.3	89.1	0.0		0.0	
2	0.3	196	5.8	41.5	1.7	76.7
3	0.0		0.0		10.7	30.6
4	0.0		1.8	74.5	0.0	
5	2.3	66.5	22.8	20.9	33.7	17.2
6	0.0		2.6	59.8	39.7	15.9
7	0.0		0.8	112	4.7	46.1
8	5.3	43.6	6.8	38.3	15.7	25.2
9	5.3	43.6	7.8	35.8	24.7	20.1
10	10.3	31.2	5.8	41.5	38.7	16.1
(31B) 11	0.0		0.0		0.0	

EDITDATA.D07 Archived to C:\ARCH\ARCH07D.185  
 C:\DATA\N7DATA Copied to C:\DATA\ARCH07A.185

26 Feb 07 14:41:17 Packard Model 5003 COBRA SN: 424559

PROTOCOL # 7  
 SWIPES  
 CHESAPEAKE NUCLEAR  
 COUNT TIME 1.00 Minutes

Sample #	Window A		Window B		Window C	
	A:CPM	A:DPM	B:CPM	B:DPM	C:CPM	C:DPM
1	1	2	0	0	0	0
2	0	0	6	7	2	2
3	0	0	0	0	11	15
4	0	0	2	2	0	0
5	2	3	23	27	34	48

	6	0	0	3	3	40	56
	7	0	0	1	1	5	7
	8	5	7	7	8	16	22
	9	5	7	8	9	25	35
(31B)	10	10	13	6	7	39	55
	11	0	0	0	0	0	0

22

NIH

REVIEWED BY: <i>JD</i> 2/28/07
-----------------------------------

Assay Definition- C1-C30

Assay Description:  
CHESAPEAKE NUCLEAR

Assay Type: DPM (Triple)  
 Report Name: Report1  
 Output Data Path: C:\Packard\Tricarb\Results\NIH\Triple Lable DPM  
 Raw Results Path: C:\Packard\Tricarb\Results\NIH\Triple Lable DPM\20070228\_0727.results  
 Assay File Name: C:\Packard\TriCarb\Assays\Triple Lable DPM.lsa

Count Conditions-

Nuclide: Triple Label  
 Quench Indicator: tSIE/AEC  
 External Std Terminator (sec): 0.5 2s%  
 Pre-Count Delay (min): 0.00

Quench Sets:  
 Low Energy: 3H-TOL-7-17-06  
 Mid Energy: 14C-TOL-07-17-06  
 High Energy: 32P-UG-02-28-05

Count Time (min): 5.00  
 Count Mode: Normal  
 Assay Count Cycles: 1                    Repeat Sample Count: 1  
 #Vials/Sample: 1                        Calculate % Reference: Off

Background Subtract: On - 1st Vial  
 Low CPM Threshold: Off  
 2 Sigma % Terminator: Off

Regions	LL	UL	Bkg Subtract
A	0.0	12.0	1st Vial
B	12.0	156.0	1st Vial
C	156.0	2000.0	1st Vial

Count Corrections-

Static Controller: On                    Luminescence Correction: On  
 Colored Samples: On                    Heterogeneity Monitor: n/a  
 Coincidence Time (nsec): 18           Delay Before Burst (nsec): 75

Half Life-

Half Life Correction: Off

Regions	Half Life	Units	Reference Date	Reference Time
A				
B				
C				

Cycle 1 Results

S#	Time	CPMA	CPMB	CPMC	DPM1	DPM2	DPM3	SIS	tSIE	LUM
BKA 1	10.00	5	8	6	0	0	0	57.03	557.01	1
IC 2	5.00	0	1	0	-0	1	0	94.29	462.46	1
3	5.00	0	3	1	-0	4	2	23.18	445.34	1
4	5.00	-1	5	2	-3	6	3	68.50	498.42	2
5	5.00	0	0	-1	0	1	-1	67.14	536.01	1
6	5.00	-1	2	1	-3	2	2	165.05	401.30	3
7	5.00	-1	1	2	-4	1	2	0.00	453.80	2
8	5.00	0	2	-0	0	3	-0	4.01	466.14	1
QC 9	5.00	0	2	1	0	3	1	49.20	447.97	0

NIH

User: NIH

*LD*

9C	10	5.00	-1	3	-0	-2	3	-0	14.28	435.11	0
↓	11	5.00	-1	0	-0	-3	1	-0	0.00	467.48	2
	12	5.00	2	1	1	4	1	1	68.81	496.99	1
	13	5.00	2	3	2	4	3	2	24.20	494.78	1
	14	5.00	-2	2	0	-4	3	0	291.31	485.55	1
	15	5.00	-0	3	-1	-1	4	-1	98.21	526.58	1
	16	5.00	0	1	2	0	1	3	100.05	473.52	1
	17	5.00	-1	3	1	-3	4	1	15.83	409.92	1
	18	5.00	0	3	0	-0	4	0	43.64	419.27	1
	19	5.00	0	2	1	-0	3	2	88.34	508.49	1
	20	5.00	-2	4	1	-6	5	1	109.70	469.81	1
	21	5.00	1	1	1	1	1	1	26.30	493.88	0
	22	5.00	-0	5	2	-2	5	2	81.71	457.87	1
	23	5.00	-0	3	1	-2	3	1	82.78	485.97	1
	24	5.00	0	2	0	0	2	0	131.77	525.48	1
	25	5.00	-0	0	1	-0	-0	2	0.00	365.34	1
	26	5.00	-0	4	0	-2	4	0	60.47	400.52	1
	27	5.00	0	8	2	-2	10	2	49.10	436.35	1
	28	5.00	4	15	1	5	17	1	51.71	443.39	1
	29	5.00	12	20	0	21	23	-0	37.18	451.32	0
	30	5.00	124	176	0	226	195	-1	37.13	474.19	0
30C	31	5.00	-0	4	0	-1	4	0	56.09	451.11	1



CHESAPEAKE NUCLEAR

Count Time(minutes): 1.00  
 Assay Type: CPM  
 Background Subtract : IPA Bkg  
 Outlier: 5.0 FLAG  
 %Spillup: 0.00  
 %Spilldown: 0.00  
 Screening: OFF

REVIEWED BY:  
*JD* 2/28/07

	Window A	Window B	Window C
Nuclide:	I-125 15 - 75 keV	Co-57 75 - 165 keV	MAN 15 - 2000 keV
Bkg:	24.7	29.2	229
Sigma:	0.00	0.00	2.00
LCR:	0	0	0
Half Life(hours):	0.00	0.00	
Multiplier:	1.0000		
%CV Flag Limit:	0.00	0.00	

S#	A:CPM	A:%SIG	B:CPM	B:%SIG	C:CPM	C:%SIG
1	0.0		2.8	59.8	0.0	
2	0.0		0.0		0.0	
3	0.0		0.8	112	0.0	

EDITDATA.D07 Archived to C:\ARCH\ARCH07D.184  
 C:\DATA\P7DATA Copied to C:\DATA\ARCH07A.184

26 Feb 07 14:35:40 Packard Model 5003 COBRA SN: 424559

PROTOCOL # 7  
 SWIPES  
 CHESAPEAKE NUCLEAR  
 COUNT TIME 1.00 Minutes

	Window A		Window B		Window C	
LLD:	15 keV		75 keV		15 keV	
ULD:	75 keV		165 keV		2000 keV	
EFF:	79 %		85 %		70 %	
Sample #	A:CPM	A:DPM	B:CPM	B:DPM	C:CPM	C:DPM
1	0	0	3	3	0	0
2	0	0	0	0	0	0
3	0	0	1	1	0	0



Radiation Service Organization

March 27, 2007

Chesapeake Nuclear  
Attn: Stewart Bland  
788 Sonne Dr.  
Annapolis, MD 21401

*Annotated in response to request  
for additional information*

*JW Moon 9-5-07*

*JS Bland 10-5-07*

Dear Mr. Bland,

Enclosed please find the results for the wipe tests received on March 26, 2007. The wipe tests were analyzed using Liquid Scintillation, Gamma Counters and Gamma Spectroscopy. An individual data print out for each analysis process is attached for your review. The only elevated activity indicated on the analysis reports were as follows:

→ *Note: Range of wipe test group is 31C through 67C.*  
Wipe test group 3C to 67C (37 wipe tests) found 3 wipe tests exceeding 100 and 2 wipe tests exceeding 1,000 dpm. Please review attached beta-gamma LSC data results for activity concentrations.

Analysis of swabs 5, 6 & 8 found no activity exceeding 10 dpm.  
Please review attached beta-gamma LSC data results for activity concentrations.

Wipe tests were Gamma counted and analysis results indicated all activity levels below 50 dpm. Please review attached gamma data results for activity concentrations.

Gamma spec analysis of scrapings received within 7 small bags found no spectrum outside of normal background.

If you have any questions please do not hesitate to call me at (301) 953-2482 ext. 305 or by e-mail [james.dean@rsoinc.com](mailto:james.dean@rsoinc.com).

Sincerely,

James W. Dean  
Manager, Radiation Safety Services – Radiation Safety Officer

Enclosure



CHESAPEAKE NUCLEAR

Count Time(minutes): 1.00  
 Assay Type: CPM  
 Background Subtract : IPA Bkg  
 Outlier: 5.0 FLAG  
 %Spillup: 0.00  
 %Spilldown: 0.00  
 Screening: OFF

REVIEWED BY:  
*D* 3/27/07

	Window A		Window B		Window C	
Nuclide:	I-125	15 - 75 keV	Co-57	75 - 165 keV	MAN	15 - 2000 keV
Bkg:	23.1		26.7		210	
Sigma:	0.00		0.00		2.00	
LCR:	0		0		0	
Half Life(hours):	0.00		0.00			
Multiplier:	1.0000					
%CV Flag Limit:	0.00		0.00			

*Sum of 7 max scrapings*

S#	A:CPM	A:%SIG	B:CPM	B:%SIG	C:CPM	C:%SIG
1	1.9	72.2	0.0		0.0	
2	9.9	31.8	2.3	65.4	6.2	40.2
3	3.9	50.5	3.3	54.7	15.2	26.6
4	0.0		3.3	54.7	20.2	22.2
5	0.0		3.3	54.7	21.2	21.7
6	11.9	29.0	6.3	39.7	41.2	15.6
7	0.0		0.3	171	6.2	40.2

EDITDATA.D07 Archived to C:\ARCH\ARCH07D.191  
 C:\DATA\P7DATA Copied to C:\DATA\ARCH07A.191

26 Mar 07 14:10:59 Packard Model 5003 COBRA SN: 424559

PROTOCOL # 7  
 SWIPES  
 CHESAPEAKE NUCLEAR  
 COUNT TIME 1.00 Minutes

Sample #	Window A		Window B		Window C	
	A:CPM	A:DPM	B:CPM	B:DPM	C:CPM	C:DPM
1	2	2	0	0	0	0
2	10	13	2	3	6	9
3	4	5	3	4	15	22
4	0	0	3	4	20	29
5	0	0	3	4	21	30
6	12	15	6	7	41	59
7	0	0	0	0	6	9

NIH

REVIEWED BY: <i>JD</i> 3/27/07
-----------------------------------

Assay Definition-

Assay Description:  
CHEASAPEAKE NUCLEAR

Assay Type: DPM (Triple)  
Report Name: Report1  
Output Data Path: C:\Packard\Tricarb\Results\NIH\Triple Lable DPM  
Raw Results Path: C:\Packard\Tricarb\Results\NIH\Triple Lable DPM\20070326\_1554.results  
Assay File Name: C:\Packard\TriCarb\Assays\Triple Lable DPM.lsa

Count Conditions-

Nuclide: Triple Label  
Quench Indicator: tSIE/AEC  
External Std Terminator (sec): 0.5 2s%  
Pre-Count Delay (min): 0.00  
Quench Sets:  
Low Energy: 3H-TOL-7-17-06  
Mid Energy: 14C-TOL-07-17-06  
High Energy: 32P-UG-02-28-05  
Count Time (min): 5.00  
Count Mode: Normal  
Assay Count Cycles: 1 Repeat Sample Count: 1  
#Vials/Sample: 1 Calculate % Reference: Off

Background Subtract: On - 1st Vial  
Low CPM Threshold: Off  
2 Sigma % Terminator: Off

Regions	LL	UL	Bkg Subtract
A	0.0	12.0	1st Vial
B	12.0	156.0	1st Vial
C	156.0	2000.0	1st Vial

Count Corrections-

Static Controller: On Luminescence Correction: On  
Colored Samples: On Heterogeneity Monitor: n/a  
Coincidence Time (nsec): 18 Delay Before Burst (nsec): 75

Half Life-

Half Life Correction: Off

Regions	Half Life	Units	Reference Date	Reference Time
A				
B				
C				

Cycle 1 Results

S#	Time	CPMA	CPMB	CPMC	DPM1	DPM2	DPM3	SIS	tSIE	LUM	
8K-1	10.00	6	11	6	0	0	0	68.71	527.52	2	
↑ #1	2	5.00	1	-2	3	2	-3	3	0.00	490.83	4
↑	3	5.00	1	-2	-1	4	-2	-1	0.00	497.42	4
3IC	4	5.00	0	1	1	0	1	2	0.00	481.85	2
	5	5.00	1	0	2	2	-0	3	0.00	505.94	2
	6	5.00	0	0	1	1	-0	1	0.00	497.94	2
	7	5.00	1	7	3	0	7	4	47.92	456.63	2
↓	8	5.00	1	2	1	1	3	2	0.00	502.96	2
3EC	9	5.00	0	4	3	-0	4	3	17.25	464.03	2

NIH

39C	10	5.00	0	1	2	0	1	2	0.00	470.50	2	
	11	5.00	-1	1	1	-2	2	1	0.00	473.34	3	
↓	12	5.00	0	2	2	-0	2	2	0.00	422.26	2	
	13	5.00	-1	-1	5	-2	-2	6	0.00	498.13	3	
43C	14	5.00	2426	4726	5	3998	5389	-16	41.30	482.06	0	} Sink Top
44C	15	5.00	100	162	3	168	182	3	41.74	518.21	0	} 113 B
45C	16	5.00	129	168	3	237	184	3	35.88	481.58	0	
↓	17	5.00	5	5	2	11	5	3	4.24	408.48	1	
	18	5.00	0	4	2	-1	5	2	40.89	407.03	2	
	19	5.00	9	12	4	16	12	4	23.53	457.51	1	
49C	20	5.00	649	1164	1	1147	1318	-3	37.46	447.54	0	Speed Concentrator
↓	21	5.00	-0	3	2	-2	3	2	0.00	420.95	1	(internals) 113A
	22	5.00	3	1	1	7	1	2	0.00	446.18	2	
	23	5.00	1	5	-0	-0	6	-0	45.66	432.58	2	
	24	5.00	-1	1	1	-2	1	1	0.00	397.77	1	
	25	5.00	1	1	3	3	0	3	0.00	464.81	2	
	26	5.00	9	3	-1	18	3	-1	8.11	490.25	1	
	27	5.00	14	13	-2	30	14	-2	12.92	395.32	1	
	28	5.00	1	0	2	3	-0	2	0.00	496.22	2	
	29	5.00	26	2	1	63	-2	1	0.00	408.92	1	
	30	5.00	3	3	0	5	4	0	0.00	487.01	2	
	31	5.00	6	2	1	12	1	1	0.00	488.62	2	
	32	5.00	5	0	2	10	-1	2	0.00	500.78	2	
	33	5.00	24	9	-1	51	8	-1	14.71	485.19	1	Rm 113C
	34	5.00	44	22	1	107	20	1	13.43	369.64	0	} Pre-decon
	35	5.00	10	5	-2	20	6	-2	22.25	521.84	1	} Refrigerator
	36	5.00	4	3	1	7	3	2	31.37	487.86	3	(internals)
66C	37	5.00	17	10	3	32	9	3	18.44	541.92	1	
#37	38	5.00	2	2	2	4	2	2	1.42	507.76	2	Rm 113D sinktop
#5	39	5.00	1	-3	0	4	-4	0	0.00	535.89	3	left side
#6	40	5.00	3	3	3	6	3	4	29.67	515.97	2	
#8	41	5.00	3	-2	3	6	-4	3	0.00	524.08	2	} Drain Swabs

67C

\*\*\*\*\*  
 \*\*\*\*\* G A M M A S P E C T R U M A N A L Y S I S \*\*\*\*\*  
 \*\*\*\*\*

Report Generated On : 3/26/07 12:30:12 PM  
 Sample Title : Soil  
 Spectrum Description :  
 Sample Identification : CHESAPEAKE NUC  
 Sample Type : Sol  
 Sample Geometry : Marinelli Beaker  
 Peak Locate Threshold : 3.00  
 Peak Locate Range (in channels) : 50 - 8192  
 Peak Area Range (in channels) : 50 - 8192  
 Identification Energy Tolerance : 1.000 keV  
 Sample Size : 1.000E+000 Grams  
 Sample Taken On : 3/26/07 12:15:06 PM  
 Acquisition Started : 3/26/07 12:15:06 PM  
 Live Time : 900.0 seconds  
 Real Time : 900.1 seconds

REVIEWED BY:  
*JD* 3/27/07

Energy Calibration Used Done On : 1/25/07  
 Efficiency Calibration Used Done On : 1/23/07

Note: Scrapings were  
 wax surface over  
 contaminated linoleum  
 floor tiles Rm 113 and  
 113B

*Jim*

*I put these 7 small bags of scrapings  
 into a beaker + counted. Let me know  
 if you need additional info.*

*JWhoun  
 +  
 JRBnd*

*Rich  
 3/26/07*

\*\*\*\*\*  
\*\*\*\*\* N U C L I D E I D E N T I F I C A T I O N R E P O R T \*\*\*\*\*  
\*\*\*\*\*

Sample Title: Soil  
Nuclide Library Used: C:\GENIE2K\CAMFILES\NORMPLUS.NLB

## ..... IDENTIFIED NUCLIDES .....

Nuclide Name	Id Confidence	Energy (keV)	Yield (%)	Activity (pCi/Gram)	Activity Uncertainty
-----------------	------------------	-----------------	--------------	------------------------	-------------------------

\* = Energy line found in the spectrum.

@ = Energy line not used for Weighted Mean Activity

Energy Tolerance : 1.000 keV

Nuclide confidence index threshold = 0.30

Errors quoted at 2.000 sigma



\*\*\*\*\*  
 \*\*\*\*\* INTERFERENCE CORRECTED REPORT \*\*\*\*\*  
 \*\*\*\*\*

Nuclide Name	Nuclide Id Confidence	Wt mean Activity (pCi/Gram)	Wt mean Activity Uncertainty
-----------------	-----------------------------	-----------------------------------	------------------------------------

? = nuclide is part of an undetermined solution  
 X = nuclide rejected by the interference analysis  
 @ = nuclide contains energy lines not used in Weighted Mean Activity

Errors quoted at 2.000 sigma

\*\*\*\*\* UNIDENTIFIED PEAKS \*\*\*\*\*

Peak Locate Performed on: 3/26/07 12:30:11 PM  
 Peak Locate From Channel: 50  
 Peak Locate To Channel: 8192

Peak No.	Energy (keV)	Peak Size in Counts per Second	Peak CPS % Uncertainty
1	26.35	1.5569E-001	25.45

M = First peak in a multiplet region  
 m = Other peak in a multiplet region  
 F = Fitted singlet

Errors quoted at 2.000 sigma



Radiation Service Organization

July 10, 2007

Chesapeake Nuclear  
Attn: Stewart Bland  
788 Sonne Dr.  
Annapolis, MD 21401

*Annotated in response to request  
for additional information*

*JW Moon 9-5-07  
JS Bland 10-5-07*

Dear Mr. Bland,

Enclosed please find the results of the 10 wipe tests received on July 2, 2007. The wipe tests were analyzed using Liquid Scintillation (LSC) counting technology. An LSC individual data results print out denoting each analysis result is attached for your review. The results of the first sample are for background determination. The wipe test analysis begins with sample location #2. Wipe test results were background deducted presenting net results. Reported analytical data indicates all activity levels below 50 dpm.

If you have any questions please do not hesitate to call me at (301) 953-2482 ext. 305 or by e-mail [james.dean@rsoinc.com](mailto:james.dean@rsoinc.com).

Sincerely,

James W. Dean  
Manager, Radiation Safety Services – Radiation Safety Officer

Enclosure

July 2, 2007

Stewart Bland  
Chesapeake Nuclear Services, Inc.  
788 Sonne Dr.  
Annapolis, MD 21401  
USA

Dear Stewart:

The ten swipes delivered to RSO Inc. were found to be < 50dpm. The final results will be sent to you with the invoice.

Sincerely,

A handwritten signature in black ink, appearing to read "Richard Emmons". The signature is fluid and cursive, with a long horizontal flourish extending to the right.

Mr. Richard Emmons  
Laboratory Technician

REVIEWED BY:  
*JD* 7/06/07

Assay Definition-

Assay Description:  
 CHESAPEAKE NUCLEAR

Assay Type: DPM (Triple)  
 Report Name: Report1  
 Output Data Path: C:\Packard\Tricarb\Results\Default\Triple Lable DPM  
 Raw Results Path: C:\Packard\Tricarb\Results\Default\Triple Lable  
 DPM\20070702\_1238.results  
 Assay File Name: C:\Packard\TriCarb\Assays\Triple Lable DPM.lsa

Count Conditions-

Nuclide: Triple Label  
 Quench Indicator: tSIE/AEC  
 External Std Terminator (sec): 0.5 2s%  
 Pre-Count Delay (min): 0.00  
 Quench Sets:  
 Low Energy: 3H-TOL-7-17-06  
 Mid Energy: 14C-TOL-07-17-06  
 High Energy: 32P-UG-02-28-05  
 Count Time (min): 1.00  
 Count Mode: Normal  
 Assay Count Cycles: 1 Repeat Sample Count: 1  
 #Vials/Sample: 1 Calculate % Reference: Off

Background Subtract: On - 1st Vial  
 Low CPM Threshold: Off  
 2 Sigma % Terminator: Off

Regions	LL	UL	Bkg Subtract
A	0.0	12.0	1st Vial
B	12.0	156.0	1st Vial
C	156.0	2000.0	1st Vial

Count Corrections-

Static Controller: On Luminescence Correction: On  
 Colored Samples: On Heterogeneity Monitor: n/a  
 Coincidence Time (nsec): 18 Delay Before Burst (nsec): 75

Half Life-

Half Life Correction: Off

Regions	Half Life	Units	Reference Date	Reference Time
A				
B				
C				

Cycle 1 Results

S#	Time	CPMA	CPMB	CPMC	DPM1	DPM2	DPM3	SIS	tSIE	LUM
1	10.00	7	8	8	0	0	0	53.73	524.81	2
2	1.00	8	21	-2	10	25	-3	57.54	556.93	0 Rm 113B Sinktop Remnant
3	1.00	1	6	-1	-1	7	-2	101.77	552.25	0 } Rm 113B Floor & adjacent surfaces
4	1.00	3	3	-2	5	3	-3	71.39	556.11	0 } post remediation
5	1.00	5	5	-2	8	6	-3	31.53	544.69	0 Rm 113A below SC
6	1.00	-2	2	-3	-5	4	-4	587.91	480.71	0 Rm 113 Floor
7	1.00	-3	1	5	-8	1	6	0.00	424.99	0 } Post Remediation
8	1.00	6	10	-0	9	12	-0	33.38	563.77	

9	1.00	14	6	-4	27	6	-5	22.48	529.99
10	1.00	4	2	-2	7	2	-3	64.25	531.70
11	1.00	-2	5	-1	-6	6	-2	120.79	547.00

0 } Rm 113C Refrige  
 0 } Post Decon  
 0 Rm 113D Adjacent  
 surface & floor  
 post remediation

*JD 7/26/07*

**The following additional information was provided to NHPP by the facility contractor, in reference to the previous 18 pages (Annotated Version of Attachments 5.0 and 7.0 in Enclosure 1)**

Page 5: NHPP Reviewer Comments

Gamma count results—Can sample #s 1-10 be annotated to an actual field location? Is #1 background? I only see “(24A)” shown for sample #11. It is just unclear what sample # goes with what field location.

*Facility Contractor Response: The contracted laboratory performed the gamma analysis before the LSC analysis. Ten wipe tests were separated and rolled together in their packaging and counted as a composite sample. If elevated activity is found, then each of the 10 wipes would be counted separately. Therefore, there were 10 composite vials analyzed for each of the A and B sets, and only 3 for the C set. There is no first vial for background for gamma wipe test analysis. No elevated gamma was detected, so we do not have separate results by individual location for the gamma analysis. The exception for this is for location #24A, which was counted separately and represented a sample of the liquid from the drum in the radwaste processing area (Room 137).*

Page 6: NHPP Reviewer Comments

Looks like sample #6 was lost on page break. Can you write in the results for it?

*Facility Contractor Response: The results for sample #6 have been deduced from the count data which is also included (in a table of count data above the table with the missing sample 6 entry).*

Page 10: NHPP Reviewer Comments

Same as Page 5...I only see “(31B)” identified for sample #11.

*Facility Contractor Response: Same response as provided above [for Page 5]. The separate gamma analysis for smear #31B was for liquid (water) that had accumulated under a sink in Room 113B.*

Page 11: NHPP Reviewer Comments

Sample #6 results were lost between page break.

*Facility Contractor Response: This is the same issue as discussed above [for Page 6]. Results have been deduced from the count data that is included.*

Page 14: NHPP Reviewer Comments

Note in header says these are for samples 1C-30C. I am not sure what this means since there are only three sample count results. Were samples composited? Maybe these could be annotated.

*Facility Contractor Response: As discussed above, for the gamma counts the smears were composited into groups of 10. Therefore, there were only three composite analyses. Since there was no detectable gamma, separate smear analyses were not performed.*

Page 17: NHPP Reviewer Comments

Same comment as Pages 5, 10, and 14 regarding what field samples these correspond to. From cover letter this appears to be seven scrapings from rooms 113/113B.

*Facility Contractor Response: The analysis was a qualitative evaluation of wax scrapings from the floor in Rooms 113 and 113B from areas identified as contaminated. The purpose of these samples was for qualifying the contamination, whether embedded in the wax or the floor tile. The separate gamma analysis and the composite gamma spectral analysis showed no detectable gamma radionuclides. The contaminated tiles were removed during the remediation.*

**Enclosure 4**

Additional Comments on Enclosure 1 by NHPP Reviewer  
(Thomas E. Huston, PhD, CHP) with Permittee Responses

Note: Facility's response to each comment is shown in italics after the NHPP comment.

1. A review of permit records indicates there has been no history of sealed sources over 100 microcuries used at the facility. There have been some smaller sealed sources listed on the license/permit that were possibly used in Building 72. The sources include the following:

C-14: Not more than 25 microcurie/source

Eu-152: Not more than 25 microcurie/source

*Facility's response to Point 1*

*The VAHA RSO [Radiation Safety Officer] maintained a surveillance program over the activities in Building 72 that included detailed radionuclide inventories including sealed sources and their ultimate disposition. The C-14 sealed source was not listed as having been used in Building 72 and the Eu-152 source (installed in a liquid scintillation counter) had been removed from the instrument and transferred to the inventory of the radiopharmaceutical lab in the main hospital.*

2. The report did not contain any discussion of the maximum quantities of radioactive materials that could have been present in the buildings and last dates of use. Also a comparison of the decay-corrected maximum possession values to 10 CFR 20, Appendix C is warranted (as per NUREG-1757, Vol. 1, Rev. 2, Figure 7.1).

A review of the facility use permit indicates the possession limits shown in the table below for research purposes, potentially used in Building 72 (e.g., see Items 6F-6S on Amendment No. 69 of license/permit for unsealed sources). Based on information in permit files maintained by NHPP, the last research use of radionuclides in Building 72 was most likely during 2001. So a five-year decay period was applied to determine which nuclides could still be present at significant levels. Based on conservative assumptions only H-3, C-14, Cl-36, and Fe-55 could remain as potential contaminants of significance (i.e., above values in 10 CFR 20, Appendix C). H-3 is a very low-energy beta emitter (max energy = 19 keV). C-14 is a low-energy beta emitter (max energy = 156 keV). Cl-36 is a medium-energy beta emitter (max energy = 710 keV). Fe-55 decays by electron capture, emitting low-energy x-rays.



Nuclide	Half life	Possession Limit (mCi)	Maximum Amount (mCi) (after 5yr-decay)	10 CFR 20 Appendix C (mCi)	Activity Fraction
H-3	12.3 y	100	75.449	1	0.43
C-14	5730 y	90	89.946	0.100	0.51
P-32	14.3 d	150	0.000	0.010	0.00
S-35	87.4 d	2	0.000	0.100	0.00
Cl-36	301000 y	9	9.000	0.010	0.05
K-42	0.5 d	25	0.000	1.000	0.00
Ca-45	163 d	9	0.004	0.100	0.00
Cr-51	28 d	30	0.000	1.000	0.00
Fe-55	997 d	10	2.810	0.100	0.02
Fe-59	45 d	10	0.000	0.010	0.00
Ru-103	39 d	5	0.000	0.100	0.00
I-125	60.1 d	105	0.000	0.001	0.00
I-131	8 d	3	0.000	0.001	0.00
		Total-->	177.209		1.00

Possession Limits set as maximum values observed in past permits.  
5-year decay used per references in permit file that research use ended upon shipment of wastes offsite in 2001.

Facility's response to Point 2

*We felt that since the RSO and his staff had maintained such tight controls of the radionuclide inventories present in Building 72 including new incoming inventory additions disposals and current inventories verified quarterly, that such an analysis as performed in Item 2 was not necessary. Of note, while listed on the facility permit, [there were] no indications that the radionuclides Cl-36 or Fe-55 were ever ordered or used in Building 72. The inventories left only the key long-lived radionuclides C-14 and H-3 of primary concern.*

3. Survey results with portable meters use the detector efficiency for C-14 (around 0.20) to convert cpm to dpm. There was no provision to account for the possibility that some surface contamination may be from H-3 (or possibly other contaminants such as Cl-36 and Fe-55 which were listed on past versions of the license and may have been introduced into the area). The total effective efficiency should be:

$$\begin{aligned} \text{Total Efficiency} = & (\text{Fraction of Activity that is C-14}) * (\text{Efficiency for C-14}) \\ & + (\text{Fraction of Activity that is H-3}) * (\text{Efficiency for H-3}) \\ & + (\text{Other Radionuclides}) * (\text{Efficiency of other nuclides}) \end{aligned}$$

Since the Efficiency for H-3 is zero and assuming the same for all other nuclides except C-14 (for detectors used in this effort), the total efficiency simply becomes:

$$\text{Total Efficiency} = (\text{Fraction of Activity that is C-14}) * (\text{Efficiency for C-14})$$

Assuming that ~50% of the total surface activity is from C-14 (as discussed in Item 2 above), the total detection efficiency for surface activity would be reduced from 0.2 (for C-14 alone) to 0.1. This would have the net effect of increasing all of the vendor's interpreted survey results (dpm) by a factor of 2. However, even with this efficiency adjustment, no areas were

reported to remain at any levels exceeding NRC pre-approved screening DCGLs in Table B.1 of NUREG-1757, Vol. 1, Rev. 2. (additional discussion in Item 11 of **Enclosure 5**).

Facility's response to Point 3

The [portable scanning] survey instrumentation used was not sensitive to the very low-energy beta emitted by H-3. Therefore, smear analysis was used for evaluating and identifying residual H-3 contamination. Both Cl-36 and Fe-55 were not identified during the HSA as being radionuclides of concern. Regardless, we concur with Dr. Huston's evaluations demonstrating sufficient detection capability even if these radionuclides were present.

4. The report did not include a comparison of "Background" and "Investigation Levels" to release limits for the different detection techniques employed. It appears that a level of "2 x background" was used to label surfaces as "contaminated" above background. To provide additional information, the reviewer performed calculations using data supplied in the report to determine these levels in "dpm/100 cm<sup>2</sup>" so they could be compared to the release limits.

In the first table the total efficiency was assigned as 0.1, consistent with the discussion in Item 3 above. This assumes that about half of the activity present is from C-14 (see Item 1). This is also supported by some of the swipe samples which had positive activity. The second table assigns an efficiency of 0.2 (equal to the efficiency for C-14). The Investigation Level, traditional "static count" Minimum Detectable Concentration ( $MDC_{static}$ ), and scan MDC were calculated using the following equations (where  $b$  is the background count rate, cpm):

$$\text{Investigation level (net dpm/100cm}^2\text{)} = \frac{(2b - b)}{\text{Efficiency}_{total}} * \frac{\text{Detector Probe Area}}{100 \text{ cm}^2}$$

$$MDC_{static} (\text{dpm/100cm}^2) = \frac{3 + 4.65\sqrt{b}}{\text{Efficiency}_{total}} * \frac{\text{Detector Probe Area}}{100 \text{ cm}^2} \text{ (for 1 minute count)}$$

$$MDC_{scan} (\text{dpm/100cm}^2) = \frac{d' \frac{\sqrt{b_i}}{i\sqrt{p}}}{\text{Efficiency}_{total}} * \frac{\text{Detector Probe Area}}{100 \text{ cm}^2}$$

Where:

$b_i$  is the number of background counts in observation interval  $i$  (2 seconds used)

$d'$  is the "detectability index" (2.32 from Table 6.5 in MARSSIM, based on tolerance rates of 95% for true positives 75% for false positives).

$p$  is the surveyor efficiency relative to the ideal observer (0.5 from MARSSIM, Section 6.7.2.1)

Media	Bkgd (cpm)	MDC <sub>static</sub> (dpm/100cm <sup>2</sup> )	MDC <sub>scan</sub> (dpm/100cm <sup>2</sup> )	2xBkg (dpm/100cm <sup>2</sup> )
<b>Ludlum 43-37-1 (771 cm<sup>2</sup>) (Using Total Efficiency = 0.1)</b>				
Sealed concrete	618	154	579	802
Ceramic Tile	929	188	710	1205
8-inch Tile	1240	216	821	1608
<b>Ludlum 43-68 (126 cm<sup>2</sup>) (Using Total Efficiency = 0.1)</b>				
Lab Bench	239	594	2205	1897

Media	Bkgd (cpm)	MDC <sub>static</sub> (dpm/100cm <sup>2</sup> )	MDC <sub>scan</sub> (dpm/100cm <sup>2</sup> )	2xBkg (dpm/100cm <sup>2</sup> )
<b>Ludlum 43-37-1 (771 cm<sup>2</sup>) (Using C-14 Efficiency = 0.2)</b>				
Sealed concrete	618	77	290	401
Ceramic Tile	929	94	355	602
8-inch Tile	1240	108	410	804
<b>Ludlum 43-68 (126 cm<sup>2</sup>) (Using C-14 Efficiency = 0.2)</b>				
Lab Bench	239	297	1102	948

The above data indicate that surface measurement techniques (using a 2x background decision point) are generally comparable to the scan MDC values that would have been obtained if a strict MARSSIM approach had been used. Also a "2 times background" action level has sensitivity necessary to identify contamination at both the NRC License Termination Screening Levels (i.e., 1.20E+8 dpm/100cm<sup>2</sup> for H-3, 3.70E+6 dpm/100cm<sup>2</sup> for C-14, 5.00E+5 dpm/100cm<sup>2</sup> for Cl-36, and 4.50E+6 dpm/100 cm<sup>2</sup> for Fe-55, in Table B.1 of NUREG-1757, Vol. 1, Rev. 2) and at the facility's adopted lower release criteria based on NUREG-1556, Volume 7, Appendix Q (i.e., direct levels < 5000 dpm/100 cm<sup>2</sup> averaged over 1 m<sup>2</sup> and < 15,000 dpm/100 cm<sup>2</sup> maximum surface contamination).

The wipe sample techniques (with background generally below about 10 cpm, efficiencies above about 0.5, nominal 1 minute sample count time, and assumed wipe area of 100 cm<sup>2</sup>) were associated with MDCs < ~40 dpm/100 cm<sup>2</sup>. This is well below the facility's adopted release criteria of 1000 dpm/100 cm<sup>2</sup> for removable beta-gamma activity (from NRC Reg Guide 1.86). This is also much less than 0.1 times the NUREG-1757 screening levels (0.1 is what the authors assumed for the removable fraction of activity in deriving NRC screening levels in NUREG-1757).

In conclusion, the measurement techniques have the necessary sensitivity to identify contamination above the release criteria.

*Facility's response to Point 4\**

*We concur with the additional analysis as performed by Dr. Huston; our instrumentation and survey techniques were selected precisely to obtain these results; however, a rigorous analysis was not performed rather was based on our long experience with the clean-up levels and the techniques and instrumentation required to attain sufficient measurement sensitivity to demonstrate compliance with the clean-up criteria.*

\*Note: Additional discussion and calculation of "Scan MDCs" were added after the facility reviewed and commented; however, final conclusions were unchanged; thus no follow-up comments were sought from the facility. (T. Huston, NHPP Reviewer)

5. Reviewer Comments on Attachment 1, Room Survey Sheets. Several of the survey sheets in the report give the reviewer the impression that contamination above release limits could still remain in the area. It is clear that some of these sheets were not updated to reflect the final status of the areas (i.e., remediation activities on June 28, 2007, and associated follow-up surveys). The following are specific references and comments on these sheets to help resolve these discrepancies:
- a. Room 113: Text in the body of the report (Sections 5.0 and 6.0) states the contaminated floor sections were removed (disposed of as radioactive waste) and the area was re-surveyed and no detectable contamination above background was found.
  - b. Room 113A: Text in the body of the report (Sections 5.0 and 6.0) indicates the "Speed Concentrator" was removed from the room and disposed of as radioactive waste. It states that other surfaces were not impacted by the Speed Concentrator.
  - c. Room 113B: Text in the body of the report (Sections 5.0 and 6.0) indicates remediation activities were performed in the area and that only one small area (~400 cm<sup>2</sup>) of detectable activity remained (sink top ~ 3600 dpm/100 cm<sup>2</sup>), but that it was below release criteria. Applying a factor of 2 to this result (to address potential presence of other nuclides) yields 7200 dpm/100 cm<sup>2</sup> (fixed) over ~400 cm<sup>2</sup>. Averaging this over 1 m<sup>2</sup> (10,000 cm<sup>2</sup>), would reduce the level below 5000 dpm/100 cm<sup>2</sup> and would be well below all applicable release criteria.
  - d. Room 113C: Text in body of report (Sections 5.0 and 6.0) indicates the refrigerator/freezer was decontaminated and final surveys showed no detectable activity above background.
  - e. Room 113D: Text in body of report (Sections 5.0 and 6.0) indicates the area was remediated and final surveys showed no contamination above background.
  - f. Room 113/A/B/C/D Objects: This is the last survey sheet in Attachment 1 of the document. The text in Sections 5.0 and 6.0 indicates remediation occurred for all contaminated objects and that only in the case of Room 113B (see Item c above) was contamination still present above background levels.

Facility's response to Point 5

*We concur with Dr. Huston's evaluation. There are no open issues concerning residual radioactive materials above the clean-up criteria in Building 72. The existing survey sets for the Room 113 complex can be annotated as detailed here if the review staff feels it is necessary.*

**Enclosure 5**

Additional Facility Details for Release of Building 72 (Hampton, Virginia)

Note: This enclosure contains information that may be useful for preparing an Environmental Assessment and Federal Register Notice for the requested action.

**1. Description of facility to be released.**

The facility to be released is a separate building, Building 72, located at the Hampton VA Medical Center (HVAMC). HVAMC is a United States Department of Veterans Affairs facility with a street address of 100 Emancipation Drive, Hampton, Virginia. The HVAMC site encompasses approximately 85 acres and contains over 25 buildings and multiple parking areas. Building 72 was constructed in 1908 and was originally used as a dining room for soldiers. It was converted into a research facility in 1974. Building 72 is a single floor, brick construction with a wooden frame attic. Additional details of Building 72 are provided in Section 1.1 of the assessment included as **Enclosure 1**.

**2. Date license initially issued.**

The first license for use of radioactive materials at HVAMC was issued August 1, 1961, by the US Atomic Energy Commission (AEC). The License No. was 45-7569-1. Following promulgation of the Energy Reorganization Act of 1974, the US Nuclear Regulatory Commission (NRC) was established and assumed regulatory authority for use of radioactive materials at the site. On March 17, 2003, NRC issued a broad-scope Master Materials License (MML) to the Department of Veterans Affairs (VA). Concurrent with issuance of the MML, VA facility licenses were converted into "Materials Permits," which are issued under various conditions of the MML. The Material Permits are administered by the Veterans Health Administration's National Health Physics Program (NHPP), located in North Little Rock, Arkansas. The use of radioactive materials at HVAMC is now authorized under VHA Materials Permit # 45-07569-01.

**3. Type of licensed material used.**

HVAMC has used licensed material for both medical diagnostic and treatment purposes and research purposes, including animal studies. Building 72 was formerly a dining hall; it began to be used as used as a research facility in 1974. Based on the Historical Site Assessment (**Enclosure 1**), it is presumed that no radioactive materials were introduced into the building until 1974. **Enclosure 4** (Item 2) provides a listing of radionuclides that were authorized to be used for research purposes. Based on that information and **Enclosure 1**, the materials of primary concern with respect to releasing Building 72 are H-3 and C-14.

**4. Type of licensed activities engaged in.**

With respect to all licensed activities at HVAMC, the facility has been engaged in both research and medical use. With respect to Building 72, the authorized activities included *in vitro*, research, and animal studies.

**5. Site description: size (square feet, square miles, acres), structures (labs, office space), surrounding area (residential, commercial, industrial, mixed).**

Building 72 is approximately 10,600 square feet and consists of vacant labs, offices, bathrooms, corridors, and storage areas. The building is on VA-controlled land and surrounded by other VA-controlled buildings. Additional details are provided in Section 1.1 of **Enclosure 1**.

**6. Size and description of affected area(s): building, rooms, areas, size.**

The following rooms were considered to be the primary affected areas and subject to 100% surface scanning: 112, 112A, 113, 113A, 113B, 113C, 113D, 124, and 124A. Other rooms in the building were subjected to 25% to 40% surface scanning. In addition, smear samples were collected from all rooms. Attachment 4.0 of **Enclosure 1** provides the surface area (SQFT) for the rooms in Building 72.

**7. Date licensed activities ceased.**

Except for some final cleaning and disposal efforts associated with final status surveys (during June 2007), the last recorded usage and disposal of radioactive materials in Building 72 was during calendar year 2001 (Section 1.2 in **Enclosure 1**). Licensed materials will continue to be used in other buildings at the facility in accordance with the facility's VHA Materials Permit.

**8. Date decontamination activities started.**

Decontamination efforts began before or during the first quarter of 2001, based on disposal records (discussed in Section 1.2 in **Enclosure 1**). Additional decontamination efforts were performed on June 28, 2007, in response to initial closeout surveys in the building.

**9. Date(s) final status surveys performed and areas surveyed.**

Final status surveys were performed by a contract firm in a phased approach. Dates of these surveys (provided in **Enclosure 1**) were February 22 and 23, 2007; March 21 and 22, 2007; and June 28, 2007, with completion being on this latter date.

**10. List of radionuclides used with half-life greater than 120 days.**

According to the Historical Site Assessment (Section 1.0 of **Enclosure 1**), radionuclides recorded to have been used in Building 72 with half-life greater than 120 days include H-3 and C-14.

**11. What DCGLs were used?**

Permit commitments require the facility to meet criteria in NUREG-1556, Volume 7, Appendix Q for unrestricted release of research facilities. These criteria are restated below as information.

For equipment released for unrestricted use (from Table Q.2, for beta emitters):

Nuclide <sup>a</sup>	Average <sup>b, c</sup>	Maximum <sup>b, d</sup>	Removable <sup>b, e</sup>
Beta-gamma emitters (nuclides with decay modes other than alpha emission or spontaneous fission) except Sr-90 and others noted above.	83.3 Bq*/100 cm <sup>2</sup> (5,000 dpm/100 cm <sup>2</sup> )	250 Bq/100 cm <sup>2</sup> (15,000 dpm /100 cm <sup>2</sup> )	16.7 Bq/100 cm <sup>2</sup> (1,000 dpm/100 cm <sup>2</sup> )

<sup>a</sup> Where surface contamination by both alpha- and beta-gamma-emitting nuclides exists, the limits established for alpha- and beta-gamma-emitting nuclides should apply independently.

<sup>b</sup> As used in this table, dpm (disintegration per minute) means the rate of emission by radioactive material as determined by correcting the counts per minute observed by an appropriate detector for background, efficiency, and geometric factors associated with the instrumentation.

<sup>c</sup> Measurements of average contaminant should not be averaged over more than 1 square meter. For objects of less surface area, the average should be derived for each such object.

<sup>d</sup> The maximum contamination level applies to an area of not more than 100 cm<sup>2</sup>.

<sup>e</sup> The amount of removable radioactive material per 100 cm<sup>2</sup> of surface area should be determined by wiping that area with filter or soft absorbent paper, applying moderate pressure, and assessing the amount of radioactive material on the wipe with an appropriate instrument of known efficiency. When removable contamination on objects of less surface area is determined, the pertinent levels should be reduced proportionally and the entire surface should be wiped.

\* 1 Bq = 1 Disintegration per second

For building surfaces (from Table Q.3, values for H-3 and C-14):

Radionuclide	Symbol	Screening levels for unrestricted release (dpm/100 cm <sup>2</sup> )
Hydrogen-3 (Tritium)	H-3	1.2 x 10 <sup>8</sup>
Carbon-14	C-14	3.7 x 10 <sup>6</sup>

According to NUREG-1556, the screening values above represent total surface concentrations of individual radionuclides that would be deemed in compliance with the 0.25 mSv/yr (25 mrem/yr) unrestricted release dose limit in 10 CFR 20.1402. For radionuclide mixtures, either a sum of fractions rule could be applied or the more restrictive limit (for C-14) simply adopted and applied to the sum of both contaminants.

The facility arbitrarily chose to apply release criteria from Regulatory Guide 1.86 (provided in Attachment 2.0 of Enclosure 1). For H-3 and C-14, the criteria in that document are much more restrictive than the values provided above for NUREG-1556, Vol. 7, Appendix Q.

In addition to release criteria above, reasonable efforts must be taken to reduce any residual contamination to levels that are ALARA. Based on the discussion in Enclosure 1 and on a site visit by NHPP following all clean-up and survey activities, it is believed that reasonable efforts were taken to reduce contamination levels to ALARA levels.



Align top of FedEx Shipping Label or ASTRA Label here.

FedEx  
TRK# 7908 5748 0420  
0201

THU - 25 OCT A2  
STANDARD OVERNIGHT

XH-ENLA

ORD  
IL-US  
60532



Emp# 331668 24OCT07 LITA

Page 1 of 1

press

RT  
FZ  
595 D  
10.25 0420

Manager | Label 790857480420

(501)257-1571  
Physics Pr  
2200 ROOTS DR  
B101 R208E  
NORTH LITTLE ROCK, AR 72114



Ship Date: 23OCT07  
ActWgt: 1 LB  
System#: 5250401/NET7091  
Account#: S \*\*\*\*\*

Delivery Address Bar Code



Ref #  
Invoice #  
PO #  
Dept #

BILL SENDER

SHIP TO: (501)257-1571  
Cassandra Frazier  
Nuclear Regulatory Commission  
2443 Warrenville Road  
Suite 210  
Lisle, IL 605324352

RT  
FZ  
595 D  
10.25 0420

press shipments only.


This pouch is resealable.

TRK# 7908 5748 0420  
0201

WED - 24OCT A2  
STANDARD OVERNIGHT

XH-ENLA

ORD  
IL-US  
60532



Press Here.  
Press Here.  
Press Here.  
Press Here.  
Small

005 FedEx 158396 REV 4/05 BP  
7492-0107

Align bottom of Airbill Pouch or FedEx and Stick Airbill here.