

November 2, 2007

Mr. David A. Christian
President and Chief Nuclear Officer
Virginia Electric and Power Company
Innsbrook Technical Center
5000 Dominion Boulevard
Glen Allen, VA 23060-6711

SUBJECT: MILLSTONE POWER STATION, UNIT NO. 2 - INDIVIDUAL NOTICE OF
CONSIDERATION OF ISSUANCE OF AMENDMENT CONCERNING THE
REVISION OF TECHNICAL SPECIFICATION 3/4.4.3 (TAC NO. MD6631)

Dear Mr. Christian:

The Nuclear Regulatory Commission (NRC) has forwarded the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing," to the Office of the Federal Register for publication.

The proposed amendment would revise Technical Specification 3/4.4.3, "Reactor Coolant System, Relief Valves" to modify the method of testing the pressurizer Power Operated Relief Valves (PORVs). Specifically, the requirement for bench testing the valves is changed to accommodate testing of the PORVs while installed in the plant. The change is requested due to the installation of new PORVs that are welded to the piping rather than bolted into the system.

If you have any questions, please contact me at 301-415-3204.

Sincerely

/ra/

John D. Hughey, Project Manager
Plant Licensing Branch 1-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-336

Enclosure:
Notice of Consideration

cc w/encls: See next page

November 2, 2007

Mr. David A. Christian
President and Chief Nuclear Officer
Virginia Electric and Power Company
Innsbrook Technical Center
5000 Dominion Boulevard
Glen Allen, VA 23060-6711

SUBJECT: MILLSTONE POWER STATION, UNIT NO. 2 - INDIVIDUAL NOTICE OF
CONSIDERATION OF ISSUANCE OF AMENDMENT CONCERNING THE
REVISION OF TECHNICAL SPECIFICATION 3/4.4.3 (TAC NO. MD6631)

Dear Mr. Christian:

The Nuclear Regulatory Commission (NRC) has forwarded the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing," to the Office of the Federal Register for publication.

The proposed amendment would revise Technical Specification 3/4.4.3, "Reactor Coolant System, Relief Valves" to modify the method of testing the pressurizer Power Operated Relief Valves (PORVs). Specifically, the requirement for bench testing the valves is changed to accommodate testing of the PORVs while installed in the plant. The change is requested due to the installation of new PORVs that are welded to the piping rather than bolted into the system.

If you have any questions, please contact me at 301-415-3204.

Sincerely

/ra/

John D. Hughey, Project Manager
Plant Licensing Branch 1-2
Division of Operatig Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-336

Enclosure:
Notice of Consideration

Cc w/encls: See next page

DISTRIBUTION:

| | | |
|-----------------|------------------|------------------------|
| PUBLIC | RidsNrrDorlLp1-2 | Lp1-2 r/f |
| RidsOgcRp | RidsNrrPMJHughey | RidsAcrsAcnwMailCenter |
| RidNrrLAABaxter | RidsNrrDorlDpr | |

ADAM Accession Nos: Package: ML073020657; Letter: ML073020662; Notice: ML073020657

| | | | | |
|--------|---------------|---------------|---------------|---------------|
| OFFICE | NRR/LPL1-2/GE | NRR/LPL1-2/PM | NRR/LPL1-2/LA | NRR/LPL1-2/BC |
| NAME | CSanders | JHughey | ABaxter | HChernoff |
| DATE | 10/31/07 | 11/01/07 | 10/31/07 | 11/02/07 |

Official Record Copy

Millstone Power Station, Unit No. 2

cc:

Lillian M. Cuoco, Esquire
Senior Counsel
Dominion Resources Services, Inc.
Building 475, 5th Floor
Rope Ferry Road
Waterford, CT 06385

Edward L. Wilds, Jr., Ph.D.
Director, Division of Radiation
Department of Environmental Protection
79 Elm Street
Hartford, CT 06106-5127

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

First Selectmen
Town of Waterford
15 Rope Ferry Road
Waterford, CT 06385

Charles Brinkman, Director
Washington Operations Nuclear Services
Westinghouse Electric Company
12300 Twinbrook Pkwy, Suite 330
Rockville, MD 20852

Senior Resident Inspector
Millstone Power Station
c/o U.S. Nuclear Regulatory Commission
P.O. Box 513
Niantic, CT 06357

Mr. J. Alan Price
Site Vice President
Dominion Nuclear Connecticut, Inc.
Building 475, 5th Floor
Rope Ferry Road
Waterford, CT 06385

Mr. J. W. "Bill" Sheehan
Co-Chair NEAC
19 Laurel Crest Drive
Waterford, CT 06385

Mr. Evan W. Woollacott
Co-Chair
Nuclear Energy Advisory Council
128 Terry's Plain Road
Simsbury, CT 06070

Ms. Nancy Burton
147 Cross Highway
Redding Ridge, CT 00870

Mr. Chris L. Funderburk
Director, Nuclear Licensing and
Operations Support
Dominion Resources Services, Inc.
Innsbrook Technical Center
5000 Dominion Boulevard
Glen Allen, VA 23060-6711

Mr. David W. Dodson
Licensing Supervisor
Dominion Nuclear Connecticut, Inc.
Building 475, 5th Floor
Rope Ferry Road
Waterford, CT 06385

Mr. Joseph Roy,
Director of Operations
Massachusetts Municipal Wholesale
Electric Company
Moody Street
P.O. Box 426
Ludlow, MA 01056