

November 2, 2007

Mr. M. R. Blevins
Senior Vice President
& Chief Nuclear Officer
Luminant Power
ATTN: Regulatory Affairs
P. O. Box 1002
Glen Rose, TX 76043

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION, UNITS 1 AND 2 -
WITHDRAWAL OF AN AMENDMENT REQUEST (TAC NOS. MD4068 AND
MD4069)

Dear Mr. Blevins:

By letter dated January 18, 2007, as supplemented July 18, 2007, you applied for an amendment to Facility Operating License Nos. NPF-87 and NPF-89, for Comanche Peak Steam Electric Station, Units 1 and 2, respectively. The proposed change would have modified the Technical Specification 3.8.1, "AC [Alternating Current] Sources - Operating," by extending the allowable completion time associated with restoration of an inoperable offsite circuit (i.e., the startup transformer). Subsequently, by letter dated October 22, 2007, you withdrew the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

/RA/

Balwant K. Singal, Senior Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-445 and 50-446

Enclosure: Notice of Withdrawal

cc w/encl: See next page

November 2, 2007

Mr. M. R. Blevins
Senior Vice President
& Chief Nuclear Officer
Luminant Power
ATTN: Regulatory Affairs
P. O. Box 1002
Glen Rose, TX 76043

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION, UNITS 1 AND 2 -
WITHDRAWAL OF AN AMENDMENT REQUEST (TAC NOS. MD4068 AND
MD4069)

Dear Mr. Blevins:

By letter dated January 18, 2007, as supplemented July 18, 2007, you applied for an amendment to Facility Operating License Nos. NPF-87 and NPF-89, for Comanche Peak Steam Electric Station, Units 1 and 2, respectively. The proposed change would have modified the Technical Specification 3.8.1, "AC [Alternating Current] Sources - Operating," by extending the allowable completion time associated with restoration of an inoperable offsite circuit (i.e., the startup transformer). Subsequently, by letter dated October 22, 2007, you withdrew the amendment request.

The Commission has filed the enclosed Notice of Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

/RA/

Balwant K. Singal, Senior Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-445 and 50-446

Enclosure: Notice of Withdrawal

cc w/encl: See next page

DISTRIBUTION:

PUBLIC
LPLIV Reading
RidsAcrsAcnwMailCenter
RidsNrrDorIDpr

RidsNrrDorLpl4
RidsNrrPMBSingal
RidsNrrLAJBurkhardt
RidsOgcRp
RidsRgn4MailCenter

AHowe, APLA
KMiller, EEEB

ADAMS Accession Nos.: ML073030004

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	NRR/LPL4/BC
NAME	BSingal	JBurkhardt	THiltz
DATE	11/2/07	11/2/07	11/2/07

OFFICIAL RECORD COPY

UNITED STATES NUCLEAR REGULATORY COMMISSIONLUMINANT GENERATION COMPANY LLCDOCKET NOS. 50-445 AND 50-446NOTICE OF WITHDRAWAL OF APPLICATION FORAMENDMENT TO FACILITY OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (the Commission) has granted the request of Luminant Generation Company LLC (the licensee) to withdraw its January 18, 2007, application, as supplemented by letter dated July 18, 2007, for proposed amendments to Facility Operating License Nos. NPF-87 and NPF-89, for Comanche Peak Steam Electric Station, Units 1 and 2, respectively, located in Somervell County, Texas.

The proposed amendment would have revised Technical Specification 3.8.1, "AC [Alternating Current] Sources - Operating," by extending the allowable completion time associated with restoration of an inoperable offsite circuit (i.e., the startup transformer).

The Commission had previously issued a Notice of Consideration of Issuance of Amendment published in the FEDERAL REGISTER on May 8, 2007 (72 FR 26178). However, by letter dated October 22, 2007, the licensee withdrew the proposed change.

For further details with respect to this action, see the application for amendment dated January 18, 2007, as supplemented by letter dated July 18, 2007, and the licensee's letter dated October 22, 2007, which withdrew the application for license amendment. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, Public File Area O1 F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management Systems (ADAMS) Public Electronic Reading Room on the internet at the NRC Web site, <http://www.nrc.gov/reading-rm.html>. Persons who do not

have access to ADAMS or who encounter problems in accessing the documents located in ADAMS should contact the NRC PDR Reference staff by telephone at 1-800-397-4209, or 301-415-4737 or by email to pdr@nrc.gov.

Dated at Rockville, Maryland, this 2nd day of November, 2007.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

Balwant K. Singal, Senior Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Comanche Peak Steam Electric Station

cc:

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 2159
Glen Rose, TX 76403-2159

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

Mr. Fred W. Madden, Director
Regulatory Affairs
Luminant Generation Company LLC
P.O. Box 1002
Glen Rose, TX 76043

Timothy P. Matthews, Esq.
Morgan Lewis
1111 Pennsylvania Avenue, NW
Washington, DC 20004

County Judge
P.O. Box 851
Glen Rose, TX 76043

Environmental and Natural
Resources Policy Director
Office of the Governor
P.O. Box 12428
Austin, TX 78711-3189

Mr. Richard A. Ratliff, Chief
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756-3189

Mr. Brian Almon
Public Utility Commission
William B. Travis Building
P.O. Box 13326
1701 North Congress Avenue
Austin, TX 78701-3326

Ms. Susan M. Jablonski
Office of Permitting, Remediation
and Registration
Texas Commission on Environmental
Quality
MC-122
P.O. Box 13087
Austin, TX 78711-3087

Mr. Anthony P. Jones
Chief Boiler Inspector
Texas Department of Licensing
and Regulation
Boiler Division
E.O. Thompson State Office Building
P.O. Box 12157
Austin, TX 78711

October 2007