



Crystal River Nuclear Plant  
Docket No. 50-302  
Operating License No. DPR-72

Ref: ITS 5.6.2.18(d)

October 23, 2007  
3F1007-14

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555-0001

Subject: Crystal River Unit 3 – Core Operating Limits Report, Cycle 15, Revision 2

Reference: Crystal River Unit 3 to NRC letter dated December 1, 2005, “Crystal River Unit 3 – Core Operating Limits Report, Cycle 15, Revision 0 and Revision 1”

Dear Sir:

Florida Power Corporation, doing business as Progress Energy Florida, Inc., hereby submits the Crystal River - Unit 3 (CR-3) Core Operating Limits Report (COLR), Cycle 15, Revision 2, as required by Improved Technical Specifications (ITS) 5.6.2.18(d).

Revision 2 adds the end of Cycle 15 Refueling Boron Concentration to the COLR to support the upcoming Refueling Outage 15 at CR-3.

No new regulatory commitments are made in this letter.

If you have any questions regarding this submittal, please contact Mr. Dennis Herrin, Acting Supervisor, Licensing and Regulatory Programs at (352) 563-4633.

Sincerely,

Stephen J. Cahill  
Engineering Manager

SJC/dar

Attachment: Core Operating Limits Report, Cycle 15, Revision 2

xc: NRR Project Manager  
Regional Administrator, Region II  
Senior Resident Inspector

Progress Energy Florida, Inc.  
Crystal River Nuclear Plant  
15760 W. Powerline Street  
Crystal River, FL 34428

AB01

NRR

**PROGRESS ENERGY FLORIDA, INC.**

**CRYSTAL RIVER UNIT 3**

**DOCKET NUMBER 50 - 302 / LICENSE NUMBER DPR - 72**

**ATTACHMENT**

**Core Operating Limits Report, Cycle 15, Revision 2**

Progress Energy - Florida  
Crystal River Unit 3

Cycle 15  
**Core Operating Limits Report**  
Revision 2

Referencing  
Improved Technical Specifications

## 1.0 Core Operating Limits

The analytical methods used to determine the core protective and operating limits shall be those previously reviewed and approved by the NRC. These methods are documented in the following topical reports and Technical Specification Amendments:

Safety Criteria and Methodology for Acceptable Cycle Reload Analyses, BAW-10179P-A, Rev. 5, Framatome-ANP, Lynchburg, Virginia, December 2004.


"Crystal River Unit 3 - Issuance of Amendment Re Dual Channel Control Rod Position Indication (TAC No M82990)," Licensing Amendment No 144, letter from H Silver to P M Beard, June 25, 1992.

The Cycle 15 limits generated using the methodologies above are documented in BAW-2492 Rev. 1, "Crystal River Unit 3 Cycle 15 Reload Report", dated November 2005.

The following limits are included in this report.

SL 2.1.1.1	AXIAL POWER IMBALANCE Protective Limits
SL 2.1.1.2	AXIAL POWER IMBALANCE Protective Limits
LCO 3.1.1	SHUTDOWN MARGIN
LCO 3.1.3	Moderator Temperature Coefficient (MTC)
SR 3.1.7.1	API/RPI Position Indication Agreement
LCO 3.2.1	Regulating Rod Insertion Limits
LCO 3.2.2	AXIAL POWER SHAPING ROD (APSR) Insertion Limits
LCO 3.2.3	AXIAL POWER IMBALANCE Operating Limits
LCO 3.2.4	QUADRANT POWER TILT
LCO 3.2.5	Power Peaking Factors
LCO 3.3.1	Reactor Protection System (RPS) Instrumentation
SR 3.4.1.1	Reactor Coolant System Pressure DNB Limits
SR 3.4.1.2	Reactor Coolant System Temperature DNB Limits
SR 3.4.1.3	Reactor Coolant System Flow DNB Limits
LCO 3.9.1	Boron Concentration

**AXIAL POWER IMBALANCE Protective Limits**



### SHUTDOWN MARGIN

Normal operating procedures require RCS boration to 1.0% $\Delta k/k$  Subcritical at 73°F prior to bypassing EFIC actuation on low steam generator pressure, or when high steam generator levels exist during secondary system chemistry control and steam generator cleaning in MODES 3, 4, and 5, therefore

Mode 3,4,5  $SDM \geq 1.0\% \Delta k/k$

These limits are  
referred to by  
Technical  
Specification  
LCO 3.1.1

Reference: Improved Technical Specification Bases B3.1.1.

**Moderator Temperature Coefficient Limit (MTC)**


Lower Limit

MTC at HFP >  $-3.58 \times 10^{-4} \Delta k/k/^\circ F$

Upper Limit

MTC  $\leq$  The curve below:

The following Upper Limits may not be exceeded (limits ensure the validity of the ECCS analysis is preserved) for operation in MODES 1 and 2:



These limits are referred to by  
Technical Specification  
LCO 3.1.3

**Absolute Position Indicator (API)/ Relative Position Indicator (RPI) Agreement Limits**

2.7% when the comparison is performed using the plant computer, or

3.5% when the comparison is performed using the panel meters on the main control board.

These limits are  
referred to by  
Technical  
Specification  
SR 3.1.7.1

Reference: "Crystal River Unit 3 – Issuance of Amendment Re: Dual Channel Control Rod Position Indication (TAC No. M82990)", Licensing Amendment No. 144, Letter from H.S. Silver to P.M. Beard, June 25, 1992.


Note 1 If the plant computer is not available, then the following meter models are approved for use: Keithley 2001, Keithley 197, Keithley 197A (Ref. EC 61264).



Regulating Rod Insertion Limits

**Regulating Rod Group Insertion  
Error Adjusted Limits**

Four Pump Operation  
0 EFPD to EOC




Note 1: A Rod group overlap of  $25 \pm 5\%$  between sequential groups 5 and 6, and 6 and 7 shall be maintained

Regulating Rod Insertion Limits (Continued)

**Regulating Rod Group Insertion  
 Error Adjusted Limits**

Three Pump Operation  
 0 EFPD to EOC



Note 1: A Rod group overlap of 25 ±5% between sequential groups 5 and 6, and 6 and 7 shall be maintained


**AXIAL POWER SHAPING ROD (APSR) Insertion Limits**

The Axial Power Shaping Rods (APSRs) shall be inserted at the initial startup following fuel reload and may be positioned as necessary during the Power Imbalance Detector Correlation (PIDC) test. The APSRs shall be fully withdrawn from the core before exceeding 4 EFPD and prior to thermal power escalation above 80% RTP. Once the APSR pull maneuver has been completed, the APSRs shall not be inserted for the remainder of the fuel cycle during normal operation.

These limits are  
referred to by  
Technical  
Specification  
LCO 3.2.2

**AXIAL POWER IMBALANCE Operating Limits**


**Axial Power Imbalance Error Adjusted  
 Operating Limit and Trip Setpoint Envelopes**  
 Four Pump Operation  
 0 EFPD to EOC



—◆— Allowable Trip Setpoint Envelope    - - ■ - - Operating Limit Envelope    —▲— Actual Trip Setpoint Envelope

**AXIAL POWER IMBALANCE Operating Limits (Continued)**

**Axial Power Imbalance Error Adjusted  
 Operating Limit and Trip Setpoint Envelopes**  
 Three Pump Operation  
 0 EFPD to EOC



**QUADRANT POWER TILT**

**QUADRANT POWER TILT Limits For Thermal Power  $\leq$  60%**

For Operation from 0 EFPD to EOC

QUADRANT POWER TILT As Measured By:	STEADY-STATE <u>LIMIT(%)</u>	TRANSIENT <u>LIMIT(%)</u>	MAXIMUM <u>LIMIT(%)</u>
Symmetrical Incore Detector System	7.50	10.03	20.0
Power Range Channels	4.94	6.96	20.0
Minimum Incore Detector System	3.07	4.40	20.0
Measurement System Independent	8.58	11.07	20.0

**QUADRANT POWER TILT Limits For Thermal Power  $>$  60%**

For Operation from 0 EFPD to EOC

QUADRANT POWER TILT As Measured By:	STEADY-STATE <u>LIMIT(%)</u>	TRANSIENT <u>LIMIT(%)</u>	MAXIMUM <u>LIMIT(%)</u>
Symmetrical Incore Detector System	4.44	10.03	20.0
Power Range Channels	1.96	6.96	20.0
Minimum Incore Detector System	1.90	4.40	20.0
Measurement System Independent	4.92	11.07	20.0

<p>These limits are referred to by                  Technical Specification LCO 3.2.4</p>
---

**Power Peaking Factors**

These Limits are referred to by Technical Specification LCO 3.2.5

**Heat Flux Hot Channel Factor  $F_Q$  (for NAS)**

$F_Q$  shall be limited by the following relationships:

$$F_Q \leq LHR^{allow}(Bu) / [LHR^{avg} * P] \text{ (for } P \leq 1.0)$$

$LHR^{allow}(Bu)$  = See the following table

$LHR^{avg}$  = 5.9476 kW/ft for Batches 14D2 and 15E2 Mark-B10I fuel

$LHR^{avg}$  = 5.8533 kW/ft for Batch 16 Mark-B-HTP fuel

$LHR^{avg}$  = 5.8636 kW/ft for Batch 17 Mark-B-HTP fuel

P = ratio of THERMAL POWER / RATED THERMAL POWER

Bu = fuel burnup (MWd/mtU)

**CR-3 Cycle 15 Reload Allowable LHR Limits  
 Batch 17F (Mark-B-HTP)  $LHR^{allow}$   
 Allowable Peak LHR for Specified Burnup, kW/ft**

NAS Level	0-725 EFPD 13396 – 35028 MWd/mtU
1	15.3
2	15.6
3	16.2
4	16.4
5	16.8
6	16.5
7	15.9
8	15.6

This table is referred to  
 by Technical Specification  
 LCO 3.2.5

**Power Peaking Factors (Continued)**

**CR-3 Cycle 15 Reload Allowable LHR Limits  
 Batch 17A, B, C, D, & E (Mark-B-HTP) LHR<sup>allow</sup>  
 Allowable Peak LHR for Specified Burnup, kW/ft**

NAS Level	0-725 EFPD 13396 – 35028 MWd/mtU
1	15.4
2	15.7
3	16.3
4	16.5
5	17.1
6	16.8
7	16.2
8	15.9

**CR-3 Cycle 15 Reload Allowable LHR Limits  
 Batch 16B, C, D, E, & F (Mark-B-HTP) LHR<sup>allow</sup>  
 Allowable Peak LHR for Specified Burnup Range, kW/ft**

NAS Level	0-423 EFPD 13396 – 26016 MWd/mtU	423-500 EFPD 26016 – 28314 MWd/mtU	500-600 EFPD 28314 – 31298 MWd/mtU	600-650 EFPD 31298 – 32790 MWd/mtU	650-725 EFPD 32790 – 35028 MWd/mtU
1	15.6	15.4	15.1	15.0	14.8
2	15.9	15.6	15.3	15.1	14.9
3	16.5	16.1	15.7	15.5	15.2
4	16.7	16.4	15.9	15.7	15.3
5	17.1	16.6	16.1	15.8	15.4
6	16.8	16.4	15.9	15.7	15.3
7	16.2	15.8	15.5	15.3	15.0
8	15.9	15.6	15.3	15.1	14.9

These tables are referred to  
 by Technical Specification.  
 LCO 3.2.5



**Power Peaking Factors (Continued)**

**CR-3 Cycle 15 Reload Allowable LHR Limits  
 Batch 16A (Mark-B-HTP) LHR<sup>allow</sup>  
 Allowable Peak LHR for Specified Burnup, kW/ft**

NAS Level	0-725 EFPD 13396 – 35028 MWd/mtU
1	15.3
2	15.6
3	16.2
4	16.4
5	16.8
6	16.5
7	15.9
8	15.6

**CR-3 Cycle 15 Reload Allowable LHR Limits  
 Batch 14D2 and 15E2 (Mark-B10I) LHR<sup>allow</sup>  
 Allowable Peak LHR for Specified Burnup Range, kW/ft**

NAS Level	0-150 EFPD 13396 – 17871 MWd/mtU	150-300 EFPD 17871 – 22347 MWd/mtU	300-450 EFPD 22347 – 26822 MWd/mtU	450-600 EFPD 26822 – 31298 MWd/mtU	600-725 EFPD 31298 – 35028 MWd/mtU
1	14.4	14.1	13.5	12.9	12.3
2	14.6	14.3	13.6	13.0	12.3
3	15.0	14.7	14.0	13.1	12.4
4	15.1	14.7	14.0	13.1	12.4
5	15.2	14.8	14.1	13.2	12.5
6	15.0	14.7	14.0	13.2	12.4
7	14.6	14.3	13.6	13.0	12.3
8	14.4	14.1	13.5	12.9	12.3

These tables are referred to  
 by Technical Specification.  
 LCO 3.2.5

**Power Peaking Factors (Continued)**

This Limit is referred to by Technical Specification LCO 3.2.5

**Enthalpy Rise Hot Channel Factor  $F_{\Delta H}^N$  (for NAS)**

$$F_{\Delta H}^N \leq \text{ARP} [1 + (1/\text{RH})(1 - P/P_m)]$$

ARP = Allowable Radial Peak, See the following table

P = ratio of THERMAL POWER / RATED THERMAL POWER and  $P \leq 1.0$

$P_m = 1.0$  for 4-RCP operation

$P_m = 0.75$  for 3-RCP operation

RH = 3.34

**Cycle 15 Allowable Radial Peaks (ARP)**

<u>Axial Peak</u>	<u>Axial Location<sup>(1)</sup> (X/L)</u>	<u>ARP<sup>(2)</sup></u>	<u>Axial Peak</u>	<u>Axial Location<sup>(1)</sup> (X/L)</u>	<u>ARP<sup>(2)</sup></u>
1.1	0.00	1.9281	1.5	0.00	1.9790
1.1	0.10	1.9264	1.5	0.10	1.9041
1.1	0.14	1.9262	1.5	0.14	1.8847
1.1	0.20	1.9254	1.5	0.20	1.9034
1.1	0.40	1.9240	1.5	0.40	1.9694
1.1	0.60	1.9229	1.5	0.60	1.8275
1.1	0.80	1.9224	1.5	0.80	1.6786
1.1	0.88	1.9000	1.5	0.88	1.6328
1.1	0.90	1.8798	1.5	0.90	1.6358
1.1	1.00	1.8000	1.5	1.00	1.5712
1.2	0.00	2.0085	1.7	0.00	1.7737
1.2	0.10	2.0050	1.7	0.10	1.6867
1.2	0.14	2.0046	1.7	0.14	1.6635
1.2	0.20	2.0035	1.7	0.20	1.6795
1.2	0.40	2.0008	1.7	0.40	1.7622
1.2	0.60	1.9993	1.7	0.60	1.6947
1.2	0.80	1.8783	1.7	0.80	1.5617
1.2	0.88	1.8304	1.7	0.88	1.5218
1.2	0.90	1.8185	1.7	0.90	1.5308
1.2	1.00	1.7394	1.7	1.00	1.4687
1.3	0.00	2.0936	1.9	0.00	1.6083
1.3	0.10	2.0878	1.9	0.10	1.5149
1.3	0.14	2.0874	1.9	0.14	1.4891
1.3	0.20	2.0858	1.9	0.20	1.5027
1.3	0.40	2.0827	1.9	0.40	1.5812
1.3	0.60	1.9721	1.9	0.60	1.5791
1.3	0.80	1.8095	1.9	0.80	1.4620
1.3	0.88	1.7599	1.9	0.88	1.4259
1.3	0.90	1.7547	1.9	0.90	1.4364
1.3	1.00	1.6824	1.9	1.00	1.3811

<sup>(1)</sup>Based on an active core height of 142.75 inches. Linear interpolation is acceptable.

<sup>(2)</sup>These limits have been increased to reflect the 3.8% peaking uncertainty treated by SCD.

---

**Reactor Protection System (RPS) Instrumentation**

**RCS Variable Low Pressure Setpoint Equation**

$$P_{\text{Trip}} \geq (11.59 * T_{\text{HOT}} - 5037.8) \text{ psig}$$

This limit is referred to by ITS  
Table 3.3.1-1, Item 5

**Reactor Coolant System DNB Pressure Limits**

RCS loop pressure  $\geq$  2064 psig

(Assumes 20% tube plugging and bounds either four or three RCPs operating).

These limits are  
referred to by  
SR 3.4.1.1

**Reactor Coolant System DNB Temperature Limit**

RCS Hot Leg Temperature  $\leq 605.8^{\circ}\text{F}$

(Assumes 20% OTSG tube plugging).

These limits are  
referred to by  
SR 3.4.1.2

**Reactor Coolant System DNB Flow Rate Limits**

RCS total flow rate  $\geq 133.5$  E6 lb/hr with four RCPs operating, or  $\geq 99.7$  E6 lb/hr with three RCPs operating.

(Assumes 20% OTSG tube plugging).

These limits are  
referred to by  
SR 3.4.1.3

### **Boron Concentration**

The refueling boron concentration must be greater than 2755 ppmB.

The value includes  $1\% \Delta k/k$  for uncertainties and is based on a 698 EFPD cycle 14. The refueling boron concentration must be increased by 2 ppm for each EFPD that the cycle 14 length is less than 698 EFPD, and 1 ppm/EFPD may be deducted for each EFPD that the cycle 14 length is more than 698 EFPD.

The Mode 6 refueling boron concentration must be greater than 1522 ppmB for the cycle 15 core configuration or during offload of the cycle 15 core, subject to the following:

- 1) allowances are included for a cycle 15 length as short as 643 EFPD;
- 2) must be corrected for the actual expected  $^{10}\text{B}$  isotopic atom percent if less than the basis of 19.8  $^{10}\text{B}$  isotopic atom percent;
- 3) no allowance is included for intermediate cycle 15 core locations;
- 4) control rod assemblies and APSR's do not affect the required refueling boron concentration.

This limit is referred to by  
Technical Specification  
LCO 3.9.1

### Revision History

Revision 0 – November 2005; Original Cycle 15 COLR.

Revision 1 – November 2005; Revision to include Batch 14D2 into Heat Flux Hot Channel Factor  $F_Q$  due to core redesign. Additionally the  $LHR^{avg}$  values for Mark-B-HTP fuel were updated with Batch specific values.

Revision 2 – September 2007; Cycle 15 COLR update to add Mode 6 refueling boron concentration.