

November 7, 2007

Mr. Timothy G. Mitchell
Vice President, Operations
Arkansas Nuclear One
Entergy Operations, Inc.
1448 S. R. 333
Russellville, AR 72802

SUBJECT: ARKANSAS NUCLEAR ONE, UNIT NO. 2 - REQUEST FOR ADDITIONAL
INFORMATION REGARDING LICENSE AMENDMENT REQUEST TO REVISE
TECHNICAL SPECIFICATION 3.1.3.4, "CEA DROP TIME" (TAC NO. MD6627)

Dear Mr. Mitchell:

By letter dated August 30, 2007, Entergy Operations, Inc. proposed to revise Technical Specification (TS) 3.1.3.4, CEA [Control Element Assembly] Drop Time for Arkansas Nuclear One, Unit 2. The TS change proposed to revise the limit on the drop time for an individual CEA.

The U.S. Nuclear Regulatory Commission staff has reviewed the request, and determined that we require additional information to complete our review. A request for additional information is enclosed. This request was discussed with David Bice of your staff on October 29, 2007, and it was agreed that a response would be provided within 60 days of receipt of this letter.

If you or your staff have any questions concerning the resolution of this matter, please contact me at (301) 415-1445.

Sincerely,

/RA/

Alan B. Wang, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-368

Enclosure: Request for Additional Information

cc w/encl: See next page

November 7, 2007

Mr. Timothy G. Mitchell
Vice President, Operations
Arkansas Nuclear One
Entergy Operations, Inc.
1448 S. R. 333
Russellville, AR 72802

SUBJECT: ARKANSAS NUCLEAR ONE, UNIT NO. 2 - REQUEST FOR ADDITIONAL
INFORMATION REGARDING LICENSE AMENDMENT REQUEST TO REVISE
TECHNICAL SPECIFICATION 3.1.3.4, "CEA DROP TIME" (TAC NO. MD6627)

Dear Mr. Mitchell:

By letter dated August 30, 2007, Entergy Operations, Inc. proposed to revise Technical Specification (TS) 3.1.3.4, CEA [Control Element Assembly] Drop Time for Arkansas Nuclear One, Unit 2. The TS change proposed to revise the limit on the drop time for an individual CEA.

The U.S. Nuclear Regulatory Commission staff has reviewed the request, and determined that we require additional information to complete our review. A request for additional information is enclosed. This request was discussed with David Bice of your staff on October 29, 2007, and it was agreed that a response would be provided within 60 days of receipt of this letter.

If you or your staff have any questions concerning the resolution of this matter, please contact me at (301) 415-1445.

Sincerely,

/RA/

Alan B. Wang, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-368
Enclosure: Request for Additional Information
cc w/encl: See next page

DISTRIBUTION:

PUBLIC
LPLIV R/F\
RidsAcrcsAcnwMailCenter
RidsAcrcsAcnwMailCenter

RidsNrrDorlDpr
RidsNrrDorlLpl4
RidsNrrLAJBurkhardt
RidsNrrPMAWang

RidsOgcRp
RidsRgn4MailCenter
LLois, NRR/DSS/SRXB

ADAMS Accession Number: ML073050296

OFFICE	LPL4/PM	LPL4/LA	LPL4/BC
NAME	AWang	JBurkhardt	THiltz
DATE	11/7/07	11/6/07	11/7/07

OFFICIAL RECORD COPY

REQUEST FOR ADDITIONAL INFORMATION
BY THE OFFICE OF NUCLEAR REACTOR REGULATION
ARKANSAS NUCLEAR ONE, UNIT 2
ENTERGY OPERATIONS, INC.
DOCKET NO. 50-368
OPERATING LICENSE NO. NPF-6

By letter dated August 30, 2007, Entergy Operations, Inc. proposed to revise Technical Specification (TS) 3.1.3.4, CEA [Control Element Assembly] Drop Time for Arkansas Nuclear One, Unit 2 (ANO-2). The TS change proposed to revise the limit on the drop time for an individual CEA. During a conference call on October 29, 2007, the U.S. Nuclear Regulatory Commission (NRC) staff discussed our concerns with the licensee regarding the licensee's analyses to support its statement that the "...average CEA drop time concept has been verified ...". Based on the conference call, the NRC has determined that additional information is needed to complete our review.

As the submittal pointed out, the two major factors in the CEA drop time are core ΔP (change in differential pressure) and the weight of the extension shafts. It is assumed that other factors do not change, i.e., fuel management and control element drive mechanism circuits. In your submittal you state that "... While the slowest individual CEA is expected to fall up to 0.2 seconds slower and the distance between the fastest and slowest CEAs is increasing, the average CEA drop time concept has been re-verified for a NGF [Next Generation Fuel] core..." The NRC staff has the following questions regarding this conclusion:

1. If all other factors are the same and the slowest CEA slows by 0.2 seconds, the NRC staff believes that the average drop time should be slower by 0.2 seconds. Entergy has stated that the average stays unchanged. Please justify this conclusion.
2. If the slowest CEA drop time gets slower and the distance (slowest to fastest) increases, how does the average stay constant?
3. In the submittal, Entergy indicates that the full NGF core to be the limiting case. Please discuss the transition core (ANO-2 Cycle 20) expected drop times especially if some NGF and Combustion Engineering (CE) assemblies are not in uniformly mixed regions.
4. Entergy states that an evaluation was performed for the CE and the NGF cores that added the difference of the calculated insertion time to the worst average drop time. The result showed that there is sufficient margin compared to the limit of 3.2 seconds. With regard to this conclusion:
 - (a) How did you perform those calculations and what were the numerical results?

- (b) How are the calculations relevant for time differences of 0.2 seconds?
 - (c) What were the criteria of sufficiency?
 - (d) Did the CEA drop distribution that produced less fission energy include the 0.2 second delay in the slowest CEA drop?
5. The 0.2 second change represents almost the entire spread in the drop distribution for both fuels, i.e., $3.2 \times 0.079 = 0.25$ seconds. Therefore, the proposed change appears to be significant. Why does Entergy believe it is not?
6. Has Entergy accounted for the case in Cycle 20 when the new fuel will be at its peak reactivity? (That is about 10 to 14 megawatt days/metric ton of burn up.)

Arkansas Nuclear One

cc:

Senior Vice President
Entergy Nuclear Operations
P.O. Box 31995
Jackson, MS 39286-1995

Senior Vice President
& Chief Operating Officer
Entergy Operations, Inc.
P.O. Box 31995
Jackson, MS 39286-1995

Vice President, Operations Support
Entergy Operations, Inc.
P.O. Box 31995
Jackson, MS 39286-1995

Site Vice President
Entergy Operations, Inc.
Arkansas Nuclear One
1448 S.R. 333
Russellville, AR 72802

General Manager Plant
Operations
Entergy Operations, Inc.
Arkansas Nuclear One
1448 SR 333
Russellville, AR 72802

Director, Nuclear Safety & Licensing
Entergy Services, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Director, Nuclear Safety Assurance
Entergy Operations, Inc.
Arkansas Nuclear One
1448 SR 333
Russellville, AR 72802

Senior Manager, Nuclear Safety
& Licensing
Entergy Operations, Inc.
1340 Echelon Parkway
Jackson, MS 39213-8298

Manager, Licensing
Entergy Operations, Inc.
Arkansas Nuclear One
1448 SR 333
Russellville, AR 72802

Section Chief, Division of Health
Radiation Control Section
Arkansas Department of Health and
Human Services
4815 West Markham Street, Slot 30
Little Rock, AR 72205-3867

Section Chief, Division of Health
Emergency Management Section
Arkansas Department of Health and
Human Services
4815 West Markham Street, Slot 30
Little Rock, AR 72205-3867

County Judge of Pope County
Pope County Courthouse
100 W. Main Street
Russellville, AR 72801

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 310
London, AR 72847

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064