

November 26, 2007

Mr. David A. Christian  
President and Chief Nuclear Officer  
Virginia Electric and Power Company  
Innsbrook Technical Center  
5000 Dominion Boulevard  
Glen Allen, VA 23060-6711

SUBJECT: MILLSTONE POWER STATION, UNIT NO. 2 - NRC RECEIPT OF RESPONSE  
TO GENERIC LETTER 2006-03, "POTENTIALLY NONCONFORMING HEMYC  
AND MT FIRE BARRIER CONFIGURATIONS" (TAC NO. MD1598)

Dear Mr. Christian:

The U.S. Nuclear Regulatory Commission (NRC) acknowledges the receipt of your responses dated June 8, 2006, and May 31, 2007, to NRC Generic Letter 2006-03 (GL 2006-03), "Potentially Nonconforming Hemyc and MT Fire Barrier Configurations." The aforementioned documents can be found in the Agencywide Documents Access and Management System (ADAMS) Accession Nos. ML061590505, ML071520515, and ML053620142, respectively.

You have stated that Millstone Power Station, Unit No. 2, does not rely on either the Hemyc or MT fire barrier system. You have also submitted documentation that 1 or 3-hour fire barriers, other than Hemyc or MT barriers, that separate redundant safe shutdown trains located within the same fire area have been designed and installed in accordance with current NRC guidance. Based on your response, no further action is requested of you at this time and TAC No. MD1598 will be closed.

If you have any questions regarding this response, please contact me at 301-415-3204.

Sincerely,

*/ra/*

John D. Hughey, Project Manager  
Plant Licensing Branch 1-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-336

cc: see next page

November 26, 2007

Mr. David A. Christian  
President and Chief Nuclear Officer  
Virginia Electric and Power Company  
Innsbrook Technical Center  
5000 Dominion Boulevard  
Glen Allen, VA 23060-6711

SUBJECT: MILLSTONE POWER STATION, UNIT NO. 2 - NRC RECEIPT OF RESPONSE TO GENERIC LETTER 2006-03, "POTENTIALLY NONCONFORMING HEMYC AND MT FIRE BARRIER CONFIGURATIONS" (TAC NO. MD1598)

Dear Mr. Christian:

The U.S. Nuclear Regulatory Commission (NRC) acknowledges the receipt of your responses dated June 8, 2006, and May 31, 2007, to NRC Generic Letter 2006-03 (GL 2006-03), "Potentially Nonconforming Hemyc and MT Fire Barrier Configurations." The aforementioned documents can be found in the Agencywide Documents Access and Management System (ADAMS) Accession Nos. ML061590505, ML071520515, and ML053620142, respectively.

You have stated that Millstone Power Station, Unit No. 2, does not rely on either the Hemyc or MT fire barrier system. You have also submitted documentation that 1 or 3-hour fire barriers, other than Hemyc or MT barriers, that separate redundant safe shutdown trains located within the same fire area have been designed and installed in accordance with current NRC guidance. Based on your response, no further action is requested of you at this time and TAC No. MD1598 will be closed.

If you have any questions regarding this response, please contact me at 301-415-3204.

Sincerely,

*/ra/*

John D. Hughey, Project Manager  
Plant Licensing Branch 1-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-336

cc: see next page

DISTRIBUTION:

Public LPL1-2 r/f RidsNrrDorlLpl1-2  
RidsNrrPMJHughey RidsNrrLAABaxter RidsOgcRp  
RidsRgn1MailCenter RidsNrrDorlDpr RidsAcrcAcnwMailCenter  
AKlein TDinh  
Accession Number: ML073060199

OFFICE	LPL1-2/GE	LPL1-2/PM	LPL1-2/LA	AFPB/BC	LPL1-2/BC
NAME	CSanders	JHughey	ABaxter	AKlein	HChernoff
DATE	11/08/2007	11/08/2007	11/08/2007	11/14/2007	11/26/2007

Official Record Copy

Millstone Power Station, Unit No. 2

cc:

Lillian M. Cuoco, Esquire  
Senior Counsel  
Dominion Resources Services, Inc.  
Building 475, 5<sup>th</sup> Floor  
Rope Ferry Road  
Waterford, CT 06385

Edward L. Wilds, Jr., Ph.D.  
Director, Division of Radiation  
Department of Environmental Protection  
79 Elm Street  
Hartford, CT 06106-5127

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

First Selectmen  
Town of Waterford  
15 Rope Ferry Road  
Waterford, CT 06385

Charles Brinkman, Director  
Washington Operations Nuclear Services  
Westinghouse Electric Company  
12300 Twinbrook Pkwy, Suite 330  
Rockville, MD 20852

Senior Resident Inspector  
Millstone Power Station  
c/o U.S. Nuclear Regulatory Commission  
P.O. Box 513  
Niantic, CT 06357

Mr. J. Alan Price  
Site Vice President  
Dominion Nuclear Connecticut, Inc.  
Building 475, 5<sup>th</sup> Floor  
Rope Ferry Road  
Waterford, CT 06385

Mr. J. W. "Bill" Sheehan  
Co-Chair NEAC  
19 Laurel Crest Drive  
Waterford, CT 06385

Mr. Evan W. Woollacott  
Co-Chair  
Nuclear Energy Advisory Council  
128 Terry's Plain Road  
Simsbury, CT 06070

Ms. Nancy Burton  
147 Cross Highway  
Redding Ridge, CT 00870

Mr. Chris L. Funderburk  
Director, Nuclear Licensing and  
Operations Support  
Dominion Resources Services, Inc.  
Innsbrook Technical Center  
5000 Dominion Boulevard  
Glen Allen, VA 23060-6711

Mr. William D. Bartron  
Licensing Supervisor  
Dominion Nuclear Connecticut, Inc.  
Building 475, 5<sup>th</sup> Floor  
Rope Ferry Road  
Waterford, CT 06385

Mr. Joseph Roy,  
Director of Operations  
Massachusetts Municipal Wholesale  
Electric Company  
Moody Street  
P.O. Box 426  
Ludlow, MA 01056