

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

830 Power Building

MAR 20 1978

Central file

*50-390
391*

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Region II - Suite 1217
230 Peachtree Street, NW.
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

OFFICE OF INSPECTION AND ENFORCEMENT BULLETIN 78-01, RII:JPO 50-327,
-328, -390, -391, -438, -439, -518, -519, -520, -521, -553, -554,
-566, -567 - SEQUOYAH, WATTS BAR, BELLEFONTE, HARTSVILLE, PHIPPS BEND,
AND YELLOW CREEK - FLAMMABLE CONTACT-ARM RETAINERS IN G.E. CR120 A
RELAYS

This is in response to your January 16, 1978, letter which transmitted
IE Bulletin 78-01. We have reviewed the design of our plants with
construction permits and have determined that none of the relays of the
type described in the bulletin are installed or scheduled to be installed
in class IE systems.

Very truly yours,

J. E. Gilleland

J. E. Gilleland
Assistant Manager of Power

cc: Dr. Ernst Volgenau, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

*NO 2
EP*