

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 237 which are attached hereto, are hereby incorporated into this renewed operating license. Duke Power Company LLC shall operate the facility in accordance with the Technical Specifications.

(3) Updated Final Safety Analysis Report

The Updated Final Safety Analysis Report supplement submitted pursuant to 10 CFR 54.21(d), as revised on December 16, 2002, describes certain future activities to be completed before the period of extended operation. Duke shall complete these activities no later than December 6, 2024, and shall notify the NRC in writing when implementation of these activities is complete and can be verified by NRC inspection.

The Updated Final Safety Analysis Report supplement as revised on December 16, 2002, described above, shall be included in the next scheduled update to the Updated Final Safety Analysis Report required by 10 CFR 50.71(e)(4), following issuance of this renewed operating license. Until that update is complete, Duke may make changes to the programs described in such supplement without prior Commission approval, provided that Duke evaluates each such change pursuant to the criteria set forth in 10 CFR 50.69 and otherwise complies with the requirements in that section.

(4) Antitrust Conditions

Duke Power Company LLC shall comply with the antitrust conditions delineated in Appendix C to this renewed operating license.

(5) Fire Protection Program (Section 9.5.1, SER, SSER #2, SSER #3, SSER #4, SSER #5)

Duke Power Company LLC shall implement and maintain in effect all provisions of the approved fire protection program as described in the Updated Final Safety Analysis Report, as amended, for the facility and as approved in the SER through Supplement 5, subject to the following provision:

The licensee may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

*The parenthetical notation following the title of this renewed operating license condition denotes the section of the Safety Evaluation Report and/or its supplement wherein this renewed license condition is discussed.

(6) Mitigation Strategies

Develop and maintain strategies for addressing large fires and explosions and that include the following key areas:

- (a) Fire fighting response strategy with the following elements:
 - 1. Pre-defined coordinated fire response strategy and guidance
 - 2. Assessment of mutual aid fire fighting assets
 - 3. Designated staging areas for equipment and materials
 - 4. Command and control
 - 5. Training of response personnel

- (b) Operations to mitigate fuel damage considering the following:
 - 1. Protection and use of personnel assets
 - 2. Communications
 - 3. Minimizing fire spread
 - 4. Procedures for implementing integrated fire response strategy
 - 5. Identification of readily-available pre-staged equipment
 - 6. Training on integrated fire response strategy
 - 7. Spent fuel pool mitigation measures

- (c) Actions to minimize release to include consideration of:
 - 1. Water spray scrubbing
 - 2. Dose to onsite responders

(7) Additional Conditions

The Additional Conditions contained in Appendix B, as revised through Amendment No. 237, are hereby incorporated into this renewed operating license. Duke Power Company LLC shall operate the facility in accordance with the Additional Conditions.

- D. The facility requires exemptions from certain requirements of Appendix J to 10 CFR Part 50, as delineated below and pursuant to evaluations contained in the referenced SER and SSERs. These include, (a) partial exemption from the requirement of paragraph III.D.2(b)(ii) of Appendix J, the testing of containment airlocks at times when the containment integrity is not required (Section 6.2.6 of the SER, and SSERs # 3 and #4), (b) exemption from the requirement of paragraph III.A.(d) of Appendix J, insofar as it requires the venting and draining of lines for type A tests (Section 6.2.6 of SSER #3), and (c) partial exemption from the requirements of paragraph III.B of Appendix J, as it relates to bellows testing (Section 6.2.6 of the SER and SSER #3). These exemptions are authorized by law, will not present an undue risk to the public health and safety, are consistent with the common defense and security, and are consistent with certain special circumstances as discussed in the referenced SER and SSERs. These exemptions are, therefore, hereby granted pursuant to 10 CFR 50.12. With the granting of these exemptions, the facility will operate, to the extent authorized herein, in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission.

<u>Amendment Number</u>	<u>Additional Condition</u>	<u>Implementation Date</u>
173	<p>The schedule for the performance of new and revised surveillance requirements shall be as follows:</p> <p>For surveillance requirements (SRs) that are new in Amendment No. 173 the first performance is due at the end of the first surveillance interval that begins at implementation of Amendment No. 173. For SRs that existing prior to Amendment No. 173, including SRs with modified acceptance criteria and SRs who intervals of performance are being extended, the first performance is due at the end of the first surveillance interval that begins on the date the surveillance was last performed prior to implementation of amendment No. 173. For SRs that existed prior to Amendment No. 173, whose intervals of performance are being reduced, the first reduced surveillance interval begins upon completion of the first surveillance performed after implementation of Amendment No. 173</p>	By January 31, 1999
180	The maximum rod average burnup for any rod shall be limited to 60 GWd/mtU until the completion of an NRC environmental assessment supporting an increased limit.	Within 30 days of date of amendment.
	<p>In association with the ECCS sump strainer modification and Generic Safety Issue (GSI)-191 requirements:</p> <ol style="list-style-type: none"> 1. Unit 1 shall enter Mode 5 for the outage to install the sump strainer modification no later than May 19, 2008 and 2. The Unit 1 sump strainer modification shall be completed prior to entry into Mode 4 after May 19, 2008. 	Within 30 days of date of amendment and no later than December 31, 2007

*John
Add bar
on sup.
copy*