

NRC Staff Comments on FAQ 06-0019, Rev. 3:

Page 2 of 2, bottom paragraph, remove the sentence, “The scope of equipment required for plant operations is defined by components and cables selected per NFPA 805 2.4.2.”

The scope of equipment required for plant operations goes well beyond that defined in 2.4.2. “Required for plant operations” includes all equipment needed to generate electricity (main turbine, feedwater, circulating water, service water, main steam, etc.) as well as that equipment needed to mitigate accidents required by the Technical Specifications (safety injection, emergency diesel generators, containment spray, emergency service water, etc.).