

July 26, 1974



Mr. Norman C. Moseley, Director
Directorate of Regulatory Operations
U.S. Atomic Energy Commission
Region II - Suite 818
230 Peachtree Street, NW.
Atlanta, Georgia 30303

Dear Mr. Moseley:

This is submitted as a final response to Directorate of Regulatory Operations Bulletin No. 74-6 transmitted by your May 30, 1974, letter RO:II:NCM 50-327, -328, -390, -391.

Arrangements have been made with the Westinghouse Electric Corporation, Pittsburgh, Pennsylvania, to have their site personnel at Sequoyah Nuclear Plant work with TVA site personnel to inspect the W-2 switches and correct any problems. Repair parts will also be inspected to assure that no defective parts are used. The Sequoyah Nuclear Plant inspection program is scheduled to be completed by May 1, 1975, for units 1 and 2.

As previously stated in our interim report, dated July 3, 1974, no W-2 switches have been shipped from Westinghouse for the Watts Bar Nuclear Plant; therefore, we do not feel it is necessary to extend this inspection program to the Watts Bar Nuclear Plant.

Very truly yours,

A handwritten signature in cursive script that reads 'J. E. Gilleland'.

J. E. Gilleland
Assistant to the Manager of Power

Regulation Bulletin No. 74-6

Tennessee Valley Authority

50-327
50-328
50-390
50-391

Letter from Tennessee Valley Authority, J. E. Gilleland,
dated July 26, 1974.

Distribution:

H. D. Thornburg, RO

RO:HQ (4)

Directorate of Licensing (4)

DR Central Files

John Rizzo, OOE, RO:Hqs

PDR

Local PDR

NSIC

OIS, OR