

OCT 26 2007

SCH07-122



Certified Mail
Return Receipt Requested
Article Number: 7006 0100 0004 0657 2202.

Administrator of Water Compliance and Enforcement
New Jersey Department of Environmental Protection
401 East State Street, 4th Floor East
PO Box 422
Trenton, New Jersey 08625-0422

**RE: PSEG Nuclear LLC - Salem Generating Station
NJPDES Permit No. NJ0005622
NJDEP Case No. 07-10-24-0927-50
Retraction of Report of Discharge to Waters of The State**

Dear Sir/Madam:

In accordance with N.J.A.C. 7:14A-6.10 Noncompliance Reporting, PSEG Nuclear LLC (PSEG) is submitting this report to retract the notification of a possible discharge of oil to the Delaware River from the Circulating Water structure. The possible discharge was reported to the New Jersey Department of Environmental Protection (NJDEP) hotline and assigned case number 07-10-24-0927-50. This report contained information as known at the time of the notification. In accordance with the regulations, additional information will be provided if it becomes available.

On May 24th, 2007 at approximately 0920, a pinhole leak in a hydraulic line on Circulating Water trash rake was discovered. The trash rake was stopped and stowed in the up position stopping the leak. Approximately one pint of biodegradable hydraulic oil was released to the Delaware River. The oil was drawn into 23B Circulating Water intake. No oil sheen was observed on the Delaware River. The appropriate remedial measures, including isolation of the trash rake, were taken. There is no threat to human health or the environment.

If you have any questions regarding this information, please contact Clifton Gibson of my staff at (856) 339-12686.

Sincerely,

A handwritten signature in cursive script, appearing to read "George H. Gellrich".

George H. Gellrich
Salem Plant Manager

IF23
COOL
MRR

OCT 26 2007

Administrator of Water Compliance and Enforcement
SCH07-122

C NJDEP
Southern Enforcement Office
One Port Center
2 Riverside Drive, Suite 201
Camden, NJ 08102
Attn: Mr. Steven Mathis

NJDEP
Bureau of Point Source Permitting Region 2
401 East State Street
Trenton, NJ 08625-0029
Attn: Ms. Susan Rosenwinkel

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Delaware Emergency Management Agency
Attn.: Janet Chomiszak
165 Brick Store Landing Road
Smyrna, DE 19977