



OCT 29 2007

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001

Serial No. 07-0436B
KPS/LIC/JG: R1
Docket No. 50-305
License No. DPR-43

DOMINION ENERGY KEWAUNEE, INC.
KEWAUNEE POWER STATION
STATION BLACKOUT RESPONSE CORRECTION SUPPLEMENT

In Reference 1, Dominion Energy Kewaunee (DEK), provided a correction to a previous submittal regarding implementation of the Station Blackout (SBO) Rule (10 CFR 50.63) at Kewaunee Power Station (KPS). The corrected information concerned the quality assurance (QA) controls under which the Technical Support Center (TSC) diesel generator (DG) was initially installed.

During subsequent telephone conversations between DEK and NRC staff, NRC staff requested clarifying information regarding the QA requirements under which the TSC DG would be maintained.

The TSC DG was purchased and installed as QA type 3. It has subsequently been reclassified as QA type 2 and is maintained in accordance with the QA requirements for SBO equipment and meets the guidance contained in RG 1.155, Section 3.5 and Appendix A. DEK will continue to maintain the TSC DG in accordance with Dominion Nuclear Facility Quality Assurance Program Description – Topical Report DOM-QA-1, Revision 1.

The commitment made in Reference 1 will continue to be met. An updated description of the SBO alternate AC source, including the quality assurance program requirements for the TSC DG as defined in the Dominion Nuclear Facility Quality Assurance Program Description, will be incorporated into the KPS Updated Safety Analysis Report and provided to the NRC in accordance with 10 CFR 50.71(e).

If you have questions or require additional information, please contact Mr. Jack Gadzala at 920-388-8604.

Very truly yours,

A handwritten signature in black ink, appearing to read "L. N. Hartz".

L. N. Hartz
Site Vice President, Kewaunee Power Station

A001
LNR

References:

1. Letter from L. N. Hartz (DEK) to Document Control Desk (NRC), "Station Blackout Response Correction," dated July 27, 2007.

Commitment made (reaffirmed) by this letter:

An updated description of the SBO alternate AC source, including the quality assurance program requirements for the TSC DG as defined in the Dominion Nuclear Facility Quality Assurance Program Description, will be incorporated into the KPS Updated Safety Analysis Report and provided to the NRC in accordance with 10 CFR 50.71(e).

cc: Regional Administrator, Region III
U. S. Nuclear Regulatory Commission
2443 Warrenville Road
Suite 210
Lisle, Illinois 60532-4352

Mr. P. D. Milano
Senior Project Manager
U. S. Nuclear Regulatory Commission
Mail Stop O-8-H-4a
Washington, D. C. 20555

NRC Resident Inspector
Kewaunee Power Station