From:	Getachew Testaye	
To:	DAFLUCAS Ronda M.	
Date:	Thu, Aug 23, 2007 6:12 AM	
Subject:	Fwd: Review of EPR Topical Report - BNL's Comments	
	· .	
Ronda,	•	
Attached plea	ase find BNL's comments on your responses to the Piping TR RAI	ís.
Please let's	s know when we can have a conference call to discuss these	
comments. Ne	ext week will not be good for BNL.	

Thanks, Getachew Tesfaye NRO/DNRL/NARP

. CC:

Arnold Lee; Larry Burkhart; Tarun Roy

Mail Envelope Properties

(46CD5D74.9C8 : 24 : 8846)

Subject:Fwd: Review of EPR Topical Report - BNL's CommentsCreation DateThu, Aug 23, 2007 6:12 AMFrom:Getachew Tesfaye

Created By:

GXT2@nrc.gov

Recipients

areva.com Ronda.Daflucas (DAFLUCAS Ronda M.)

nrc.gov

LJB3 CC (Larry Burkhart)

nrc.gov

AJL CC (Arnold Lee)

nrc.gov

TCR1 CC (Tarun Roy)

Post Office

...

Delivered Opened

Transferred

Action

Delivered Opened

Delivered Opened

Delivered

Route

areva.com nrc.gov nrc.gov nrc.gov

Date & Time

08/23/07 6:12 AM

08/23/07 6:12 AM

08/23/07 8:39 AM

08/23/07 6:12 AM

08/23/07 6:50 AM

08/23/07 6:12 AM 08/23/07 7:41 AM

FilesSizeMESSAGE684AREVA Topical BNL's responses to RAIs.wpd20074:35 PM

Date & Time

Thursday, August 23, 2007 6:12 AM 219304 Wednesday, August 22,

Options	
Auto Deleté:	No
Expiration Date:	None
Notify Recipients:	No
Priority:	Standard
ReplyRequested:	No
Return Notification:	None
Concealed Subject:	No
Security:	Standard

To Be Delivered: Status Tracking: Immediate

Delivered & Opened

RAI Topic	RAI Description	AREVA Response	BNL Disposition
RAI Topic Piping and Pipe Support Design - General	RAI Description RAI EPR-1: Section 1.0 of the Topical Report (TR) states that the reactor coolant loop (RCL) and pressurizer surge line piping requirements, modeling techniques, analysis approaches and acceptance criteria are not specifically addressed in this document and will be included in the design control document (DCD). The TR presents nearly all of the design certification requirements, acceptance criteria, analysis methods and modeling techniques for the American Society for Engineers (ASME) Class 1, 2 and 3 piping and pipe supports, as required in	AREVA Response Reactor Coolant System large bore piping requirements, modeling techniques, analysis approaches and acceptance criteria are not specifically addressed in the TR because of the major differences in mathematical modeling and model loading approaches and techniques that exist between the RCL structural analysis and Class 1 piping analysis. The RCL loop structural model includes representation of the nuclear island basemat and the Interior Concrete Structure (ICS), to which the RCL supports are attached, as well as very detailed representations of the primary components and their internals. In addition, in most cases, the RCL	Acceptable.
	Section 3.12 for new reactors. Describe any significant differences between the requirements, techniques, approaches and design criteria for the RCL and pressurizer surge line piping, and those included in the TR.	the model. Class 1 piping models do not include representations of the supporting concrete structures or detailed representations of components, and the supports are not typically explicitly modeled. The method of seismic loading is also quite different, with the RCL loop structural model being loaded through application of	

RAI Topic	RAI Description	AREVA Response	BNL Disposition
		basemat excitation to the base of the ICS, whereas Class 1 piping models are loaded through the application of attachment point response spectra (or time histories), floor response spectra (or time histories) and seismic anchor motions at the various support locations in the model. Other aspects of RCL structural analysis are the same as those described for Class 1 piping in this TR, aspects such as damping requirements, load combinations, mass distribution requirements, cut-off frequency requirements, and applicable ASME stress and fatigue allowables. A thorough description of the approaches and methods employed in the structural, stress and fatigue analysis of	
		Chapter 3 of the U.S. EPR Design Control Document.	
ASME B31.1 and Section XI Codes	RAI EPR-2: A. In accordance with RG 1.26, Quality Group (QG) D piping that may contain radioactive material is considered to be outside the ASME Code Class 1, 2, and 3	A. The U.S. EPR piping systems containing radioactive material (outside the Reactor Coolant Pressure Boundary) are classified as Quality Group D and are designed to ASME B31.1, 2004.	A. Acceptable. AREVA needs to change the TR Section with the proposed text.

RAI Topic	RAI Description	· AREVA Response	BNL Disposition
	piping systems. The Regulatory Guide (RG) recommends that	Section 1.0 and 2.1 of the TR will be revised to include the following text:	
	are to be designed in accordance with the requirements of the ASME	"Quality Group D piping will be analyzed to ASME B31.1, 2004 Edition, no addenda."	
	Please clarify if the Evolutionary Power Reactor (EPR) piping and pipe supports will have QG D systems; and confirm that		
	whether EPR piping design will use the ASME B31.1 Code for these systems, otherwise provide technical justification for using other than the B31.1 Code	· · · ·	
	 B. Confirm that ASME Code Section XI requirements will be used in the piping and pipe support design for EPR. 	B. The U.S. EPR adheres to the requirements of the ASME XI, 2004 Edition, no addenda. No Section XI code cases are used for the U.S. EPR.	B. Not Acceptable 10 CFR 50.55a has not yet endorsed 2004 Edition. Justify using this edition of the ASME Code.
10CFR50.55a(b) Limitations and	RAI EPR-3: Section 2.1 of the TR states that for the dynamic loads, including seismic loads,	The limitations of 10CFR50.55a(b)(1) are considered in the U.S. EPR design as follows:	Not Acceptable. Explain why the limitations in items (v) and (vi) are not

RAI Topic	RAI Description	AREVA Response	BNL Disposition
Modifications	the pipe stress analyses will be performed in accordance with the Sub-articles NB/NC/ND-3650 of the 1993 Addenda of the ASME Code as required by 10CFR50.55a(b)(1)(iii). However, AREVA did not address other limitations and modifications (related to Section III materials, weld leg dimensions, etc.) applicable to piping system design as included in 10CFR50.55a(b)(1). Explain how all limitations and modifications specified in 10CFR50.55a(b) will be satisfied.	 (b)(1)(i) Section III "Materials" – This is not considered for the U.S. EPR because it addresses the application of 1992 Edition of ASME. The U.S. EPR uses a later version of the code. (b)(1)(ii), "Weld leg dimensions" is incorporated into the U.S. EPR design. (b)(1)(iv) "Quality Assurance" – U.S. EPR Quality Assurance program is developed for a later edition of the code. This restriction does not apply to the U.S. EPR. (b)(1)(v) – Independence of Inspection – The inspection program for the U.S. EPR will not apply NCA-4134.10(a). (b)(1)(vi) Subsection NH – The U.S. EPR will not use Type 316 stainless pressurizer heater sleeves above a service temperature of 900°F. 	applicable to EPR. If the US EPR meets these limitations, then why aren't these 2 items simply included in the proposed text that states the design meets the 2001 ASME Code, Section III, Division 1 through the 2003 addenda with limitations in 10CFR50.55a(b)(1) (ii) Weld Leg, (iii) Seismic, (v) Independence of Inspection, and (vi) Inspection NH, and other limitations (i) Section III-Materials and (iv) Quality Assurance do not apply?
		For clarity, Section 2.1 of the TR will be revised to include the following text: "Piping analysis and pipe support design for the U.S. EPR addressed in this Topical Report use the 2001 ASME Code, Section III, Division 1, 2003 addenda as the base code with limitations identified in the Code of	

RAI Topic	RAI Description	AREVA Response	BNL Disposition
		Federal Regulations, 10 CFR 50.55a(b)(1)(ii) "Weld leg" and (iii)" Seismic" and "All other limitations of 10CFR50.55a(b)(1) do not apply to the U.S. EPR."	
Mathematical Modeling	RAI EPR-4: Mathematical Modeling TR Section 4.2 states that the seismic analysis methods for seismic Category I systems to withstand the effects of a safe shutdown earthquake (SSE) and to maintain the capability of performing their safety function will use the methods in accordance with SRP 3.7.3.		
	A. Describe the mathematical representation of a piping system, including the development of the mass, stiffness, and damping matrices in the analytical model, that will be used in the three methods of analysis (i.e., response spectrum, time history, and equivalent static load methods).	A. A description of the mathematical modeling techniques is presented in TR Section 5.2. A section cross reference will be added to Section 4.2. Section 4.2 will be revised to incorporate the following text: "The seismic response of a piping system is determined by developing a mathematical model of the system suitable for calculating the response of	A. Acceptable. AREVA needs to change the TR Section with the proposed text.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	Also, discuss the types of loading functions that will be used in each of these methods of analysis.	the system to the seismic input. Dynamic equilibrium equations are formulated for the system using the direct stiffness method. In this method, the element stiffness matrices are formed according to virtual work principles and assembled to form a global stiffness matrix for the system relating external forces and moments to nodal displacements and rotations. Details on the dynamic piping model can be found in Section 5.2.	
		Once the mathematical model has been established, dynamic equilibrium equations are solved to determine the seismic response of the system by performing either a modal analysis by either the Response Spectrum Method or Time History Method. Alternatively, the Direct Integration Time History Method and, where applicable, the Equivalent Static Load Method may be used."	
	B. Confirm if these methods of analysis will be limited to an	B. The modeling techniques in TR Section 5.2 are used for elastic analysis.	B. Acceptable.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	elastic basis. If not, discuss the application limits for these three methods. C. Identify conditions or limits when each of these three methods of analysis will be used in obtaining the piping system responses.	C. Factors considered when choosing the analysis method to be used for a given piping configuration include complexity of the system, type of loads, to be included in the analysis, class of piping (ASME 1,2, 3 or non-seismic) and analysis tools available. In general, for seismic load cases, response spectra (RS) and time history (TH) will produce similar results with TH producing acceptable results that are not as conservative as RS. Class 1 piping analysis which requires considerably more detail may be analyzed by TH methods although RS will yield acceptable results. Time history is also used when transient loads due to pipe break, water hammer or other dynamic events are anticipated and static analysis produces a high level of conservatism. Class 2/3 and non seismic piping analysis is generally analyzed using RS methods. Equivalent static analysis can only be used on Class 2/3 and non seismic piping 2 NPS and smaller where the piping	C. Acceptable.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	D. Discuss the analysis methods that will be used in the design of non-seismic Category I (or seismic Category II) piping systems.	configuration can be reduced to simple models. D. Non-seismic piping that interacts with seismic systems will be analyzed by RS or equivalent static methods.	D. Not Acceptable.
Piping Analysis Methods	RAI EPR-5: After constructing a mathematical model to reflect the static or dynamic characteristics of the piping system, describe the step by step computations (e.g., static analysis, modal analysis, modal participation factors) that may be performed to obtain the piping system response for each of the three methods of analysis (i.e., response spectrum, time history, and equivalent static load methods).	Section 4.2.2 will be revised to include the step by step computations for response spectra analysis. Section 4.2.2 will be revised as provided in Attachment A to this document. Section 4.2.3 will be revised as follows to address the computations when Time History Analysis is employed: "The modal superposition method of time history analysis is used for seismic piping analyses with acceleration time history seismic input. This method is based on decoupling of the differential equations of motion, considering a	Not Acceptable. Regarding the proposed changes in Section 4.2.4, the staff position on the case of a factor of 1.0 is as follows: For cases where a piping configuration can be demonstrated to respond as a single degree of freedom system with a known fundamental frequency or rigid system with a fundamental frequency beyond the cutoff frequency, a factor of 1.0 may be used with the highest spectral acceleration at that frequency or any higher frequency (as may be the case for

RAI Topic	RAI Description	AREVA Response	BNL Disposition
		method as that described in Section 4.2.2."	proposed text for the Section 4.2.4 are not consistent with the staff position. Therefore, address
		"The Direct Integration Time History Analysis method may be used as an alternative to the modal superposition time history analysis. In this method the differential equation of motion, as provided in Section 4.2.2, is solved directly on the uncoupled equations without transformation. Rayleigh damping, or mass and stiffness damping, is used when direct integration time history analysis is performed."	this inconsistency.
		Section 4.2.4 will be revised to include the following: "For cases where piping configurations are calculated as single degree of freedom systems with known fundamental frequencies or rigid systems with fundamental frequencies beyond the cutoff frequency, a factor of 1.0 may be used with the spectral accelerations at that frequency. Mathematically the seismic force F1 on a mass point in one (1) direction is	

BNL Disposition **RAI Topic RAI** Description **AREVA** Response represented as: $F_1 = kmS_2$ Where: k = 1.0 for single degree of freedom or rigid system k=1.5 for multiple degree of freedom system m = mass in direction 1 Sa = value of acceleration from response spectrum The forces from each of the three orthogonal directions of earthquake are applied to calculate seismic stresses and then combined by SRSS to calculate overall seismic stresses." A. Acceptable. Pipina RAI EPR-6: A. SRP Section A. The criterion for the inclusion of 3.9.2, Item II.2.A(i)(3) requires sufficient number of modes stated in Analysis Criteria an investigation for a sufficient SRP 3.9.2 II A(i)(3) is that the "inclusion number of modes to be included of additional modes does not result in in the piping modeling to ensure more than a 10-percent increase in responses." All modes with frequencies that all significant modes have participated in the analysis. below the ZPA frequency are included in the piping analysis. Above this Provide the criterion that would ensure this requirement. frequency, in the rigid range, the effects of all additional modes are included by the application of the missing mass

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	B. The cutoff frequency for modal responses is defined as the frequency at which the spectral acceleration approximately returns to the zero period acceleration (ZPA) of the input response spectrum. Define this cutoff frequency qualitatively or quantitatively for seismic and other building dynamic loads (if any) applicable to the piping analysis for the EPR.	correction as discussed in TR Sections 4.2.2.3.2 and 4.2.3. B. The cutoff frequency for a given spectra is the frequency at which the response curves for all damping values converge to the same acceleration value (ZPA) and remain at this value for all frequencies above this cutoff frequency. Section 4.2.2.3 will be revised to add, "For the U.S. EPR the cutoff frequency is 50 hertz or as defined by figure 2 and 3 in RG 1.92, Rev 2."	B. Not Acceptable. Either provide technical justification for the selection of 50 Hz as the cutoff frequency or commit to the criteria as defined in Figure 2 and 3 in RG 1.92, Rev 2. Also, note that the resolution of this also applies to the text proposed for RAI EPR-9.
Branch Pipe Inputs	RAI EPR-7: When a small seismic Category I or non-seismic Category I piping is directly attached to seismic Category I piping, it can be decoupled from seismic Category I piping if it satisfies the decoupling criteria. However, the TR did not describe how the inputs for the small branch piping will be determined for both inertial and seismic anchor motion (SAM) response analyses	The model of a decoupled Class 1 branch line includes an anchor where the branch line connects to the RCL. The seismic inertial analysis of the RCL yields time histories at branch connections and equipment nozzles. The inertial seismic analysis results then become input into the Class 1 branch line seismic analysis in the form of time histories or response spectra which are generated from the time histories using classical response spectra generation techniques. If	Not Acceptable. Note the following: (a) The reference to RG 1.60 R1 for the ±15% spectra broadening should be RG 1.122 R1. (b) For the remaining decoupled branch lines not connected to the RCL, the amplification of the RS and SAM at the small pipe connection locations should be used in the analysis, as in the case of the RCL. The method presented in the responseis not in

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	when the piping system is decoupled from a large pipe run or connected to flexible equipment connections. The staff notes that computer code RESPECT (TR Section 5.1.8) generates seismic amplified response spectra at the branch nozzle locations in a model of a piping system. Describe the seismic analysis methods and procedures, including the input response spectra and input SAM displacements, that apply to the small branch piping design when decoupled from a large run pipe or connected to flexible equipment. The description should also discuss how any amplification effects and SAM effects, from the main run pipe at the attachment to the small branch pipe, are considered.	response spectra are used, they are peak broadened by ±15% in accordance with RG 1.60 R1 before application to the Class 1 branch line model. The analysis of the Class 1 branch line also considers seismic movements generated from the RCL (seismic anchor motions), which are applied as static displacements at the branch-to-RCL anchor. This analysis captures the effects of run pipe amplification on the branch pipe. For the remaining decoupled branch lines (not connected to the RCL), the model of a decoupled branch line includes an anchor at the run to branch intersection. The analysis of the branch line includes all anchor movements greater than 1/16" from the run pipe applied at the run to branch anchor for all load cases. The inertial seismic input for the branch line comes from the appropriately applied building and/or flexible equipment spectra based on support configurations and the inertial movements from the run pipe. The decoupling criterion stated in the TR	agreement with this approach, and therefore, the technical basis for the treatment of the inertial effects of the main run (large diameter piping) needs to be provided. The technical basis shall also explain what input spectra will be used at the branch-to-run pipe anchor in the method when performing the dynamic analysis of the branch line. Note that the envelope of building excitations for the nearest supports on the branch pipes alone may be acceptable only on case-by-case basis, when it can be demonstrated that there is no significant amplification caused by the main run piping at the branch pipe anchor connection.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
		assures that the run pipe is rigid compared to the branch pipe and no amplification effects are considered.	
		The last paragraph of Section 5.4.2 will be changed to the following:	
		"The branch pipe analysis must include more consideration for the effects of the run piping. The branch point is considered as an anchor in the analysis of the branch pipe with the same SIF and/or stress indices as the run pipe at this point. The movements (displacements and rotations) of the run pipe at the branch intersection due to statically applied loads in the run pipe analysis (such as thermal and seismic anchor movement (SAM)) shall be	
		applied as anchor movements with their respective load cases in the branch line analysis. The inertial effects of the run pipe on the branch line are considered in one of the following methods:	
	ſ	• For branch lines decoupled from the RCL, the inertial input to the branch line is generated from the analysis of the RCL. The analysis of the RCL yields	

RAI Topic	RAI Description	AREVA Response	BNL Disposition
		time history responses at the branch connections and equipment nozzles. This time history response of the RCL, or a response spectrum generated from	
•		the time history response, is then applied as the input inertial excitation at the branch-to-RCL intersection. This	
		method may also be used for decoupling pipe from flexible equipment if the response of the equipment is	
		For other decoupled lines, the effects of inertial loads from the run pipe on the branch line are captured through the	
		proper application of the building excitation and the inertial movements from the run pipe analysis. At the	
		branch-to-run pipe anchor, the applied inertial excitation to be included in the branch line analysis shall include the	
· · ·		envelope of building excitations for the nearest supports on both the branch and run pipes. The inertial movements	
		intersection are obtained from the run pipe analysis. These movements are	
· · ·		cases for each direction, at the branch-	· ·

RAI Topic	RAI Description	AREVA Response	BNL Disposition
		to-run pipe anchor. The results of these statically applied load cases are combined by the square root sum of squares (SRSS) to capture the effects of the inertial movement of the run pipe on the branch line. These results are then combined with the inertial analysis of the branch line by absolute summation to obtain the total inertial response."	
Independent Support Motion Method	RAI EPR-8: The current staff position for the Independent Support Motion (ISM) method of analysis is presented in Volume 4, Section 2 of NUREG-1061, "Report of the US NRC Piping Review Committee. "Some differences (e.g., modal combinations per RG 1.92 for uniform support motion (USM) only) were noted between the ISM method of response combinations (both methods and their sequence) presented in the TR Section 4.2.2.2.2, and the method given in NUREG-1061.	The provisions of NUREG-1061 for the ISM method of analysis will be followed. Specifically, level (group) results will first be combined using the absolute summation method. This will be followed by modal combinations by SRSS (without consideration of closely spaced modes) and directional (spatial) result combinations by SRSS. If Inertia and SAM results are combined for stresses, they will be combined using the SRSS method when using ISM. The following revisions to the TR will be made for clarification:	Not Acceptable. NUREG-1061 also provides guidance for the high frequency mode combinations as well as combination of high frequency modes with low frequency modes. Clarify if these methods are also included in the EPR piping design and revise the TR to include these criteria as well.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	provisions (for groups, modes, spatial and inertial and SAM combination methods) contained in NUREG-1061 for the ISM method of analysis will be followed or provide the technical justification for any alternatives or methods described in the TR.	include a reference to NUREG-1061, Volume 4 as follows: "When using independent support motion, the seismic response of each mode is calculated by combining the responses of all support groups into one by using absolute summation method per the recommendations of NUREG-1061, Volume 4."	
		Section 4.2.2.3.1 will be revised to add the text "performed using USM" as follows:	
		"RG 1.92 provides guidance on combining the individual modal results due to each response spectrum in a dynamic analysis <i>performed using</i> <i>USM</i> " (emphasis added).	
		and add the following text: "For piping systems analyzed using ISM methods, modal results are combined without the consideration of closely spaced modes, per NUREG-1061. Therefore, for these systems, modal results are combined by the SRSS method presented above."	

RAI Topic	RAI Description	AREVA Response	BNL Disposition
		Section 4.2.2.5 will be revised to read as follows:	
· · · · · · · · · · · · · · · · · · ·		"The analysis of these seismic anchor motions (SAM) will be performed as a static analysis with all dynamic supports active. The results of this analysis shall be combined with the piping system seismic inertia analysis results by absolute summation when an enveloped uniform support motion is used for the dynamic analysis, per SRP 3.7.3. When independent support motion is used in the inertial analysis, the responses due to the relative displacements and those due to inertia are combined by the SRSS method, per NUREG-1061."	
Time History Analysis Using Modal Superposition Method	RAI EPR-9: Since many of the dynamic loads specified in the TR, using the time history method of analysis, may have a short duration and contain very high frequency content, the use of the modal superposition method must consider all modes up to the appropriate cutoff	Missing mass will be accounted for in time history modal superposition analyses in accordance with Appendix A of RG 1.92, Rev. 2. The TR Section 4.2.3 will be revised to address this RAI as follows: "The mode shapes and frequencies are	Not Acceptable. The staff assessment for using 50 Hz as the cutoff frequency is presented in RAI EPR-6.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	frequency as well as the missing mass contribution. Discuss how the proposed modal superposition method will address these considerations in accordance with RG 1.92, Rev.2.	determined as they are in response spectrum analysis. The cutoff frequency for the determination of modal properties is 50 Hz, as this is expected to encompass all of the important response frequencies of the system. Missing mass effects of the high frequency modes beyond the cutoff frequency are included via the Missing Mass Method described in Regulatory Position C.1.4.1 and Appendix A of RG 1.92, Rev. 2."	
Time Step for Time History Analysis	RAI EPR-10: In a time history analysis, the numerical integration time step, Ät, must be sufficiently small to accurately define the dynamic excitation and to ensure stability and convergence of the solution up to the highest frequency of significance. In TR Section 4.2.3, AREVA indicates that for the most commonly used numerical integration methods, the maximum time step is limited to one-tenth of the shortest period of significance. However, this is	The integration time step used in time history analyses will be taken as 1/50 (or smaller) of the shortest period of importance or a time step study will be performed. The TR Section 4.2.3 will be revised to incorporate the responses to this RAI as follows: "The integration time step used in time history analyses will be 1/50 (or smaller) of the shortest period of importance for the system in question. Alternatively, the initial integration time	Not Acceptable. The first criterion states that the integration time step used in time history analyses will be 1/50 (or smaller) of the shortest period of importance for the system in question. Explain how the shortest period of importance is defined and how this would ensure the convergence of the time history analysis?

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	typically selected for choosing an initial time step which is later checked against analysis results and their stability and convergence. An acceptable approach for selecting the time step, △t, is that the △t used shall be small enough such that the use of ½ of △t does not change the response by more than 10%. Indicate whether this is part of the analysis requirements for time history method of analysis or provide a technical justification for not considering this criterion along with the criterion for initially choosing the time step described for seismic and other dynamic loading analyses.	step will be set to no larger than one- tenth (1/10) of the cut-off frequency and a time step study will be performed: the integration time step will be halved until it can be shown that halving it further will not increase the response of the system by more than 10%."	
Time History Analysis Uncertainties	RAI EPR-11: TR Section 4.2.3 states that to account for uncertainties in the structural analysis using the time history method, similar to peak shifting in the response spectrum method of analysis, three separate input time histories with		Υ

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	modified time steps will be analyzed. Alternatively, the time histories at the attachment points may be derived considering variations in the concrete stiffness.		
	A. Describe the detailed procedure for using the peak shifting method that will be used in the time history method of analysis with modified time steps for seismic and other dynamic loadings.	 A. The method of accounting for uncertainties in time history analysis will be further described in the TR, as indicated below. The fifth paragraph of TR Section 4.2.3 will be revised to incorporate the responses to this RAI as follows: "To account for uncertainties in the structural analysis for seismic loading, a peak shifting approach, similar to that described in Section 4.2.2.1.2 for response spectrum analysis, is used. This is accomplished by first converting the seismic time history excitations into response spectra, and then proceeding through the methodology outlined in Section 4.2.2.1.2. Note that shifting of the input excitation peaks is 	 A. Not Acceptable. More detailed explanation should be provided about this approach, which should also include: The response indicates that the starting point is "seismic time history excitations." Does this mean that there are multiple sets of time histories in each of the orthogonal directions for each support or a single set. If multiple sets, then are the results from all of these time history analyses enveloped? Do these different sets of time histories correspond to different supports or one set of time histories for all supports which bound the excitation at all supports?

RAI Topic	RAI Description	AREVA Response	BNL Disposition
		accomplished by adjusting the time step of the time histories which represent the excitations."	(3) Clarify the steps following the development of the shifting factor presented in TR Section 4.2.2.1.2.
	B. Describe all of the dynamic loads for which the time history will be adjusted to account for material and/or modeling uncertainties and provide the basis for the amount of the adjustment.	B. Topical Report will be revised to clarify that methods used to account for uncertainties will only be used in seismic analysis as the intent is to approximate the effect of the application of peak broadened spectra in a response spectrum analysis. The time step compression/expansion approach to account for uncertainties will be clarified and equated to the peak shifting method used in response spectrum analysis as described in TR Section 4.2.2.1.2.	B. Acceptable. AREVA needs to revise the TR Section.
	C. Explain how the time histories at the attachment point derived considering variations in the concrete stiffness are alternate to the peak shifting method to be used in the time history method of analysis. Also, provide the percentage variations in the concrete stiffness to be used in the EPR piping design.	C. The approach of considering variations in concrete stiffness to account for uncertainties in seismic time history analysis will be removed from the TR.	C. Acceptable. AREVA needs to revise the TR Section.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
Equivalent Static Load Analysis	RAI EPR-12: Confirm that the equivalent static load is always determined by multiplying 1.5 to the peak acceleration for all cases including a single degree of freedom system with known fundamental frequency or a rigid system with the fundamental frequency beyond the cutoff frequency. If not, then provide the criterion that will be used for these special cases.	For clarity, Section 4.2.4 will be revised to include the following text: "For multiple degree of freedom systems, the peak acceleration of the appropriate floor response spectra will be multiplied by 1.5. For cases where piping configurations are calculated as single degree of freedom systems with known fundamental frequencies or rigid systems with fundamental frequencies beyond the cutoff frequency (ZPA), a factor of 1.0 may be used with the spectral accelerations at that frequency."	Not Acceptable. The staff assessment for the equivalent static load method is presented under RAI EPR-5.
Small Bore Piping	RAI EPR-13: The TR did neither define nor address the design of small bore piping to be used in the EPR piping design. Define the small bore piping to be used in the EPR piping design and discuss, with technical bases, the methods of analysis (handbook or a system flexibility analysis) that will be used in the small bore piping design for ASME Class 1, 2, 3 and QG D piping.	Section 4.5 of the TR will be added to include the following text: "Small bore piping for the U.S. EPR is defined as ASME Class 1 piping that is 1" NPS and smaller and Class 2, 3 and QG D that is 2" NPS and smaller. This piping may be analyzed using response spectrum methods described in 4.2.2 of the Topical Report, the equivalent static method described in 4.2.3 or by handbook method."	Not Acceptable. For the case of the handbook method to be developed by the COL applicant, either include the criteria for the approach in the TR or this should be noted in the TR as a COL action item in TR Table 1-1. In addition, confirm that the criteria provided for the small bore piping also is intended to cover instrumentation lines. Include this in the TR.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
		If the COL applicant elects to use the handbook method, the COL applicant will develop the handbook.	
Non-Seismic/ Seismic Interaction	RAI EPR-14: A. TR Section 4.4.1 states that non-seismic piping which cannot be completely separated from seismic systems is routed as far away as possible. With examples, please discuss under what conditions this type of isolation is used in the EPR piping design and also, quantify the meaning of "as far away as possible."	A. Section 4.4.1 states "Non-seismic piping which cannot be completely separated from seismic systems is routed as far away as possible." The sentence in the TR stems from standard seismic "II over I" layout guidance, which would, for example, have two piping systems in the same room (one seismic and one non- seismic) be physically located away from each other as much as possible, such that there will be little chance of the non-seismic piping adversely interacting with the seismic piping, potentially causing damage to the seismic piping during a seismic event. In addition to the physical separation distance used in common areas, the layouts utilize physical barriers within	A. Acceptable. AREVA needs to change the TR Section with the proposed text.
		the area, such as large equipment items which can provide obvious protection for the seismic system from the potential effects of the damaged	

RAI Topic	RAI Description	AREVA Response	BNL Disposition
		nonseismic system. The present guidance is that any non-seismic piping in a common area with seismic piping has been upgraded to a Seismic Class II status to preclude any potential adverse interactions between the two.	
		For clarity, the sentence in the TR will be revised as follows: "Non-seismic piping which cannot be completely separated from seismic systems must be shown to have no interaction with the seismic systems based on separation distance or an intermediate barrier, or be classified as Seismic Category II piping."	
· · ·	B. TR Section 4.4.2 states that following the failure of the non-seismic pipe, (i) if the nonseismic restraints within the ASME B31.1 Code suggested pipe support spacing shown in TR Table 4-1, it is considered to lose its pressure boundary integrity, but not fall onto a safety-related piping or	B. (i) Table 4-1 provides the maximum deadweight support spacings, as provided in the B31.1 Code for proper deadweight supporting of B31.1 piping. It is possible that supports may exist for a piping line which will provide restraint to the piping during a seismic event (such as rigid guide supports), but are not seismically analyzed. If these supports are placed within the B31.1 deadweight spacings, such a supporting	B(i). Not Acceptable. The response does not provide technical justification which demonstrates that supports (not seismically analyzed) would provide adequate restraint for the piping to prevent their collapse, such that the margin of safety is equivalent to that of the Category I piping as required by SRP Section 3.7.2.II.8. This needs to

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	equipment. Provide the technical basis for this assumption.	scheme will provide a level of seismic restraint to the piping. There is still the potential in this case for plasticity of the piping and the supports, however it can be expected that the piping will not fall, but likewise may be expected to not necessarily remain functional. The support scheme from B31.1, which will limit deadweight deflections to less than 1/8 inch, and deadweight stresses to approximately 1,500 psi, should in turn also provide reasonable seismic supporting to accomplish prevention of the pipe falling.	also be demonstrated for the piping as well. This needs to be addressed and the TR revised accordingly.
	(ii) the side motion of a failed moderate energy piping is assumed to be ± 6 inches (centerline to centerline) from the original position. Provide the technical basis for this assumption of ± 6 inches side motion for all pipe sizes.	(ii) The six inches of side motion assumed for a falling non-seismic pipe is based on Section D.2.1 of Appendix D of the SQUG Generic Implementation Procedure. The Appendix is entitled "Seismic Interaction" and contains the following phrase for consideration of seismic interaction of distribution systems due to lateral movements: "and 6 inches for relatively flexible systems would normally be adequate to prevent impacts"	B(ii). Not Acceptable. The guidance provided in the SQUG Generic Implementation Procedure is applicable to verification of the seismic adequacy of equipment in existing plants, not for the design of new plants. In addition, if a non- seismic pipe fails at one location, it can rotate and deform much more than 6 inches at the other end that is still attached.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	(iii) safety-related piping with NPS and thickness equal to or greater than that of the non-seismic piping may be assumed to stop the downward motion of the nonseismic piping without failure of the safety-related piping. Provide the technical basis for this assumption.	(iii) Per Section III.2 of SRP 3.6.2, an unrestrained whipping pipe is not postulated to cause breaks or cracks in target pipes of equal or larger diameter and thickness. This justification also applies to a falling non-seismic pipe, where failure of its supports has occurred.	Therefore, provide justification requested in the RAI or revise the criteria. B(iii). Not Acceptable. Pipe break criterion is not applicable for evaluating the seismic adequacy of seismic Category I piping subjected to the collapse of non-seismic Category I components. Also, there are conditions where the criterion given in the response would not be applicable. One such case as if the end of a section of pipe falls first, it could pierce the Category I pipe even if the Category I pipe has a larger diameter and thickness. Therefore, provide justification for the approach in the TR or revise the criteria.
Buried Piping	RAI EPR-15: TR Section 3.10 did not give details on the analysis method and how the criteria are to be applied in the design of buried piping. A. Based on the criteria	A. Section 3.10 of the TR will be revised to include analysis methods and design requirements for buried piping, as shown in Attachment B to this response. The methods developed for the U.S. EPR buried piping meet	A & B. Not Acceptable. Note the following: (i) The last equation given in Section 3.10.1.3 does not appear to be correct. (ii) In Section 3.10.1.1, the use of

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	presented in the TR, describe the analysis method and design requirements that will be used for buried piping design (including buried pipe tunnel if used in the design). Explain how these methods compare to the analytical methods referenced in the recently published NRC Standard Review Plan 3.7.3, Rev. 3, (i.e., ASCE Standard 4-98, ASCE Report - Seismic Response of Buried Pipes and Structural Components, and NUREG/CR-1161). B. Why doesn't TR Section 3.10 include consideration of ground-water effects and soil arching effects which could increase or decrease the stresses in the pipe due to the overlying soil plus the ground surface loads?	requirements in SRP 3.7.3, Rev. 3, NUREG/CR-1161, ASCE Standard 4-98 and ASCE Report-Seismic Response of Buried Pipes and Structural Components. B. Section 3.10 will be revised to include buoyancy forces from ground- water, overburden and surface traffic from trucks, rail and construction equipment, as shown in Attachment B to this response.	the external pressure Px due to the overburden soil can be used to determine the required pipe wall thickness in accordance with NC/ND-3133. However, the statement that the external pressure counteracts the internal pressure is not always true since there would be conditions when the internal pressure would be zero. The design should also consider this condition. (iii) For stress analysis of buried pipe the external pressures Px, Ps, and Pv are not normally treated as external radial pressure loads which would reduce the internal pressures. These soil pressures are generally represented as vertical loads acting on the top upper half of the pipe cross section (see NUREG/CR-6876, Section 5). In view of this, what is the technical basis for defining P=internal pressure +Px+Ps+Pv in Section 3.10.1 and are all of the values always treated as positive? If not,

RAI Topic	RAI Description	AREVA Response	BNL Disposition
			then see item (ii) above. (iv) Where are Tables 3-5 and 3- 6, which referred to in Section 3 10 1 42
			(v) The equation for thermal- induced stress and equations
			10M and 11M given in Section 3.10.2 include the expression for
			pressure-induced stress with an opposite sign. Explain why P in this expression is used in light of
			item (iii) above, why it acts to reduce all of the other stresses,
			and why in P need twice in equation 10M and 11M? Also, what is the allowable stress for
- - -			equation 10M? (vi) Section 3.10.3.1 should be- updated to reflect some of the
	,		changes made in the more recent ASCE 4-98 standard (e.g., E
			equations given in axial and bending strains should include the
			wave velocity coefficients, etc.). (vii) The equation given for S_{OL} at the end of Section 3.10.3.1 has
			two terms for strains which should

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	C. How is the assumption related to soil liquefaction and fault displacement, which is noted in TR Section 3.10, assured?	C. The path of any buried piping should be surveyed to determine soil conditions with emphasis on avoiding soil conditions such as liquefaction and faults. Section 3.10 of the TR will be revised to include options that can be used to avoid these soil conditions or repair them, as shown in Attachment B to this response.	be stresses. Also, why wasn't the stress contribution from pressure also included? These items also affect Table 3-4. C. Acceptable. AREVA needs to revise the TR Section.
	D. TR Table 3-4 provides the design conditions, load combinations and acceptance criteria for Class 2/3 buried piping. Explain clearly the term non-repeated anchor movement, Equation 9U (vs 9), and Equation 9E (vs 9). While the intent may be interpreted, it is important that these terms be clearly defined in the TR. For Equations 10M and 11M, which are identified as "modified to include axial friction	D. Non-repeated anchor movements, in the case of buried pipe, refers to building settlement at the point where the buried pipe enters the building. Equations 9U and 9F refer to upset and faulted respectively. These designations are used to distinguish the differences in plant events that occur during the upset or faulted plant conditions and must be combined per equation 9 and meet the allowable stresses as noted in the various section of NC/ND 3650.	D. Not Acceptable. As requested in the RAI define all terms used in the TR equations.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	forces," provide the equations to show how they are modified.	SEE EQ 10M AND 11M FROM RESPONSE.	
	E. For the Faulted loading	Where: Mc is moments from arching or thermal anchor movements MA is moments from weight of pipe and the remaining part of the equation is the stress from friction due to thermal differences due to soil/pipe interaction.	E. Acceptable.
	condition in TR Table 3-4, why isn't the load thermal anchor movement (TAM) included in the load combination, as it is in Table 3-2 for Class 2 & 3 Piping? Also, why is the stress criteria of 3Sh used rather than the minimum of 3.0 Sh and 2.0 Sy, as presented in Table 3-2?	will be added to the faulted load condition in Table 3-4. The allowable stress for the faulted condition is less than or equal to 3.0Sh but not greater than 2.0Sy.	Section.
	F. Confirm that Note 5 in the TR Table is applicable to all cases cited in TR Table 3-4 since it is not referenced in the Table like the other notes are. Also, explain how the criteria of NC/ND-3133 of the ASME Code (Note 5 in the	F. Note 5 will be added to Table 3-4 as appropriate. As shown in Attachment B, the external pressure of the soil overburden defined in NC/ND-3133 will be added to the discussion in 3.10.	F. Not Acceptable. Attachment B still does not indicate where note 5 is applicable. Explain why.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	Table) will be implemented in conjunction with meeting the loads and loading conditions specified in Table 3-4.		
Computer Codes	RAI EPR-16: TR Section 5.1 provides short descriptions of the major computer programs to be used in the analysis and design of safety-related piping systems. Piping related computer programs include SUPERPIPE		
	BWSPAN, BWHIST, BWSPEC, COMPAR2, CRAFT2, P91232, and RESPECT. AREVA states that SUPERPIPE has been thoroughly verified and validated to U.S. NRC standards. For all		
	other computer codes, AREVA did not indicate if these programs are verified for their application by appropriate methods, such as hand calculations, or comparison with results from similar		
	programs, experimental tests, or published literature, including analytical results or numerical results to the benchmark		

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	problems and validated as the piping program. Moreover, AREVA did not mention how the quality of these programs and computer results is controlled. To facilitate the staff review of the computer programs used in the EPR design, provide the following additional information:		
	A. Identify which computer programs will be used during the design certification phase.	A. BWSPAN is being used for analysis of the RCL piping during the design certification phase. While the other codes given in the initial version of the TR are also being used for RCL analysis in the design certification phase, they are not strictly piping analysis codes (they are general purpose hydraulic and post processing codes) and so their description will be removed from the TR. SUPERPIPE is being used during design certification for the analysis of ASME Class 2 and 3 piping. It may be used for Class 1 piping.	A. Acceptable. AREVA needs to revise the TR Section.
	B. Identify which programs have	B. The use of BWSPAN for Class 1 RCL analysis has previously been	B. Acceptable.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	previously been reviewed by the NRC on prior plant license applications. Include the program name, version, and prior plant license application. As stated in	approved by the NRC, see letter David E. LaBarge (NRC) to W.R. McCollum, Jr. (Duke Energy Corporation), "Oconee Nuclear Station, Units 1, 2 and 3 Re: Reactor Coolant Loop Analysis	
	SRP 3.9.1, this will eliminate the need for the licensee to resubmit, in a subsequent	Methodology for Steam Generator Replacement (TAC Nos. MA9886, MA9887, and MA9888)," dated	
	license application, the computer solutions to the test problems used for verification.	September 6, 2001. Earlier versions of BWSPAN have been successfully benchmarked to the piping problems	, ,
		given in NUREG/CR-1677. Later versions have been benchmarked to a prior version of BWSPAN by running	
		demonstrate that the changes made in moving from one version to the next	
		BWSPAN is controlled and maintained per AREVA NP, Inc. administrative	
		the verification, validation, maintenance and control of BWSPAN are available. These files will provide the author.	
		source, dated version, program description, the extent and limitation of the program application; and the computer solutions to the test problems	

RAI Topic	RAI Description	AREVA Response	BNL Disposition
RAI Topic	RAI Description	AREVA Response described above. SUPERPIPE - The use of SUPERPIPE, in previous versions, has been approved by the NRC for a number of previous license applications including the Catawba Nuclear Station (CNS UFSAR, Rev. 12, Table 3-68) and the System 80+ Design Certification (NUREG-1462, Section 3.12.3). Current versions of SUPERPIPE have been subsequently verified under the AREVA software QA program by comparison of results to the results of previously accepted versions. SUPERPIPE is controlled and maintained per AREVA NP Inc. administrative procedures. The files which document the verification, validation, maintenance and control of	BNL Disposition
	C. Confirm that the following	SUPERPIPE are available. These files will provide the author, source, dated version, program description, the extent and limitation of the program application; and the computer solutions to the test problems described above. C. The information on computer codes is available for NRC inspection. These files will provide the author, source,	C. Acceptable.
RAI Topic	RAI Description	AREVA Response	BNL Disposition
------------------------------	--	---	-----------------
	information is available for staff review for each program: the author, source, dated version, and facility; a description, and the extent and limitation of the program application; and the computer solutions to the test problems described above.	dated version, program description, the extent and limitation of the program application; and the computer solutions to the test problems described above.	
Inclusion of Support Mass	 <u>RAI EPR-17:</u> TR Section 5.2 describes a criterion for inclusion of support masses to the piping model mass at the support attachment location and states that a portion of the weight of the support is considered in the piping analysis and also, because the mass of a given support will not contribute to the piping response in the direction of the support, only the unsupported directions need to be considered. A. Clarify under what conditions only a portion of the support weight would be considered. 	A. The TR states "The mass contributed by the support is included in the	A. Acceptable.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	B. Provide justification as to why the support mass would not contribute to the piping response in the direction of the support if the support is flexible (e.g., spring hangers).	the total mass of the adjacent pipe span (including pipe contents, insulation and concentrated masses)." B. It is agreed that if the support is determined to be flexible in the direction of the restraint, the support mass should also be included in this direction, as well as for the unrestrained directions. TR Section 5.2 will be revised as follows: "Because the mass of a given support will not typically contribute to the piping response in the direction of the support, only the support mass in the unsupported directions needs to be considered, unless the support is flexible in the supported direction."	B. Acceptable. AREVA needs to change the TR Section with the proposed text.
Piping Model Structural Boundaries	RAI EPR-18: TR Sections 5.4.1.2 and 5.4.1.3 describe two alternate approaches of separating a piping analysis model using an elbow or a tee within the piping model. While	The configurations shown in Figures 5-1 and 5-2 produce boundaries which, over a relatively short distance, provide effective restraint for the six degrees of freedom. The configuration creates a rigid zone of pipe with natural	Acceptable.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	these approaches may be technically sound, no references or technical justifications are provided for each of these methods. Provide technical justifications and limitations (if any) for these two methods of establishing piping model terminations. Also, discuss the basis for selecting the dimensions of L1 and L2 in TR Figure 5-1 for a restrained elbow and Figure 5-2 for a restrained tee.	frequencies well above the ZPA and provides four restraints in the out-of- plane direction. The location of the two in-plane restraints on each side of the elbow or each segment of the tee provides a very short, stiff segment of piping from the intersect point and therefore create an effective axial restraint for the piping in the in plane direction. This configuration meets the recommendations for an overlap zone presented in NUREG/CR-1980.	
Piping Model Boundaries Using Model Isolations	RAI EPR-19: TR Sections 5.4.3.1 and 5.4.3.2 describe two approaches of dividing a large piping analysis model using the overlap region or the influence zone method. While these approaches may be technically sound, no references or technical justifications are provided for each of these methods. Provide technical justifications and limitations (if any) for these two methods of	The overlap methodology provided in TR Section 5.4.3.1 is consistent with the recommendations of NUREG/CR 1980. The following phrase will be added to the text in 5.4.3.1: "and must meet the following criteria which are consistent with the recommendations of NUREG/CR- 1980." The Zone of Influence (ZOI) method is provided as an option when the requirement for a rigid section of piping can not be met in order to use the	Acceptable. AREVA needs to change the TR Section with the proposed text.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	isolating piping models. Also, discuss the basis for selecting the overlap region and the influence zone in TR Figure 5-3.	overlap methodology. In this method, all piping must be modeled to a point where boundary conditions and loadings no longer impact the piping being qualified. This will typically be more piping than is required by the overlap method and the validity of the boundary is required to be demonstrated during the analysis. TR Section 5.4.3.2 will be revised to include these statements. As stated in TR Section 5.4.3, TR Figure 5-3 is included to show the differences in the boundaries of qualification for piping and supports when using the Overlap Method versus the Influence Zone Method. It is not used as a guide for selecting the overlap or influence zone regions. The title of the figure will be revised to " <i>Model Isolation Methods of</i> <i>Division</i> . <i>Comparison of Quilification</i>	
	,	Boundaries."	· · · · · · · · · · · · · · · · · · ·
Piping Benchmark Program	RAI EPR-20: Final piping and pipe support stress analyses cannot be completed before	AREVA will identify three (3) representative calculations from the analyses currently being completed for	Not Acceptable. TR Section 5.3 and item 6 of TR Table 1-1 refer to the "NRC

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	design certification because their completion is dependent on as-built or as-procured information. Under a piping benchmark program, the combined operating license (COL) applicant applies his computer program to construct a series of selected piping system mathematical models that are representative of the standard plant piping designs. Please confirm if AREVA has established such a piping benchmark program to be used by the COL applicants and whether its own piping analysis computer code described in Section 5.1 was verified using models representative of the U.S. EPR.	the U.S. EPR Design Certification to be used in the benchmark program. These calculations will be completed prior to the submittal of the DCD and will utilize the piping analysis codes identified in 5.1 of the TR. The COL applicant will implement this benchmarking program if he chooses to use programs other than those stated in TR 5.1. This requirement is Item 6 of Table 1-1.	benchmark program," not the AREVA benchmark program for the 3 representative calculations. This is somewhat confusing. Therefore, clarify the text in TR Section 5.3 and item 6 of TR Table 1-1 to match the description provided in the RAI response.
Model Decoupling Criteria	RAI EPR-21: TR Section 5.4.2 states that adequate flexibility in the branch line is provided by maintaining a minimum length from the run pipe to the first restraint of ½ of the pipe span in	In the third paragraph of TR 5.2 it is stated "Torsional effects of eccentric masses are included in the analysis." This applies to all eccentric masses including valves in the first half span of a branch line.	Not Acceptable. The first para refers to the general application of the analyzed piping system, not to the decoupled system. Therefore, as requested in the RAI, provide technical

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	TR Table 4-1 for the branch line. The mass to be considered at the branch connection of the run pipe is the mass of ½ of the first span of the branch pipe, including concentrated weights, in each direction. However, AREVA did not discuss other effects (e.g., moment or torsional load at the branch connection) of the eccentric concentrated masses, such as valves, in the first one-half span length from the main run pipe. Provide technical justification on how to account for the effect of a large concentrated mass near the branch connection in the decoupling criteria discussed in the TR.	If a large valve or other large concentrated mass is located within the first span of the branch piping, the torsional effects of the eccentric mass must be considered. In these cases, the branch piping will be modeled and analyzed with the run pipe, or a portion of the branch line shall be included in the run pipe analysis to adequately include the torsional effects of the eccentric weight.	justification on how to account for the effect of a large concentrated mass near the branch connection in the decoupling criteria discussed in the TR. The second paragraph is acceptable but requires a change to the TR.
Dynamic Analysis of Branch Lines	RAI EPR-22: TR Section 5.4.2 states that for the SSE inertia load case, each individual run pipe movement shall be analyzed as a separate anchor movement load case on the branch line and combined	For branch lines decoupled from the RCL, the inertial seismic input at the branch-to run anchor is a time history or response spectrum generated by seismic analysis of the RCL as discussed in RAI EPR-7. The analysis of the branch line also includes the	Not Acceptable. It is still not clear how the inertial movements of the run pipe is included as part of the inertial analysis of the branch pipe. How can the SAM analysis of the branch pipe take care of the

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	with its respective load case by absolute summation. Provide additional clarification to explain this procedure.	thermal and seismic movements of the RCL which are applied as static displacements at the branch-to-RCL anchor. For decoupled branches analyzed using run pipe displacements to capture the inertial effect of the run pipe, Section 5.4.2 of the TR will be revised as follows to clarify the following method of combination: "The inertial movements of the run pipe at the branch intersection are obtained from the run pipe analysis. These movements are statically applied, in individual load cases for each direction, at the branch-to-run pipe anchor. The results of these statically applied load cases are combined by the SRSS to capture the effects of the inertial movement of the run pipe on the branch line. These results are then combined with the inertial analysis of the branch line by absolute summation to obtain the total inertial reanance."	inertial effects of the run pipe? What spectra are used at the run- to-branch connection when performing the dynamic analysis of the branch pipe; do they include the amplified spectra at the main run pipe to branch line connection? This is also addressed in RAI EPR-7.
Model	RAI EPR-23: A. TR Section 5.5	A. The statement in 5.5 will be changed	A. Acceptable.
Isolation and	states that when the isolation	to "four seismic restraints in each of the	AREVA needs to change the TR

RAI Topic	RAI Description	AREVA Response	BNL Disposition
Analysis	methods discussed in TR Section 5.4.3 are used, isolation of dynamic effects is provided by three (3) seismic restraints in each of the three orthogonal directions beyond the seismic Category I design boundary. However, TR Section 5.4.3.1 states that as a minimum, four (4) such restraints in each orthogonal direction in the overlap region are required for the same isolation method. Explain this discrepancy.	three orthogonal directions beyond the Seismic Category I system boundary."	Section with the proposed text.
	B. TR Section 5.5 states that for loads resulting from the potential failure of the non-seismic piping and pipe supports, three separate analyses are performed by applying a plastic moment in each of three orthogonal directions at the termination of the model and then the results of these three analyses are enveloped. Please clarify how	 B. The following text will be added to 5.5: "The plastic moment is calculated as: TWO EQs. SEE RESPONSE Each moment is applied and evaluated in a separate analysis and the results of each analysis are individually combined with the seismic inertia results by absolute summation methods. The 	B. Acceptable. AREVA needs to change the TR Section with the proposed text.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	these loads are calculated and how the results from the three analyses are combined with the results of the dynamic analysis of the seismic Category I piping.	results of these three analyses are then enveloped to obtain the design loads for the piping and supports."	
Transient Loads	RAI EPR-24: Provide the list of transients and the number of events associated with each of these transients during a life span of 60 years that will be part of the design requirements of ASME Code Class piping and pipe supports. If such a list is not developed at this stage of the design certification, then include this in the DCD or include as one of the COL-Action Items listed in TR Table 1-1.	The list of transients will be included in Chapter 3 of the DCD.	Acceptable.
Piping Load Combinations	 <u>RAI EPR-25:</u> The staff needs clarification of several items associated with TR Section 3.3 and Tables 3-1 and 3-2. A. In TR Section 3.3.1.7, it is stated that pipe breaks in the PCL main stoam and 	A. Leak-Before-Break will be addressed in Chapter 3 of the DCD. It was not	A. Acceptable.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	pressurizer surge lines which meet the leak-before-break (LBB) size criteria are eliminated from the consideration based on	addressed in SRP 3.12.	
	impact of smaller attached lines and other lines outside the LBB analyzed zone will be		
	considered. Per SECY 93-087, the staff has approved the LBB approach on a case-by-case basis for austenitic stainless		
	steel and carbon steel with stainless steel clad piping inside the primary containment and pipe size of at least 6-inch NPS.		
	Based on this document, appropriate bounding limits are to be established using preliminary analysis results		
	during the design certification phase and verified during the COL phase by performing the appropriate ITAAC discussed in		
	it. Discuss the technical basis for exclusion of pipe break analysis for the above three lines, with the LBB criteria to be used for		

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	the EPR piping design.		B. Not Acceptable.
	B. Note 3 to TR Table 3-1 states that dynamic loads are to be combined considering timing and causal relationships. SSE and Design Basis Pipe Break (including loss-of-coolant accident (LOCA)) shall be combined using the square root of the sum of the squares (SRSS) method. This is acceptable in accordance to NUREG-0484, Rev. 1. However, for dynamic responses resulting from the same initiating events (other than SSE), when time-phase relationship between the responses cannot be established, the summation of these dynamic responses should be used. Confirm if this is true for the EPR piping design. If not,	 B. AREVA expects to be able to establish the timing and causal relationships between dynamic events such as pipe rupture and valve actuation. However, if this relationship cannot be established between two dynamic events, the responses from these events will be combined by absolute sum. Table 3-1 will be revised to clarify this point as shown in Attachment C to this response. Note 5 of Table 3-2 will be revised to include: "When causal relationships can be established, dynamic loads will be combined by the square root of the sum of the squares (SRSS). When this relationship cannot be established, dynamic loads will be combined by absolute sum. SSE and High Energy Line Break loads are always combined 	B. Not Acceptable. The criteria for SSE plus LOCA as well as the combination method between dynamic events when the causal relationship cannot be established are acceptable. However, when causal relationships can be established between dynamic events, will the criteria in NUREG- 0484, rev.1 regarding the non- exceedance probability be used to determine whether absolute sum or SRSS is used? This also needs to be reflected in TR Tables 3-1 and 3-2.
	justification the combination method to be used when multiple LOCA or other dynamic load	using the SRSS method."	

RAI Topic	RAI Description	AREVA Response	BNL Disposition
RAI Topic	RAI Description combined. This combination criterion is also applicable to note 5 of the TR Table 3-2, which states that dynamic loads are combined by the SRSS. C. Note 8 to TR Table 3-1 states that the earthquake inertial load used in the Level D Primary Stress (Equation 9F) calculations shall be taken as the peak SSE inertial load. The earthquake anchor motion load used in the Level D Primary Stress (Equation 9F) calculations shall be taken as the peak SSE anchor motion load. The staff position on the use of a	C. At the time that the Topical Report was written, portions of Section III NB- 3600 in the 2004 Edition of the ASME Boiler and Pressure Code were not endorsed by the NRC, per the version of 10CFR50.55a in effect at that time. The proposed draft of 10CFR50.55a which was published in spring of 2007 indicates that restrictions on the use of the rules involving seismic loading have been removed. AREVA will therefore reference the equations from NB- 3656(b)(4) for the treatment of SSE	BNL Disposition C. Not Acceptable. Since the OBE is eliminated for design, the staff position for ASME Code Class 1, 2 and 3 piping is that the following items in TR Tables 3-1 and 3-2 be addressed: <u>For Class 1 (TR Table 3-1)</u> (1) In the upset loading condition for primary plus secondary stress intensity range (EQ 10), the loads should include the SSE. The SSE was originally included in the TR. However, it was deleted in the
	position on the use of a single-earthquake design in SECY-93-087 states that the effects of anchor displacements in the piping caused by an SSE be considered with the Service Level D limits. For simplified elastic-plastic discontinuity analysis, if Eq. 10 cannot be satisfied for all pairs of load sets, then the alternative analysis per	3656(b)(4) for the treatment of SSE anchor motions. Table 3-1 has been revised for this reason and to provide further clarification of the Class 1 load combinations.	However, it was deleted in the TR. However, it was deleted in the Table submitted with the RAI response and added to the Peak SIR (EQ 11). The SSE loading needs to be included in both EQ 10 and 11 calculations. (2) The current staff position (as delineated in NUREG-1503, Section 3) for simplified elastic- plastic discontinuity analysis (NB- 3653.6) is that if Eq. 10 cannot be

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	NB-3653.6 for Service Level D should be followed. In addition, the combined moment range for either the resultant thermal expansion and thermal anchor movements plus ½ the SSE seismic anchor motion or the resultant moment due to the full SSE anchor motion alone, whichever is greater must satisfy the equation (known as Eq. 12a) given in NB-3656(b)(4). Clarify if this is applicable to EPR piping design. Also, justify why this anchor motion stress is categorized as a primary stress in the TR Table 3-1 for the faulted condition.		satisfied for all pairs of load sets, then the alternative analysis as described in NB-3653.6 should be followed. In addition, the following condition shall be satisfied: $S_{sam} = (C_2D_o/2I)(M_i^*+M_i^{**}) \le 6S_m$ Where M_i^* is same as M_i^* in Eq. 12 and M_i^{**} is the same as M_i in Eq. 10 except that it includes only moments due to SAM caused by an SSE. The combined moment range for either the resultant thermal expansion and thermal anchor
		-	movements plus ½ the SSE seismic anchor motion or the resultant moment due to the full SSE anchor motion alone, whichever is greater.
	D. Identify the applicability of notes 3 and 5 in the TR Table 3-2.	D. Note 3 applies to the "Design" loading condition and Equation 8. Note 5 applies to Equations 9E and 9F.	D. Not Acceptable. For the combination of dynamic loads, see staff assessment under Item B above. Why doesn't

REQUESTS FOR ADDITIONAL INFORMATION (RAI) RESPONSE EVALUATION

AREVA Topical Report ANP-10264NP (Rev. 0) for U.S. EPR Piping Analysis and Pipe Support Design

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	E. Explain why equation 11a under NC/ND-3653.2 is not included in the TR Table. Are there any dynamic loads other than the SSE (e.g., building response due to hydrodynamic loads such as SRV actuation) that can occur?	E. Equation 11a of NC/ND 3653.2 is for reversing loads such as seismic but it did not appear until after the 1993 addenda. Therefore, it was not included in the TR. The seismic (reversing) inertia loads are included in Equation 9 and the secondary effects of these loads are included in Equation 10 as in the 1993 Code Addenda. See also response to RAI EPR-3. There are no other dynamic loads on the building structure that would impact piping analysis and support design.	the Table shows these notes at the applicable locations? Confirm this is done for all the notes in both Tables 3-1 and 3-2. E. Acceptable.
Piping Damping Values	RAI EPR-26: In TR Section 4.2.5, it is identified that Rev. 0 of the RG 1.61 values of damping will be used in the seismic analysis of structures, systems, and components (SSCs) using ISM response spectrum analysis or time history analysis. However, for piping systems analyzed using USM		

RAI Description	AREVA Response	BNL Disposition
response spectrum analysis, 5% damping will be used provided that the system is not		
susceptible to stress corrosion cracking. Five percent damping will not be used for analyzing the		
dynamic response of piping systems using supports designed to dissipate energy by		
yielding.	A TR Section 4.25 will be revised to	A Not Acceptable
A Since staff has issued the	allow the use of Reg. Guide 1.61 Rev. 1	The TR should be revised to
Rev.1 of RG 1.61 in March 2007,	damping values.	specify that Rev.1 of RG 1.61 "will
indicate if the design of EPR		be used" (not "allow the use") for
piping systems will use Rev. 1 of the RG-recommended damping		the EPR piping design.
values.		
	B. TR Section 4.2.5 will be revised to	B. Not Acceptable.
B. For piping systems analyzed	state that piping analyzed using the	Based on the response and the
using uniform support motion	uniform support motion response	current text in TR Section 4.2.5, it
response spectrum analysis and 5% damping verify that all of the	spectrum method and meeting all limitations specified in Regulatory Guide	Is not clear that the use of 5%
limitations specified in RG 1.84	1.61. Rev. 1 will use 5 percent	with RG 1.61. Rev.1. The current
for ASME Code Case N-411 (or	damping.	staff position for damping of
RG 1.61, Rev.1) will be met.	· · · ·	piping regardless of pipe size is
		4% for the SSE and 3% for the
		Spectra and equivalent static
	RAI Description response spectrum analysis, 5% damping will be used provided that the system is not susceptible to stress corrosion cracking. Five percent damping will not be used for analyzing the dynamic response of piping systems using supports designed to dissipate energy by yielding. A. Since staff has issued the Rev.1 of RG 1.61 in March 2007, indicate if the design of EPR piping systems will use Rev. 1 of the RG-recommended damping values. B. For piping systems analyzed using uniform support motion response spectrum analysis and 5% damping, verify that all of the limitations specified in RG 1.84 for ASME Code Case N-411 (or RG 1.61, Rev.1) will be met.	RAI DescriptionAREVA Responseresponse spectrum analysis, 5% damping will be used provided that the system is not susceptible to stress corrosion cracking. Five percent damping will not be used for analyzing the dynamic response of piping systems using supports designed to dissipate energy by yielding.A. TR Section 4.2.5 will be revised to allow the use of Reg. Guide 1.61 Rev. 1 damping values.A. Since staff has issued the Rev.1 of RG 1.61 in March 2007, indicate if the design of EPR piping systems will use Rev. 1 of the RG-recommended damping values.A. TR Section 4.2.5 will be revised to allow the use of Reg. Guide 1.61 Rev. 1 damping values.B. For piping systems analyzed using uniform support motion response spectrum analysis and 5% damping, verify that all of the limitations specified in RG 1.84 for ASME Code Case N-411 (or RG 1.61, Rev.1) will be met.B. TR Section 4.2.5 will be revised to state that piping analyzed using the uniform support motion response spectrum method and meeting all limitations specified in RG 1.84 for ASME Code Case N-411 (or RG 1.61, Rev.1) will be met.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
			analysis procedures. As an alternative for the response spectrum analysis using an envelope of the spectra at all support points, <u>frequency-</u> <u>dependent damping</u> may be used subject to five restrictions. All of these criteria are presented in RG 1.61, Rev. 1 (March 2007). Therefore, indicate whether the criteria in the RG will be followed as stated here or provide technical justification for the 5% damping value independent of frequency described in TR Section 4.2.5.
· · · · · · · · · · · · · · · · · · ·	C. Also, discuss what damping values will be used for cases when the system is susceptible to SCC and when using supports designed to dissipate energy by yielding.	C. TR Section 4.2.5 will be revised to state that the U.S. EPR will use 4 percent damping for systems susceptible to SCC and when supports that dissipate energy are used.	C. Acceptable.
Modal Combinations	RAI EPR-27: In TR Section 4.2.2.3.1, it is stated that for the response spectrum method of analysis, the modal contributions		

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	to the inertial responses are normally combined by the SRSS method. If some or all of the modes are closely spaced, any one of the methods (Grouping method, 10% method, and Double Sum method, as well as the less conservative methods in revision 2 of the RG 1.92) is applicable for the combination of modal responses. This combination method is applicable to both USM and ISM methods of analysis.		
	A. If guidance given in Revision 2 of the RG 1.92 is used for the EPR piping design, then Revision 2 of the RG no longer recognizes the Grouping method, 10% method and Double Sum method for closely spaced modes. These methods are renamed and AREVA should identify them as noted in the RG.	A. In the Background discussion of Section B of RG 1.92 Revision 2, the methods of Revision 1 are included by reference as remaining acceptable for use. AREVA will add Revision 1 of RG 1.92 to the references since the detail for these methods are not provided in Revision 2.	A. Not Acceptable. The current practice for advanced reactors is to follow the current NRC regulatory guidance. Therefore, RG 1.92, Rev. 2 should be the followed. The phrase in the "Background" discussion referred to in RG 1.92, Rev. 2, was primarily included because the use of the Rev. 1 version for existing plants is still considered acceptable. The new RG 1.92, Rev. 2 is the currently

RAI Topic	RAI Description	AREVA Response	BNL Disposition
-			the preferred method for new plants because it incorporates improved and more accurate methods, and in many cases reduces unnecessary conservatisms. Also, RG 1.92, Rev.2 has additional requirements that were not captured in the Rev. 1 version (e.g., residual rigid response of missing mass, definition of cutoff frequency, etc.). Clarify if RG 1.92 Rev.2 is still the guidance document for modal combinations to be used in the EPR piping design.
	B. TR states that for closely spaced modes AREVA may use less conservative methods discussed in the RG. Please identify which methods are less conservative methods and explain why they are less conservative with respect to the other method(s).	B. This statement is only intended to point out that the methods of modal combination provided in Revision 2 of RG 1.92 are less conservative than the methods presented in Revision 1 as stated in the Background discussion of the RG.	B. Not Acceptable. See staff assessment presented under item A above for resolution of this item.
Missing Mass	RAI EPR-28: TR Section 4.2.2.3.2 presents a procedure		

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	to account for high-frequency modes in the response spectrum methods for calculating seismic and other dynamic load responses. A. Discuss the differences in the mathematical derivations of the high frequency modes presented in the TR versus the methods acceptable to the staff as given in RG 1.92, Rev. 2.	A. The method detailed in the TR is based on the Left-Out-Force method. This method is performed by the SUPERPIPE piping analysis code which has been accepted for use at many operating plants. Although this method is different than that shown in RG 1.92, it produces the same result. BWSPAN uses the missing mass method given in Appendix A of RG 1.92, R2. TR Section 2.2.3.2 will be revised to state that BWSPAN uses the missing mass method outlined in Appendix A of RG 1.92 Revision 2	A. Not Acceptable. Provide the technical basis that demonstrate both methods produce the same result.
	B. The TR states that the response from high frequency modes will be included in the response of the piping system if it results in an increase in the dynamic results of more than 10%. However, in accordance with RG 1.92, Rev.2, C.1.4.1,	B. The residual rigid response of the missing mass modes will be included in all seismic analyses of SSCs. Section 4.2.2.3.2 will be revised to remove the option of using the 10% criteria.	B. Not Acceptable. Guidance for including the missing mass effects should only refer to RG 1.92, Rev. 2, and not Appendix A of SRP 3.7.2. Note that in the current SRP 3.7.2, this criteria was removed. Therefore, section 4.2.2.3.2 should be revised to reflect the above.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	this criterion may yield non-conservative results and should not be used. Since this guideline does not consider the total mass that is missing, which		· · · · · · · · · · · · · · · · · · ·
	in the limit, could be 10%, provide technical justification for using this criteria as a screening requirement for including the effects of any missing mass		
			C. Acceptable.
	C. The TR also states that peak modal responses of the system	c. The TR Section 4.2.2.3.2 will be revised as follows:	AREVA needs to change the TR Section with the proposed text.
	at frequencies above the ZPA are considered to be in phase.	"Thus, the responses of all high frequency modes are combined by	
	Thus, the responses of all high frequency modes are combined	algebraic summation."	
	by absolute summation. Explain if the peak modal responses are	•	
	in phase, then why the absolute sum method is recommended for the EPR piping design.		
	D. Finally, the TD states that this	D. The TD will be revised to state that	D. Not Acceptable.
	D. Finally, the TR states that this missing mass mode is considered to have a modal frequency and acceleration equal to the cut-off frequency used in	the rigid range (missing mass) results will be combined with the low frequency modal results by SRSS.	and low frequency modal results are described in Section 1.5 of RG 1.92, Rev. 2. Explain whether

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	the modal analysis. These modal results are combined with the low frequency modal results using the methods described in TR Section 4.2.2.3.1 for the low frequency modes (per RG 1.92). Please explain the combination method for the results to be used from both low and high frequency modes.		these combination methods (A or B) are used. These would require a change to the TR. For ISM, see RAI EPR-8.
Nonlinear Vibrations Due to Support Gaps	RAI EPR-29: The TR does not provide an analytical method to account for nonlinear effects of excessively large gaps (for frame type supports) between the pipe and supports subject to high frequency vibration loads. Should such large gaps exist, provide the piping analysis method to be used to address the nonlinearity when subjected to vibratory loads with significant high-frequency caused by the gaps between the pipe and its supports.	As stated in TR Section 6.5, and further discussed in Section 6.11, the U.S. EPR design does not intend to utilize gapped supports. For the U.S. EPR, the normal design practice for frame structure guide supports is to utilize a nominal 1/16" gap between the surface of the pipe and the edge of the support member for both sides of the pipe in the restrained direction. Section 6.5 will be revised to add the following text: "Although the use of gapped supports is not anticipated for the U.S. EPR, should the need for such supports arise, one of the following two methodologies would	Not Acceptable. AREVA needs to change the TR Section with the proposed text. If the second methodology for analyzing piping systems with gapped supports is utilized, the technical basis for the approach needs to be submitted for staff review.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
		be employed. Either the non-linear piping analysis problem is solved using direct integration time history methods, or the piping is analyzed as a linear problem, where the supports are assumed effective and the results are summed with the results of a static load case which deflects the pipe enough to close the support gap(s). These linear analyses will use either response spectra or time history modal superposition techniques."	
Thermal Stratification	RAI EPR-30: A. TR Section 3.7.1 states that the main feedwater nozzle is located in the conical section of the steam generator which aids in reducing thermal stratification. Please explain how this reduces thermal stratification.	A. Since the main feedwater nozzle is attached to the sloped conical section of the steam generator, it too is inclined: ~18 degrees from the horizontal. This incline promotes mixing of the colder and hotter fluid layers in the line which in turn retards stratification. The inclined design also prevents permanent thermal stratification at low flow rates and ensures run-full conditions in the nozzle.	A. Not Acceptable. Per TR Section 3.7.1, the effects of thermal stratification and striping will be evaluated during the evaluation of the main feedwater system and the evaluation will confirm that all load cases meet the ASME Code allowables. Confirm that this evaluation will be fully described in the DCD.
	B. TR Section 3.7.2 states that the surge line may not be subjected to significant	B. There are three major features of the surge line which minimize the amount of stratification in the line: 1) The take-	B. Not Acceptable . Per TR Section 3.7.2, the effects of thermal stratification and

RAI Topic	RAI Description	AREVA Response	BNL Disposition
-	stratification/striping effects due to design features that mitigate these effects. Describe these design features and explain how they mitigate the effects of thermal stratification in the surge line.	off from the hot leg is vertical upward and of sufficient length that turbulent penetration from hot leg flow does not spill over into the surge line beyond the take-off, and thus causing stratification; 2) the surge line is sloped ~5 degrees between the vertical take-off at the hot leg and the vertical leg at the pressurizer, which promotes contributes to mixing of the colder and hotter fluid layers in the line; and 3) during normal operation, a continuous bypass spray flow of sufficient magnitude is maintained to further suppress turbulent penetration from the hot leg flow.	striping on the pressurizer surge line will be analyzed with the RCL piping and supports or it will be demonstrated that the surge line is not subjected to significant stratification/striping effects. Confirm that this evaluation will be fully described in the DCD. For TR Section 3.7.3, covering unisolable piping due to leaking valve, also confirm that this evaluation will be fully described in the DCD.
Safety Relief Valve	RAI EPR-31: Describe the SRV design parameters and criteria that will need to be specified to the COL applicant to ensure that the specific piping configuration and safety relief valves (SRVs) purchased and installed at the COL applicant stage will match the test and design parameters used at the design certification stage. An example is the minimum rise time for the SRV	Discussion of SRV design parameters and criteria is beyond the scope of this TR. Relevant parameters and criteria will be addressed in the DCD.	Acceptable.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	valve operation; this can greatly affect the transient loads imposed on the piping system analysis. Also, any change in the discharge piping system configuration may affect the SRV loadings.		
Composite Damping	RAI EPR-32: The composite modal damping ratio can be used when the modal superposition method of analysis (either time history or response spectrum) is used, as described in SRP Section 3.7.2, II.13. If AREVA plans to use composite modal damping for U.S. EPR piping design, provide a description of the methods for determining the composite modal damping value.	Composite modal damping may be applied when the modal superposition method of analysis is used. The methods used will meet the requirements of SRP 3.7.2. Section 4.2.5 of the TR will be revised as follows: "When composite modal damping is applied in a dynamic analysis, each model subgroup (piping, supports, equipment, etc) is assigned an appropriate damping value per RG 1.61 R1. The equivalent modal damping matrix, or composite modal damping matrix, is calculated for each mode by one of the two methods shown below: EQUATIONS, SEE RESPONSE. Note: Damping beyond 20 percent will	Acceptable. AREVA needs to change the TR Section with the proposed text.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
		not be used."	
Codes for Support Design	RAI EPR-33: A. TR Section 6.1 states that for Service Levels A, B and C, the seismic Category I pipe supports will be designed in accordance with Subsection NF of the ASME Code and for Service Level D, Appendix F of Section III of the ASME Code will be utilized. However, TR Section 6.2 states that all piping supports designed in accordance with the rules of Subsection NF of the Code up to the building structure interface are defined by the jurisdictional boundaries in Subsection NF-1130 of the ASME Codes. (i) Since Appendix F of the Section III provides only the Service Level D limits for evaluation of loading [per Code Table NF-3523(b)-1 for stress	A. (i) TR Section 6.1 will be corrected to indicate that Seismic Category I pipe supports will be designed to ASME Subsection NF loadings for Service Levels A, B, C and D, while using the acceptance limits of Subsection NF for Levels A, B and C, and the acceptance limits of Appendix F for Level D. (ii) Subsection NF of the ASME Code will be used for the manufacturing, installation and testing of all Seismic Category I pipe supports.	A. Acceptable. AREVA needs to revise the TR Section.
·	limit factors] for Class 1, 2, 3 and MC type supports, clarify if the seismic Category I pipe supports will be designed to ASME Subsection NF for all four		· · · ·

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	Service Level A, B, C and D loads, while using the acceptance stress limits by the Appendix F for Service Level D supports. (ii) Also, clarify if the Subsection NF will be used to manufacture, install and test all seismic Category I pipe supports. If not, which other standard will be used.		
	B. AREVA also states that seismic Category II pipe supports are designed to ANSI/AISC N690, "Specification for the Design, Fabrication and Erection of Steel Safety-Related Structures for Nuclear Facilities." These standards are used to design the structures or structural elements of a support for nuclear facilities, not the standard component supports (e.g., clamps, snubbers). ASME Code Subsection NF is typically used for seismic Category II pipe supports. Identify the standard that will be used to design	B. For all Seismic Category II pipe supports other than standard component supports, the design, manufacturing, installation and testing will meet the requirements of ANSI/AISC N690. Standard component supports will be designed, manufactured, installed and tested to Subsection NF of the ASME Code. Any structural members used as part of a pipe support also containing standard components will be designed, manufactured, installed and tested to ANSI/AISC N690.	B. Not Acceptable. AREVA needs to revise the TR Section. The use of ANSI/AISC N690 should include Supplement 2 (2004) of the specification N690, in accordance with SRP Sections 3.8.3 and 3.8.4, March 2007.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	manufacture, install and test seismic Category II pipe supports.	-	
	C. AREVA states that non-seismic category pipe supports are designed using guidance from the AISC Manual of Steel Construction. This manual is used to design steel constructions in frame type or other structural element of component supports. Based on TR Section 6.2, ASME Code B31.1 is being used for a certain class of piping (also see request for additional information (RAI) EPR-2). The design of all supports for the non-nuclear piping (that typically uses B31.1 for piping analysis) should satisfy the requirements of ASME/ANSI B31.1 Power Piping Code, Paragraph 120 for loads on pipe supporting elements and Paragraph 121 for design of pipe supporting elements. Clarify if this is applicable to U.S. EPP	C. For non-seismic pipe supports supporting piping analyzed to B31.1, the requirements of B31.1 for supports (Sections 120 and 121) will be met, where applicable. In addition, the structural elements will meet the requirements of the AISC Manual. For standard components used in such supports, vendor's catalog requirements will be utilized, which also meet B31.1 requirements. For non- seismic pipe supports supporting unanalyzed piping, the structural elements will meet the requirements of the AISC Manual and standard components will meet vendor's catalog requirements.	C. Acceptable. AREVA needs to revise the TR Section.

RAI Description **AREVA** Response **BNL Disposition RAI** Topic pipe support design, otherwise explain how the AISC manual will be used to design component supports (e.g., clamps, springs). load RAI EPR-34: While reviewing TR Combination Section 6.3. the staff needs clarification of the following for Supports items. A. TR Section 6.3.11 provided a A. The Minimum Design Load criteria A. Not Acceptable. minimum design load criteria that given in this section is based on criteria If the current approach stated in will be used for all supports so given in Welding Research Council the response is to apply a 25% (WRC) Bulletin 353, Section 2.4.7. The that uniformity is obtained in the increase to all pipe support loads load carrying capability of the bulletin recommends 125% of the Level for possible future increases, and supports. All supports will be A condition load, as the only difference this approach is also designed for the largest of the from the topical's criteria. Presently, for recommended in the WRC following three loads: 100% of the analyses being performed as part of Bulletin 353, then the TR should the Design Certification process, the the Level A condition load, the state this. weight of a standard ASME guidance is to apply a 25 percent B31.1 span of water filled, increase to all pipe support loads to allow for possible future increases in schedule 80 pipe, and minimum value of 150 pounds. Provide the support loads beyond the initial design. technical basis for this criteria. B. TR Table 6-1 provides the B. Not Acceptable. specific load combinations that B. Table 6-1 includes three Faulted load

RAI Topic **RAI Description AREVA** Response **BNL Disposition** will be used in the design of pipe combinations which contain SSE loads. AREVA needs to revise the TR supports. The acceptance In addition, Note 3 of the table states Section. Define all terms used in criteria associated with the that SSE includes inertia and SAM the Table 6-1 and include the Service Levels will be per ASME loads combined by absolute sum. definitions in Table 6-1 or cross Code. Subsection NF. These would all apply to Class 1, 2 &3 reference where they are already pipe supports. In addition, struts and defined. It is acceptable to design ANSI/AISC N690 or the AISC Manual of Steel Construction, as anchors/quides will be analyzed to all snubbers to all load combinations appropriate: Note 1 to the Table load combinations shown in the table. except normal level load states that operating basis Snubbers will be designed to all but the combinations. However, for the earthquake (OBE) inertia and Normal Level load combinations shown load combinations where wind SAM loads are not included in and tornado occur, will the piping in the table. the design of Class 2/3 piping. Note that Class 1 was inadvertently not and all supports be designed for included in Note 1 of Table 6-1. This will the following two conditions: Explain how the seismic inertia and SAM loads are accounted be corrected in the next revision of the snubbers included and snubbers excluded? If not, explain why not. for in the design of Class 2/3 TR. Note 1 will be revised to state. pipe supports. Also, clarify how "OBE inertia and SAM loads are not included in the design of Class 1, 2 & 3 the same table is applicable to snubbers, struts, and piping." anchors/guides. C. AREVA discusses wind/tornado loads in TR C. Section 3.3.1.6 states that for Design C. Not Acceptable. Certification, no Class 1, 2 and 3 piping (1) Explain why the friction load F Sections 6.3.5 and 6.3.6 for pipe supports. However, for the piping is exposed to wind and tornado loads. is not included in the load in TR Section 3.3.1.6. AREVA and further states that if a COL combinations that contain wind or identified these loads to be COL Applicant creates such an exposed tornado since these two loads Action Item 3. Clarify AREVA's piping condition, it will be addressed at may not always act as dynamic that time. Sections 6.3.5 and 6.3.6 position on this. type loadings. (2) For piping

REQUESTS FOR ADDITIONAL INFORMATION (RAI) RESPONSE EVALUATION

AREVA Topical Report ANP-10264NP (Rev. 0) for U.S. EPR Piping Analysis and Pipe Support Design

RAI Topic	RAI Description	AREVA Response	BNL Disposition
		discuss the inclusion of such wind related loads for pipe supports. AREVA's position on wind loadings for both piping and supports is as stated in Section 3.3.1.6. Clarification will be added to Sections 6.3.5 and 6.3.6 to cross reference this section, and state that these sections show how such loads would be treated if the need arises.	design and pipe support design why isn't R_{SOT} considered in other load combinations (i.e., in combination with R_{DBPB} , $R_{MS/FWPB}$, LOCA, R_{DBPB} +SSE, $R_{MS/FWPB}$ +SSE, and LOCA+SSE)?
Snubber Design	RAI EPR-35: AREVA, in TR Section 6.6, states that design specifications are to be provided to the snubber suppliers and the installation and operation of snubbers will be verified by the COL applicant. For design certification, SRP Section 3.9.3 requires that design, installation, operation and testing of the snubbers should be included in the design document. Clarify, whether AREVA intends to include all design-related specifications associated with snubbers in the TR or in the DCD.	As stated in item 2 of Table 1-1 of the TR, design specifications will be the responsibility of the COL applicant. The specification will be generated using the snubber specification requirements given in Chapter 3 of the DCD.	Acceptable.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
RAI Topic Support Stiffness	RAI Description RAI EPR-36: AREVA does not adequately describe in TR Section 6.7 how the representative stiffness values are developed for all supports other than snubbers. Describe: 1. the approach used to develop the representative stiffness values, 2. the procedure that will be imposed to ensure that the final designed supports match the stiffness values assumed in the piping analysis, 3. the procedure used to consider the mass (along with the support stiffness) if the pipe support is not dynamically rigid, and 4. the same information [(1), (2), and (3) above] for the building steel/structure (i.e., beyond the NF jurisdictional boundary) and for equipment to which the piping may be connected to.	AREVA Response The initial piping analyses will assume all supports rigid (except for the few cases where the actual support structures are included in the piping model), and therefore utilize the default rigid support stiffness values contained in the analysis program. In addition, the initial pipe support designs will be developed to create a rigid support, based on the deflection check criteria given in Section 6.7 of the topical. If for some reason, a rigid support cannot be achieved, an actual support stiffness will need to be developed for the support noted, as well as for the other supports in the model. Typically, unless the support is a very simple structure, a frame support will be modeled using an analysis program such as GT STRUDL. This model will include the self-weight of the support, and will also be used to establish the deflections needed for the stiffness checks. Note that this model will include any flexible building steel, as applicable.	BNL Disposition Not Acceptable. (1) Explain and justify the definition of rigid supports (e.g., frequency greater than some value with the mass of the support and contributing pipe spans in each direction), default rigid support stiffness, how the rigid support stiffness corresponds to the definition of rigid supports, and how do the deflection requirements in TR Section 6.7 ensure the supports are rigid. (2) Since GT STRUDL may be used for evaluation of pipe supports, provide the information and validation approach in accordance with the request made in RAI EPR-16 for piping computer codes. This should be done for GT STRUDL and any other structural computer code that may be used.
·		rigidity, the model can be used to	

RAI Topic	RAI Description	AREVA Response	BNL Disposition
		determine the actual stiffness of the support structure using the self-weight load case. In addition, the support mass can be determined from the model. This would be created for the supports in the model and provided to the piping analyst. At this point, the supports would need to be rechecked for the loads from the revised piping analysis. If any support changes were required, an iteration of the process would be required to assure that the stiffnesses and masses are consistent for both the support qualifications and the piping analysis.	
Inclusion of Support Self- Weight Excitation	 RAI EPR-37: In TR Section 6.8, AREVA did not indicate if the criteria presented is also applicable to other dynamic loads and did not discuss how the damping value will be used in the response spectrum analysis. A. Clarify whether the criterion presented in the TR is also applicable to other dynamic loads. If not, provide technical 	A. The support structure itself will be excited by SSE dynamic inputs, as the SSE event is applicable to the whole	A. Not Acceptable. Section 6.8 of the TR refers to RG 1.61, October 1973 for damping

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	justification.	site in the form of ground motion. As such, the excitation for the support's attachment to the building will be applied to the self-weight of the structure in the form of response spectra g values. For other fluid dynamic transient events within the piping system, forces from the fluid moving along the pipe are included in the pipe support loads for that event, but any subsequent excitation of the support structure itself for the fluid dynamic event will not be evaluated, as the forcing function at each support beyond applied piping loads will be minimal, and not usually defined. This is standard practice in pipe support design. The supports are typically not modeled with the piping.	values to be used in the evaluation of support self weight response to the SSE event. The current staff position is to use RG 1.61, Rev. 1 March 2007. Also, using the current version of RG 1.61 for supports and piping results in a consistent set of criteria for piping systems. Explain whether this approach will be followed or why not.
· · ·	B. Since the piping and support structure damping value may be different per RG 1.61, discuss what damping value will be used in the response spectrum analysis when the support structure is also modeled as part of the piping analysis. See also RAI EPR-32.	B. In most cases, Revision 1 of RG 1.61 calls for 4 percent damping for the piping analysis. Similarly, the RG allows for 4 percent damping for welded steel or bolted steel with friction connections and 7 percent for bolted steel with bearing connections, which would be	B. Not Acceptable. The response did not address the requested information. When the support is modeled in the piping analysis, if the damping values are different for the supports and the piping, how is damping treated? [i.e., is the lower (more

RAI Topic	RAI Description	AREVA Response	BNL Disposition
		applicable for the supports. If frequency dependent damping values are used in the piping analysis, the support structure will still utilize the 4 percent or 7 percent damping values.	conservative) value used for both or is the composite modal damping method discussed in the response to RAI EPR-32 used?]
Instrument Line Support Design	RAI EPR-38: TR Section 6.12 states that the applicable loading combinations for instrumentation lines will follow those used for normal and faulted levels in TR Table 6-1. Please explain why the load combinations for upset and emergency levels in TR Table 6-1 are not applicable to instrumentation line supports.	Based on the inclusion of only deadweight, thermal and SSE seismic loadings for analysis of the tubing, the vast majority of the support loads would fall into Normal or Faulted conditions. Since there may be thermal loads for other levels, this section of the topical will be modified to delete the reference to only Normal and Faulted loading conditions. Section 6.12 will be revised to state: "The applicable loading combinations will similarly follow those used for the ASME Levels in Table 6-1utilizing the design loadings mentioned above."	Acceptable. AREVA needs to change the TR Section with the proposed text.
Pipe Deflection Limits	RAI EPR-39: In TR Section 6.13, AREVA provided examples of the limitations which include travel limits for spring hangers, stroke limits for snubbers, swing angles for rods, struts and	The first check mentioned is the travel range limitation for spring hangers. This check will utilize the "working range" given in the standard Load Table for Selection of Hanger Size typically given in the vendor catalogs. This working	Acceptable.

RAI Topic	RAI Description	AREVA Response	BNL Disposition
	snubbers, alignment angles between clamps or end brackets with their associated struts and snubbers, and the variability check for variable spring supports. In addition to the manufacturer's recommended limits, allowances will be made in the initial designs for tolerances on such limits. Please specify the actual allowable limits that are applicable to EPR support design for pipe deflection limits.	range already provides a deflection tolerance beyond each end limit of the range (with the magnitude dependent on the spring type), provided the hot and cold loads fall within the working range. The second check-mentioned is the stroke limit checks for snubbers. The current project guidance is to allow at least ½ inch of stroke at each end for the initial design checks. The third check mentioned is the swing angle check for rods, struts and snubbers. For current analyses, ANVIL, International hardware is being used. ANVIL's limit for these checks is 4 degrees. AREVA will apply a tolerance of 1 degree to this, thus checking to 3 degrees for initial design. The fourth check	BAL DISPOSITION
		mentioned is for alignment angles of strut and snubber paddles and their associated clamps or end brackets. ANVIL's limit is 5 degrees. AREVA will apply a tolerance of 1 degree to this, thus checking to 4 degrees for initial design. The fifth check mentioned is for the spring variabilitý check. The recommended limit on this check by ANVIL is 25 percent. AREVA will apply	

RAI Topic	RAI Description	AREVA Response	BNL Disposition
		a tolerance of 5 percent to this, thus checking to 20 percent for initial design.	
			`