

- E. Pursuant to the Act and 10 CFR Parts 40 and 70 to receive, possess, and use at any time 100 milligrams each of any source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactively contaminated apparatus;
 - F. Pursuant to the Act and 10 CFR Parts 30 and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of Turkey Point Units Nos. 3 and 4.
3. This renewed operating license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations: 10 CFR Part 20, Section 30.34 of 10 CFR Part 30, Section 40.41 of 10 CFR Part 40, Sections 50.54 and 50.59 of 10 CFR Part 50, and Section 70.32 of 10 CFR Part 70; and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect, and is subject to the additional conditions specified below:
- A. Maximum Power Level

The applicant is authorized to operate the facility at reactor core power levels not in excess of 2300 megawatts (thermal).
 - B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 236 are hereby incorporated into this renewed license. The Environmental Protection Plan contained in Appendix B is hereby incorporated into this renewed license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.
 - C. Final Safety Analysis Report

The licensee's Final Safety Analysis Report supplement submitted pursuant to 10 CFR 54.21(d), as revised on November 1, 2001, describes certain future inspection activities to be completed before the period of extended operation. The licensee shall complete these activities no later than July 19, 2012.

The Final Safety Analysis Report supplement as revised on November 1, 2001, described above, shall be included in the next scheduled update to the Final Safety Analysis Report required by 10 CFR 50.71(e)(4), following the issuance of this renewed license. Until that update is complete, the licensee may make changes to the programs described in such supplement without prior Commission approval, provided that the licensee evaluates each such change pursuant to the criteria set forth in 10 CFR 50.59 and otherwise complies with the requirements in that section.

- E. Pursuant to the Act and 10 CFR Parts 40 and 70 to receive, possess, and use at any time 100 milligrams each of any source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactively contaminated apparatus;
 - F. Pursuant to the Act and 10 CFR Parts 30 and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of Turkey Point Units Nos. 3 and 4.
3. This renewed operating license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations: 10 CFR Part 20, Section 30.34 of 10 CFR Part 30, Section 40.41 of 10 CFR Part 40, Sections 50.54 and 50.59 of 10 CFR Part 50, and Section 70.32 of 10 CFR Part 70; and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect, and is subject to the additional conditions specified below:
- A. Maximum Power Level

The applicant is authorized to operate the facility at reactor core power levels not in excess of 2300 megawatts (thermal).
 - B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 231 are hereby incorporated into this renewed license. The Environmental Protection Plan contained in Appendix B is hereby incorporated into this renewed license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.
 - C. Final Safety Analysis Report

The licensee's Final Safety Analysis Report supplement submitted pursuant to 10 CFR 54.21(d), as revised on November 1, 2001, describes certain future inspection activities to be completed before the period of extended operation. The licensee shall complete these activities no later than April 10, 2013.

The Final Safety Analysis Report supplement as revised on November 1, 2001, described above, shall be included in the next scheduled update to the Final Safety Analysis Report required by 10 CFR 50.71(e)(4), following the issuance of this renewed license. Until that update is complete, the licensee may make changes to the programs described in such supplement without prior Commission approval, provided that the licensee evaluates each such change pursuant to the criteria set forth in 10 CFR 50.59 and otherwise complies with the requirements in that section.

ADMINISTRATIVE CONTROLS

6.1 RESPONSIBILITY

6.1.1 The Plant General Manager shall be responsible for overall unit operation of both units and shall delegate in writing the succession to this responsibility during his absence.

6.1.2 The Nuclear Plant Supervisor (or during his absence from the control room, a designated individual) shall be responsible for the control room command function. A management directive to this effect, signed by the Site Vice President shall be reissued to all station personnel on an annual basis.

6.2 ORGANIZATION

ONSITE AND OFFSITE ORGANIZATION

6.2.1 An onsite and an offsite organization shall be established for facility operation and corporate management. The onsite and offsite organization shall include the positions for activities affecting the safety of the nuclear power plant.

- a. Lines of authority, responsibility and communication shall be established and defined from the highest management levels through intermediate levels to, and including all operating organization positions. Those relationships shall be documented and updated, as appropriate, in the form of organizational charts. These organizational charts will be documented in the Quality Assurance Topical Report and updated in accordance with 10 CFR 50.54(a)(3).
- b. The Chief Nuclear Officer shall have corporate responsibility for overall plant nuclear safety, and shall take any measures needed to ensure acceptable performance of the staff in operating, maintaining, and providing technical support to the plant to ensure nuclear safety.
- c. The Plant General Manager shall be responsible for overall plant safe operation and shall have control over those onsite activities necessary for safe operation and maintenance of the plant.
- d. Although the individuals who train the operating staff and those who carry out the quality assurance functions may report to the appropriate manager onsite, they shall have sufficient organizational freedom to be independent from operating pressures.
- e. Although health physics individuals may report to any appropriate manager onsite, for matters relating to radiological health and safety of employees and the public, the Health Physics Supervisor shall have direct access to that onsite individual having responsibility for overall unit management. Health physics personnel shall have the authority to cease any work activity when worker safety is jeopardized or in the event of unnecessary personnel radiation exposures.

ADMINISTRATIVE CONTROLS

6.8 PROCEDURES AND PROGRAMS

6.8.1 Written procedures shall be established, implemented, and maintained covering the activities referenced below:

- a. The applicable procedures required by the Quality Assurance Topical Report.
- b. The emergency operating procedures required to implement the requirements of NUREG-0737 and Supplement 1 to NUREG-0737 as stated in Generic Letter No. 82-33;
- c. PROCESS CONTROL PROGRAM implementation;
- d. OFFSITE DOSE CALCULATION MANUAL implementation;
- e. Quality Control Program for effluent monitoring using the guidance in Regulatory Guide 1.21, Revision 1, June 1974;
- f. Facility Fire Protection Program;
- g. Quality Control Program for environmental monitoring using the guidance in Regulatory Guide 4.1, Revision 1, April 1975; and
- h. Diesel Fuel Oil Testing Program implementation.

6.8.2 Deleted

6.8.3 Deleted