



$A = 1.47 (q)$ = Effect of uniform full coverage surface surcharge
 $B1 = 3346 \text{ psf}$ = Passive earth pressure at ground surface due to soil cohesion
 $B = 194 (z)$ = Passive earth pressure above water table
 $C = 102.3 (h)$ = Passive earth pressure increment below water table
 $Pp = A + B1 + B$ = Passive lateral earth pressure above water table ($z \leq dw$)
 $Pp = A + B1 + 194.3 dw + 102.3 (z - dw)$ = Passive lateral earth pressure below water table

Conditions on information:

- Units of pressure = lbs/ft²
- Backfill of borrow soil meeting Class I properties as defined in FSAR, 1986 compacted to 95% MDD by ASTM D698 (Reference 448)
- No factors included
- $\gamma_s = 132 \text{ lbs/ft}^3$ = saturated unit weight of backfill above water table
- $\gamma = 69.6 \text{ lbs/ft}^3$ = submerged soil density
- $\phi_{cu} = 11 \text{ deg}$ = angle of internal friction of soil (95% Maximum dry density at 2% above optimum moisture; total stress)
- $KP = 1.47$ = Coefficient of passive earth pressure due to ϕ (Rankine equation)
- $C_{cu} = 1380 \text{ psf}$ = shear strength intercept of soil (total stress, saturated CU test)
- Plane strain conditions (corner adjustment factors not included)
- Dynamic soil pressure not included
- Design water table Unit 3 = Elevation 605 ft.
- Design water table Unit 4 = Elevation 615 ft.