




Survey Unit Release Record

| | | | | |
|---|--|-------------------|--------------|--------------------|
| Design # | EP-FH-102 | Revision # | Original | Page 1 of 3 |
| Survey Unit #(s) | FH-102 | | | |
| Description | <p>1) Embedded Pipe (EP) Survey Unit FH-102 meets the definition of embedded pipe for Plum Brook Reactor Facility (PBRF).</p> <p>2) EP FH-102 is a Class 1, Group 3.1 survey unit as per the PBRF Final Status Survey Plan (FSSP) and Technical Basis Document (TBD)-06-004.</p> <p>3) Surveys in EP FH-102 were performed using a scintillation detector optimized to measure gamma energies representative of Cs-137. Sample #EP 3-6 from Survey Request (SR)-13 was referenced for this decision.</p> <p>4) Survey Instructions for this survey unit are incorporated into and performed in accordance with (IAW) the Babcock Services Incorporated (BSI)/LVS-002, Work Execution Package (WEP) 05-006. Survey instructions described in this document constitute "Special Methods" and the survey design used in the acquisition of survey measurements.</p> <p>5) Instrument efficiency determinations are developed in accordance with the BSI/LVS-002, WEP 05-006, these determinations are appropriate for the types of radiation involved and the media being surveyed.</p> | | | |
| Approval Signatures | | | Date: | |
| FSS/Characterization Engineer |  | | 8-26-07 | |
| Technical Reviewer (FSS/Characterization Engineer) |  | | 10-23-07 | |
| FSS/Characterization Manager | R. Case  | | 11/30/07 | |

Form
CS-09/1
Rev 0

Survey Unit: FH-102

1.0 History/Description

- 1.1 The subject pipe system is the 4" drain line system for the Fan House (FH). The FH floor drain system consists of two major branches that both tie into the header and sump that services the Hot Pipe Tunnel (HPT). The system was accessed at four different locations on the -12 ft elevation of the Fan House. The purpose of the system was to convey water from the floor drain openings on the -12 ft elevation of the FH to a sump located on the -12' elevation of the HPT.
- 1.2 EP FH-102 consists of approximately 113 feet of drain system piping.

2.0 Survey Design Information

- 2.1 EP FH-102 was surveyed IAW Procedure #BSI/LVS-002.
- 2.2 100% of the 4" ID pipe was accessible for survey. The accessible 4" ID pipe was surveyed by static measurement at one foot increments, for a total of 113 survey measurements.
- 2.3 Surface area for the 4" ID piping is 973 cm² for each foot of piping, corresponding to a total 4" ID piping surface area of 109,935 cm² (11.0 m²) for the entire length of (113') of 4" piping.

3.0 Survey Unit Measurement Locations/Data

- 3.1 Pipe interior radiological survey forms are provided in Attachment 2 of this release record.

4.0 Survey Unit Investigations/Results

- 4.1 None

5.0 Data Assessment Results

- 5.1 Data assessment results are provided in the EP/Buried Pipe (BP) Survey Report provided in Attachment 1.
- 5.2 All measurement results are less than the Derived Concentration Guideline Level (DCGL) for radionuclide specific EP that corresponds to the 1 mrem/yr dose goal established in Table 3-3 of the FSSP.
- 5.3 When implementing the Unity Rule, provided in Section 3.6.3 of the FSSP, and applying the Nuclide Fraction (NF), provided in TBD-06-004, the survey unit that is constituted by EP FH-102 passes FSS.
- 5.4 Background was not subtracted from the survey measurements and the Elevated Measurement Comparison (EMC) was not employed for this survey unit.

Survey Unit: FH-102

5.5 Statistical Summary Table

| Statistical Parameter | 4" Pipe |
|--|------------|
| Total Number of Survey Measurements | 113 |
| Number of Measurements >MDC | 107 |
| Number of Measurements Above 50% of DCGL | 0 |
| Number of Measurements Above DCGL | 0 |
| Mean | 0.0219 |
| Median | 0.0147 |
| Standard Deviation | 0.0272 |
| Maximum | 0.1842 |
| Minimum | 0.0028 |

6.0 Documentation of evaluations pertaining to compliance with the unrestricted use limit of 25 mrem/yr and dose contributions from Embedded Pipe and radionuclides contributing 10% in aggregate of the total dose for both structural scenarios and soils.

6.1 A review of the survey results has shown that the dose contribution for EP FH-102 to be less than 1 mrem/yr. The dose contribution is estimated to be 0.022 mrem/yr based on the average of the actual gross counts.

7.0 Attachments

Attachment 1 – BSI EP/BP Survey Report

Attachment 2 – Pipe Interior Radiological Survey Form

Attachment 3 – DQA Worksheet

Attachment 4 – Disc containing RR for EP FH-102 & Spreadsheet

SECTION 7
ATTACHMENT 1
5 **PAGE(S)**



BSI EP/BP SURVEY REPORT

| | | | |
|---|-----------|---|-----------------------------|
| Pipe ID | EP FH-102 | Survey Location | Fan House |
| Survey Date | 02-Nov-06 | 2350-1 # | 203438 |
| Survey Time | 08:13 | Detector-Sled # | 44-159 238369 / 101 |
| Pipe Size | 4" | Detector Efficiency | 0.00019 |
| DCGL (dpm/100cm ²) | 3.79E+06 | Pipe Area Incorporated by Detector Efficiency (In cm ²) | 973 |
| Pipe Area Incorporated by Survey Data (m ²) | 11.0 | Field BKG (cpm) | 5.1 |
| Routine Survey | X | Field MDCR (cpm) | 10.8 |
| QA Survey | | Nominal MDC (dpm/100cm ²) | 9,453 |
| Survey Measurement Results | | | |
| Total Number of Survey Measurements | | | 113 |
| Number of Measurements >MDC | | | 107 |
| Number of Measurements Above 50% DCGL | | | 0 |
| Number of Measurements Above DCGL | | | 0 |
| Mean | | | 0.0219 |
| Median | | | 0.0147 |
| Standard Deviation | | | 0.0272 |
| Maximum | | | 0.1842 |
| Minimum | | | 0.0028 |
| Survey Technician(s) | STOCK | | |
| | | | |
| | | | |
| | | | |
| | | | |
| Survey Unit Classification | | | 1 |
| TBD 06-004 Piping Group | | | 3.1 |
| SR-13 Radionuclide Distribution Sample | | | EP 3-6 |
| Measured Nuclide | | | Cs-137 |
| Area Factor/EMC Used | | | No |
| Pass/Fail FSS | | | Pass |
| MREM/YR Contribution | | | <1 |
| | | | |
| COMMENTS: | | | |
| ACTIVITY VALUES NOT BACKGROUND CORRECTED | | | |
| | | | |
| RP Engineer Date | | 8-26-07 | |

EP FH-102
4" Pipe
TBD 06-004 Group 3.1

| Measurement # | gcpm | ncpm | Cs-137 activity (total dpm) | Cs-137 activity (dpm/100cm2) | Co-60 activity (dpm/100cm2) | Eu-152 activity (dpm/100cm2) | Eu-154 activity (dpm/100cm2) | Nb-94 activity (dpm/100cm2) | Ag-108m activity (dpm/100cm2) | Unity |
|---------------|------|------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|---------------------------------|--------------------------------|----------------------------------|-------|
| 1 | 18 | 18 | 94,737 | 9,738 | 1,067 | - | 68 | - | - | 0.007 |
| 2 | 19 | 19 | 100,000 | 10,279 | 1,126 | - | 72 | - | - | 0.008 |
| 3 | 18 | 18 | 94,737 | 9,738 | 1,067 | - | 68 | - | - | 0.007 |
| 4 | 7 | 7 | 36,842 | 3,787 | 415 | - | 27 | - | - | 0.003 |
| 5 | 17 | 17 | 89,474 | 9,197 | 1,008 | - | 65 | - | - | 0.007 |
| 6 | 17 | 17 | 89,474 | 9,197 | 1,008 | - | 65 | - | - | 0.007 |
| 7 | 20 | 20 | 105,263 | 10,820 | 1,185 | - | 76 | - | - | 0.008 |
| 8 | 19 | 19 | 100,000 | 10,279 | 1,126 | - | 72 | - | - | 0.008 |
| 9 | 29 | 29 | 152,632 | 15,689 | 1,719 | - | 110 | - | - | 0.011 |
| 10 | 22 | 22 | 115,789 | 11,902 | 1,304 | - | 84 | - | - | 0.009 |
| 11 | 17 | 17 | 89,474 | 9,197 | 1,008 | - | 65 | - | - | 0.007 |
| 12 | 34 | 34 | 178,947 | 18,394 | 2,015 | - | 129 | - | - | 0.013 |
| 13 | 23 | 23 | 121,053 | 12,443 | 1,363 | - | 87 | - | - | 0.009 |
| 14 | 31 | 31 | 163,158 | 16,771 | 1,837 | - | 118 | - | - | 0.012 |
| 15 | 27 | 27 | 142,105 | 14,607 | 1,600 | - | 103 | - | - | 0.011 |
| 16 | 30 | 30 | 157,895 | 16,230 | 1,778 | - | 114 | - | - | 0.012 |
| 17 | 54 | 54 | 284,211 | 29,213 | 3,200 | - | 205 | - | - | 0.021 |
| 18 | 33 | 33 | 173,684 | 17,853 | 1,956 | - | 125 | - | - | 0.013 |
| 19 | 25 | 25 | 131,579 | 13,525 | 1,482 | - | 95 | - | - | 0.010 |
| 20 | 18 | 18 | 94,737 | 9,738 | 1,067 | - | 68 | - | - | 0.007 |
| 21 | 17 | 17 | 89,474 | 9,197 | 1,008 | - | 65 | - | - | 0.007 |
| 22 | 28 | 28 | 147,368 | 15,148 | 1,659 | - | 106 | - | - | 0.011 |
| 23 | 24 | 24 | 126,316 | 12,984 | 1,422 | - | 91 | - | - | 0.010 |
| 24 | 27 | 27 | 142,105 | 14,607 | 1,600 | - | 103 | - | - | 0.011 |
| 25 | 18 | 18 | 94,737 | 9,738 | 1,067 | - | 68 | - | - | 0.007 |
| 26 | 23 | 23 | 121,053 | 12,443 | 1,363 | - | 87 | - | - | 0.009 |
| 27 | 27 | 27 | 142,105 | 14,607 | 1,600 | - | 103 | - | - | 0.011 |
| 28 | 18 | 18 | 94,737 | 9,738 | 1,067 | - | 68 | - | - | 0.007 |
| 29 | 23 | 23 | 121,053 | 12,443 | 1,363 | - | 87 | - | - | 0.009 |
| 30 | 19 | 19 | 100,000 | 10,279 | 1,126 | - | 72 | - | - | 0.008 |
| 31 | 22 | 22 | 115,789 | 11,902 | 1,304 | - | 84 | - | - | 0.009 |
| 32 | 54 | 54 | 284,211 | 29,213 | 3,200 | - | 205 | - | - | 0.021 |

EP FH-102
4" Pipe
TBD 06-004 Group 3.1

| Measurement # | gcpm | ncpm | Cs-137 activity (total dpm) | Cs-137 activity (dpm/100cm2) | Co-60 activity (dpm/100cm2) | Eu-152 activity (dpm/100cm2) | Eu-154 activity (dpm/100cm2) | Nb-94 activity (dpm/100cm2) | Ag-108m activity (dpm/100cm2) | Unity |
|---------------|------|------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|---------------------------------|--------------------------------|----------------------------------|-------|
| 33 | 21 | 21 | 110,526 | 11,361 | 1,245 | - | 80 | - | - | 0.008 |
| 34 | 25 | 25 | 131,579 | 13,525 | 1,482 | - | 95 | - | - | 0.010 |
| 35 | 31 | 31 | 163,158 | 16,771 | 1,837 | - | 118 | - | - | 0.012 |
| 36 | 36 | 36 | 189,474 | 19,476 | 2,134 | - | 137 | - | - | 0.014 |
| 37 | 29 | 29 | 152,632 | 15,689 | 1,719 | - | 110 | - | - | 0.011 |
| 38 | 36 | 36 | 189,474 | 19,476 | 2,134 | - | 137 | - | - | 0.014 |
| 39 | 32 | 32 | 168,421 | 17,312 | 1,897 | - | 122 | - | - | 0.013 |
| 40 | 31 | 31 | 163,158 | 16,771 | 1,837 | - | 118 | - | - | 0.012 |
| 41 | 20 | 20 | 105,263 | 10,820 | 1,185 | - | 76 | - | - | 0.008 |
| 42 | 22 | 22 | 115,789 | 11,902 | 1,304 | - | 84 | - | - | 0.009 |
| 43 | 16 | 16 | 84,211 | 8,656 | 948 | - | 61 | - | - | 0.006 |
| 44 | 28 | 28 | 147,368 | 15,148 | 1,659 | - | 106 | - | - | 0.011 |
| 45 | 29 | 29 | 152,632 | 15,689 | 1,719 | - | 110 | - | - | 0.011 |
| 46 | 453 | 453 | 2,384,211 | 245,068 | 26,847 | - | 1,720 | - | - | 0.179 |
| 47 | 222 | 222 | 1,168,421 | 120,099 | 13,157 | - | 843 | - | - | 0.088 |
| 48 | 92 | 92 | 484,211 | 49,771 | 5,452 | - | 349 | - | - | 0.036 |
| 49 | 121 | 121 | 636,842 | 65,460 | 7,171 | - | 459 | - | - | 0.048 |
| 50 | 116 | 116 | 610,526 | 62,755 | 6,875 | - | 440 | - | - | 0.046 |
| 51 | 44 | 44 | 231,579 | 23,803 | 2,608 | - | 167 | - | - | 0.017 |
| 52 | 49 | 49 | 257,895 | 26,508 | 2,904 | - | 186 | - | - | 0.019 |
| 53 | 36 | 36 | 189,474 | 19,476 | 2,134 | - | 137 | - | - | 0.014 |
| 54 | 37 | 37 | 194,737 | 20,017 | 2,193 | - | 141 | - | - | 0.015 |
| 55 | 44 | 44 | 231,579 | 23,803 | 2,608 | - | 167 | - | - | 0.017 |
| 56 | 55 | 55 | 289,474 | 29,754 | 3,260 | - | 209 | - | - | 0.022 |
| 57 | 32 | 32 | 168,421 | 17,312 | 1,897 | - | 122 | - | - | 0.013 |
| 58 | 41 | 41 | 215,789 | 22,181 | 2,430 | - | 156 | - | - | 0.016 |
| 59 | 45 | 45 | 236,842 | 24,344 | 2,667 | - | 171 | - | - | 0.018 |
| 60 | 46 | 46 | 242,105 | 24,885 | 2,726 | - | 175 | - | - | 0.018 |
| 61 | 44 | 44 | 231,579 | 23,803 | 2,608 | - | 167 | - | - | 0.017 |
| 62 | 31 | 31 | 163,158 | 16,771 | 1,837 | - | 118 | - | - | 0.012 |
| 63 | 27 | 27 | 142,105 | 14,607 | 1,600 | - | 103 | - | - | 0.011 |

EP FH-102
4" Pipe
TBD 06-004 Group 3.1

| Measurement # | gcpm | ncpm | Cs-137 activity (total dpm) | Cs-137 activity (dpm/100cm2) | Co-60 activity (dpm/100cm2) | Eu-152 activity (dpm/100cm2) | Eu-154 activity (dpm/100cm2) | Nb-94 activity (dpm/100cm2) | Ag-108m activity (dpm/100cm2) | Unity |
|---------------|------|------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|---------------------------------|--------------------------------|----------------------------------|-------|
| 64 | 24 | 24 | 126,316 | 12,984 | 1,422 | - | 91 | - | - | 0.010 |
| 65 | 37 | 37 | 194,737 | 20,017 | 2,193 | - | 141 | - | - | 0.015 |
| 66 | 38 | 38 | 200,000 | 20,558 | 2,252 | - | 144 | - | - | 0.015 |
| 67 | 28 | 28 | 147,368 | 15,148 | 1,659 | - | 106 | - | - | 0.011 |
| 68 | 27 | 27 | 142,105 | 14,607 | 1,600 | - | 103 | - | - | 0.011 |
| 69 | 33 | 33 | 173,684 | 17,853 | 1,956 | - | 125 | - | - | 0.013 |
| 70 | 34 | 34 | 178,947 | 18,394 | 2,015 | - | 129 | - | - | 0.013 |
| 71 | 41 | 41 | 215,789 | 22,181 | 2,430 | - | 156 | - | - | 0.016 |
| 72 | 42 | 42 | 221,053 | 22,722 | 2,489 | - | 159 | - | - | 0.017 |
| 73 | 37 | 37 | 194,737 | 20,017 | 2,193 | - | 141 | - | - | 0.015 |
| 74 | 33 | 33 | 173,684 | 17,853 | 1,956 | - | 125 | - | - | 0.013 |
| 75 | 44 | 44 | 231,579 | 23,803 | 2,608 | - | 167 | - | - | 0.017 |
| 76 | 46 | 46 | 242,105 | 24,885 | 2,726 | - | 175 | - | - | 0.018 |
| 77 | 320 | 320 | 1,684,211 | 173,116 | 18,965 | - | 1,215 | - | - | 0.127 |
| 78 | 100 | 100 | 526,316 | 54,099 | 5,927 | - | 380 | - | - | 0.040 |
| 79 | 67 | 67 | 352,632 | 36,246 | 3,971 | - | 254 | - | - | 0.027 |
| 80 | 465 | 465 | 2,447,368 | 251,560 | 27,559 | - | 1,766 | - | - | 0.184 |
| 81 | 58 | 58 | 305,263 | 31,377 | 3,437 | - | 220 | - | - | 0.023 |
| 82 | 29 | 29 | 152,632 | 15,689 | 1,719 | - | 110 | - | - | 0.011 |
| 83 | 41 | 41 | 215,789 | 22,181 | 2,430 | - | 156 | - | - | 0.016 |
| 84 | 36 | 36 | 189,474 | 19,476 | 2,134 | - | 137 | - | - | 0.014 |
| 85 | 39 | 39 | 205,263 | 21,099 | 2,311 | - | 148 | - | - | 0.015 |
| 86 | 46 | 46 | 242,105 | 24,885 | 2,726 | - | 175 | - | - | 0.018 |
| 87 | 59 | 59 | 310,526 | 31,918 | 3,497 | - | 224 | - | - | 0.023 |
| 88 | 51 | 51 | 268,421 | 27,590 | 3,023 | - | 194 | - | - | 0.020 |
| 89 | 52 | 52 | 273,684 | 28,131 | 3,082 | - | 197 | - | - | 0.021 |
| 90 | 44 | 44 | 231,579 | 23,803 | 2,608 | - | 167 | - | - | 0.017 |
| 91 | 63 | 63 | 331,579 | 34,082 | 3,734 | - | 239 | - | - | 0.025 |
| 92 | 76 | 76 | 400,000 | 41,115 | 4,504 | - | 289 | - | - | 0.030 |
| 93 | 47 | 47 | 247,368 | 25,426 | 2,785 | - | 178 | - | - | 0.019 |
| 94 | 39 | 39 | 205,263 | 21,099 | 2,311 | - | 148 | - | - | 0.015 |

EP FH-102
4" Pipe
TBD 06-004 Group 3.1

| Measurement # | gcpm | ncpm | Cs-137 activity (total dpm) | Cs-137 activity (dpm/100cm2) | Co-60 activity (dpm/100cm2) | Eu-152 activity (dpm/100cm2) | Eu-154 activity (dpm/100cm2) | Nb-94 activity (dpm/100cm2) | Ag-108m activity (dpm/100cm2) | Unity |
|---------------|------|------|--------------------------------|---------------------------------|--------------------------------|---------------------------------|---------------------------------|--------------------------------|----------------------------------|-------|
| 95 | 54 | 54 | 284,211 | 29,213 | 3,200 | - | 205 | - | - | 0.021 |
| 96 | 45 | 45 | 236,842 | 24,344 | 2,667 | - | 171 | - | - | 0.018 |
| 97 | 79 | 79 | 415,789 | 42,738 | 4,682 | - | 300 | - | - | 0.031 |
| 98 | 73 | 73 | 384,211 | 39,492 | 4,326 | - | 277 | - | - | 0.029 |
| 99 | 62 | 62 | 326,316 | 33,541 | 3,674 | - | 235 | - | - | 0.025 |
| 100 | 207 | 207 | 1,089,474 | 111,985 | 12,268 | - | 786 | - | - | 0.082 |
| 101 | 72 | 72 | 378,947 | 38,951 | 4,267 | - | 273 | - | - | 0.029 |
| 102 | 96 | 96 | 505,263 | 51,935 | 5,690 | - | 365 | - | - | 0.038 |
| 103 | 50 | 50 | 263,158 | 27,049 | 2,963 | - | 190 | - | - | 0.020 |
| 104 | 80 | 80 | 421,053 | 43,279 | 4,741 | - | 304 | - | - | 0.032 |
| 105 | 46 | 46 | 242,105 | 24,885 | 2,726 | - | 175 | - | - | 0.018 |
| 106 | 56 | 56 | 294,737 | 30,295 | 3,319 | - | 213 | - | - | 0.022 |
| 107 | 42 | 42 | 221,053 | 22,722 | 2,489 | - | 159 | - | - | 0.017 |
| 108 | 60 | 60 | 315,789 | 32,459 | 3,556 | - | 228 | - | - | 0.024 |
| 109 | 85 | 85 | 447,368 | 45,984 | 5,038 | - | 323 | - | - | 0.034 |
| 110 | 107 | 107 | 563,158 | 57,886 | 6,341 | - | 406 | - | - | 0.042 |
| 111 | 115 | 115 | 605,263 | 62,214 | 6,816 | - | 437 | - | - | 0.046 |
| 112 | 90 | 90 | 473,684 | 48,689 | 5,334 | - | 342 | - | - | 0.036 |
| 113 | 55 | 55 | 289,474 | 29,754 | 3,260 | - | 209 | - | - | 0.022 |
| | | | | | | | | | | |
| | | | | | | | | | MEAN | 0.022 |
| | | | | | | | | | MEDIAN | 0.015 |
| | | | | | | | | | STD DEV | 0.027 |
| | | | | | | | | | MAX | 0.184 |
| | | | | | | | | | MIN | 0.003 |

SECTION 7
ATTACHMENT 2
8 **PAGE(S)**

Pipe Interior Radiological Survey Form

Date: 11/02/06 Time: 0813
 Pipe ID#: FH-102 Pipe Diameter: 4" Access Point Area: FH-1
 Building: FAN HOUSE Elevation: -12' System: FLR. DRN.

Type of Survey Investigation Characterization Final Survey Other
 Gross Co60 Cs
 Detector ID# / Sled ID# 44-159 #238369 / 101
 Detector Cal Date: 9/5/06 Detector Cal Due Date: 9/5/07
 Instrument: 2350-1 Instrument ID #: 203488
 Instrument Cal Date: 7/5/06 Instrument Cal Due Date: 7/5/07

From the Daily Pipe Survey Detector Control Form for the Selected Detector

Background Value 5.1 cpm
 MDCR_{static} 10.8 cpm
 Efficiency Factor for Pipe Diameter 0.00019 (from detector efficiency determination)
 MDC_{static} 9453 dpm/ 100 cm²
 Is the MDC_{static} acceptable? Yes No (if no, adjust sample count time and recalculate MDCR_{static})
 Comments: POST HYDRO RESURVEY PARTIAL
POSITION # 1 IS THE DROP.
EP3-6

Technician Signature 

Pipe Interior Radiological Survey

| Position # | Feet into Pipe from Opening | Count Time (min) | Gross Counts | Gross cpm | Net cpm | dpm/100cm ² |
|------------|-----------------------------|------------------|--------------|-----------|---------|------------------------|
| 1 | 1 | 1 | 18 | 18 | n/a | n/a |
| 2 | 2 | ↓ | 19 | 19 | ↓ | ↓ |
| 3 | 3 | | 18 | 18 | | |
| 4 | 4 | | 7 | 7 | | |
| 5 | 5 | | 17 | 17 | | |
| 6 | 6 | | 17 | 17 | | |
| 7 | 7 | | 20 | 20 | | |
| 8 | 8 | | 19 | 19 | | |
| 9 | 9 | | 29 | 29 | | |
| 10 | 10 | | 22 | 22 | | |

Pipe Interior Radiological Survey Form (Continuation Form)

Date: 11/02/06
 Pipe ID#: FH-102 Pipe Diameter: 4" Access Point Area: FH-1
 Building: FAN HOUSE Elevation: -12' System: PLR DRNS

| Position # | Feet into Pipe from Opening | Count Time (min) | Gross Counts | Gross cpm | Net cpm | dpm/100cm ² | | | |
|---------------|-----------------------------|------------------|--------------|-----------|---------|------------------------|----|---|---|
| 11 | 11 | ↑ | 17 | 17 | n/a | n/a | | | |
| 12 | 12 | ↓ | 34 | 34 | ↓ | ↓ | | | |
| 13 | 13 | | 23 | 23 | | | | | |
| 14 | 14 | | 31 | 31 | | | | | |
| 15 | 15 | | 27 | 27 | | | | | |
| 16 | 16 | | 30 | 30 | | | | | |
| 17 | 17 | | 54 | 54 | | | | | |
| 18 | 18 | | 33 | 33 | | | | | |
| 19 | 19 | | 25 | 25 | | | | | |
| 20 | 20 | | 18 | 18 | | | | | |
| 21 | 21 | | 17 | 17 | | | | | |
| 22 | 22 | | 28 | 28 | | | | | |
| 23 | 23 | | 24 | 24 | | | | | |
| 24 | 24 | | 27 | 27 | | | | | |
| 25 | 25 | | 18 | 18 | | | | | |
| 26 | 26 | | 23 | 23 | | | | | |
| 27 | 27 | | 27 | 27 | | | | | |
| 28 | 28 | | 18 | 18 | | | | | |
| 29 | 29 | | 23 | 23 | | | | | |
| 30 | 30 | | 19 | 19 | | | | | |
| 31 | 31 | | 22 | 22 | | | | | |
| 32 | 32 | | 54 | 54 | | | | | |
| 33 | 33 | | 21 | 21 | | | | | |
| 34 | 34 | | 25 | 25 | | | | | |
| 35 | 35 | | 31 | 31 | | | | | |
| 36 | 36 | | 36 | 36 | | | | | |
| 37 | 37 | | 29 | 29 | | | | | |
| 38 | 38 | | 36 | 36 | | | | | |
| 39 | 39 | | 32 | 32 | | | | | |
| 40 | 40 | | 31 | 31 | | | | | |
| 41 | 41 | | ↓ | 20 | | | 20 | ↓ | ↓ |
| | | | | N | | | | | |
| | | | | A | | | | | |

Pipe Interior Radiological Survey Form

Date: 11/02/06 Time: 1054
 Pipe ID#: FH-102 Pipe Diameter: 4" Access Point Area: FH-2
 Building: FAU HOUSE Elevation: -12' System: PLR DRN

Type of Survey Investigation Characterization Final Survey Other
 Gross Co60 Cs

Detector ID# / Sled ID# 44-159 238369 1 101
 Detector Cal Date: 9/5/06 Detector Cal Due Date: 9/5/07
 Instrument: 2350-1 Instrument ID #: 203488
 Instrument Cal Date: 7/5/06 Instrument Cal Due Date: 7/5/07

From the Daily Pipe Survey Detector Control Form for the Selected Detector

Background Value 5.1 cpm
 MDCR_{static} 10.8 cpm
 Efficiency Factor for Pipe Diameter 0.00019 (from detector efficiency determination)
 MDC_{static} 9453 dpm/ 100 cm²
 Is the MDC_{static} acceptable? Yes No (if no, adjust sample count time and recalculate MDCR_{static})
 Comments: POST HYDRO RESURVEY EP3-6 PARTIAL

POSITION # 4 IS THE PROP

Technician Signature 

Pipe Interior Radiological Survey

| Position # | Feet into Pipe from Opening | Count Time (min) | Gross Counts | Gross cpm | Net cpm | dpm/100cm ² |
|------------|-----------------------------|------------------|--------------|-----------|---------|------------------------|
| 1 | 1 | 1 | 22 | 22 | n/a | n/a |
| 2 | 2 | 1 | 16 | 16 | ↓ | ↓ |
| 3 | 3 | 1 | 28 | 28 | | |
| 4 | 1 | 1 | 29 | 29 | | |
| 5 | | | | | | |
| 6 | | | | | | |
| 7 | | | N | | | |
| 8 | | | | | | |
| 9 | | | | A | | |
| 10 | | | | | | |

Pipe Interior Radiological Survey Form

Date: 11/02/06 Time: 1104
 Pipe ID#: FH-102 Pipe Diameter: 4" Access Point Area: FH-3
 Building: FAN HOUSE Elevation: -12' System: FLR DRN

Type of Survey Investigation Characterization Final Survey Other

Gross Co60 Cs

Detector ID# / Sled ID# 44-159 # 238369 / 101

Detector Cal Date: 9/5/06 Detector Cal Due Date: 9/5/07

Instrument: 2350-1 Instrument ID #: 203488

Instrument Cal Date: 7/5/06 Instrument Cal Due Date: 7/5/07

From the Daily Pipe Survey Detector Control Form for the Selected Detector

Background Value 5.1 cpm

MDCR_{static} 10.8 cpm

Efficiency Factor for Pipe Diameter 0.00019 (from detector efficiency determination)

MDC_{static} 9453 dpm/ 100 cm²

Is the MDC_{static} acceptable? Yes No (if no, adjust sample count time and recalculate MDC_{static})

Comments: POST HYDRO RESURVEY EP3-6 PARTIAL
POSITION # 32 IS THE DROP.

Technician Signature [Signature]

Pipe Interior Radiological Survey

| Position # | Feet into Pipe from Opening | Count Time (min) | Gross Counts | Gross cpm | Net cpm | dpm/100cm ² |
|------------|-----------------------------|------------------|--------------|-----------|---------|------------------------|
| 1 | 1 | ↓ | 453 | 453 | nia | nia |
| 2 | 2 | ↓ | 222 | 222 | ↓ | ↓ |
| 3 | 3 | ↓ | 92 | 92 | ↓ | ↓ |
| 4 | 4 | ↓ | 121 | 121 | ↓ | ↓ |
| 5 | 5 | ↓ | 116 | 116 | ↓ | ↓ |
| 6 | 6 | ↓ | 44 | 44 | ↓ | ↓ |
| 7 | 7 | ↓ | 49 | 49 | ↓ | ↓ |
| 8 | 8 | ↓ | 36 | 36 | ↓ | ↓ |
| 9 | 9 | ↓ | 37 | 37 | ↓ | ↓ |
| 10 | 10 | ↓ | 44 | 44 | ↓ | ↓ |

Pipe Interior Radiological Survey Form (Continuation Form)

Date: 11/02/06
 Pipe ID#: FH-102 Pipe Diameter: 4" Access Point Area: FH-3
 Building: FAN HOUSE Elevation: -12' System: FLR DRN

| Position # | Feet into Pipe from Opening | Count Time (min) | Gross Counts | Gross cpm | Net cpm | dpm/100cm ² | | | |
|------------|-----------------------------|------------------|--------------|-----------|---------|------------------------|-----|---|---|
| 11 | 11 | 1 | 55 | 55 | n/a | n/a | | | |
| 12 | 12 | ↓ | 32 | 32 | ↓ | ↓ | | | |
| 13 | 13 | | 41 | 41 | | | | | |
| 14 | 14 | | 45 | 45 | | | | | |
| 15 | 15 | | 46 | 46 | | | | | |
| 16 | 16 | | 44 | 44 | | | | | |
| 17 | 17 | | 31 | 31 | | | | | |
| 18 | 18 | | 27 | 27 | | | | | |
| 19 | 19 | | 24 | 24 | | | | | |
| 20 | 20 | | 37 | 37 | | | | | |
| 21 | 21 | | 38 | 38 | | | | | |
| 22 | 22 | | 28 | 28 | | | | | |
| 23 | 23 | | 27 | 27 | | | | | |
| 24 | 24 | | 33 | 33 | | | | | |
| 25 | 25 | | 34 | 34 | | | | | |
| 26 | 26 | | 41 | 41 | | | | | |
| 27 | 27 | | 42 | 42 | | | | | |
| 28 | 28 | | 37 | 37 | | | | | |
| 29 | 29 | | 33 | 33 | | | | | |
| 30 | 30 | | 44 | 44 | | | | | |
| 31 | 31 | | 1 | 46 | | | 46 | ↓ | ↓ |
| 32 | 1 | | 1 | 320 | | | 320 | | |
| N A | | | | | | | | | |

Pipe Interior Radiological Survey Form

Date: 11/02/06 Time: 1345
 Pipe ID#: FH-102 Pipe Diameter: 4" Access Point Area: FH-4
 Building: FAN HOUSE Elevation: -12' System: FLR DRN

Type of Survey Investigation Characterization Final Survey Other
 Gross Co60 Cs

Detector ID# / Sled ID# 44159 238369 1 101
 Detector Cal Date: 9/5/06 Detector Cal Due Date: 9/5/07
 Instrument: 2350-1 Instrument ID #: 203488
 Instrument Cal Date: 7/5/06 Instrument Cal Due Date: 7/5/07

From the Daily Pipe Survey Detector Control Form for the Selected Detector

Background Value 5.1 cpm
 MDCR_{static} 10.8 cpm
 Efficiency Factor for Pipe Diameter 0.00019 (from detector efficiency determination)
 MDC_{static} 9453 dpm/ 100 cm²
 Is the MDC_{static} acceptable? Yes No (if no, adjust sample count time and recalculate MDC_{static})
 Comments: POST HYDRO RESURVEY EP3-6 POSITION # 36 IS THE DROP COMPLETE

Technician Signature [Signature]

Pipe Interior Radiological Survey

| Position # | Feet into Pipe from Opening | Count Time (min) | Gross Counts | Gross cpm | Net cpm | dpm/100cm ² |
|------------|-----------------------------|------------------|--------------|-----------|---------|------------------------|
| 1 | 1 | 1 | 100 | 100 | n/a | n/a |
| 2 | 2 | ↓ | 67 | 67 | ↓ | ↓ |
| 3 | 3 | | 465 | 465 | | |
| 4 | 4 | | 58 | 58 | | |
| 5 | 5 | | 29 | 29 | | |
| 6 | 6 | | 41 | 41 | | |
| 7 | 7 | | 36 | 36 | | |
| 8 | 8 | | 39 | 39 | | |
| 9 | 9 | | 46 | 46 | | |
| 10 | 10 | | 59 | 59 | | |



SECTION 7
ATTACHMENT 3
___ / ___ PAGE(S)

DQA Check Sheet

| | | | | |
|---------------|-----------|------------|----------|--|
| Design # | EP FH-102 | Revision # | Original | |
| Survey Unit # | EP FH-102 | | | |

Preliminary Data Review

| Answers to the following questions should be fully documented in the Survey Unit Release Record | Yes | No | N/A |
|--|-----|----|-----|
| 1. Have surveys been performed in accordance with survey instructions in the Survey Design? | X | | |
| 2. Is the instrumentation MDC for structure static measurements below the DCGL _w for Class 1 and 2 survey units, or below 0.5 DCGL _w for Class 3 survey units? | | | X |
| 3. Is the instrumentation MDC for embedded/buried piping static measurements below the DCGL _w ? | X | | |
| 4. Was the instrumentation MDC for structure scan measurements, soil scan measurements, and embedded/buried piping scan measurements below the DCGL _w , or, if not, was the need for additional static measurements or soil samples addressed in the survey design? | | | X |
| 5. Was the instrumentation MDC for volumetric measurements and smear analysis < 10% DCGL _w ? | | | X |
| 6. Were the MDCs and assumptions used to develop them appropriate for the instruments and techniques used to perform the survey? | X | | |
| 7. Were the survey methods used to collect data proper for the types of radiation involved and for the media being surveyed? | X | | |
| 8. Were "Special Methods" for data collection properly applied for the survey unit under review? | X | | |
| 9. Is the data set comprised of qualified measurement results collected in accordance with the survey design, which accurately reflects the radiological status of the facility? | x | | |

Graphical Data Review

| | | | |
|--|--|--|---|
| 1. Has a posting plot been created? | | | X |
| 2. Has a histogram (or other frequency plot) been created? | | | X |
| 3. Have other graphical data tools been created to assist in analyzing the data? | | | X |

Data Analysis

| | | | |
|--|---|--|---|
| 1. Are all sample measurements below the DCGL _w (Class 1 & 2), or 0.5 DCGL _w (Class 3)? | X | | |
| 2. Is the mean of the sample data < DCGL _w ? | X | | |
| 3. If elevated areas have been identified by scans and/or sampling, is the average activity in each elevated area < DCGL _{EMC} (Class 1), < DCGL _w (Class 2), or <0.5 DCGL _w (Class 3)? | | | X |
| 4. Is the result of the Elevated Measurements Test < 1.0? | | | X |
| 5. Is the result of the statistical test (<i>S</i> + for Sign Test or <i>W</i> , for WRS Test) ≥ the critical value? | | | X |

Comments:

| | | | |
|--|---------------------|------|----------|
| FSS/Characterization Engineer (print/sign) | <i>Dale Randall</i> | Date | 8-26-07 |
| FSS/ Characterization Manager (print/sign) | R. Case | Date | 10/30/07 |

Form
CS-09/2
Rev 0

**SECTION 7
ATTACHMENT 4
1 DISC**