

September 18, 1974



Mr. Norman C. Moseley, Director
Directorate of Regulatory Operations
U.S. Atomic Energy Commission
Region II - Suite 818
230 Peachtree Street, NW.
Atlanta, Georgia 30303

Dear Mr. Moseley:

This is in further response to Directorate of Regulatory Operations Bulletin No. 74-6 transmitted by your May 30, 1974, letter RO:II:NCM 50-327, -328, -390, and -391. To ensure that Westinghouse type W-2 switches being procured for Watts Bar Nuclear Plant do not contain the defect described in DRO Bulletin 74-6, switches and repair kits to be shipped directly from Westinghouse to the site will be inspected before shipment. Westinghouse W-2 switches and repair kits being shipped from sources other than Westinghouse will be inspected upon receipt at the site. The inspection will be documented.

Very truly yours,

A handwritten signature in cursive script, appearing to read "J. E. Gilleland".

J. E. Gilleland
Assistant to the Manager of Power

SEP 30 1974


Letter from Tennessee Valley Authority, J. E. Gilleland, dated
September 18, 1974 - ROB 74-6 - 50-390 and 50-391

DISTRIBUTION:

H. D. Thornburg

RO:HQ (4)

Directorate of Licensing (4)

DR Central Files 

PDR

Local PDR

NSIC

TIC

Chief, Regulatory News Branch

A. J.
2