



FPL Energy.

Duane Arnold Energy Center

FPL Energy Duane Arnold, LLC
3277 DAEC Road
Palo, Iowa 52324

November 7, 2007

NG-07-0809
10 CFR 50.55a

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555-0001

Duane Arnold Energy Center
Docket 50-331
License No. DPR-49

Response to Request for Additional Information Related to the Relief Request for 3rd
Period Limited Weld Examinations

- References:
1. Letter, Gary Van Middlesworth (FPL Energy Duane Arnold) to Document Control Desk (USNRC) Relief Request for 3rd Period Limited Weld Examinations, dated May 18, 2007 (ML071510076)
 2. Letter, Karl D. Feintuch (USNRC) to Richard L Anderson (FPL Energy Duane Arnold), Duane Arnold Energy Center - Request for Additional Information Re: Relief Request from American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI, Rules for Inservice Inspection of Nuclear Power Components, 1998 Edition, Subsection IWB, Subarticle IWB-2500, "Examination and Pressure Test Requirements," and Subsection IWC, Subarticle IWC-2500, "Examination and Pressure Test Requirements," to Allow Performance of Limited Examinations of Various Welds (TAC No. MD5669), dated October 31, 2007 (ML072820132)

Reference 1 provided a request for relief from IWB-2500 and IWC-2500 to allow performance of limited examinations of various welds.

By letter dated October 31, 2007 (Reference 2), the Staff issued a request for additional information regarding Reference 1. The response to the requests of Reference 2 is provided in Enclosure 1 of this letter.

FPL Energy Duane Arnold requests approval of the request of Reference 1 by the end of May 2008.


This letter contains no new commitments nor revises any previous commitments.

AOY

LIR

NG-07-0809
November 7, 2007
Page 2 of 2

If you have any questions, please contact Steve Catron at (319) 851-7234.

A handwritten signature in black ink, reading "Richard L. Anderson". The signature is fluid and cursive, with the first name "Richard" and last name "Anderson" clearly legible.

Richard L. Anderson
Vice President, Duane Arnold Energy Center
FPL Energy Duane Arnold, LLC

Enclosures

cc: Administrator, Region III, USNRC
Project Manager, DAEC, USNRC
Senior Resident Inspector, DAEC, USNRC

Enclosure 1

**Response to Request for Additional Information (RAI) Related to the Relief
Request for 3rd Period Limited Weld Examinations**

**Response to Request for Additional Information (RAI) Related to the Relief
Request for 3rd Period Limited Weld Examinations**

**2.1 Request for Relief, Examination Category B-D, Item B3.90, Full
Penetration Welded Nozzles in Vessels**

The licensee previously proposed an alternative, which was approved by Safety Evaluation Report (SER) dated October 6, 2004 (ADAMS accession number ML042380089), to use ASME Code Case N-613-1, which limits the examination volume of Examination Category B-D welds to the weld and 1/2-inch of adjacent base material on each side, in lieu of the ASME Code-required examination volume of the weld and 1/2-T of adjacent base material, where T is the vessel thickness. The current request for relief indicates that achieving greater than 90% (of the volume approved by the October 6, 2004 SER) could not be accomplished for the subject reactor pressure vessel (RPV) nozzle-to-vessel welds.

- 2.1.1** *Please re-calculate and report the volumetric coverage(s) obtained for the subject Examination Category B-D nozzle-to-vessel welds with respect to ASME Code requirements, i.e., calculate the coverage when the volume required is the weld and 1/2-T of adjacent base material, where T is the vessel wall thickness.*

FPL Energy Duane Arnold Response:

The following Table provides the recalculated percentages

Component Number	Recalculated Coverage	Description
MSC-D001	56.83%	Main Steam Nozzle to Vessel Weld
MSD-D001	56.83%	Main Steam Nozzle to Vessel Weld
FWB-D001	56.71%	Feedwater Nozzle to Vessel Weld
FWC-D001	56.71%	Feedwater Nozzle to Vessel Weld
FWD-D001	56.71%	Feedwater Nozzle to Vessel Weld
RRG-D001	53.73%	Recirculation Riser Nozzle to Vessel Weld
JPB-D001	53.49%	Jet Pump Instrumentation Nozzle to Vessel Weld
LCA-D001	50.72%	Standby Liquid Control Nozzle to Vessel Weld
VIB-D001	57.45%	Vessel Instrumentation Nozzle to Vessel Weld

2.1.2 *The licensee stated that the subject nozzle-to-vessel welds are accessible from the vessel side of the RPV, but examinations cannot be performed from the nozzle side due to forging curvature. It is also stated that certain nozzle-to-vessel weld examinations are additionally limited by RPV design obstructions. However, these statements do not provide adequate descriptive information and technical discussion to support a determination of impracticality and that the required examinations have been performed to the maximum extent possible at DAEC.*

- a. *Provide a detailed description of examination limitations including access requirements for automated or manual ultrasonic techniques employed, and a description of each component geometry that restricts or limits examinations. The technical bases should include cross-sectional sketches of the weld indicating ultrasonic coverage(s) for each technique employed and details of the weld and base metal materials.*

FPL Energy Duane Arnold Response:

The examination of all nozzle-to-vessel welds is limited by the nozzle forging curvature. The configuration for each of the above mentioned nozzles is included for review in Enclosure 2.

For nozzle LCA-D001, the examination is additionally limited by the proximity of the weld attaching the skirt knuckle to the RPV bottom head. The distance from the bottom of LCA-D001 weld to the skirt is approximately six inches.

For nozzle JPB-D001, the examination is additionally limited due to an insulation bracket welded on the vessel. Removal of this bracket is not feasible due to the fact that it supports the lower ring of RPV insulation.

- b. *In addition, the licensee should submit argument(s) as to why the use of other inspection methods (such as phased array ultrasonic testing) would not reasonably increase the examination coverage(s).*

FPL Energy Duane Arnold Response:

As stated in Reference 1, the procedures used at DAEC incorporate examination techniques qualified under Appendix VIII of ASME Section XI Code by the Performance Demonstration Initiative (PDI) for examination of the nozzle-to-vessel shell welds. In addition, FPL Energy Duane Arnold contracted EPRI to computer model each nozzle-to-vessel weld and nozzle inner corner region to assist FPL Energy Duane Arnold in developing and qualifying ultrasonic techniques for these regions. At the time that these components were examined, the phased array technology had not been qualified by Performance Demonstration Initiative for examination of nozzle-

to-vessel welds or the nozzle inner corner region. With the computer modeling of the examination volume and the qualified PDI technique, the examinations were performed utilizing the latest technology.

- 2.1.3 *State the total number of Examination Category B-D welds at DAEC, and provide a listing of the volumetric coverage(s) completed for each of these welds. Report any unacceptable flaws detected during the examination of the welds.*

FPL Energy Duane Arnold Response:

The total number of Category B-D welds at the DAEC is 34 of which one is inaccessible due to the CRD array (the inaccessible nozzle is the bottom head drain). There have been no unacceptable flaws identified during the examinations of the listed welds. FPL Energy Duane Arnold has submitted three relief requests with Safety Evaluation Reports (SERs) dated October 18, 1999, March 7, 2001, and March 26, 2003. Below is a table with the accumulated percentages of nozzle to vessel welds from the above SERs.

List of Nozzle-to-Vessel Welds

Nozzle ID	Period Examined	Code Coverage*	Remarks
CRA-D001	1	61.3%	Control Rod Drive
CSA-D001	1	63%	Core Spray
CSB-D001	1	66%	Core Spray
FWA-D001	1	56.5%	Feedwater
HVA-D001	1	66.0%	Head Vent
HSB-D001	2	70.9%	Head Spare
JPA-D001	1	61.1%	Jet Pump
MSA-D001	1	59.6%	Main Steam
MSB-D001	2	63%	Main Steam
RHA-D001	1	65.7%	Head Spray
RCA-D001	2	59%	Recirculation Suction
RCB-D001	1	57%	Recirculation Suction
RRA-D001	1	63%	Recirculation Inlet
RRB-D001	1	63%	Recirculation Inlet
RRC-D001	1	63%	Recirculation Inlet
RRD-D001	1	51.4%	Recirculation Inlet
RRE-D001	1	64%	Recirculation Inlet
RRF-D001	2	73.36%	Recirculation Inlet
RRH-D001	1	64%	Recirculation Inlet
VIA-D001	2	86.2%	Vessel Instrumentation
VIC-D001	2	86.2%	Vessel Instrumentation
VID-D001	2	63%	Vessel Instrumentation
VIE-D001	1	66%	Vessel Instrumentation
VIF-D001	2	86.2%	Vessel Instrumentation

*Due to the nozzle design it is not feasible to effectively exam 100% of the required code volume as defined in Figure IWB-2500-7(b).

2.2 Request for Relief, Examination Category B-D, Item B3.100, Inner Radius Sections of Full Penetration Welded Nozzles in Vessels

2.2.1 *The licensee stated that the proximity of the RPV skirt weld obstructed access for performing the inner radius section examination on Standby Liquid Control Nozzle LCA-D001. However, this statement does not provide adequate descriptive information and technical discussion to support a determination of impracticality and that the required examination was performed to the maximum extent possible at DAEC.*

- a. *Provide a detailed description of examination limitations including access requirements for automated or manual ultrasonic techniques employed, and a description of the component geometry that restricts or limits the examination. The technical basis should include cross-sectional sketches of the inner radius section indicating ultrasonic coverage for each technique employed.*

FPL Energy Duane Arnold Response:

A description of examination limitations for performing the UT on the inner radius section on Standby Liquid Control Nozzle LCA-D001 is included for review as Enclosure 3. The configuration of the nozzle and a photo indicating the proximity of the nozzle to the skirt is also included for review. The request for additional information included a request for cross sectional sketches of the inner radius section. Since the limitation is due to the skirt welded to the vessel and not the configuration as it was on the nozzle-to-vessel welds discussed above, a cross-sectional view is not warranted. To clarify, the skirt limits the surface contact area of the transducer.

The manual ultrasonic techniques employed were as recommended in the EPRI modeling Report IR-2004-62. The techniques utilized were limited by the proximity of the weld attaching the Skirt Knuckle to the RPV bottom head. The supplied photo in Enclosure 3 shows that the nozzle is located close (approximately six inches) to the skirt weld.

- b. *In addition, the licensee should submit an argument as to why the use of other inspection methods (such as phased array ultrasonic testing) would not reasonably increase the examination coverage.*

FPL Energy Duane Arnold Response:

Please refer to the Section 2.1.2 b response. FPL Energy Duane Arnold used the latest PDI demonstrated procedure for the examination of the listed welds at the DAEC.

2.3 Request for Relief, Examination Category B-J, Item B9.11, Pressure Retaining Welds in Piping

2.3.1 *The licensee stated that Weld RBB-J001 is a branch connection of the recirculation bypass line to the recirculation discharge line, and that the weldolet side is not accessible for scanning due to geometry. However, this statement does not provide adequate descriptive information and technical discussion to support a determination of impracticality and that the required examination was performed to the maximum extent possible at DAEC.*

- a. Provide a detailed description of examination limitations including access requirements for automated or manual ultrasonic techniques employed, and a description of the component geometry that restricts or limits the examination. The technical basis should include cross-sectional sketches of the weld indicating ultrasonic coverage for each technique employed.*

FPL Energy Duane Arnold Response:

The weld RBB-J001 is a branch connection of the recirculation bypass line to the recirculation discharge line. The weldolet side of the weld is not accessible for scanning. The PDI qualified procedure is NOT qualified for "detection or length sizing of circumferentially oriented flaw indications when only single side access is available and the flaw is located on the far side of the weld." Because of this, only 50% coverage can be claimed. The examination of this weld is further limited by the existing weld crown. Included for review is Inservice Inspection Report I01070 in Enclosure 4.

- b. State the size, thickness and materials of construction of the subject weld.*

FPL Energy Duane Arnold Response:

The size of the weld is 4 inches, thickness 0.337 inches, and material is 304 stainless steel.

2.3.2 *The licensee listed this weld as Examination Category B-J, Item B9.11, which is for circumferential butt welds, NPS 4-inch and larger. However, the licensee stated that Weld RBB-J001 is a branch connection. Discuss why this weld is not listed as ASME Code Item B9.31 or B9.32.*

FPL Energy Duane Arnold Response:

The weld is the first circumferential weld off of a weld-o-let connection. Please refer to Enclosure 4 which illustrates the weld limitation.

- 2.3.3 *State the total population of ASME Code Examination Category B-J welds of similar pipe diameter and wall thickness examined on the same recirculation loop at DAEC, and discuss the volumetric coverage(s) obtained for each of these welds.*

FPL Energy Duane Arnold Response:

There are a total of nine welds on the same bypass line for Recirculation Loop B. Weld RBB-J001 was the only weld selected for examination under the ISI Program (1989 Edition of ASME Section XI). For the implementation of Risked Informed ISI, these nine welds are categorized as Category 6a (5a with IGSCC). None of these welds were selected under the RI-ISI Program.

2.4 **Request for Relief, Examination Category C-A, Item C1.20, Pressure Retaining Welds in Vessels**

- 2.4.1 *The license stated that heat exchanger tie-down brackets obstruct access to the subject head-to-shell weld, limiting examination coverage. However, this statement does not provide adequate descriptive information and technical discussion to support a determination of impracticality and that the required examination was performed to the maximum extent possible at DAEC.*
- a. *Provide further text and/or a cross-sectional sketch describing the basis for impracticality and showing volumetric coverage for Weld HEA-CA-05. In addition, state or show the material, thicknesses, and outside diameters for the subject component. Discuss why the tie-down brackets cannot be removed to allow greater access.*

FPL Energy Duane Arnold Response:

Please refer to the attached ISI Report I01098 page 54 of 56 (Enclosure 5) for location of the heat exchanger tie-down brackets that obstruct the head-to-shell weld on the Residual Heat Removal (RHR) Heat Exchanger (Weld HEA-CA-05), which limits the examination coverage. Also provided in Enclosure 5 are some photos showing typical welded attachments to the heat exchanger. The original Form U-1 (Enclosure 6) is attached to identify material, thickness, and outside diameter of the RHR Heat Exchanger.

- b. *State whether the volumetric examination was performed with procedures and personnel that have been qualified in accordance with ASME Code, Section XI, Appendix VIII.*

FPL Energy Duane Arnold Response:

The FPL Energy Duane Arnold Administrative Control Procedure that was utilized at the DAEC for the examination on Weld HEA-CA-05 – Head to shell weld on the RHR Heat Exchanger was ACP 1211.34, "Manual Ultrasonic Examination of Ferritic Welds \leq 2 inches Thickness." This procedure is in accordance with ASME Section XI, Appendix III.

- 2.4.1(1) *State the total population of ASME Code Examination Category C-A welds at DAEC, and discuss the volumetric coverage(s) obtained for each of these welds.*

FPL Energy Duane Arnold Response:

The DAEC has one category C-A Item C1.20 weld (HEA-CA-05) and two category C-A, Item C1.10 welds (HEA-CA-01 and HEA-CA-03). The following table provides the examination coverage of the three identified welds.

Examination Category	Item Number	Component Number	Period Examined	Code Coverage	Description
C-A	C1.10	HEA-CA-01	3	94%	RHR Heat Exchanger Tube Sheet to Shell Weld
C-A	C1.10	HEA-CA-03	1	100%	RHR Heat Exchanger Shell Course Weld
C-A	C1.20	HEA-CA-05	2	78.07%	RHR Heat Exchanger Head to Shell Weld

ULTRASONIC EXAMINATION DATA SHEET REACTOR PRESSURE VESSEL WELDS

9

Site: DAEC

Report No.: 105005

Calibration Sheet No.: C-110, C-111

Data Sheet No.: N/A

Procedure No.: ACP 1211.27 Rev. 1

System: <u>Reactor Vessel</u>	Exam Surface Temp.: <u>111</u> °F	Couplant: <u>Humex</u>
Weld ID: <u>MSC-D001</u>	Thermometer S/N: <u>3991</u>	Batch No.: <u>98165</u>

Examination Surface: ID <input type="checkbox"/> OD <input checked="" type="checkbox"/>	Material Type: CS <input checked="" type="checkbox"/> SS <input type="checkbox"/>	Exam Date: <u>04/14/05</u>
L ₀ Reference: <u>TDC</u>	R ₀ Reference: <u>WCL</u>	Exam Start: <u>10:00</u>
		Exam End: <u>11:00</u>

Scan Surface	Exam Number	Search Unit Angle	Scan Sensitivity	Exam Number
Perpendicular UpStream	1	60° RL Zone 1	76.7 dB	1, 3, 4
Perpendicular DownStream	2	60° RL Zone 2	83.0 dB	1, 3, 4
Parallel CW	3	N/A	N/A	N/A
Parallel CCW	4	N/A	N/A	N/A

INDICATIONS

Indication No.	L (In) From Ref			W (In) From Ref			Sweep Reading <input checked="" type="checkbox"/> MP or <input type="checkbox"/> Depth			Max Amp % Dac	Examination (1 - 4)
	L-1	L-Max	L-2	W-1	W-Max	W-2	SW-1 M1 <input type="checkbox"/>	SW-Max	SW-2 M2 <input type="checkbox"/>		
NRI	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

REMARKS/LIMITATIONS

WO: 1129016

Single side access due to configuration. Reference EPRI modeling report No. IR-2004-62 for inner 15% examination. Obtained 79.38% coverage of required volume. See attached coverage plot.

☒ Previous Examination Data Reviewed

 Stevermer, A. Examiner (s)	II Level	04/14/05 Date	 Dohmen, F. Level III Review	4/19/05 Date	 Bowers, J. ANII Review	4-20-05 Date
-----------------------------------	-------------	------------------	------------------------------------	-----------------	-------------------------------	-----------------

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-110</u>	
		Linearity Sheet No.: <u>L-002</u>	
Procedure No.: <u>ACP 1211.27</u>		Revision: <u>1</u>	
Instrument: <u>Panametrics</u>		Epoch III	
Manufacturer: <u>TRL2-ST</u>		Model No. <u>01448103</u>	
Search Unit: <u>RTD</u>		Serial No. <u>2 (24X42) mm Rectangular</u>	
Manufacturer: <u>FS-125 mm</u>		Size: <u>2.0</u> MHz	
Model: <u>02-102</u>		Angle / Mode: <u>60° / RL</u>	
Serial No. <u>0</u>		Incident to wedge front: <u>1.05"</u>	
Cable: <u>2 (RG-174)</u>		Length: <u>12'</u>	
Type: <u>0</u>		No. of Connectors: <u>0</u>	
Calibration Standard: <u>IE-30</u>		Carbon Steel	
Serial No. <u>NA / 5.25"</u>		Size / Thickness: <u>66</u> °F	
Material: <u>Humex</u>		Temp. <u>3991</u>	
Batch No. <u>98165</u>		Thermometer: <u>3991</u>	
Type: <u>Humex</u>		Serial No. <u>3991</u>	

DAC	Instrument Settings
<p style="text-align: center;">Sweep: 0 - 10 = <u>5.329"</u></p> <p><input type="checkbox"/> Depth <input checked="" type="checkbox"/> Metal Path</p>	<p>Pulser: <u>High</u> Frequency: <u>Fixed</u></p> <p>Pulse Energy: <u>High</u> Range: <u>6.329"</u></p> <p>Pulse Width: <u>N/A</u> Velocity: <u>.2332</u></p> <p>Rep Rate: <u>Auto</u> Delay: <u>0.00</u></p> <p>Damping: <u>150 Ohms</u> Zero Offset: <u>12.98</u></p> <p>Display Mode: <u>Fullwave</u> Gain - Axial Scan: <u>62.7 dB</u></p> <p>Filter: <u>STD</u> Gain - Circ. Scan: <u>N/A dB</u></p> <p>Reject: <u>Off</u> <input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual</p> <p>Pulse Amplitude: <u>Fixed</u></p>

Field Simulator <u>CS Rompas</u> S/N <u>LMT-17</u>			Calibration Verification			
Reflector:	<u>1/4T SDH</u>	<u>2" RAD</u>	Initial Calibration Time:	<u>08:56</u>	Verification Times:	
Max Amplitude:	<u>80%</u>	<u>80%</u>	Final Calibration Time:	<u>13:55</u>	<u>N/A</u>	<u>N/A</u>
Sweep:	<u>4.0</u>	<u>3.2</u>			<u>N/A</u>	<u>N/A</u>
Gain:	<u>62.7 dB</u>	<u>47.6 dB</u>				

Welds Examined	Report No.	Comments
MSC-D001	105005	Work Order: 1129016
MSD-D001	105007	Work Order: 1129016
VCB-C005	105090	Work Order: 1129072
		Squint Angle 5°
		Configuration of Elements: D-SBS
		Zone 1

	II	04/14/05		4/19/05		4-20-05
Examiner	Level	Date	Level III Review	Date	ANIL Review	Date

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-111</u>																			
		Linearity Sheet No.: <u>L-002</u>																			
Procedure No.: <u>ACP 1211.27</u>		Revision: <u>1</u>																			
Instrument: <u>Panametrics</u> <small>Manufacturer</small>		Epoch III <small>Model No.</small>																			
		01448103 <small>Serial No.</small>																			
Search Unit: <u>RTL2-ST</u> <small>Manufacturer</small>		<u>FS~125 mm</u> <small>Model</small>																			
		<u>02-102</u> <small>Serial No.</small>																			
Cable: <u>2 (RG-174)</u> <small>Type</small>		<u>12'</u> <small>Length</small>																			
		<u>0</u> <small>No. of Connectors</small>																			
Calibration Standard: <u>IE-30</u> <small>Serial No.</small>		<u>Carbon Steel</u> <small>Material</small>																			
		<u>NA / 5.25"</u> <small>Size / Thickness</small>																			
Couplant: <u>Humex</u> <small>Type</small>		<u>98165</u> <small>Batch No.</small>																			
		Thermometer: <u>3991</u> <small>Serial No.</small>																			
DAC		Instrument Settings																			
<p style="text-align: center;">Sweep: 0 - 10 = <u>14.45"</u></p> <p><input type="checkbox"/> Depth <input checked="" type="checkbox"/> Metal Path</p>		<p>ID Notch</p> <table style="width: 100%;"> <tr> <td>Pulser: <u>High</u></td> <td>Frequency: <u>Fixed</u></td> </tr> <tr> <td>Pulse Energy: <u>High</u></td> <td>Range: <u>14.45"</u></td> </tr> <tr> <td>Pulse Width: <u>N/A</u></td> <td>Velocity: <u>.2332</u></td> </tr> <tr> <td>Rep Rate: <u>Auto</u></td> <td>Delay: <u>12.98</u></td> </tr> <tr> <td>Damping: <u>150 Ohms</u></td> <td>Zero Offset: <u>0.0</u></td> </tr> <tr> <td>Display Mode: <u>Fullwave</u></td> <td>Gain - Axial Scan: <u>71.0 dB</u></td> </tr> <tr> <td>Filter: <u>STD</u></td> <td>Gain - Circ. Scan: <u>N/A dB</u></td> </tr> <tr> <td>Reject: <u>Off</u></td> <td><input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual</td> </tr> <tr> <td>Pulse Amplitude: <u>Fixed</u></td> <td></td> </tr> </table>		Pulser: <u>High</u>	Frequency: <u>Fixed</u>	Pulse Energy: <u>High</u>	Range: <u>14.45"</u>	Pulse Width: <u>N/A</u>	Velocity: <u>.2332</u>	Rep Rate: <u>Auto</u>	Delay: <u>12.98</u>	Damping: <u>150 Ohms</u>	Zero Offset: <u>0.0</u>	Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>71.0 dB</u>	Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>	Reject: <u>Off</u>	<input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual	Pulse Amplitude: <u>Fixed</u>	
Pulser: <u>High</u>	Frequency: <u>Fixed</u>																				
Pulse Energy: <u>High</u>	Range: <u>14.45"</u>																				
Pulse Width: <u>N/A</u>	Velocity: <u>.2332</u>																				
Rep Rate: <u>Auto</u>	Delay: <u>12.98</u>																				
Damping: <u>150 Ohms</u>	Zero Offset: <u>0.0</u>																				
Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>71.0 dB</u>																				
Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>																				
Reject: <u>Off</u>	<input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual																				
Pulse Amplitude: <u>Fixed</u>																					
Field Simulator <u>CS Rompas</u> <u>S/N</u> <u>LMT-17</u>		Calibration Verification																			
Reflector:	<u>ID Notch</u>	Initial Calibration Time:	<u>09:04</u>																		
Max Amplitude:	<u>80%</u>	Final Calibration Time:	<u>13:58</u>																		
Sweep:	<u>7.5</u>	Verification Times:																			
Gain:	<u>71.0 dB</u>	<u>N/A</u>	<u>N/A</u>																		
		<u>N/A</u>	<u>N/A</u>																		
Welds Examined		Report No.																			
MSC-D001		I05005																			
MSD-D001		I05007																			
VCB-C005		I05090																			
		Squint Angle 5°																			
		Configuration of Elements: D-SBS																			
Zone 2																					
II 04/14/05		4/19/05																			
Examiner		Level III Review																			
Date		Date																			
		Bowers, J.																			
		Date																			
		ANII Review																			

Nozzle to RPV Coverage Calculation Sheet

Coverage calculated to requirements of Code Case N-613 - I
Note: calculations performed using 2D plot only

Nozzle ID N3

Area required to be examined

Axial scan direction: Height x width

5.25 inches x 3.007 inches equals 15.7868 square inches

Parallel scan direction: Height x width

5.25 inches x 3.007 inches equals 15.7868 square inches

Total area required to be examined 31.5735 square inches required for complete exam

Actual area examined

60 degree R.L. Axial scan direction: Height x width

5.25 inches x 3.007 inches equals 15.7868 square inches

Triangular area not examined (if applies) 1.24 1/2 base x 2.16 height equals 1.3392 square inches

Axial scan direction area examined 14.4476 square inches

60 degree R.L. Parallel scan direction: Height x width

5.25 inches x 1.86 inches equals 9.765 square inches


Additional Inner 15% area achieved using 40 & 45 degree shear techniques: Height x width

0.7875 inches x 1.08 inches equals 0.8505 square inches

Combining all scan directions: 25.0631 square inches for total exam

Divide area examined by required area: equals coverage achieved 79.38 % coverage for total exam

Calculations performed by:


Todd Blechinger

Level III

DAEC Review


Frank Dohmen

Level III

ANII Review

Jeremy Bowers

JSB 4/20/05

DAEC N3 Coverage Plot


Parallel scan direction

Examiner *[Signature]*

Review *[Signature]*

Report # 1050075


Page of



DAEC N3 Coverage Plot

Axial scan direction


Examiner W. S. [Signature]
Review _____
Report # 105005
Page _____ of _____



DAEC N3 Coverage Plot

Axial scan direction

Examiner [Signature]
Review _____
Report # 105005
Page ____ of ____



ULTRASONIC EXAMINATION DATA SHEET REACTOR PRESSURE VESSEL WELDS

(10)

Site: DAEC

Report No.: 105007

Calibration Sheet No.: C-110, C-111

Data Sheet No.: N/A

Procedure No.: ACP 1211.27 Rev. 1

System: <u>Reactor Vessel</u>	Exam Surface Temp.: <u>111</u> °F	Couplant: <u>Humex</u>
Weld ID: <u>MSD-D001</u>	Thermometer S/N: <u>3991</u>	Batch No.: <u>98165</u>

Examination Surface: <input type="checkbox"/> ID <input checked="" type="checkbox"/> OD	Material Type: <input checked="" type="checkbox"/> CS <input type="checkbox"/> SS	Exam Date: <u>04/14/05</u>
L _o Reference: <u>TDC</u>	R _o Reference: <u>WCL</u>	Exam Start: <u>10:00</u>
		Exam End: <u>11:00</u>

Scan Surface	Exam Number	Search Unit Angle	Scan Sensitivity	Exam Number
Perpendicular UpStream	1	60° RL Zone 1	76.7 dB	1, 3, 4
Perpendicular DownStream	2	60° RL Zone 2	83.0 dB	1, 3, 4
Parallel CW	3	N/A	N/A	N/A
Parallel CCW	4	N/A	N/A	N/A

INDICATIONS

Indication No.	L (In) From Ref			W (In) From Ref			Sweep Reading <input checked="" type="checkbox"/> MP or <input type="checkbox"/> Depth			Max Amp % Dac	Examination (1 - 4)
	L-1	L-Max	L-2	W-1	W-Max	W-2	SW-1 <input type="checkbox"/> M1 <input type="checkbox"/>	SW-Max	SW-2 <input type="checkbox"/> M2 <input type="checkbox"/>		
NRI	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

REMARKS/LIMITATIONS

WO: 1129016


Single side access due to configuration. Reference EPRI modeling report No. 1R-2004-62 for inner 15% examination. Obtained 79.38% coverage of required volume. See attached coverage plot.

☒ Previous Examination Data Reviewed

 Stevenmer, A. Examiner (s)	Level <u>II</u> Date <u>04/14/05</u>	 Dohmen, F. Level III Review	Date <u>4/19/05</u>	 Bowers, J. ANII Review	Date <u>4-20-05</u>
-----------------------------------	---	------------------------------------	---------------------	-------------------------------	---------------------




ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-110</u>	
		Linearity Sheet No.: <u>L-002</u>	
Procedure No.: <u>ACP 1211.27</u>		Revision: <u>1</u>	
Instrument: <u>Panametrics</u> Manufacturer		Epoch III Model No. <u>01448103</u> Serial No.	
Search Unit: <u>RTL</u> Manufacturer		<u>TRL2-ST</u> Model	
<u>FS-125 mm</u> Model		<u>02-102</u> Serial No.	
<u>2 (24X42) mm</u> Size		<u>2.0</u> MHz Freq.	
<u>60° / RL</u> Angle / Mode		<u>1.05"</u> Incident to wedge front	
Cable: <u>2 (RG-174)</u> Type		<u>12'</u> Length	
<u>0</u> No. of Connectors			
Calibration Standard: <u>IE-30</u> Serial No.		<u>Carbon Steel</u> Material	
<u>NA / 5.25"</u> Size / Thickness		<u>66</u> °F Temp.	
Couplant: <u>Humex</u> Type		<u>98165</u> Batch No.	
		Thermometer: <u>3991</u> Serial No.	

DAC	Instrument Settings																		
 <p style="text-align: center;">Sweep: 0 - 10 = <u>6.329"</u></p> <p><input type="checkbox"/> Depth <input checked="" type="checkbox"/> Metal Path</p>	<table style="width: 100%;"> <tr> <td>Pulser: <u>High</u></td> <td>Frequency: <u>Fixed</u></td> </tr> <tr> <td>Pulse Energy: <u>High</u></td> <td>Range: <u>6.329"</u></td> </tr> <tr> <td>Pulse Width: <u>N/A</u></td> <td>Velocity: <u>.2332</u></td> </tr> <tr> <td>Rep Rate: <u>Auto</u></td> <td>Delay: <u>0.00</u></td> </tr> <tr> <td>Damping: <u>150 Ohms</u></td> <td>Zero Offset: <u>12.98</u></td> </tr> <tr> <td>Display Mode: <u>Fullwave</u></td> <td>Gain - Axial Scan: <u>62.7 dB</u></td> </tr> <tr> <td>Filter: <u>STD</u></td> <td>Gain - Circ. Scan: <u>N/A dB</u></td> </tr> <tr> <td>Reject: <u>Off</u></td> <td><input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual</td> </tr> <tr> <td>Pulse Amplitude: <u>Fixed</u></td> <td></td> </tr> </table>	Pulser: <u>High</u>	Frequency: <u>Fixed</u>	Pulse Energy: <u>High</u>	Range: <u>6.329"</u>	Pulse Width: <u>N/A</u>	Velocity: <u>.2332</u>	Rep Rate: <u>Auto</u>	Delay: <u>0.00</u>	Damping: <u>150 Ohms</u>	Zero Offset: <u>12.98</u>	Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>62.7 dB</u>	Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>	Reject: <u>Off</u>	<input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual	Pulse Amplitude: <u>Fixed</u>	
Pulser: <u>High</u>	Frequency: <u>Fixed</u>																		
Pulse Energy: <u>High</u>	Range: <u>6.329"</u>																		
Pulse Width: <u>N/A</u>	Velocity: <u>.2332</u>																		
Rep Rate: <u>Auto</u>	Delay: <u>0.00</u>																		
Damping: <u>150 Ohms</u>	Zero Offset: <u>12.98</u>																		
Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>62.7 dB</u>																		
Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>																		
Reject: <u>Off</u>	<input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual																		
Pulse Amplitude: <u>Fixed</u>																			

Field Simulator <u>CS Rompas</u> S/N <u>LMT-17</u>			Calibration Verification			
Reflector:	<u>1/4T SDH</u>	<u>2" RAD</u>	Initial Calibration Time:	<u>08:56</u>	Verification Times:	
Max Amplitude:	<u>80%</u>	<u>80%</u>	Final Calibration Time:	<u>13:55</u>	<u>N/A</u>	<u>N/A</u>
Sweep:	<u>4.0</u>	<u>3.2</u>			<u>N/A</u>	<u>N/A</u>
Gain:	<u>62.7 dB</u>	<u>47.6 dB</u>				

Welds Examined	Report No.	Comments
MSC-D001	I05005	Work Order: 1129016
MSD-D001	I05007	Work Order: 1129016
VCB-C005	I05090	Work Order: 1129072
		Squint Angle 5°
		Configuration of Elements: D-SBS
		Zone 1

 Stevermer, A. Examiner	II	04/14/05 Date	 Dohmen, F. Level III Review	4/19/05 Date	 Bowers, J. ANII Review
--	----	------------------	---	-----------------	--

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-111</u>	
		Linearity Sheet No.: <u>L-002</u>	
Procedure No.: <u>ACP 1211.27</u>		Revision: <u>1</u>	
Instrument: <u>Panametrics</u>		Epoch III	
Manufacturer		Model No.	
Search Unit: <u>RTL2-ST</u>		Serial No. <u>01448103</u>	
Manufacturer		Model No.	
Search Unit: <u>RTD</u>		<u>FS~125 mm</u>	
Manufacturer		Model	
Search Unit: <u>02-102</u>		<u>2 (24X42) mm</u>	
Manufacturer		Serial No.	
Cable: <u>2 (RG-174)</u>		<u>12'</u>	
Type		Length	
Cable: <u>0</u>		<u>0</u>	
Type		No. of Connectors	
Calibration Standard: <u>IE-30</u>		Carbon Steel	
Serial No.		Material	
Calibration Standard: <u>NA / 5.25"</u>		<u>66</u>	
Serial No.		Temp.	
Couplant: <u>Humex</u>		98165	
Type		Batch No.	
Thermometer: <u>3991</u>			
Serial No.			




DAC

Sweep: 0 - 10 = 14.45"

☐ Depth ☒ Metal Path

Instrument Settings

Pulser:	High	Frequency:	Fixed
Pulse Energy:	High	Range:	14.45"
Pulse Width:	N/A	Velocity:	.2332
Rep Rate:	Auto	Delay:	12.98
Damping:	150 Ohms	Zero Offset:	0.0
Display Mode:	Fullwave	Gain - Axial Scan:	71.0 dB
Filter:	STD	Gain - Circ. Scan:	N/A dB
Reject:	Off	<input type="checkbox"/> Pulse Echo	<input checked="" type="checkbox"/> Dual
Pulse Amplitude:	Fixed		

Field Simulator			CS Rompas		S/N	LMT-17		Calibration Verification			
Reflector:	ID Notch	2" RAD	Initial Calibration Time:		09:04		Verification Times:				
Max Amplitude:	80%	80%	Final Calibration Time:		13:58		N/A	N/A	N/A	N/A	
Sweep:	7.5	1.2									
Gain:	71.0 dB	47.2 dB									
Welds Examined			Report No.		Comments						
MSC-D001			105005		Work Order: 1129016						
MSD-D001			105007		Work Order: 1129016						
VCB-C005			105090		Work Order: 1129072						
					Squint Angle 5°						
					Configuration of Elements: D-SBS						
					Zone 2						
 Stevenmer, A. Examiner			II	04/14/05	 Dohmen, F. Level III Review			4/19/05	 Bowers, J. ANII Review		
			Level	Date				Date			

Nozzle to RPV Coverage Calculation Sheet

Coverage calculated to requirements of Code Case N-613 - 1

Note: calculations performed using 2D plot only

Nozzle ID N3

Area required to be examined

Axial scan direction: Height x width

5.25 inches x 3.007 inches equals 15.7868 square inches

Parallel scan direction: Height x width

5.25 inches x 3.007 inches equals 15.7868 square inches

Total area required to be examined 31.5735 square inches required for complete exam

Actual area examined

60 degree R.L. Axial scan direction: Height x width

5.25 inches x 3.007 inches equals 15.7868 square inches

Triangular area not examined (if applies) 1.24 1/2 base x 2.16 height equals 1.3392 square inches

Axial scan direction area examined 14.4476 square inches

60 degree R.L. Parallel scan direction: Height x width

5.25 inches x 1.86 inches equals 9.765 square inches

Additional Inner 15% area achieved using 40 & 45 degree shear techniques: Height x width

0.7875 inches x 1.08 inches equals 0.8505 square inches

Combining all scan directions: 25.0631 square inches for total exam


Divide area examined by required area: equals coverage achieved 79.38 % coverage for total exam

Calculations performed by:


Todd Blechinger

Level III

DAEC Review


Frank Dohmen 4/19/05

Level III

ANII Review

Jeremy Bowers

 4-20-05

DAEC N3 Coverage Plot


Axial scan direction

Examiner

Review

Report # 105007

Page of



DAEC N3 Coverage Plot


Parallel scan direction

Examiner *[Signature]*

Review _____

Report # 105007

Page _____ of _____



Nozzle to RPV Coverage Calculation Sheet

Coverage Re-calculated using IWB-2500-7(b) volume 60°

Note: calculations performed using 2D plot only

Nozzle ID N3 Main Steam MSC-D001 & MSD-D001

Area required to be examined

Axial scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{7.875} \text{ inches equals } \underline{41.344} \text{ square inches}$$

Parallel scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{7.875} \text{ inches equals } \underline{41.344} \text{ square inches}$$

Total area required to be examined 82.688 square inches required for complete exam

Actual area examined

60° R.L. Axial scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{7.875} \text{ inches equals } \underline{41.344} \text{ square inches}$$

Triangular area not examined (if applies)	<u>2.5</u>	base	x	<u>4.25</u>	height	equals	<u>5.3125</u>	square inches	A=bh/2
	<u>1.218</u>	base	x	<u>2.125</u>	height	equals	<u>1.2941</u>	square inches	

Axial scan direction area examined 34.737 square inches

60° R.L. Parallel scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{7.875} \text{ inches equals } \underline{41.344} \text{ square inches}$$

Area not examined (if applicable)	<u>5.25</u>	height	x	<u>3.2</u>	width	equals	<u>16.8</u>	square inches
	<u>5.25</u>	height	x	<u>2.125</u>	width	equals	<u>11.156</u>	square inches
<u>41.344</u> inches minus area not examined				<u>27.956</u>	inches	equals	<u>13.388</u>	square inches

Combining all scan directions: 48.125 square inches for total exam

Divide area examined by required area: equals coverage achieved 58.2 % coverage for total exam

Calculations performed by:	<u>Frank Dohmen</u>	Level	<u>III</u>	<u>58.2</u>	60°
				<u>56.1</u>	40°
				<u>56.35</u>	45°
				<u>170.65</u>	
DAEC Review	<u>Gary Park</u>			<u>56.83</u>	

Nozzle to RPV Coverage Calculation Sheet

Coverage Re-calculated using IWB-2500-7(b) volume 45 degree for Inner 15%

Note: calculations performed using 2D plot only

Nozzle ID N3 Main Steam MSC-D001 & MSD-D001

Area required to be examined

Axial scan direction: Height x width

0.7875 inches x 7.875 inches equals 6.20156 square inches

Parallel scan direction: Height x width

0.7875 inches x 7.875 inches equals 6.20156 square inches

Total area required to be examined 12.4031 square inches required for complete exam

Actual area examined

45 degree Axial scan direction: Height x width

0.7875 inches x 7.875 inches equals 6.20156 square inches

Triangular area not examined (if applies) 0.75 1/2 base x 0.7875 height equals 0.29531 square inches

Rect. area not examined (if applies) 1.375 x 0.7875 equals 1.08281

Axial scan direction area examined 4.82344 square inches

45 degree shear Parallel scan direction: Height x width

0.7875 inches x 7.875 inches equals 6.20156 square inches

Area not examined (if applies) 3.0 base x 0.7875 height equals 2.3625 square inches

Area not examined (if applies) 2.125 base x 0.7875 height equals 1.67344 square inches

Parallel scan direction area examined 2.16563 square inches

Combining all scan directions: 6.98906 square inches for total exam

Divide area examined by required area: equals coverage achieved 56.35 % coverage for total exam

Calculations performed by: Frank Dohmen Level III

DAEC Review Gary Park

ANII Review

Nozzle to RPV Coverage Calculation Sheet

Coverage Re-calculated using IWB-2500-7(b) volume 40 degree for Inner 15%

Note: calculations performed using 2D plot only

Nozzle ID N3 Main Steam MSC-D001 & MSD-D001

Area required to be examined

Axial scan direction: Height x width

0.7875 inches x 7.875 inches equals 6.20156 square inches

Parallel scan direction: Height x width

0.7875 inches x 7.875 inches equals 6.20156 square inches

Total area required to be examined 12.4031 square inches required for complete exam

Actual area examined

40 degree Axial scan direction: Height x width

0.7875 inches x 7.875 inches equals 6.20156 square inches

Triangular area not examined⁽¹⁾ (if applies) 0 1/2 base x 0 height equals 0 square inches

Rect. area not examined⁽¹⁾ (if applies) 0 x 0 equals 0

Triangular area not examined⁽²⁾ (if applies) 0.66 1/2 base x 0.7875 height equals 0.25988 square inches

Rect. area not examined⁽²⁾ (if applies) 1.46 x 0.7875 equals 1.14975

Axial scan direction area examined 4.79194 square inches

40 degree shear Parallel scan direction: Height x width

0.7875 inches x 7.875 inches equals 6.20156 square inches

Area not examined (if applies) 3.0 base x 0.7875 height equals 2.3625 square inches

Area not examined (if applies) 2.125 base x 0.7875 height equals 1.67344

Parallel scan direction area examined 2.16563 square inches

Combining all scan directions: 6.95756 square inches for total exam

Divide area examined by required area: equals coverage achieved 56.1 % coverage for total exam

Calculations performed by: Frank Dohmen Level III



DAEC Review Gary Park

ANII Review

014KX8

N35

40 & 45
inner 15%



N 30°

Axial
NOT
Examined

60°

1.05 inch defect - wedge point

Edge of
transducers
for Parallel
Scan

1 1/4"

60°
45°

75°

Parallel
not examined

Parallel
NOT
Scanned
(Assumed)

5.25

60°

1.278"


2.125

$t_s/2 = 2.625$

$t_s/2 = 2.625$

7.875"

NOT
Scanned



2	8/8/95	REVISED PER DURF-0011	DA	GD	SS	SS
1	12-09-94	DRAFTED FOR VESSEL INSPECTION PROGRAM	MS	DF	GP	SS
NO.	DATE	REVISION	DRFTR.	CHK'D.	ENGR.	VER.


NO.	DESCRIPTION	BILL OF MATL.	PROCD.
1	FORGING	SA508 CLASS 2	
2	SAFE END FORGING	SA508 CLASS 1	
3	1ST CLAD LAYER	309	
4	2ND & 3RD CLAD LAYER	308L	
5	SHELL PLATE *4	SA533 CLASS 1 GR.B	

IES:
Inservice Inspection Program
Reactor Pressure Vessel Sketch

REFERENCE DRAWING:
APED-B11-2655-098

DWG. NO. VS-01-12
STEAM OUTLET
NOZZLE MK N3A/D

REV.
2



ULTRASONIC EXAMINATION DATA SHEET REACTOR PRESSURE VESSEL WELDS

Site: DAEC Report No.: 105011 Calibration Sheet No.: C-071, C-072
Data Sheet No.: N/A

Procedure No.: ACP 1211.27 Rev. 1

11

System: <u>Reactor Vessel</u>	Exam Surface Temp.: <u>96</u> °F	Couplant: <u>Humex</u>
Weld ID: <u>FWB-D001</u>	Thermometer S/N: <u>3991</u>	Batch No.: <u>98165</u>

Examination Surface: ID <input type="checkbox"/> OD <input checked="" type="checkbox"/>	Material Type: CS <input checked="" type="checkbox"/> SS <input type="checkbox"/>	Exam Date: <u>4/11/05</u>
L ₀ Reference: <u>TDC</u>	R ₀ Reference: <u>WCL</u>	Exam Start: <u>10:40</u>
		Exam End: <u>12:00</u>

Scan Surface	Exam Number	Search Unit Angle	Scan Sensitivity	Exam Number
Perpendicular UpStream	1	60° RL ZONE 1	74.5 dB	1, 3, 4
Perpendicular DownStream	2	60° RL ZONE 2	79.0 dB	1, 3, 4
Parallel CW	3			
Parallel CCW	4			




INDICATIONS

Indication No.	L (In) From Ref			W (In) From Ref			Sweep Reading <input checked="" type="checkbox"/> MP or <input type="checkbox"/> Depth			Max Amp % Dac	Examination (1 - 4)
	L-1	L-Max	L-2	W-1	W-Max	W-2	SW-1 M1 <input type="checkbox"/>	SW-Max	SW-2 M2 <input type="checkbox"/>		
NRI	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

REMARKS/LIMITATIONS


WO:1129008
Obtained 87.67% coverage of required volume.
See attached coverage plot.

☒ Previous Examination Data Reviewed

 Stevermer, A. Examiner (s)	II Level	04/11/05 Date	 Dohmen, F. Level III Review	4/15/05 Date	 Bowers, J. ANII Review	4-14-05 Date
--	-------------	------------------	---	-----------------	--	-----------------




ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-071</u>	
		Linearity Sheet No.: <u>L-004</u>	
Procedure No.: <u>ACP 1211.27</u>		Revision: <u>1</u>	
Instrument: <u>Panametrics</u>		Epoch III	
Manufacturer: <u>TRL2-Aust</u>		Model No. <u>FS-125 mm</u>	
Search Unit: <u>RTD</u>		Serial No. <u>00-447</u>	
Cable: <u>2 (RG-174)</u>		Size <u>2 (24X42) mm Rectangular</u>	
Type <u>12'</u>		Freq. <u>2.0</u> MHz	
Length <u>0</u>		Angle / Mode <u>60° / Long.</u>	
No. of Connectors <u>0</u>		Incident to wedge front	
Calibration Standard: <u>IE-30</u>		Carbon Steel	
Serial No. <u>NA / 5.25"</u>		Size / Thickness <u>66</u> °F	
Couplant: <u>Humex</u>		Thermometer: <u>3991</u>	
Type <u>98165</u>		Serial No. <u>3991</u>	
Batch No.			

DAC	Instrument Settings																		
 <p style="text-align: center;">Sweep: 0 - 10 = <u>8.003"</u></p> <p><input type="checkbox"/> Depth <input checked="" type="checkbox"/> Metal Path</p>	<table style="width: 100%;"> <tr> <td>Pulser: <u>High</u></td> <td>Frequency: <u>Fixed</u></td> </tr> <tr> <td>Pulse Energy: <u>High</u></td> <td>Range: <u>8.003"</u></td> </tr> <tr> <td>Pulse Width: <u>N/A</u></td> <td>Velocity: <u>.2309</u></td> </tr> <tr> <td>Rep Rate: <u>Auto</u></td> <td>Delay: <u>0.000</u></td> </tr> <tr> <td>Damping: <u>150 Ohms</u></td> <td>Zero Offset: <u>12.38</u></td> </tr> <tr> <td>Display Mode: <u>Fullwave</u></td> <td>Gain - Axial Scan: <u>62.0 dB</u></td> </tr> <tr> <td>Filter: <u>STD</u></td> <td>Gain - Circ. Scan: <u>N/A dB</u></td> </tr> <tr> <td>Reject: <u>Off</u></td> <td><input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual</td> </tr> <tr> <td>Pulse Amplitude: <u>Fixed</u></td> <td></td> </tr> </table>	Pulser: <u>High</u>	Frequency: <u>Fixed</u>	Pulse Energy: <u>High</u>	Range: <u>8.003"</u>	Pulse Width: <u>N/A</u>	Velocity: <u>.2309</u>	Rep Rate: <u>Auto</u>	Delay: <u>0.000</u>	Damping: <u>150 Ohms</u>	Zero Offset: <u>12.38</u>	Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>62.0 dB</u>	Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>	Reject: <u>Off</u>	<input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual	Pulse Amplitude: <u>Fixed</u>	
Pulser: <u>High</u>	Frequency: <u>Fixed</u>																		
Pulse Energy: <u>High</u>	Range: <u>8.003"</u>																		
Pulse Width: <u>N/A</u>	Velocity: <u>.2309</u>																		
Rep Rate: <u>Auto</u>	Delay: <u>0.000</u>																		
Damping: <u>150 Ohms</u>	Zero Offset: <u>12.38</u>																		
Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>62.0 dB</u>																		
Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>																		
Reject: <u>Off</u>	<input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual																		
Pulse Amplitude: <u>Fixed</u>																			


Field Simulator <u>CS Rompas</u> S/N <u>LMT-17</u>			Calibration Verification			
Reflector:	<u>1/4T SDH</u>	<u>2" RAD</u>	Initial Calibration Time: <u>08:01</u>	Verification Times:		
Max Amplitude:	<u>80%</u>	<u>80%</u>	Final Calibration Time: <u>16:40</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep:	<u>4.0</u>	<u>3.4</u>				
Gain:	<u>62.0 dB</u>	<u>48.0 dB</u>				

Welds Examined	Report No.	Comments
FWB-D001	I05011	WO-1129008
FWC-D001	I05017	WO-1129009
		Squint Angle 3°
		Configuration of Elements: D-SBS
		ZONE 1 60° PL CAL

 Stevermer, A. Examiner	II	34/11/05	 Dohmen, F. Level III Review	4/18/05	 Bowers, J. ANII Review	4-1905
--	----	----------	---	---------	--	--------

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: DAEC Calibration Sheet No.: C-072
 Linearity Sheet No.: L-004
 Procedure No.: ACP 1211.27 Revision: 1
 Instrument: Panametrics Epoch III 01435501
 Manufacturer Model No. Serial No.
 Search Unit: RTL TRL2-Aust 00-447 2 (24X42) mm 2.0 60° / Long. 1.05"
 Manufacturer Model Serial No. Size Freq. Angle / Mode Incident to
 Cable: 2 (RG-174) 12' 0
 Type Length No. of Connectors
 Calibration Standard: IE-30 Carbon Steel NA / 5.25" 66 °F
 Serial No. Material Size / Thickness Temp.
 Couplant: Humex 98165 Thermometer: 3991
 Type Batch No. Serial No.



Field Simulator			Calibration Verification			
<u>CS Rompas</u>	<u>S/N</u>	<u>LMT-17</u>	Initial Calibration Time:	<u>07:58</u>	Verification Times:	
Reflector:	<u>ID Notch</u>	<u>2" RAD</u>	Final Calibration Time:	<u>16:42</u>	<u>N/A</u>	<u>N/A</u>
Max Amplitude:	<u>80%</u>	<u>80%</u>			<u>N/A</u>	<u>N/A</u>
Sweep:	<u>7.5</u>	<u>1.2</u>				
Gain:	<u>73.0 dB</u>	<u>48.0 dB</u>				

Welds Examined	Report No.	Comments	
<u>FWB-D001</u>	<u>I05011</u>	<u>WO: 1129008</u>	
<u>FWC-D001</u>	<u>I05017</u>	<u>WO: 1129009</u>	
		<u>Squint Angle 3°</u>	
		<u>Configuration of Elements: D-SBS</u>	
		<u>ZONE 2 60° RL CAL</u>	
<u>Stevermer, A.</u>	<u>04/11/05</u>	<u>Frank Dohmen</u>	<u>4/18/05</u>
Examiner	Date	Level III Review	Date
		<u>Bowers, J.</u>	<u>4-19-05</u>
		ANII Review	Date

DAEC N4 coverage plot


Axial scan direction

Examiner [Signature] 4-11-05

Review _____

Report # I05011

Page _____ of _____



DAEC N4 coverage plot

Parallel scan direction


Examiner [Signature]

4-11-05

Review _____

Report # I05011

Page ____ of ____



ULTRASONIC EXAMINATION DATA SHEET NOZZLE TO SHELL WELD AND INNER RADIUS

Site: DAEC

Report No.: 105011

Calibration Sheet No.: C-075 THROUGH C-081

Data Sheet No.: N/A

Procedure No.: ACP 1211.44 Rev. 0

System: <u>Reactor Vessel</u>	Exam Surface Temp.: <u>96</u> °F	Couplant: <u>Humex</u>
Nozzle ID: <u>FWB-Bore, FWB-Nozzle, FWB-D001 IR</u>	Thermometer S/N: <u>3991</u>	Batch No.: <u>98165</u>

Examination Surface: ID <input type="checkbox"/> OD <input checked="" type="checkbox"/>	Material Type: CS <input checked="" type="checkbox"/> SS <input type="checkbox"/>	Exam Date: <u>04/11/05</u>
L _o Reference: <u>TDC</u>	R _o Reference: <u>WCL</u>	Exam Start: <u>10:40</u>
		Exam End: <u>12:00</u>

Scan Surface	Exam Number	Search Unit Angle / Skew	Scan Sensitivity	Exam Number
Vessel CW	1	21.8° +- 90°	63.5 dB	5, 6
Vessel CCW	2	25° +- 90°	63.5 dB	3, 4
Blend CW	3	40° +- 90°	53.5 dB	3, 4
Blend CCW	4	70° +- 24°	78.5 dB	3, 4
Nozzle Boss CW	5	70° (+- 13° to 36°)	78.5 dB	1, 2
Nozzle Boss CCW	6	45° (+- 59° to 80°)	55.5 dB	1, 2




Ind. #	Transducer Azimuth Location	Indication Metal Path	Transducer 'R' Location	Transducer Skew	Scan Sensitivity	Exam Number
NRI	N/A	N/A	N/A	N/A	N/A	N/A

REMARKS/LIMITATIONS

100% Coverage obtained based on modeling program for nozzle examinations. Reference EPRI report no.: IR-2004-62.
21.8° Exam obtained 95.69% of required volume due to thermocouple obstruction.
See attached limitation sheet.

WO: 1129008


☒ Previous Examination Data Reviewed

 Stevermer, A. Examiner	II Level 04/11/05 Date	 Dohmen, F. Level III Review	4/19/05 Date	 Bowers, J. ANII Review	4-1905 Date
--	---------------------------------	---	-----------------	--	----------------

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: DAEC Calibration Sheet No.: C-080
 Linearity Sheet No.: L-004
 Procedure No.: ACP 1211.44 Revision: 0
 Instrument: Panametrics Epoch III 01435501
 Manufacturer Model No. Serial No.
 Search Unit: Krautkramer Comp G 014XX3 .75" Round 2.25 MHz ° / Shear .8"
 Manufacturer Model Serial No. Size Freq. Angle / Mode Incident to
 Cable: RG-174 12' 0
 Type Length No. of Connectors
 Calibration Standard: IE-30 Carbon Steel NA / 5.25" 66 °F
 Serial No. Material Size / Thickness Temp.
 Couplant: Humex 98165 Thermometer: 3991
 Type Batch No. Serial No.

DAC



Instrument Settings

Pulsar: High Frequency: Fixed
 Pulse Energy: High Range: 8.650"
 Pulse Width: N/A Velocity: .1228
 Rep Rate: Auto Delay: 0.00
 Damping: 150 Ohms Zero Offset: 16.92
 Display Mode: Fullwave Gain - Axial Scan: 47.5 dB
 Filter: STD Gain - Circ. Scan: N/A dB
 Reject: Off ☒ Pulse Echo ☐ Dual
 Pulse Amplitude: Fixed

Field Simulator N/A S/N N/A

Calibration Verification

Reflector:	ID Notch	N/A	Initial Calibration Time: 08:04	Verification Times:			
Max Amplitude:	80%	N/A	Final Calibration Time: 16:58	N/A	N/A	N/A	N/A
Sweep:	9.0	N/A					
Gain:	47.5 dB	N/A					

Weeds Examined

Report No.

Comments

FWB-D001	105011	Work Order: 1129008
FWC-D001	105017	Work Order: 1129009
Wedge S/N: 366-003-087		
Configuration of Elements: Single		
* 40° ± 90°		

 Stevermer, A. Examiner	II Level	04/11/05 Date	 Dohmen, F. Level III Review	4/12/05 Date	 Bowers, J. ANII Review	4-1925 Date
-------------------------------	-------------	------------------	------------------------------------	-----------------	-------------------------------	----------------

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: DAEC			Calibration Sheet No.: C-081 Linearity Sheet No.: L-004											
Procedure No.: ACP 1211.44			Revision: 0											
Instrument: Panametrics <small>Manufacturer</small>			Epoch III <small>Model No.</small>			01435501 <small>Serial No.</small>								
Search Unit: Krautkramer <small>Manufacturer</small>			Comp G <small>Model</small>		014XX8 <small>Serial No.</small>		.75" Round <small>Size</small>		2.25 MHz <small>Freq.</small>		45° / Shear <small>Angle / Mode</small>		.8" <small>Incident to wedge front</small>	
Cable: RG-174 <small>Type</small>			12' <small>Length</small>		0 <small>No. of Connectors</small>									
Calibration Standard: IE-30 <small>Serial No.</small>			Carbon Steel <small>Material</small>		NA / 5.25" <small>Size / Thickness</small>		66 °F <small>Temp.</small>							
Couplant: Humex <small>Type</small>			98165 <small>Batch No.</small>		Thermometer: <small>Serial No.</small>		3991							
DAC						Instrument Settings								
<div style="display: flex; align-items: center;"><div style="writing-mode: vertical-rl; transform: rotate(180deg); font-weight: bold;">AMPLITUDE</div><div style="flex-grow: 1;"></div><div style="margin-left: 10px; writing-mode: vertical-rl; transform: rotate(180deg); font-weight: bold;">ID Notch</div></div> <div style="margin-top: 10px;"><input type="checkbox"/> Depth <input checked="" type="checkbox"/> Metal Path</div>						<div style="display: flex; justify-content: space-between;"><div>Pulser: High Pulse Energy: High Pulse Width: N/A Rep Rate: Auto Damping: 150 Ohms Display Mode: Fullwave Filter: STD Reject: Off Pulse Amplitude: Fixed</div><div>Frequency: Fixed Range: 8.650" Velocity: .1228 Delay: 0.00 Zero Offset: 16.92 Gain - Axial Scan: 47.5 dB Gain - Circ. Scan: N/A dB <input checked="" type="checkbox"/> Pulse Echo <input type="checkbox"/> Dual</div></div>								
Field Simulator CS Rompas S/N LMT-17						Calibration Verification								
Reflector:			ID Notch	.7" SDH	Initial Calibration Time: 08:02		Verification Times:							
Max Amplitude:			80%	80%	Final Calibration Time: 16:52		N/A	N/A	N/A	N/A				
Sweep:			9.0	1.2										
Gain:			47.5 dB	36.0dB										
Welds Examined				Report No.	Comments									
FWB-D001				I05011	Work Order: 1129008									
FWC-D001				I05017	Work Order: 1129009									
					Wedge S/N:366-001-204									
					Configuration of Elements: Single									
II		04/11/05	Frank Dohmen		4/9/05		JG		4-19-05					
Stevermer, A. Examiner		Level	Date	Dohmen, F. Level III Review		Date	Bowers, J.		Date					
								ANII Review						

Nozzle to RPV Coverage Calculation Sheet

Coverage calculated to requirements of Code Case N-613--I
Note: calculations performed using 2D plot only

Nozzle ID N4

Area required to be examined

Axial scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{2.86} \text{ inches equals } \underline{15.015} \text{ square inches}$$

Parallel scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{2.86} \text{ inches equals } \underline{15.015} \text{ square inches}$$

Total area required to be examined 30.03 square inches required for complete exam

Actual area examined

60 degree R.L. Axial scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{2.86} \text{ inches equals } \underline{15.015} \text{ square inches}$$

Triangular area not examined (if applies) 0.88 1/2 base x 1.54 height equals 0.6776 square inches

Axial scan direction area examined 14.3374 square inches

60 degree R.L. Parallel scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{2.17} \text{ inches equals } \underline{11.3925} \text{ square inches}$$

Additional Inner 15% area achieved using 40 & 45 degree shear techniques: Height x width

$$\underline{0.7875} \text{ inches} \times \underline{0.76} \text{ inches equals } \underline{0.5985} \text{ square inches}$$

Combining all scan directions: 26.3284 square inches for total exam

Divide area examined by required area: equals coverage achieved 87.67 % coverage for total exam

Calculations performed by:


Todd Blechinger


Level III

DAEC Review


Frank Dohmen

Level III

ANIII Review

Jeremy Bowers

4-19-05

ULTRASONIC EXAMINATION DATA SHEET REACTOR PRESSURE VESSEL WELDS

Site: DAEC Report No.: 105017 Calibration Sheet No.: C-071, C-072
Data Sheet No.: N/A

Procedure No.: ACP 1211.27 Rev. 1

(12)

System: <u>Reactor Vessel</u>	Exam Surface Temp.: <u>96</u> °F	Couplant: <u>Humex</u>
Weld ID: <u>FWC-D001</u>	Thermometer S/N: <u>3991</u>	Batch No.: <u>98165</u>

Examination Surface: ID <input type="checkbox"/> OD <input checked="" type="checkbox"/>	Material Type: CS <input checked="" type="checkbox"/> SS <input type="checkbox"/>	Exam Date: <u>4/11/05</u>
L _o Reference: <u>TDC</u>	R _o Reference: <u>WCL</u>	Exam Start: <u>14:40</u>
		Exam End: <u>16:00</u>

Scan Surface	Exam Number	Search Unit Angle	Scan Sensitivity	Exam Number
Perpendicular UpStream	1	60° RL ZONE 1	74.5 dB	1, 3, 4
Perpendicular DownStream	2	60° RL ZONE 2	79.0 dB	1, 3, 4
Parallel CW	3			
Parallel CCW	4			




INDICATIONS

Indication No.	L (In) From Ref			W (In) From Ref			Sweep Reading <input checked="" type="checkbox"/> MP or <input type="checkbox"/> Depth			Max Amp % Dac	Examination (1 - 4)
	L-1	L-Max	L-2	W-1	W-Max	W-2	SW-1 <input type="checkbox"/> M1 <input type="checkbox"/>	SW-Max	SW-2 <input type="checkbox"/> M2 <input type="checkbox"/>		
NRI	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

REMARKS/LIMITATIONS


WO:1129009
Obtained 87.67% coverage of required volume.
See attached coverage plot.

☒ Previous Examination Data Reviewed

 Stevermer, A. Examiner (s)	II Level	04/11/05 Date	 Dohmen, F. Level III Review	4/18/05 Date	 Bowers, J. ANII Review	4-19-05 Date
--	-------------	------------------	---	-----------------	--	-----------------

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-071</u>	
Linearity Sheet No.: <u>L-004</u>			
Procedure No.: <u>ACP 1211.27</u>		Revision: <u>1</u>	
Instrument: <u>Panametrics</u>		Epoch III	
Manufacturer: <u>TRL2-Aust</u>		Model No. <u>01435501</u>	
Search Unit: <u>RTD</u>		Serial No. <u>FS~125 mm</u>	
Manufacturer: <u>00-447</u>		Size: <u>2 (24X42) mm Rectangular</u>	
Cable: <u>2 (RG-174)</u>		Freq. <u>2.0</u> MHz	
Type: <u>12'</u>		Angle / Mode: <u>60° / Long.</u>	
Length: <u>0</u>		Incident to wedge front	
No. of Connectors: <u>0</u>			
Calibration Standard: <u>IE-30</u>		Carbon Steel	
Serial No. <u>NA / 5.25"</u>		Size / Thickness	
Temp. <u>66</u> °F			
Couplant: <u>Humex</u>		Thermometer: <u>3991</u>	
Type: <u>98165</u>		Serial No. <u>3991</u>	
Batch No. <u>3991</u>			

DAC	Instrument Settings																		
 <p style="text-align: center;">Sweep: 0 - 10 = <u>8.003"</u></p> <p><input type="checkbox"/> Depth <input checked="" type="checkbox"/> Metal Path</p>	<table style="width: 100%;"> <tr> <td>Pulser: <u>High</u></td> <td>Frequency: <u>Fixed</u></td> </tr> <tr> <td>Pulse Energy: <u>High</u></td> <td>Range: <u>8.003"</u></td> </tr> <tr> <td>Pulse Width: <u>N/A</u></td> <td>Velocity: <u>.2309</u></td> </tr> <tr> <td>Rep Rate: <u>Auto</u></td> <td>Delay: <u>0.000</u></td> </tr> <tr> <td>Damping: <u>150 Ohms</u></td> <td>Zero Offset: <u>12.38</u></td> </tr> <tr> <td>Display Mode: <u>Fullwave</u></td> <td>Gain - Axial Scan: <u>62.0 dB</u></td> </tr> <tr> <td>Filter: <u>STD</u></td> <td>Gain - Circ. Scan: <u>N/A dB</u></td> </tr> <tr> <td>Reject: <u>Off</u></td> <td><input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual</td> </tr> <tr> <td>Pulse Amplitude: <u>Fixed</u></td> <td></td> </tr> </table>	Pulser: <u>High</u>	Frequency: <u>Fixed</u>	Pulse Energy: <u>High</u>	Range: <u>8.003"</u>	Pulse Width: <u>N/A</u>	Velocity: <u>.2309</u>	Rep Rate: <u>Auto</u>	Delay: <u>0.000</u>	Damping: <u>150 Ohms</u>	Zero Offset: <u>12.38</u>	Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>62.0 dB</u>	Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>	Reject: <u>Off</u>	<input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual	Pulse Amplitude: <u>Fixed</u>	
Pulser: <u>High</u>	Frequency: <u>Fixed</u>																		
Pulse Energy: <u>High</u>	Range: <u>8.003"</u>																		
Pulse Width: <u>N/A</u>	Velocity: <u>.2309</u>																		
Rep Rate: <u>Auto</u>	Delay: <u>0.000</u>																		
Damping: <u>150 Ohms</u>	Zero Offset: <u>12.38</u>																		
Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>62.0 dB</u>																		
Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>																		
Reject: <u>Off</u>	<input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual																		
Pulse Amplitude: <u>Fixed</u>																			

Field Simulator <u>CS Rompas</u> <u>S/N</u> <u>LMT-17</u>			Calibration Verification			
Reflector:	<u>1/4T SDH</u>	<u>2" RAD</u>	Initial Calibration Time:	<u>08:01</u>	Verification Times:	
Max Amplitude:	<u>80%</u>	<u>80%</u>	Final Calibration Time:	<u>16:40</u>	<u>N/A</u>	<u>N/A</u>
Sweep:	<u>4.0</u>	<u>3.4</u>			<u>N/A</u>	<u>N/A</u>
Gain:	<u>62.0 dB</u>	<u>48.0 dB</u>				

Welds Examined	Report No.	Comments
<u>FWB-D001</u>	<u>I05011</u>	<u>WO-1129008</u>
<u>FWC-D001</u>	<u>I05017</u>	<u>WO-1129009</u>
		<u>Squint Angle 3°</u>
		<u>Configuration of Elements: D-SBS</u>
<u>ZONE 1 60° RL CAL</u>		
<u>Stevermer, A.</u>	<u>II</u>	<u>04/11/05</u>
Examiner	Level	Date
<u>Frank Dohmen</u>	<u>4/18/05</u>	<u>39</u>
Dohmen, F.	Date	<u>4-19-05</u>
Level III Review		ANII Review

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-072</u>	
		Linearity Sheet No.: <u>L-004</u>	
Procedure No.: <u>ACP 1211.27</u>		Revision: <u>1</u>	
Instrument: <u>Panametrics</u>		Epoch III	
Manufacturer		Model No.	
Search Unit: <u>RTL2-Aust</u>		Serial No. <u>01435501</u>	
Manufacturer		Model	
Search Unit: <u>FS~125 mm</u>		Size <u>2 (24X42) mm Rectangular</u>	
Manufacturer		Serial No. <u>00-447</u>	
Cable: <u>2 (RG-174)</u>		Freq. <u>2.0</u> MHz	
Type		Angle / Mode <u>60° / Long.</u>	
Length <u>12'</u>		Incident to wedge front <u>1.05"</u>	
No. of Connectors <u>0</u>			
Calibration Standard: <u>IE-30</u>		Carbon Steel	
Serial No.		Material	
Couplant: <u>Humex</u>		NA / 5.25"	
Type		Size / Thickness	
Batch No. <u>98165</u>		Temp. <u>66</u> °F	
Thermometer: <u>3991</u>		Serial No.	

DAC	Instrument Settings
<p style="text-align: center;">Sweep: 0 - 10 = <u>16.27"</u></p> <p><input type="checkbox"/> Depth <input checked="" type="checkbox"/> Metal Path</p>	<p>Pulser: <u>High</u></p> <p>Pulse Energy: <u>High</u></p> <p>Pulse Width: <u>N/A</u></p> <p>Rep Rate: <u>Auto</u></p> <p>Damping: <u>150 Ohms</u></p> <p>Display Mode: <u>Fullwave</u></p> <p>Filter: <u>STD</u></p> <p>Reject: <u>Off</u></p> <p>Pulse Amplitude: <u>Fixed</u></p> <p>Frequency: <u>Fixed</u></p> <p>Range: <u>16.27"</u></p> <p>Velocity: <u>.2309</u></p> <p>Delay: <u>0.000</u></p> <p>Zero Offset: <u>12.38</u></p> <p>Gain - Axial Scan: <u>73.0 dB</u></p> <p>Gain - Circ. Scan: <u>N/A dB</u></p> <p><input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual</p>

Field Simulator <u>CS Rompas</u> S/N <u>LMT-17</u>			Calibration Verification			
Reflector:	<u>ID Notch</u>	<u>2" RAD</u>	Initial Calibration Time:	<u>07:58</u>	Verification Times:	
Max Amplitude:	<u>80%</u>	<u>80%</u>	Final Calibration Time:	<u>16:42</u>	<u>N/A</u>	<u>N/A</u>
Sweep:	<u>7.5</u>	<u>1.2</u>			<u>N/A</u>	<u>N/A</u>
Gain:	<u>73.0 dB</u>	<u>48.0 dB</u>				

Welds Examined	Report No.	Comments
<u>FWB-D001</u>	<u>I05011</u>	<u>WO: 1129008</u>
<u>FWC-D001</u>	<u>I05017</u>	<u>WO: 1129009</u>
		<u>Squint Angle 3°</u>
		<u>Configuration of Elements: D-SBS</u>
		<u>ZONE 2 60° RL CAL</u>
<u>Stevermer, A.</u>	<u>04/11/05</u>	<u>4/18/05</u>
Examiner	Date	Date
	<u>Dohmen, F.</u>	<u>Bowers, J.</u>
	Level III Review	ANII Review

Nozzle to RPV Coverage Calculation Sheet

Coverage calculated to requirements of Code Case N-613-1

Note: calculations performed using 2D plot only

Nozzle ID N4

Area required to be examined

Axial scan direction: Height x width

5.25 inches x 2.86 inches equals 15.015 square inches

Parallel scan direction: Height x width

5.25 inches x 2.86 inches equals 15.015 square inches

Total area required to be examined 30.03 square inches required for complete exam

Actual area examined

60 degree R.L. Axial scan direction: Height x width

5.25 inches x 2.86 inches equals 15.015 square inches

Triangular area not examined (if applies) 0.88 1/2 base x 1.54 height equals 0.6776 square inches

Axial scan direction area examined 14.3374 square inches

60 degree R.L. Parallel scan direction: Height x width

5.25 inches x 2.17 inches equals 11.3925 square inches

Additional Inner 15% area achieved using 40 & 45 degree shear techniques: Height x width

0.7875 inches x 0.76 inches equals 0.5985 square inches

Combining all scan directions: 26.3284 square inches for total exam

Divide area examined by required area: equals coverage achieved 87.67 % coverage for total exam

Calculations performed by:


Todd Blechinger

Level III


DAEC Review


Frank Dohmen

Level III

ANIII Review


Jeremy Bowers


4-19-05

DAEC N4 coverage plot

Axial scan direction

Examiner AK 4-11-05
Review _____
Report # T05017
Page _____ of _____



DAEC N4 coverage plot

Parallel scan direction


Examiner [Signature]

4-11-05

Review _____

Report # 205017

Page _____ of _____



ULTRASONIC EXAMINATION DATA SHEET

NOZZLE TO SHELL WELD AND INNER RADIUS

Site: DAEC

Report No.: I05017

Calibration Sheet No.: C-075 THROUGH C-081

Data Sheet No.: N/A

Procedure No.: ACP 1211.44 Rev. 0

System: <u>Reactor Vessel</u>	Exam Surface Temp.: <u>96</u> °F	Couplant: <u>Humex</u>
Nozzle ID: <u>FWC-Bore, FWC-Nozzle, FWC-D001 IR</u>	Thermometer S/N: <u>3991</u>	Batch No.: <u>98165</u>

Examination Surface: ID <input type="checkbox"/> OD <input checked="" type="checkbox"/>	Material Type: CS <input checked="" type="checkbox"/> SS <input type="checkbox"/>	Exam Date: <u>04/11/05</u>
L ₀ Reference: <u>TDC</u>	R ₀ Reference: <u>WCL</u>	Exam Start: <u>14:40</u>
		Exam End: <u>16:00</u>

Scan Surface	Exam Number	Search Unit Angle / Skew	Scan Sensitivity	Exam Number
Vessel CW	1	21.8° +- 90°	63.5 dB	5, 6
Vessel CCW	2	25° +- 90°	63.5 dB	3, 4
Blend CW	3	40° +- 90°	53.5 dB	3, 4
Blend CCW	4	70° +- 24°	78.5 dB	3, 4
Nozzle Boss CW	5	70° (+- 13° to 36°)	78.5 dB	1, 2
Nozzle Boss CCW	6	45° (+- 59° to 80°)	55.5 dB	1, 2

Ind. #	Transducer Azimuth Location	Indication Metal Path	Transducer 'R' Location	Transducer Skew	Scan Sensitivity	Exam Number
NRI	N/A	N/A	N/A	N/A	N/A	N/A

REMARKS/LIMITATIONS

100% Coverage obtained based on modeling program for nozzle examinations. Reference EPRI report no.: IR-2004-62.

WO: 1129009

☒ Previous Examination Data Reviewed


 Stevenmer, A. Examiner	II Level	<u>04/11/05</u> Date	 Dohmen, F. Level III Review	<u>4/18/05</u> Date	 Bowers, J. ANII Review	<u>4-19-05</u> Date
-------------------------------	-------------	-------------------------	------------------------------------	------------------------	-------------------------------	------------------------

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-080</u>	
		Linearity Sheet No.: <u>L-004</u>	
Procedure No.: <u>ACP 1211.44</u>		Revision: <u>0</u>	
Instrument: <u>Panametrics</u> Manufacturer		Epoch III Model No.	
		01435501 Serial No.	
Search Unit: <u>Krautkramer</u> Manufacturer		Comp G Model	
389-055-750 Model		014XX3 Serial No.	
		.75" Round Size	
Cable: <u>RG-174</u> Type		12' Length	
		0 No. of Connectors	
Calibration Standard: <u>IE-30</u> Serial No.		Carbon Steel Material	
		NA / 5.25" Size / Thickness	
Couplant: <u>Humex</u> Type		98165 Batch No.	
		Thermometer: <u>3991</u> Serial No.	
		66 °F Temp.	
		2.25 MHz Freq.	
		°° / Shear Angle / Mode	
		.8" Incident to wedge front	

DAC

Instrument Settings



Pulser: High
Pulse Energy: High
Pulse Width: N/A
Rep Rate: Auto
Damping: 150 Ohms
Display Mode: Fullwave
Filter: STD
Reject: Off
Pulse Amplitude: Fixed

Frequency: Fixed
Range: 8.650"
Velocity: .1228
Delay: 0.00
Zero Offset: 16.92
Gain - Axial Scan: 47.5 dB
Gain - Circ. Scan: N/A dB
☒ Pulse Echo ☐ Dual

☐ Depth ☒ Metal Path

Field Simulator N/A S/N N/A

Calibration Verification

Reflector:	ID Notch	N/A	Initial Calibration Time:	08:04	Verification Times:			
Max Amplitude:	80%	N/A	Final Calibration Time:	16:58	N/A	N/A	N/A	N/A
Sweep:	9.0	N/A						
Gain:	47.5 dB	N/A						

Welds Examined	Report No.	Comments
FWB-D001	105011	Work Order: 1129008
FWC-D001	105017	Work Order: 1129009
		Wedge S/N:366-003-087
		Configuration of Elements: Single
		* 40° +/- 90°
<u>II</u> Stevermer, A. Examiner	04/11/05 Date	<u>Frank Dohmen</u> Dohmen, F. Level III Review
		<u>4/19/05</u> Date
		<u>Bowers, J.</u> Bowers, J. ANII Review
		<u>4-19-05</u> Date

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: DAEC		Calibration Sheet No.: C-081	
		Linearity Sheet No.: L-004	
Procedure No.: ACP 1211.44		Revision: 0	
Instrument: Panametrics Epoch III		01435501	
Manufacturer		Model No.	
Serial No.			
Search Unit: Krautkramer Comp G		389-055-750 014XX8 .75" Round 2.25 MHz 45° / Shear .8"	
Manufacturer Model Serial No. Size Freq. Angle / Mode Incident to wedge front			
Cable: RG-174 12' 0		No. of Connectors	
Type Length			
Calibration Standard: IE-30 Carbon Steel NA / 5.25"		66 °F	
Serial No. Material Size / Thickness Temp.			
Couplant: Humex 98165		Thermometer: 3991	
Type Batch No. Serial No.			
DAC		Instrument Settings	
		<p>Pulsar: High Pulse Energy: High Pulse Width: N/A Rep Rate: Auto Damping: 150 Ohms Display Mode: Fullwave Filter: STD Reject: Off Pulse Amplitude: Fixed</p> <p>Frequency: Fixed Range: 8.650" Velocity: .1228 Delay: 0.00 Zero Offset: 16.92 Gain - Axial Scan: 47.5 dB Gain - Circ. Scan: N/A dB <input checked="" type="checkbox"/> Pulse Echo <input type="checkbox"/> Dual</p>	
Field Simulator CS Rompas S/N LMT-17		Calibration Verification	
Reflector: ID Notch .7" SDH		Initial Calibration Time: 08:02 Verification Times:	
Max Amplitude: 80% 80%		Final Calibration Time: 16:52 N/A N/A N/A N/A	
Sweep: 9.0 1.2			
Gain: 47.5 dB 36.0dB			
Welds Examined Report No.		Comments	
FWB-D001 I05011		Work Order: 1129008	
FWC-D001 I05017		Work Order: 1129009	
		Wedge S/N:366-001-204	
		Configuration of Elements: Single	
II 04/11/05		4/19/05	
Stevermer, A. Level Date		Dohmen, F. Level III Review Date	
		Bowers, J. ANII Review Date	

ULTRASONIC EXAMINATION DATA SHEET REACTOR PRESSURE VESSEL WELDS

Site: <u>DAEC</u>	Report No.: <u>105019</u>	Calibration Sheet No.: <u>C-067, C-068</u>
		Data Sheet No.: <u>N/A</u>

Procedure No.: ACP 1211.27 Rev. 1

13

System: <u>Reactor Vessel</u>	Exam Surface Temp.: <u>96</u> °F	Couplant: <u>Humex</u>
Weld ID: <u>FWD-D001</u>	Thermometer S/N: <u>3991</u>	Batch No.: <u>98165</u>

Examination Surface: ID <input type="checkbox"/> OD <input checked="" type="checkbox"/>	Material Type: CS <input checked="" type="checkbox"/> SS <input type="checkbox"/>	Exam Date: <u>4/11/05</u>
L _o Reference: <u>TDC</u>	R _o Reference: <u>WCL</u>	Exam Start: <u>12:15</u>
		Exam End: <u>13:50</u>

Scan Surface	Exam Number	Search Unit Angle	Scan Sensitivity	Exam Number
Perpendicular UpStream	1	60° RL ZONE 1	74.5 dB	1, 3, 4
Perpendicular DownStream	2	60° RL ZONE 2	79.0 dB	1, 3, 4
Parallel CW	3			
Parallel CCW	4			

INDICATIONS

Indication No.	L (In) From Ref			W (In) From Ref			Sweep Reading <input checked="" type="checkbox"/> MP or <input type="checkbox"/> Depth			Max Amp % Dac	Examination (1 - 4)
	L-1	L-Max	L-2	W-1	W-Max	W-2	SW-1 M1 <input type="checkbox"/>	SW-Max	SW-2 M2 <input type="checkbox"/>		
NRI	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

REMARKS/LIMITATIONS

WO:1129010
Obtained 87.67% coverage of required volume.
See attached coverage plot.

☒ Previous Examination Data Reviewed

 VanRuler, C. Examiner (s)	II Level	04/11/05 Date	 4PB Dohmen, F. Level III Review	4/18/05 Date	 Bowers, J. ANII Review
----------------------------------	-------------	------------------	--	-----------------	-------------------------------

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-0067</u>	
		Linearity Sheet No.: <u>L-004</u>	
Procedure No.: <u>ACP 1211.27</u>		Revision: <u>1</u>	
Instrument: <u>Panametrics</u>		Epoch III	
Manufacturer: <u>TRL2-Aust</u>		Model No. <u>00-447</u>	
Serial No. <u>2 (24X42) mm</u>		Serial No. <u>01435501</u>	
Search Unit: <u>RTD</u>		Size <u>2.0</u> MHz	
Manufacturer: <u>FS~125 mm</u>		Angle / Mode <u>60° / Long.</u>	
Model: <u>12'</u>		Incident to wedge front <u>1.05"</u>	
Cable: <u>2 (RG-174)</u>		No. of Connectors <u>0</u>	
Type: <u>12'</u>			
Length: <u>0</u>			
Calibration Standard: <u>IE-30</u>		Carbon Steel	
Serial No. <u>NA / 5.25"</u>		Size / Thickness <u>66</u> °F	
Temp. <u>3991</u>			
Couplant: <u>Humex</u>		Thermometer: <u>3991</u>	
Type: <u>98165</u>		Serial No. <u>3991</u>	
Batch No. <u>3991</u>			

<p style="text-align: center;">DAC</p> <p style="text-align: center;">Sweep: 0 - 10 = <u>8.003"</u></p> <p><input type="checkbox"/> Depth <input checked="" type="checkbox"/> Metal Path</p>	<p style="text-align: center;">Instrument Settings</p> <table style="width: 100%;"> <tr> <td>Pulser: <u>High</u></td> <td>Frequency: <u>Fixed</u></td> </tr> <tr> <td>Pulse Energy: <u>High</u></td> <td>Range: <u>8.003"</u></td> </tr> <tr> <td>Pulse Width: <u>N/A</u></td> <td>Velocity: <u>.2309</u></td> </tr> <tr> <td>Rep Rate: <u>Auto</u></td> <td>Delay: <u>0.000</u></td> </tr> <tr> <td>Damping: <u>150 Ohms</u></td> <td>Zero Offset: <u>12.38</u></td> </tr> <tr> <td>Display Mode: <u>Fullwave</u></td> <td>Gain - Axial Scan: <u>62.0 dB</u></td> </tr> <tr> <td>Filter: <u>STD</u></td> <td>Gain - Circ. Scan: <u>N/A dB</u></td> </tr> <tr> <td>Reject: <u>Off</u></td> <td><input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual</td> </tr> <tr> <td>Pulse Amplitude: <u>Fixed</u></td> <td></td> </tr> </table>	Pulser: <u>High</u>	Frequency: <u>Fixed</u>	Pulse Energy: <u>High</u>	Range: <u>8.003"</u>	Pulse Width: <u>N/A</u>	Velocity: <u>.2309</u>	Rep Rate: <u>Auto</u>	Delay: <u>0.000</u>	Damping: <u>150 Ohms</u>	Zero Offset: <u>12.38</u>	Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>62.0 dB</u>	Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>	Reject: <u>Off</u>	<input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual	Pulse Amplitude: <u>Fixed</u>	
Pulser: <u>High</u>	Frequency: <u>Fixed</u>																		
Pulse Energy: <u>High</u>	Range: <u>8.003"</u>																		
Pulse Width: <u>N/A</u>	Velocity: <u>.2309</u>																		
Rep Rate: <u>Auto</u>	Delay: <u>0.000</u>																		
Damping: <u>150 Ohms</u>	Zero Offset: <u>12.38</u>																		
Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>62.0 dB</u>																		
Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>																		
Reject: <u>Off</u>	<input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual																		
Pulse Amplitude: <u>Fixed</u>																			

Field Simulator <u>CS Rompas</u> S/N <u>LMT-17</u>			Calibration Verification			
Reflector:	<u>1/4T SDH</u>	<u>2" RAD</u>	Initial Calibration Time:	<u>08:01</u>	Verification Times:	
Max Amplitude:	<u>80%</u>	<u>80%</u>	Final Calibration Time:	<u>16:40</u>	<u>N/A</u>	<u>N/A</u>
Sweep:	<u>4.0</u>	<u>3.4</u>				
Gain:	<u>62.0 dB</u>	<u>48.0 dB</u>				

Welds Examined	Report No.	Comments
<u>FWD-D001</u>	<u>105019</u>	<u>Squint Angle 3°</u>
		<u>Configuration of Elements: D-SBS</u>
		<u>ZONE 1 60° RL CAL</u>
		<u>WORK ORDER: 1129010</u>
<u>VanRuler, C.</u>	<u>II</u>	<u>4/11/05</u>
Examiner	Level	Date
<u>Dohmen, F.</u>	<u>Level III Review</u>	<u>4/18/05</u>
		Date
<u>Bowers, J.</u>	<u>ANII Review</u>	<u>4-20-05</u>
		Date

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-0068</u>	
		Linearity Sheet No.: <u>L-004</u>	
Procedure No.: <u>ACP 1211.27</u>		Revision: <u>1</u>	
Instrument: <u>Panametrics</u> Manufacturer		Epoch III Model No. <u>01435501</u> Serial No.	
Search Unit: <u>RTD</u> Manufacturer		TRL2-Aust Model <u>FS-125 mm</u> Serial No. <u>00-447</u>	
Cable: <u>2 (RG-174)</u> Type		<u>12'</u> Length	
		<u>0</u> No. of Connectors	
Calibration Standard: <u>IE-30</u> Serial No.		Carbon Steel Material	
		NA / 5.25" Size / Thickness	
Couplant: <u>Humex</u> Type		98165 Batch No.	
		Thermometer: <u>3991</u> Serial No.	
		2 (24X42) mm Rectangular Size	
		2.0 Freq. MHz	
		60° / Long. Angle / Mode	
		1.05" Incident to wedge front	

DAC	Instrument Settings																		
	<table style="width: 100%;"> <tr> <td>Pulser: <u>High</u></td> <td>Frequency: <u>Fixed</u></td> </tr> <tr> <td>Pulse Energy: <u>High</u></td> <td>Range: <u>16.27"</u></td> </tr> <tr> <td>Pulse Width: <u>N/A</u></td> <td>Velocity: <u>.2309</u></td> </tr> <tr> <td>Rep Rate: <u>Auto</u></td> <td>Delay: <u>0.000</u></td> </tr> <tr> <td>Damping: <u>150 Ohms</u></td> <td>Zero Offset: <u>12.38</u></td> </tr> <tr> <td>Display Mode: <u>Fullwave</u></td> <td>Gain - Axial Scan: <u>73.0 dB</u></td> </tr> <tr> <td>Filter: <u>STD</u></td> <td>Gain - Circ. Scan: <u>N/A dB</u></td> </tr> <tr> <td>Reject: <u>Off</u></td> <td><input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual</td> </tr> <tr> <td>Pulse Amplitude: <u>Fixed</u></td> <td></td> </tr> </table>	Pulser: <u>High</u>	Frequency: <u>Fixed</u>	Pulse Energy: <u>High</u>	Range: <u>16.27"</u>	Pulse Width: <u>N/A</u>	Velocity: <u>.2309</u>	Rep Rate: <u>Auto</u>	Delay: <u>0.000</u>	Damping: <u>150 Ohms</u>	Zero Offset: <u>12.38</u>	Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>73.0 dB</u>	Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>	Reject: <u>Off</u>	<input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual	Pulse Amplitude: <u>Fixed</u>	
Pulser: <u>High</u>	Frequency: <u>Fixed</u>																		
Pulse Energy: <u>High</u>	Range: <u>16.27"</u>																		
Pulse Width: <u>N/A</u>	Velocity: <u>.2309</u>																		
Rep Rate: <u>Auto</u>	Delay: <u>0.000</u>																		
Damping: <u>150 Ohms</u>	Zero Offset: <u>12.38</u>																		
Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>73.0 dB</u>																		
Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>																		
Reject: <u>Off</u>	<input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual																		
Pulse Amplitude: <u>Fixed</u>																			

Field Simulator <u>CS Rompas</u> S/N <u>LMT-17</u>			Calibration Verification			
Reflector:	ID Notch	2" RAD	Initial Calibration Time:	07:58	Verification Times:	
Max Amplitude:	80%	80%	Final Calibration Time:	16:42	N/A	N/A
Sweep:	7.5	1.2				
Gain:	73.0 dB	48.0 dB				

Welds Examined	Report No.	Comments
FWD-D001	105019	Squint Angle 3°
		Configuration of Elements:
		D-SBS
		ZONE 2 60° RL CAL
		WORK ORDER: 1129010
<u>VanRuler, C.</u> Examiner	II Level	3/4/11/05 Date
	<u>F. Dohmen</u> Level III Review	4/18/05 Date
		<u>J. Bowers</u> ANII Review
		4-20-05 Date

Nozzle to RPV Coverage Calculation Sheet

Coverage calculated to requirements of Code Case N-613

Note: calculations performed using 2D plot only

Nozzle ID N4

Area required to be examined

Axial scan direction: Height x width

5.25 inches x 2.86 inches equals 15.015 square inches

Parallel scan direction: Height x width

6.25 inches x 2.86 inches equals 15.015 square inches

Total area required to be examined 30.03 square inches required for complete exam

Actual area examined

60 degree R.L. Axial scan direction: Height x width

5.25 inches x 2.86 inches equals 15.015 square inches

Triangular area not examined (if applies) 0.88 1/2 base x 1.54 height equals 0.6776 square inches

Axial scan direction area examined 14.3374 square inches

60 degree R.L. Parallel scan direction: Height x width

5.25 inches x 2.17 inches equals 11.3925 square inches

Additional Inner 15% area achieved using 40 & 45 degree shear techniques: Height x width

0.7875 inches x 0.76 inches equals 0.5985 square inches

Combining all scan directions: 26.3284 square inches for total exam

Divide area examined by required area: equals coverage achieved 87.67 % coverage for total exam

Calculations performed by:

Todd Blechinger

Level III

DAEC Review

Frank Dohmen 4/18/05

Level III

ANIII Review

Jeremy Bowers


JB 4-20-05

Axial scan direction

Review ⁷⁷³~~Foster~~ Frank Johnson 4/18/5

Report # 105819

Page _____ of _____



DAEC N4 coverage plot


Parallel scan direction

Examiner Ch. V. K. II 04-11-05

Review Frank Adams 4/18/05


Report # I 05019

Page of



ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>	Calibration Sheet No.: <u>C-065</u>		Linearity Sheet No.: <u>L-004</u>	
Procedure No.: <u>ACP 1211.44</u>	Revision: <u>0</u>			
Instrument: <u>Panametrics</u>	<u>Epoch III</u>		<u>01435501</u>	
<u>Manufacturer</u>	<u>Model No.</u>	<u>Serial No.</u>		
<u>Search Unit:</u>	<u>Comp G</u>	<u>014XX3</u>	<u>.75" Round</u>	<u>2.25 MHz</u>
<u>Krautkramer</u>	<u>389-055-750</u>	<u>Serial No.</u>	<u>Size</u>	<u>Freq.</u>
<u>Manufacturer</u>	<u>Model</u>	<u>Serial No.</u>	<u>Size</u>	<u>Freq.</u>
<u>Cable:</u>	<u>12'</u>	<u>0</u>	<u>°° / Shear</u>	<u>.8"</u>
<u>RG-174</u>	<u>Length</u>	<u>No. of Connectors</u>	<u>Angle / Mode</u>	<u>Incident to wedge front</u>
<u>Type</u>	<u>Length</u>	<u>No. of Connectors</u>	<u>Angle / Mode</u>	<u>Incident to wedge front</u>
Calibration Standard: <u>IE-30</u>	<u>Carbon Steel</u>	<u>NA / 5.25"</u>	<u>66</u>	<u>°F</u>
<u>Serial No.</u>	<u>Material</u>	<u>Size / Thickness</u>	<u>Temp.</u>	
Couplant: <u>Humex</u>	<u>98165</u>	Thermometer: <u>3991</u>		
<u>Type</u>	<u>Batch No.</u>	<u>Serial No.</u>		






Sweep: 0 - 10 = 8.650"

☐ Depth ☒ Metal Path

Instrument Settings

Pulser: High
Pulse Energy: High
Pulse Width: N/A
Rep Rate: Auto
Damping: 150 Ohms
Display Mode: Fullwave
Filter: STD
Reject: Off
Pulse Amplitude: Fixed

Frequency: Fixed
Range: 8.650"
Velocity: .1228
Delay: 0.00
Zero Offset: 16.92
Gain - Axial Scan: 47.5 dB
Gain - Circ. Scan: N/A dB
☒ Pulse Echo ☐ Dual

Field Simulator	N/A	S/N	N/A	Calibration Verification			
Reflector:	ID Notch	N/A	Initial Calibration Time:	08:04	Verification Times:		
Max Amplitude:	80%	N/A	Final Calibration Time:	16:58	N/A	N/A	N/A
Sweep:	9.0	N/A					
Gain:	47.5 dB	N/A					
Welds Examined		Report No.	Comments				
FWD-D001		105019	Work Order: 1129010				
			Wedge S/N:366-003-087				
			Configuration of Elements: Single				
			* 40° +/- 90°				
 VanRuler, C. Examiner		II 04/11/05 Date	 Dohmen, F. Level III Review		4/18/05 Date	 Bowers, J. ANII Review	
						4-20-05 Date	

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-059</u>	
		Linearity Sheet No.: <u>L-004</u>	
Procedure No.: <u>ACP 1211.44</u>		Revision: <u>0</u>	
Instrument: <u>Panametrics</u> Manufacturer		Epoch III Model No. <u>01435501</u> Serial No.	
Search Unit: <u>Krautkramer</u> Manufacturer		Comp G Model <u>389-055-750</u> Serial No. <u>014XX8</u>	
Cable: <u>RG-174</u> Type		<u>12'</u> Length	
		<u>0</u> No. of Connectors	
Calibration Standard: <u>IE-30</u> Serial No.		Carbon Steel Material	
		<u>NA / 5.25"</u> Size / Thickness	
Couplant: <u>Humex</u> Type		Thermometer: <u>3991</u> Serial No.	
DAC		Instrument Settings	
<p style="text-align: center;">Sweep: 0 - 10 = <u>8.650"</u></p> <p><input type="checkbox"/> Depth <input checked="" type="checkbox"/> Metal Path</p>		Pulser: <u>High</u> Pulse Energy: <u>High</u> Pulse Width: <u>N/A</u> Rep Rate: <u>Auto</u> Damping: <u>150 Ohms</u> Display Mode: <u>Fullwave</u> Filter: <u>STD</u> Reject: <u>Off</u> Pulse Amplitude: <u>Fixed</u> Frequency: <u>Fixed</u> Range: <u>8.650</u> Velocity: <u>.1228</u> Delay: <u>0.00</u> Zero Offset: <u>16.92</u> Gain - Axial Scan: <u>47.5 dB</u> Gain - Circ. Scan: <u>N/A dB</u> <input checked="" type="checkbox"/> Pulse Echo <input type="checkbox"/> Dual	
Field Simulator <u>CS Rompas</u> S/N <u>LMT-17</u>		Calibration Verification	
Reflector:	<u>ID Notch</u>	<u>.7" SDH</u>	Initial Calibration Time: <u>08:02</u>
Max Amplitude:	<u>80%</u>	<u>80%</u>	Final Calibration Time: <u>16:52</u>
Sweep:	<u>9.0</u>	<u>1.2</u>	Verification Times:
Gain:	<u>47.5 dB</u>	<u>36.0dB</u>	<u>N/A</u> <u>N/A</u> <u>N/A</u> <u>N/A</u>
Welds Examined	Report No.	Comments	
<u>FWD-D001</u>	<u>105019</u>	<u>Work Order: 1129010</u>	
		<u>Wedge S/N: 366-001-204</u>	
		<u>Configuration of Elements: Single</u>	
<u>VanRuler, C.</u> Examiner	<u>II</u> Level	<u>04/11/05</u> Date	<u>4/11/05</u> Date
		<u>Dohmen, F.</u> Level III Review	<u>Bowers, J.</u> Date
			<u>4-20-05</u> Date
			<u>ANII Review</u>

ULTRASONIC EXAMINATION DATA SHEET NOZZLE TO SHELL WELD AND INNER RADIUS

Site: DAEC

Report No.: I05019

Calibration Sheet No.: C-059 THROUGH C-065

Data Sheet No.: N/A

Procedure No.: ACP 1211.44 Rev. 0

System: <u>Reactor Vessel</u>	Exam Surface Temp.: <u>96</u> °F	Couplant: <u>Humex</u>
Nozzle ID: <u>FWD-Bore, FWD-Nozzle, FWD-D001 IR</u>	Thermometer S/N: <u>3991</u>	Batch No.: <u>98165</u>

Examination Surface: ID <input type="checkbox"/> OD <input checked="" type="checkbox"/>	Material Type: CS <input checked="" type="checkbox"/> SS <input type="checkbox"/>	Exam Date: <u>04/11/05</u>
L _o Reference: <u>TDC</u>	R _o Reference: <u>WCL</u>	Exam Start: <u>12:15</u>
		Exam End: <u>13:50</u>

Scan Surface	Exam Number	Search Unit Angle / Skew	Scan Sensitivity	Exam Number
Vessel CW	1	21.8° +- 90°	63.5 dB	5, 6
Vessel CCW	2	25° +- 90°	63.5 dB	3, 4
Blend CW	3	40° +- 90°	53.5 dB	3, 4
Blend CCW	4	70° +- 24°	78.5 dB	3, 4
Nozzle Boss CW	5	70° (+- 13° to 36°)	78.5 dB	1, 2
Nozzle Boss CCW	6	45° (+- 59° to 80°)	55.5 dB	1, 2




Ind. #	Transducer Azimuth Location	Indication Metal Path	Transducer 'R' Location	Transducer Skew	Scan Sensitivity	Exam Number
NRI	N/A	N/A	N/A	N/A	N/A	N/A

REMARKS/LIMITATIONS

100% Coverage obtained based on modeling program for nozzle examinations. Reference EPRI report no.: IR-2004-62.
21.8° Exam obtained 95.69% of required volume due to thermocouple obstruction.
See attached limitation sheet.

WO: 1129010

☒ Previous Examination Data Reviewed

 VanRuler, C. Examiner	II Level	04/11/05 Date	 Dohmen, F. Level III Review	4/18/05 Date	 Bowers, J. ANII Review	4-20-05 Date
---	-------------	------------------	---	-----------------	--	-----------------

Nozzle to RPV Coverage Calculation Sheet

Coverage Re-calculated using IWB-2500-7(b) volume 60°

Note: calculations performed using 2D plot only

Nozzle ID N4 Feedwater FWB/C/D-D001

Area required to be examined

Axial scan direction: Height x width

$$\underline{4.687} \text{ inches} \times \underline{7.187} \text{ inches equals } \underline{33.685} \text{ square inches}$$

Parallel scan direction: Height x width

$$\underline{4.687} \text{ inches} \times \underline{7.187} \text{ inches equals } \underline{33.685} \text{ square inches}$$

Total area required to be examined 67.371 square inches required for complete exam

Actual area examined

60° R.L. Axial scan direction: Height x width

$$\underline{4.687} \text{ inches} \times \underline{7.187} \text{ inches equals } \underline{33.685} \text{ square inches}$$

Triangular area not examined (if applies) $\frac{2.3}{1.06}$ base x $\frac{3.94}{1.85}$ height equals $\frac{4.531}{0.9805}$ square inches A=bh/2

Axial scan direction area examined 28.174 square inches

60° R.L. Parallel scan direction: Height x width

$$\underline{4.687} \text{ inches} \times \underline{7.187} \text{ inches equals } \underline{33.685} \text{ square inches}$$

Area not examined (if applicable) $\frac{4.687}{4.687}$ height x $\frac{2.95}{1.85}$ width equals $\frac{13.827}{8.671}$ square inches
 $\underline{33.685}$ inches minus area not examined 22.498 inches equals 11.188 square inches

Combining all scan directions: 39.362 square inches for total exam

Divide area examined by required area: equals coverage achieved 58.43 % coverage for total exam

Calculations performed by:	<u>Frank Dohmen</u>	Level	<u>III</u>	58.43	60°
				56.48	45°
				55.4	40°
DAEC Review	<u>Gary Park</u>			170.29	
				56.71	

Nozzle to RPV Coverage Calculation Sheet

Coverage Re-calculated using IWB-2500-7(b) volume 45 degree for Inner 15%

Note: calculations performed using 2D plot only

Nozzle ID N4 Feedwater FWB/C/D-D001

Area required to be examined

Axial scan direction: Height x width

0.703 inches x 7.187 inches equals 5.05246 square inches

Parallel scan direction: Height x width

0.703 inches x 7.187 inches equals 5.05246 square inches

Total area required to be examined 10.1049 square inches required for complete exam

Actual area examined

45 degree Axial scan direction: Height x width

0.703 inches x 7.187 inches equals 5.05246 square inches

Triangular area not examined (if applies) 0.703 1/2 base x 0.703 height equals 0.247 square inches

Rect. area not examined (if applies) 1.127 x 0.703 equals 0.79228

Axial scan direction area examined 4.01308 square inches

45 degree shear Parallel scan direction: Height x width

0.703 inches x 7.187 inches equals 5.05246 square inches

Area not examined (if applies) 2.95 base x 0.703 height equals 2.07385 square inches

Area not examined (if applies) 1.830 base x 0.7030 height equals 1.28649 square inches

Parallel scan direction area examined 1.69212 square inches

Combining all scan directions: 5.7052 square inches for total exam

Divide area examined by required area: equals coverage achieved 56.46 % coverage for total exam

Calculations performed by: Frank Dohmen Level III

DAEC Review Gary Park

ANII Review

Nozzle to RPV Coverage Calculation Sheet

Coverage Re-calculated using IWB-2500-7(b) volume 40 degree for Inner 15%

Note: calculations performed using 2D plot only

Nozzle ID N4 Feedwater FWB/C/D-D001

Area required to be examined

Axial scan direction: Height x width

$$\underline{0.703} \text{ inches} \times \underline{7.187} \text{ inches equals } \underline{5.05246} \text{ square inches}$$

Parallel scan direction: Height x width

$$\underline{0.703} \text{ inches} \times \underline{7.187} \text{ inches equals } \underline{5.05246} \text{ square inches}$$

Total area required to be examined 10.1049 square inches required for complete exam

Actual area examined

40 degree Axial scan direction: Height x width

$$\underline{0.703} \text{ inches} \times \underline{7.187} \text{ inches equals } \underline{5.05246} \text{ square inches}$$

Triangular area not examined⁽¹⁾ (if applies) 0.38 1/2 base x 0.3 height equals 0.057 square inches

Rect. area not examined⁽¹⁾ (if applies) 0 x 0 equals 0

Triangular area not examined⁽²⁾ (if applies) 0.6 1/2 base x 0.703 height equals 0.2109 square inches

Rect. area not examined⁽²⁾ (if applies) 1.25 x 0.703 equals 0.87875

Axial scan direction area examined 3.90581 square inches

40 degree shear Parallel scan direction: Height x width

$$\underline{0.703} \text{ inches} \times \underline{7.187} \text{ inches equals } \underline{5.05246} \text{ square inches}$$

Area not examined (if applies) 2.95 base x 0.703 height equals 2.07385 square inches

Area not examined (if applies) 1.830 base x 0.703 height equals 1.28649

Parallel scan direction area examined 1.69212 square inches

Combining all scan directions: 5.59793 square inches for total exam

Divide area examined by required area: equals coverage achieved 55.4 % coverage for total exam

Calculations performed by: Frank Dohmen Level III


DAEC Review Gary Park

ANII Review

NK's
 $\frac{1}{2}$ NK11


60°

1.05 incident
 wedge front





Parallel
 not
 scanned
 1.85

4 11/16




$N 4 \frac{1}{2}^\circ$

$45 \frac{1}{2}^\circ 40^\circ$
 \downarrow
 $(\frac{1}{2} N H)$




DISTRIBUTION		COPY	DATE
VENDOR	DATE		
CLIENT	DATE		
FIELD	DATE		
QUAL	DATE		
TEST	DATE		
REWORK	DATE		
CHG	DATE		
APPROV	DATE		
REVISION	DATE		

MAY 4 0 1976



LONGITUDINAL SECTION




ATTACHMENT SAFE END TO FORGING

GENERAL ELECTRIC

Atomic Power Equipment Department

WPS #



16 A
ELL ONLY

ULTRASONIC EXAMINATION DATA SHEET **REACTOR PRESSURE VESSEL WELDS**

Site: DAEC Report No.: 105045 Calibration Sheet No.: C-020 C-021
 Data Sheet No.: N/A

Procedure No.: ACP 1211.27 Rev. 1

14

System: <u>Reactor Vessel</u>	Exam Surface Temp.: <u>88</u> °F	Couplant: <u>Ultragel II</u>
Weld ID: <u>RRG-D001</u>	Thermometer S/N: <u>3991</u>	Batch No.: <u>00325</u>

Examination Surface: ID <input type="checkbox"/> OD <input checked="" type="checkbox"/>	Material Type: CS <input checked="" type="checkbox"/> SS <input type="checkbox"/>	Exam Date: <u>04/04/2005</u>
Lo Reference <u>TDC</u>	Ro Reference: <u>WCL</u>	Exam Start: <u>09:10</u>
		Exam End: <u>10:15</u>

Scan Surface	Exam Number
Perpendicular UpStream	1
Perpendicular DownStream	2
Parallel CW	3
Parallel CCW	4

Search Unit Angle	Scan Sensitivity	Exam Number
60° RL ZONE 1	74.5 dB	1, 3, 4
60° RL ZONE 2	72.5 dB	1, 3, 4
N/A	N/A	N/A
N/A	N/A	N/A

INDICATIONS

Indication No.	L (In) From Ref			W (In) From Ref			Sweep Reading <input checked="" type="checkbox"/> MP or <input type="checkbox"/> Depth			Max Amp % Dac	Examination (1 - 4)
	L-1	L-Max	L-2	W-1	W-Max	W-2	SW-1 <input type="checkbox"/> M1 <input type="checkbox"/>	SW-Max	SW-2 <input type="checkbox"/> M2 <input type="checkbox"/>		
NRI	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

REMARKS/LIMITATIONS

Single sided access due to configuration. Reference EPRI Modeling Report no. IR-2004-62 for inner 15% examinations.
 Obtained 80.44% code required volume.
 Obtained 80.44% coverage of required volume.
 See attached coverage plot.

☒ Previous Examination Data Reviewed

 Stevermer, A. Examiner (s)	II Level	04/04/05 Date	 Dohmen, F. Level III Review	4/17/05 Date	 Bowers, J. ANII Review	4-19-05 Date
-----------------------------------	-------------	------------------	------------------------------------	-----------------	-------------------------------	-----------------

Nozzle to RPV Coverage Calculation Sheet

Coverage calculated to requirements of Code Case N-613-1

Note: calculations performed using 2D plot only

Nozzle ID N2G

Area required to be examined

Axial scan direction: Height x width

5.25 inches x 3.008 inches equals 15.792 square inches

Parallel scan direction: Height x width

5.25 inches x 3.008 inches equals 15.792 square inches

Total area required to be examined 31.584 square inches required for complete exam

Actual area examined

60 degree R.L. Axial scan direction: Height x width

5.25 inches x 3.008 inches equals 15.792 square inches

Triangular area not examined (if applies) 1.3 1/2 base x 2.24 height equals 1.456 square inches

Axial scan direction area examined 14.336 square inches

60 degree R.L. Parallel scan direction: Height x width

5.25 inches x 1.95 inches equals 10.2375 square inches

Additional Inner 15% area achieved using 40 & 45 degree shear techniques: Height x width

0.7875 inches x 1.058 inches equals 0.83318 square inches

Combining all scan directions: 25.4067 square inches for total exam

Divide area examined by required area: equals coverage achieved 80.44 % coverage for total exam

Calculations performed by:

Todd Blechinger

Level III

DAEC Review

Frank Dohmen

Level III

ANII Review

Jeremy Bowers

Page of

4-14-05

DAEC N2G Coverage Plot

Axial scan direction

Examiner

Review


Report #

Page

of

4-4-05

105045



DAEC N2G Coverage Plot


Parallel scan direction

Examiner W. J. [Signature] 4-4-05

Review _____

Report # 105045

Page _____ of _____



ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-020</u>	
		Linearity Sheet No.: <u>L-004</u>	
Procedure No.: <u>ACP 1211.27</u>		Revision: <u>1</u>	
Instrument: <u>Panametrics</u> Manufacturer		Epoch III Model No. <u>01435501</u> Serial No.	
Search Unit: <u>RTL</u> Manufacturer		TRL2-AUST FS~125 mm Model	
Cable: <u>2 (RG-174)</u> Type		<u>12'</u> Length	
		<u>0</u> No. of Connectors	
Calibration Standard: <u>IE-30</u> Serial No.		Carbon Steel Material	
		NA / 5.25" Size / Thickness	
Couplant: <u>Ultragel II</u> Type		00325 Batch No.	
		Thermometer: <u>3991</u> Serial No.	

DAC	Instrument Settings																		
<p style="text-align: center;">Sweep: 0 - 10 = <u>8.003"</u></p> <p><input type="checkbox"/> Depth <input checked="" type="checkbox"/> Metal Path</p>	<table style="width: 100%;"> <tr> <td>Pulser: <u>HIGH</u></td> <td>Frequency: <u>FIXED</u></td> </tr> <tr> <td>Pulse Energy: <u>HIGH</u></td> <td>Range: <u>8.003"</u></td> </tr> <tr> <td>Pulse Width: <u>N/A</u></td> <td>Velocity: <u>.2309</u></td> </tr> <tr> <td>Rep Rate: <u>AUTO</u></td> <td>Delay: <u>0.000</u></td> </tr> <tr> <td>Damping: <u>150 OHMs</u></td> <td>Zero Offset: <u>12.38</u></td> </tr> <tr> <td>Display Mode: <u>Full Wave</u></td> <td>Gain - Axial Scan: <u>60.5</u> dB</td> </tr> <tr> <td>Filter: <u>STD</u></td> <td>Gain - Circ. Scan: <u>N/A</u> dB</td> </tr> <tr> <td>Reject: <u>OFF</u></td> <td><input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual</td> </tr> <tr> <td>Pulse Amplitude: <u>Fixed</u></td> <td></td> </tr> </table>	Pulser: <u>HIGH</u>	Frequency: <u>FIXED</u>	Pulse Energy: <u>HIGH</u>	Range: <u>8.003"</u>	Pulse Width: <u>N/A</u>	Velocity: <u>.2309</u>	Rep Rate: <u>AUTO</u>	Delay: <u>0.000</u>	Damping: <u>150 OHMs</u>	Zero Offset: <u>12.38</u>	Display Mode: <u>Full Wave</u>	Gain - Axial Scan: <u>60.5</u> dB	Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A</u> dB	Reject: <u>OFF</u>	<input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual	Pulse Amplitude: <u>Fixed</u>	
Pulser: <u>HIGH</u>	Frequency: <u>FIXED</u>																		
Pulse Energy: <u>HIGH</u>	Range: <u>8.003"</u>																		
Pulse Width: <u>N/A</u>	Velocity: <u>.2309</u>																		
Rep Rate: <u>AUTO</u>	Delay: <u>0.000</u>																		
Damping: <u>150 OHMs</u>	Zero Offset: <u>12.38</u>																		
Display Mode: <u>Full Wave</u>	Gain - Axial Scan: <u>60.5</u> dB																		
Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A</u> dB																		
Reject: <u>OFF</u>	<input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual																		
Pulse Amplitude: <u>Fixed</u>																			

Field Simulator: <u>CS ROMPAS</u> S/N <u>LMT-17</u>			Calibration Verification			
Reflector:	<u>1/4 T SDH</u>	<u>2" RAD</u>	Initial Calibration Time: <u>07:11</u>	Verification Times:		
Max Amplitude:	<u>80%</u>	<u>80%</u>	Final Calibration Time: <u>11:50</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep:	<u>4.0</u>	<u>2.6</u>				
Gain:	<u>60.5 dB</u>	<u>49.1 dB</u>				

Welds Examined	Report No.	Comments:
<u>RRG-D001</u>	<u>105045</u>	<u>Squint Angle 3°</u>
		<u>Configuration of Elements: D-SBS</u>
		<u>ZONE 1 60° RL Cal</u>

 Stevermer, A. Examiner	<u>II</u> Level	<u>04/04/05</u> Date	 Dohmen, F. Level III Review	<u>4/17/05</u> Date	 Bowers, J. ANII Review
-------------------------------	--------------------	-------------------------	------------------------------------	------------------------	-------------------------------

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: DAEC

Calibration Sheet No.: C-021

Linearity Sheet No.: L-004

Procedure No.: ACP 1211.27

Revision: 1

Instrument: Panametrics
Manufacturer

Epoch III
Model No. 01435501
Serial No.

Search Unit: RTL2-AUST FS-125 mm 00-447 2(24x42) 2.0 60° / Long. 1.05"
Manufacturer Model Serial No. Size Freq. MHz Angle / Mode Incident to wedge front


Cable: 2 (RG-174) 12' 0
Type Length No. of Connectors

Calibration Standard: IE-30 Carbon Steel NA / 5.25" 65 °F
Serial No. Material Size / Thickness Temp.

Couplant: Ultragel II 00325 Thermometer: 3991
Type Batch No. Serial No.

DAC

Instrument Settings



Sweep: 0 - 10 = 16.27"

☐ Depth ☒ Metal Path

Pulser: HIGH
Pulse Energy: HIGH
Pulse Width: N/A
Rep Rate: AUTO
Damping: 150 OHMS
Display Mode: Full Wave
Filter: STD
Reject: OFF
Pulse Amplitude: Fixed

Frequency: FIXED
Range: 16.27"
Velocity: .2309
Delay: 0.000
Zero Offset: 12.38
Gain - Axial Scan: 73.0 dB
Gain - Circ. Scan: N/A dB
☐ Pulse Echo ☒ Dual

Field Simulator: CS ROMPAS SIN LMT-017

Calibration Verification

Reflector:	ID NOTCH	2" RAD	Initial Calibration Time: <u>07:09</u>	Verification Times:			
Max Amplitude:	80%	80%	Final Calibration Time: <u>11:49</u>	N/A	N/A	N/A	N/A
Sweep:	7.5	1.2					
Gain:	73.0 dB	49.1 dB					

Welds Examined	Report No.	Comments
RRG-D001	105045	Squint Angle 3°
		Configuration of Elements: D-SBS
		ZONE 2 60° RL Cal

Stevermer, A. II 04/04/05
Examiner Level Date

Frank Dolan 4/12/05
Dohmen, F. Date
Level III Review

JB 4-19-05
Bowers, J. Date
ANII Review

Nozzle to RPV Coverage Calculation Sheet

Coverage Re-calculated using IWB-2500-7(b) volume 60°

Note: calculations performed using 2D plot only

Nozzle ID N2 RRG-D001

Area required to be examined

Axial scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{8.125} \text{ inches equals } \underline{42.656} \text{ square inches}$$

Parallel scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{8.125} \text{ inches equals } \underline{42.656} \text{ square inches}$$

Total area required to be examined 85.313 square inches required for complete exam

Actual area examined

60° R.L. Axial scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{8.125} \text{ inches equals } \underline{42.656} \text{ square inches}$$

Triangular area not examined (if applies)	<u>2.7</u> base	x	<u>4.66</u> height	equals	<u>6.291</u> square inches	A=bh/2
	<u>1.218</u> base	x	<u>2.125</u> height	equals	<u>1.2941</u> square inches	

Axial scan direction area examined 35.071 square inches

60° R.L. Parallel scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{8.125} \text{ inches equals } \underline{42.656} \text{ square inches}$$

Area not examined (if applicable)	<u>5.25</u> height	x	<u>3.6</u> width	equals	<u>18.9</u> square inches
	<u>5.25</u> height	x	<u>2.125</u> width	equals	<u>11.156</u> square inches
<u>42.656</u> inches minus area not examined			<u>30.056</u> inches	equals	<u>12.6</u> square inches

Combining all scan directions: 47.671 square inches for total exam

Divide area examined by required area: equals coverage achieved 55.88 % coverage for total exam

Calculations performed by:	<u>Frank Dohmen</u>	Level	<u>III</u>	<u>55.88</u>	60°
				<u>51.63</u>	40°
				<u>53.85</u>	45°
				<u>161.36</u>	
DAEC Review	<u>Gary Park</u>			<u>53.73</u>	

Nozzle to RPV Coverage Calculation Sheet

Coverage Re-calculated using IWB-2500-7(b) volume 40 degree for Inner 15%

Note: calculations performed using 2D plot only

Nozzle ID N2 RRG-D001

Area required to be examined

Axial scan direction: Height x width

0.7875 inches x 8.125 inches equals 6.39844 square inches

Parallel scan direction: Height x width

0.7875 inches x 8.125 inches equals 6.39844 square inches

Total area required to be examined 12.7969 square inches required for complete exam

Actual area examined

40 degree Axial scan direction: Height x width

0.7875 inches x 8.125 inches equals 6.39844 square inches

Triangular area not examined⁽¹⁾ (if applies) 0.72 1/2 base x 0.7875 height equals 0.2835 square inches

Rect. area not examined⁽¹⁾ (if applies) 0 x 0.7875 equals 0

Triangular area not examined⁽²⁾ (if applies) 0.76 1/2 base x 0.7875 height equals 0.29925 square inches

Rect. area not examined⁽²⁾ (if applies) 1.37 x 0.7875 equals 1.07888

Axial scan direction area examined 4.73681 square inches

40 degree shear Parallel scan direction: Height x width

0.7875 inches x 8.125 inches equals 6.39844 square inches

Area not examined (if applies) 3.625 base x 0.7875 height equals 2.85469 square inches

Area not examined (if applies) 2.125 base x 0.7875 height equals 1.67344

Parallel scan direction area examined 1.87031 square inches

Combining all scan directions: 6.60713 square inches for total exam

Divide area examined by required area: equals coverage achieved 51.63 % coverage for total exam

Calculations performed by: Frank Dohmen Level III

DAEC Review Gary Park

ANII Review

Nozzle to RPV Coverage Calculation Sheet

Coverage Re-calculated using IWB-2500-7(b) volume 45 degree for Inner 15%

Note: calculations performed using 2D plot only

Nozzle ID N2 RRG-D001

Area required to be examined

Axial scan direction: Height x width

0.7875 inches x 8.125 inches equals 6.39844 square inches

Parallel scan direction: Height x width

0.7875 inches x 8.125 inches equals 6.39844 square inches

Total area required to be examined 12.7969 square inches required for complete exam

Actual area examined

45 degree Axial scan direction: Height x width

0.7875 inches x 8.125 inches equals 6.39844 square inches

Triangular area not examined (if applies) 0.75 1/2 base x 0.7875 height equals 0.295 square inches

Rect. area not examined (if applies) 1.375 x 0.7875 equals 1.08281

Axial scan direction area examined 5.02031 square inches

45 degree shear Parallel scan direction: Height x width

0.7875 inches x 8.125 inches equals 6.39844 square inches

Area not examined (if applies) 3.625 base x 0.7875 height equals 2.855 square inches

Area not examined (if applies) 2.125 base x 0.7875 height equals 1.673 square inches

Parallel scan direction area examined 1.87031 square inches

0 inches x 0 inches equals 0 square inches

Combining all scan directions: 6.89063 square inches for total exam


Divide area examined by required area: equals coverage achieved 53.85 % coverage for total exam

Calculations performed by: Frank Dohmen Level III


DAEC Review Gary Park

ANII Review

$\sqrt{2}$'s





No. 3



8/22/07	REVISED PER DURF-U0191	TAK	DA	ALT	RS
10/24/00	REVISED PER DURF-0146	DA	JAH	GP	FED
12/17/99	ISSUED PER DURF-U0133 FOR ECP-1627	JW	TAK	LAL	CEZ
DATE	REVISION	DRFTR	CHK'D	ENGR	VER.

NO.	DESCRIPTION	BILL OF MATL.	PROCED.
1	FORGING	SA508 CLASS 2	
2	SAFE END FORGING	SB-166	
3	SAFE END EXT. FORGING	SA336 CLASS F8 S.S.	
4	CONSUMABLE INSERT	INCONEL 82	
5	1ST CLAD LAYER	309	
6	2ND & 3RD CLAD LAYER	308L	
7	THERMAL SLEEVE	SB-168	
8	THERM. SLEEVE INNER EXT.	304L SA240	
9	SHELL PLATE #1	SA533 CLASS 1 CR.B	
10	THERMAL SLEEVE ADAPTER	SB-166	

REFERENCE DRAWINGS:
APED-B11-2655-096, APED-B11-2655-097



FPI:
Inservice Inspection Program

RECIRCULATION INLET
NOZZLE MK N2A/H

ULTRASONIC EXAMINATION DATA SHEET **REACTOR PRESSURE VESSEL WELDS**

Site: DAEC

Report No.: 105061

Calibration Sheet No.: C-089 THRU C-090

Data Sheet No.: N/A

Procedure No.: ACP 1211.27 Rev. 1

15

System: <u>Reactor Vessel</u>	Exam Surface Temp.: <u>88</u> °F	Couplant: <u>Humex</u>
Weld ID: <u>JPB-D001</u>	Thermometer S/N: <u>3991</u>	Batch No.: <u>98165</u>

Examination Surface: ID <input type="checkbox"/> OD <input checked="" type="checkbox"/>	Material Type: CS <input checked="" type="checkbox"/> SS <input type="checkbox"/>	Exam Date: <u>04/14/05</u>
Lo Reference <u>TDC</u>	Ro Reference: <u>WCL</u>	Exam Start: <u>14:40</u>
		Exam End: <u>15:20</u>

Scan Surface	Exam Number	Search Unit Angle	Scan Sensitivity	Exam Number
Perpendicular UpStream	1	60° RL ZONE 1	76.7 dB	1, 3, 4
Perpendicular DownStream	2	60° RL ZONE 2	74.7 dB	1, 3, 4
Parallel CW	3			
Parallel CCW	4			

INDICATIONS




Indication No.	L (In) From Ref			W (In) From Ref			Sweep Reading <input checked="" type="checkbox"/> MP or <input type="checkbox"/> Depth			Max Amp % Dac	Examination (1 - 4)
	L-1	L-Max	L-2	W-1	W-Max	W-2	SW-1 <input type="checkbox"/> M1 <input type="checkbox"/>	SW-Max	SW-2 <input type="checkbox"/> M2 <input type="checkbox"/>		
NRI	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

REMARKS/LIMITATIONS

WO:1129013

Limitation: 5" x 3" insulation bracket located 12" below nozzle. Obtained 77.86% coverage of required volume. See attached coverage plot.

☒ Previous Examination Data Reviewed

	II	04/14/05		4/19/05		4-26-05
Stevermer, A.	Level	Date	Dohmen, F.	Date	Bowers, J.	Date
Examiner (s)			Level III Review		ANII Review	

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-089</u>	
		Linearity Sheet No.: <u>L-002</u>	
Procedure No.: <u>ACP 1211.27</u>		Revision: <u>1</u>	
Instrument: <u>Panametrics</u> Manufacturer		<u>Epoch III</u> Model No.	
		<u>01448103</u> Serial No.	
Search Unit: <u>RTL2-ST</u> Manufacturer		<u>FS~125 mm</u> Model	
		<u>02-102</u> Serial No.	
		<u>2 (24X42) mm</u> Size	
		<u>2.0</u> MHz Freq.	
		<u>60° / RL</u> Angle / Mode	
		<u>1.05"</u> Incident to wedge front	
Cable: <u>2 (RG-174)</u> Type		<u>12'</u> Length	
		<u>0</u> No. of Connectors	
Calibration Standard: <u>1E-30</u> Serial No.		<u>Carbon Steel</u> Material	
		<u>NA / 5.25"</u> Size / Thickness	
		<u>66</u> °F Temp.	
Couplant: <u>Humex</u> Type		<u>98165</u> Batch No.	
		Thermometer: <u>3991</u> Serial No.	




DAC

Sweep: 0 - 10 = 6.329"

☐ Depth ☒ Metal Path

Instrument Settings

Pulser:	<u>High</u>	Frequency:	<u>Fixed</u>
Pulse Energy:	<u>High</u>	Range:	<u>6.329"</u>
Pulse Width:	<u>N/A</u>	Velocity:	<u>.2332</u>
Rep Rate:	<u>Auto</u>	Delay:	<u>0.0</u>
Damping:	<u>150 ohms</u>	Zero Offset:	<u>12.98</u>
Display Mode:	<u>Full Wave</u>	Gain - Axial Scan:	<u>62.7</u> dB
Filter:	<u>STD</u>	Gain - Circ. Scan:	<u>N/A</u> dB
Reject:	<u>Off</u>	<input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual	
Pulse Amplitude:	<u>Fixed</u>		

Field Simulator			CS Rompas		S/N	LMT-17	Calibration Verification			
Reflector:	1/4T SDH	2" RAD.	Initial Calibration Time:		08:56		Verification Times:			
Max Amplitude:	80%	80%	Final Calibration Time:		16:02		N/A	N/A	N/A	N/A
Sweep:	4.0	3.2								
Gain:	62.7dB	47.6 dB								
Welds Examined			Report No.			Comments				
JPB-D001			I05061			Work Order: 1129013				
						Squint Angle 5°				
						Configuration of Elements: D-SBS				
						ZONE1				
 Stevermer, A. Examiner			II	04/14/05	 Dohmen, F. Level III Review	4/19/05	 Bowers, J. ANII Review	4-2005	Date	


ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-090</u>	
Linearity Sheet No.: <u>L-002</u>			
Procedure No.: <u>ACP 1211.27</u>		Revision: <u>1</u>	
Instrument: <u>Panametrics</u> Manufacturer		Epoch III Model No. <u>01448103</u> Serial No.	
Search Unit: <u>RTL2-ST</u> Manufacturer <u>RTD</u> FS~125 mm Model <u>02-102</u> 2 (24X42) mm Rectangular Size <u>2.0</u> MHz <u>60° / RL</u> Angle / Mode <u>1.05 "</u> Incident to wedge front			
Cable: <u>2 (RG-174)</u> Type <u>12'</u> Length <u>0</u> No. of Connectors			
Calibration Standard: <u>1E-30</u> Serial No. <u>Carbon Steel</u> Material <u>NA / 5.25"</u> Size / Thickness <u>66</u> Temp. <u>°F</u>			
Couplant: <u>Humex</u> Type <u>98165</u> Batch No. <u>Thermometer: 3991</u> Serial No.			
DAC		Instrument Settings	
		<p>Pulser: <u>High</u> Pulse Energy: <u>High</u> Pulse Width: <u>N/A</u> Rep Rate: <u>Auto</u> Damping: <u>150 ohms</u> Display Mode: <u>Full Wave</u> Filter: <u>STD</u> Reject: <u>Off</u> Pulse Amplitude: <u>Fixed</u></p> <p>Frequency: <u>Fixed</u> Range: <u>14.45"</u> Velocity: <u>.2332</u> Delay: <u>12.98</u> Zero Offset: <u>0.0</u> Gain - Axial Scan: <u>71.0 dB</u> Gain - Circ. Scan: <u>N/A dB</u> <input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual</p>	
Field Simulator <u>CS Rompas</u> S/N <u>LMT-17</u>		Calibration Verification	
Reflector: <u>ID Notch</u> <u>2" RAD.</u>		Initial Calibration Time: <u>09:04</u> Verification Times:	
Max Amplitude: <u>80%</u> <u>80%</u>		Final Calibration Time: <u>16:03</u> <u>N/A</u> <u>N/A</u> <u>N/A</u> <u>N/A</u>	
Sweep: <u>7.5</u> <u>1.2</u>			
Gain: <u>71.0 dB</u> <u>47.2 dB</u>			
Welds Examined		Report No.	
JPB-D001		105061	
		Work Order: 1129013	
		Squint Angle 5°	
		Configuration of Elements: D-SBS	
		ZONE2	
II <u>04/14/05</u>		<u>4/18/05</u>	
Stevermer, A. Examiner		Dohmen, F. Level III Review	
Level		Date	
		Bowers, J. ANII Review	
		Date	

DAEC N8 Coverage Plot

Parallel scan direction

Examiner *[Signature]*
Review _____
Report # 105061
Page of



DAEC N8 Coverage Plot


Parallel scan direction

Examiner AS

Review _____

Report # I05061

Page _____ of _____



Nozzle to RPV Coverage Calculation Sheet

Coverage calculated to requirements of Code Case N-613-1

Note: calculations performed using 2D plot only

Nozzle ID N8

Area required to be examined

Axial scan direction: Height x width

5.25 inches x 3.008 inches equals 15.792 square inches

Parallel scan direction: Height x width

5.25 inches x 3.008 inches equals 15.792 square inches

Total area required to be examined 31.584 square inches required for complete exam

Actual area examined

60 degree R.L. Axial scan direction: Height x width

5.25 inches x 3.008 inches equals 14.9803 square inches

Note: Only 94.86% of axial scan surface area examined due to insulation bracket interference

Triangular area not examined (if applies) 1.29 1/2 base x 2.14 height equals 1.3803 square inches

Axial scan direction area examined 13.6 square inches

60 degree R.L. Parallel scan direction: Height x width

5.25 inches x 1.93 inches equals 10.1325 square inches

Additional Inner 15% area achieved using 45 degree shear technique: Height x width

0.7875 inches x 1.09 inches equals 0.85838 square inches

Combining all scan directions: 24.5909 square inches for total exam

Divide area examined by required area: equals coverage achieved 77.86 % coverage for total exam

Calculations performed by:

Todd Blechinger

Level III

DAEC Review

Frank Dohmen

Level III

ANII Review

Jeremy Bowers

JB 4-20-05

Nozzle to RPV Coverage Calculation Sheet

Coverage Re-calculated using IWB-2500-7(b) volume 60°
Note: calculations performed using 2D plot only

Nozzle ID N8 JPB-D001

Area required to be examined

Axial scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{8.187} \text{ inches equals } \underline{42.982} \text{ square inches}$$

Parallel scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{8.187} \text{ inches equals } \underline{42.982} \text{ square inches}$$

Total area required to be examined 85.964 square inches required for complete exam

Actual area examined

60° R.L. Axial scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{8.187} \text{ inches equals } \underline{42.982} \text{ square inches}$$

Triangular area not examined (if applies)	<u>2.52</u>	base	x	<u>4.82</u>	height	equals	<u>6.073</u>	square inches	A=bh/2
	<u>1.24</u>	base	x	<u>2.12</u>	height	equals	<u>1.314</u>	square inches	
Axial scan direction area examined	<u>35.594</u>	square inches		<u>0.828</u>	29.476 sq in	x 94.86% due to bracket		<u>27.961</u>	

60° R.L. Parallel scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{8.187} \text{ inches equals } \underline{42.982} \text{ square inches}$$

Area not examined (if applicable)	<u>5.25</u>	height	x	<u>3.4</u>	width	equals	<u>17.85</u>	square inches
	<u>5.25</u>	height	x	<u>2.12</u>	width	equals	<u>11.13</u>	square inches
<u>42.982</u> inches minus area not examined				<u>28.98</u>	inches	equals	<u>14.0018</u>	square inches

Combining all scan directions: 41.963 square inches for total exam

Divide area examined by required area: equals coverage achieved 48.81 % coverage for total exam

Calculations performed by: Frank Dohmen Level III

DAEC Review Gary Park

48.81	60°
55.58	40°
56.24	45°
160.63	
53.49	

Nozzle to RPV Coverage Calculation Sheet

Coverage Re-calculated using IWB-2500-7(b) volume 40 degree for Inner 15%

Note: calculations performed using 2D plot only

Nozzle ID N8 JPB-D001

Area required to be examined

Axial scan direction: Height x width

0.7875 inches x 8.187 inches equals 6.44726 square inches

Parallel scan direction: Height x width

0.7875 inches x 8.187 inches equals 6.44726 square inches

Total area required to be examined 12.8945 square inches required for complete exam

Actual area examined

40 degree Axial scan direction: Height x width

0.7875 inches x 8.187 inches equals 6.44726 square inches

Triangular area not examined⁽¹⁾ (if applies) 0.26 1/2 base x 0.22 height equals 0.0286 square inches

Rect. area not examined⁽¹⁾ (if applies) 0 x 0 equals 0

Triangular area not examined⁽²⁾ (if applies) 0.645 1/2 base x 0.7875 height equals 0.25397 square inches

Rect. area not examined⁽²⁾ (if applies) 1.49 x 0.7875 equals 1.17338

Axial scan direction area examined 4.99132 square inches

40 degree shear Parallel scan direction: Height x width

0.7875 inches x 8.187 inches equals 6.44726 square inches

Area not examined (if applies) 3.3 base x 0.7875 height equals 2.599 square inches

Area not examined (if applies) 2.125 base x 0.7875 height equals 1.673

Parallel scan direction area examined 2.175 square inches

Combining all scan directions: 7.16639 square inches for total exam

Divide area examined by required area: equals coverage achieved 55.58 % coverage for total exam

Calculations performed by: Frank Dohmen Level III

DAEC Review Gary Park

ANII Review

Nozzle to RPV Coverage Calculation Sheet

Coverage Re-calculated using IWB-2500-7(b) volume 45 degree for Inner 15%

Note: calculations performed using 2D plot only

Nozzle ID N8 JPB-D001

Area required to be examined

Axial scan direction: Height x width

0.7875 inches x 8.187 inches equals 6.44726 square inches

Parallel scan direction: Height x width

0.7875 inches x 8.187 inches equals 6.44726 square inches

Total area required to be examined 12.8945 square inches required for complete exam

Actual area examined

45 degree Axial scan direction: Height x width

0.7875 inches x 8.187 inches equals 6.44726 square inches

Triangular area not examined (if applies) 0.75 1/2 base x 0.7875 height equals 0.295 square inches

Rect. area not examined (if applies) 1.365 x 0.7875 equals 1.075

Axial scan direction area examined 5.07701 square inches

45 degree shear Parallel scan direction: Height x width

0.7875 inches x 8.187 inches equals 6.44726 square inches

Area not examined (if applies) 3.3 base x 0.7875 height equals 2.599 square inches

Area not examined (if applies) 2.125 base x 0.7875 height equals 1.673 square inches

Parallel scan direction area examined 2.17508 square inches

Combining all scan directions: 7.25209 square inches for total exam


Divide area examined by required area: equals coverage achieved 56.24 % coverage for total exam

Calculations performed by: Frank Dohmen Level III


DAEC Review Gary Park

ANII Review

JPB 2001



FB W8



ULTRASONIC EXAMINATION DATA SHEET **REACTOR PRESSURE VESSEL WELDS**

Site: DAEC Report No.: I05065 Calibration Sheet No.: C-104, C-105
 Data Sheet No.: N/A

Procedure No.: ACP 1211.27 Rev. 1

17

System: <u>Reactor Vessel</u>	Exam Surface Temp.: <u>99</u> °F	Couplant: <u>Humex</u>
Weld ID: <u>V/B-D001</u>	Thermometer S/N: <u>3991</u>	Batch No.: <u>98165</u>

Examination Surface: ID <input type="checkbox"/> OD <input checked="" type="checkbox"/>	Material Type: CS <input checked="" type="checkbox"/> SS <input type="checkbox"/>	Exam Date: <u>04/12/05</u>
L _o Reference: <u>TDC</u>	R _o Reference: <u>WCL</u>	Exam Start: <u>12:30</u>
		Exam End: <u>13:10</u>

Scan Surface	Exam Number	Search Unit Angle	Scan Sensitivity	Exam Number
Perpendicular UpStream	1	60° RL Zone 1	76.4 dB	1, 3, 4
Perpendicular DownStream	2	60° RL Zone 2	87.6 dB	1, 3, 4
Parallel CW	3	N/A	N/A	N/A
Parallel CCW	4	N/A	N/A	N/A

INDICATIONS

Indication No.	L (In) From Ref			W (In) From Ref			Sweep Reading <input checked="" type="checkbox"/> MP or <input type="checkbox"/> Depth			Max Amp % Dac	Examination (1 - 4)
	L-1	L-Max	L-2	W-1	W-Max	W-2	SW-1 <input type="checkbox"/> M1 <input type="checkbox"/>	SW-Max	SW-2 <input type="checkbox"/> M2 <input type="checkbox"/>		
NRI	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

REMARKS/LIMITATIONS


WO: 1129015
 Single side access due to configuration. Reference EPRI modeling report No. IR-2004-62 for inner 15% examination. Obtained 82.4% coverage of required volume. See attached coverage plot.

☒ Previous Examination Data Reviewed

 Stevermer, A. Examiner (s)	II Level	04/12/05 Date	 Dohmen, F. Level III Review	4/19/05 Date	 Bowers, J. ANII Review	4/20/05 Date
-----------------------------------	-------------	------------------	------------------------------------	-----------------	-------------------------------	-----------------




ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-104</u>	
		Linearity Sheet No.: <u>L-004</u>	
Procedure No.: <u>ACP 1211.27</u>		Revision: <u>1</u>	
Instrument: <u>Panametrics</u>		Epoch III <u>01435501</u>	
Manufacturer		Model No. Serial No.	
Search Unit: <u>RTL</u>	<u>TRL2-Aust</u>	<u>00-447</u>	<u>2 (24X42) mm</u>
Manufacturer	Model	Serial No.	Size
Cable: <u>2 (RG-174)</u>	<u>12'</u>	<u>0</u>	<u>2.0</u> MHz
Type	Length	No. of Connectors	Freq.
Calibration Standard: <u>IE-30</u>		<u>Carbon Steel</u>	<u>NA / 5.25"</u>
Serial No.		Material	Size / Thickness
Couplant: <u>Humex</u>	<u>98165</u>	Thermometer: <u>3991</u>	<u>67</u> °F
Type	Batch No.	Serial No.	

<p style="text-align: center;">DAC</p> <div style="display: flex; align-items: center;">  <div style="margin-left: 10px;"> <p>1/4T SDH</p> </div> </div> <p style="text-align: center;">Sweep: 0 - 10 = <u>8.003"</u></p> <p><input type="checkbox"/> Depth <input checked="" type="checkbox"/> Metal Path</p>	<p style="text-align: center;">Instrument Settings</p> <table style="width: 100%;"> <tr> <td>Pulser: <u>High</u></td> <td>Frequency: <u>Fixed</u></td> </tr> <tr> <td>Pulse Energy: <u>High</u></td> <td>Range: <u>8.003"</u></td> </tr> <tr> <td>Pulse Width: <u>N/A</u></td> <td>Velocity: <u>.2309</u></td> </tr> <tr> <td>Rep Rate: <u>Auto</u></td> <td>Delay: <u>0.00</u></td> </tr> <tr> <td>Damping: <u>150 Ohms</u></td> <td>Zero Offset: <u>12.38</u></td> </tr> <tr> <td>Display Mode: <u>Fullwave</u></td> <td>Gain - Axial Scan: <u>62.4 dB</u></td> </tr> <tr> <td>Filter: <u>STD</u></td> <td>Gain - Circ. Scan: <u>N/A dB</u></td> </tr> <tr> <td>Reject: <u>Off</u></td> <td><input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual</td> </tr> <tr> <td>Pulse Amplitude: <u>Fixed</u></td> <td></td> </tr> </table>	Pulser: <u>High</u>	Frequency: <u>Fixed</u>	Pulse Energy: <u>High</u>	Range: <u>8.003"</u>	Pulse Width: <u>N/A</u>	Velocity: <u>.2309</u>	Rep Rate: <u>Auto</u>	Delay: <u>0.00</u>	Damping: <u>150 Ohms</u>	Zero Offset: <u>12.38</u>	Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>62.4 dB</u>	Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>	Reject: <u>Off</u>	<input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual	Pulse Amplitude: <u>Fixed</u>	
Pulser: <u>High</u>	Frequency: <u>Fixed</u>																		
Pulse Energy: <u>High</u>	Range: <u>8.003"</u>																		
Pulse Width: <u>N/A</u>	Velocity: <u>.2309</u>																		
Rep Rate: <u>Auto</u>	Delay: <u>0.00</u>																		
Damping: <u>150 Ohms</u>	Zero Offset: <u>12.38</u>																		
Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>62.4 dB</u>																		
Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>																		
Reject: <u>Off</u>	<input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual																		
Pulse Amplitude: <u>Fixed</u>																			

Field Simulator <u>CS Rompas</u> S/N <u>LMT-17</u>			Calibration Verification			
Reflector:	<u>1/4T SDH</u>	<u>2" RAD</u>	Initial Calibration Time:	<u>09:17</u>	Verification Times:	
Max Amplitude:	<u>80%</u>	<u>80%</u>	Final Calibration Time:	<u>15:25</u>	<u>N/A</u>	<u>N/A</u>
Sweep:	<u>4.0</u>	<u>2.4</u>			<u>N/A</u>	<u>N/A</u>
Gain:	<u>62.4 dB</u>	<u>47.4 dB</u>				

Welds Examined	Report No.	Comments
<u>VIB-D001</u>	<u>I05065</u>	<u>Work Order: 1129015</u>
		<u>Squint Angle 5°</u>
		<u>Configuration of Elements: D-SBS</u>
		<u>Zone 1 60° RL Cal.</u>

 Stevermer, A. Examiner	II	04/12/05	 Dohmen, F. Level III Review	4/19/05	 Bowers, J. ANII Review	4-20-05
Level	Date	Date	Date			

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-105</u>	
		Linearity Sheet No.: <u>L-004</u>	
Procedure No.: <u>ACP 1211.27</u>		Revision: <u>1</u>	
Instrument: <u>Panametrics</u> Manufacturer		Epoch III Model No. <u>01435501</u> Serial No.	
Search Unit: <u>RTL2-Aust</u> Manufacturer		Model <u>FS-125 mm</u> Serial No. <u>00-447</u>	
Cable: <u>2 (RG-174)</u> Type		<u>12'</u> Length	
Calibration Standard: <u>IE-30</u> Serial No.		Carbon Steel Material	
Couplant: <u>Humex</u> Type		98165 Batch No.	
		Thermometer: <u>3991</u> Serial No.	
DAC		Instrument Settings	
		Pulser: <u>High</u> Pulse Energy: <u>High</u> Pulse Width: <u>N/A</u> Rep Rate: <u>Auto</u> Damping: <u>150 Ohms</u> Display Mode: <u>Fullwave</u> Filter: <u>STD</u> Reject: <u>Off</u> Pulse Amplitude: <u>Fixed</u> 	
<input type="checkbox"/> Depth <input checked="" type="checkbox"/> Metal Path		Frequency: <u>Fixed</u> Range: <u>16.27"</u> Velocity: <u>.2309</u> Delay: <u>0.00</u> Zero Offset: <u>12.38</u> Gain - Axial Scan: <u>75.6 dB</u> Gain - Circ. Scan: <u>N/A dB</u> <input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual	
Field Simulator <u>CS Rompas</u> S/N <u>LMT-17</u>		Calibration Verification	
Reflector:	ID Notch	Initial Calibration Time:	09:15
Max Amplitude:	80%	Final Calibration Time:	15:26
Sweep:	7.5	Verification Times:	
Gain:	75.6 dB	N/A N/A N/A N/A	
Welds Examined		Report No.	
VIB-D001		105065	
		Work Order: 1129015	
		Squint Angle 5°	
		Configuration of Elements: D-SBS	
		Zone 2 60° RL Cal.	
<u>Stevermer, A.</u> Examiner		<u>4/19/05</u> Date	
Level II		Level III Review	
<u>4/19/05</u> Date		<u>4/22/05</u> Date	
Level		ANII Review	

Nozzle to RPV Coverage Calculation Sheet

Coverage calculated to requirements of Code Case N-613-1

Note: calculations performed using 2D plot only

Nozzle ID N11

Area required to be examined

Axial scan direction: Height x width

5.25 inches x 2.859 inches equals 15.0098 square inches

Parallel scan direction: Height x width

5.25 inches x 2.859 inches equals 15.0098 square inches

Total area required to be examined 30.0195 square inches required for complete exam

Actual area examined

60 degree R.L. Axial scan direction: Height x width

5.25 inches x 2.859 inches equals 15.0098 square inches

Triangular area not examined (if applies) 1.33 1/2 base x 2.16 height equals 1.42975 square inches

Axial scan direction area examined 13.58 square inches

60 degree R.L. Parallel scan direction: Height x width

5.25 inches x 1.96 inches equals 10.29 square inches

Additional Inner 15% area achieved using 45 degree shear technique: Height x width

0.7875 inches x 1.1 inches equals 0.86625 square inches

Combining all scan directions: 24.7363 square inches for total exam

Divide area examined by required area: equals coverage achieved 82.4 % coverage for total exam

Calculations performed by:

Todd Blechinger

Level III

DAEC Review

Frank Dohmen

Level III

ANII Review

Jeremy Bowers

4/20/05

DAEC N11 Coverage Plot


Parallel scan direction

Examiner *[Signature]*

Review _____

Report # 105065


Page _____ of _____



DAEC N11 Coverage Plot

Parallel scan direction

Examiner AP
Review _____
Report # 105065
Page _____ of _____



Nozzle to RPV Coverage Calculation Sheet

Coverage Re-calculated using IWB-2500-7(b) volume 45 degree for Inner 15%

Note: calculations performed using 2D plot only

Nozzle ID N11 VIB-D001

Area required to be examined

Axial scan direction: Height x width

$$\underline{0.703} \text{ inches} \times \underline{7.187} \text{ inches equals } \underline{5.05246} \text{ square inches}$$

Parallel scan direction: Height x width

$$\underline{0.703} \text{ inches} \times \underline{7.187} \text{ inches equals } \underline{5.05246} \text{ square inches}$$

Total area required to be examined 10.1049 square inches required for complete exam

Actual area examined

45 degree Axial scan direction: Height x width

$$\underline{0.703} \text{ inches} \times \underline{7.187} \text{ inches equals } \underline{5.05246} \text{ square inches}$$

Triangular area not examined (if applies) $\frac{0.703}{2}$ base x $\frac{0.703}{2}$ height equals 0.2471 square inches

Rect. area not examined (if applies) 1.127×0.703 equals 0.79228

Axial scan direction area examined 4.01308 square inches

45 degree shear Parallel scan direction: Height x width

$$\underline{0.703} \text{ inches} \times \underline{7.187} \text{ inches equals } \underline{5.05246} \text{ square inches}$$

Area not examined (if applies) $2.95 \text{ base} \times \frac{0.703}{2} \text{ height}$ equals 2.074 square inches

Area not examined (if applies) $1.830 \text{ base} \times \frac{0.703}{2} \text{ height}$ equals 1.286 square inches

Parallel scan direction area examined 1.69212 square inches

Combining all scan directions: 5.7052 square inches for total exam

Divide area examined by required area: equals coverage achieved 56.46 % coverage for total exam

Calculations performed by: Frank Dohmen Level III

DAEC Review Gary Park

ANII Review

Nozzle to RPV Coverage Calculation Sheet

Coverage Re-calculated using IWB-2500-7(b) volume 60°
Note: calculations performed using 2D plot only

Nozzle ID N11 VIB-D001

Area required to be examined

Axial scan direction: Height x width

$$\underline{4.687} \text{ inches} \times \underline{7.187} \text{ inches equals } \underline{33.685} \text{ square inches}$$

Parallel scan direction: Height x width

$$\underline{4.687} \text{ inches} \times \underline{7.187} \text{ inches equals } \underline{33.685} \text{ square inches}$$

Total area required to be examined 67.371 square inches required for complete exam

Actual area examined

60° R.L. Axial scan direction: Height x width

$$\underline{4.687} \text{ inches} \times \underline{7.187} \text{ inches equals } \underline{33.685} \text{ square inches}$$

Triangular area not examined (if applies) $\frac{2.3}{1.06}$ base x $\frac{3.94}{1.85}$ height equals $\frac{4.531}{0.9805}$ square inches A=bh/2

Axial scan direction area examined 28.174 square inches

60° R.L. Parallel scan direction: Height x width

$$\underline{4.687} \text{ inches} \times \underline{7.187} \text{ inches equals } \underline{33.685} \text{ square inches}$$

Area not examined (if applicable) $\frac{4.687}{4.687}$ height x $\frac{2.95}{1.85}$ width equals $\frac{13.827}{8.671}$ square inches
 $\frac{4.687}{22.498}$ height x $\frac{1.85}{inches}$ width equals $\frac{8.671}{11.188}$ square inches

33.685 inches minus area not examined

22.498 inches

equals 11.188 square inches

Combining all scan directions: 39.362 square inches for total exam

Divide area examined by required area: equals coverage achieved 58.43 % coverage for total exam


Calculations performed by:	<u>Frank Dohmen</u>	Level	<u>III</u>	58.43	60°
				56.46	45°
DAEC Review	<u>Gary Park</u>			114.89	
				57.45	

3	8/22/07	REVISED PER DURF-U0191	TAK	DA	ALT	RS
2	8/8/95	REVISED PER DURF-0011	DA	GD	SS	SS
1	12-08-94	DRAFTED FOR VESSEL INSPECTION PROGRAM	MS	DF	GP	SS
NO.	DATE	REVISION	DRFTR.	CHK'D.	ENGR.	VER.

NO.	DESCRIPTION	BILL OF MATL.	PROCD.
1	FORGING	SA508 CLASS 2	
2	SAFE END FORGING	SA336 CLASS F8	
3	INSERT	INCONEL 82	
4	1ST CLAD LAYER	309	
5	2ND & 3RD CLAD LAYER	308L	
6	SHELL PLATE #3	SA533 CLASS 1 GR.B	

REFERENCE DRAWING:
APED-B11-2655-109

FPL:
Inservice Inspection Program
Reactor Pressure Vessel Sketch



DWG. NO. VS-01-20
INSTRUMENTATION
NOZZLE MK N11A/B

REV.
3

ULTRASONIC EXAMINATION DATA SHEET REACTOR PRESSURE VESSEL WELDS

Site: DAEC

Report No.: I05064

Calibration Sheet No.: C-117, C-118

Data Sheet No.: N/A

Procedure No.: ACP 1211.27 Rev. 1

16

System: <u>Reactor Vessel</u>	Exam Surface Temp.: <u>88</u> °F	Couplant: <u>Humex</u>
Weld ID: <u>LCA-D001</u>	Thermometer S/N: <u>3991</u>	Batch No.: <u>98165</u>

Examination Surface: ID <input type="checkbox"/> OD <input checked="" type="checkbox"/>	Material Type: CS <input checked="" type="checkbox"/> SS <input type="checkbox"/>	Exam Date: <u>04/12/05</u>
L _o Reference: <u>TDC</u>	R _o Reference: <u>WCL</u>	Exam Start: <u>13:20</u>
		Exam End: <u>14:15</u>

Scan Surface	Exam Number	Search Unit Angle	Scan Sensitivity	Exam Number
Perpendicular UpStream	1	60° RL Zone 1	76.7 dB	1, 3, 4
Perpendicular DownStream	2	60° RL Zone 2	83.0 dB	1, 3, 4
Parallel CW	3	N/A	N/A	N/A
Parallel CCW	4	N/A	N/A	N/A

INDICATIONS											
Indication No.	L (in) From Ref			W (in) From Ref			Sweep Reading <input checked="" type="checkbox"/> MP or <input type="checkbox"/> Depth			Max Amp % Dac	Examination (1 - 4)
	L-1	L-Max	L-2	W-1	W-Max	W-2	SW-1 M1 <input type="checkbox"/>	SW-Max	SW-2 M2 <input type="checkbox"/>		
NRI	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

REMARKS/LIMITATIONS

WO: 1129014


Single side access due to configuration.
Reference EPRI modeling report no. IR-2004-62 for inner 15% examination.
Obtained 63.71% coverage of required volume due to proximity of skirt weld.
See attached coverage plot.

☒ Previous Examination Data Reviewed

 Stevermer, A. Examiner (S)	II	04/12/05	 Dohmen, F. Level III Review	4/19/05	 Bowers, J. ANII Review	4-20-05
-----------------------------------	----	----------	------------------------------------	---------	-------------------------------	---------




ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-117</u>	
		Linearity Sheet No.: <u>L-002</u>	
Procedure No.: <u>ACP 1211.27</u>		Revision: <u>1</u>	
Instrument: <u>Panametrics</u> Manufacturer		Epoch III Model No. <u>01448103</u> Serial No.	
Search Unit: <u>RTL2-ST</u> Manufacturer <u>RTD</u> Model <u>FS~125 mm</u> Serial No. <u>02-102</u> Size <u>2 (24X42) mm Rectangular</u> Freq. <u>2.0</u> MHz Angle / Mode <u>60° / RL</u> Incident to wedge front <u>1.05"</u>			
Cable: <u>2 (RG-174)</u> Type Length <u>12'</u> No. of Connectors <u>0</u>			
Calibration Standard: <u>IE-30</u> Serial No. <u>Carbon Steel</u> Material <u>NA / 5.25"</u> Size / Thickness <u>67</u> Temp. <u>°F</u>			
Couplant: <u>Humex</u> Type <u>98165</u> Batch No. <u>Thermometer: 3991</u> Serial No.			

<p style="text-align: center;">DAC</p> <div style="display: flex; align-items: center;">  <div style="margin-left: 10px;"> <p>1/4T SDH</p> </div> </div> <p style="text-align: center;">Sweep: 0 - 10 = <u>6.329"</u></p> <p><input type="checkbox"/> Depth <input checked="" type="checkbox"/> Metal Path</p>	<p style="text-align: center;">Instrument Settings</p> <table style="width:100%;"> <tr> <td>Pulser: <u>High</u></td> <td>Frequency: <u>Fixed</u></td> </tr> <tr> <td>Pulse Energy: <u>High</u></td> <td>Range: <u>6.329"</u></td> </tr> <tr> <td>Pulse Width: <u>N/A</u></td> <td>Velocity: <u>.2332</u></td> </tr> <tr> <td>Rep Rate: <u>Auto</u></td> <td>Delay: <u>0.00</u></td> </tr> <tr> <td>Damping: <u>150 Ohms</u></td> <td>Zero Offset: <u>12.98</u></td> </tr> <tr> <td>Display Mode: <u>Fullwave</u></td> <td>Gain - Axial Scan: <u>62.7 dB</u></td> </tr> <tr> <td>Filter: <u>STD</u></td> <td>Gain - Circ. Scan: <u>N/A dB</u></td> </tr> <tr> <td>Reject: <u>Off</u></td> <td><input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual</td> </tr> <tr> <td>Pulse Amplitude: <u>Fixed</u></td> <td></td> </tr> </table>	Pulser: <u>High</u>	Frequency: <u>Fixed</u>	Pulse Energy: <u>High</u>	Range: <u>6.329"</u>	Pulse Width: <u>N/A</u>	Velocity: <u>.2332</u>	Rep Rate: <u>Auto</u>	Delay: <u>0.00</u>	Damping: <u>150 Ohms</u>	Zero Offset: <u>12.98</u>	Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>62.7 dB</u>	Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>	Reject: <u>Off</u>	<input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual	Pulse Amplitude: <u>Fixed</u>	
Pulser: <u>High</u>	Frequency: <u>Fixed</u>																		
Pulse Energy: <u>High</u>	Range: <u>6.329"</u>																		
Pulse Width: <u>N/A</u>	Velocity: <u>.2332</u>																		
Rep Rate: <u>Auto</u>	Delay: <u>0.00</u>																		
Damping: <u>150 Ohms</u>	Zero Offset: <u>12.98</u>																		
Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>62.7 dB</u>																		
Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>																		
Reject: <u>Off</u>	<input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual																		
Pulse Amplitude: <u>Fixed</u>																			

Field Simulator <u>CS Rompas</u> S/N <u>LMT-17</u>			Calibration Verification				
Reflector:	<u>1/4T SDH</u>	<u>2" RAD</u>	Initial Calibration Time: <u>09:17</u>	Verification Times:			
Max Amplitude:	<u>80%</u>	<u>80%</u>	Final Calibration Time: <u>15:25</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep:	<u>4.0</u>	<u>3.2</u>					
Gain:	<u>62.7 dB</u>	<u>47.6 dB</u>					

Welds Examined	Report No.	Comments
<u>LCA-D001</u>	<u>105064</u>	<u>Work Order: 1129014</u>
		<u>Squint Angle 5°</u>
		<u>Configuration of Elements: D-SBS</u>
		<u>Zone 1</u>

 Stevevermer, A. Examiner	II Level	04/12/05 Date	 Dohmen, F. Level III Review	4/19/05 Date	 Bowers, J. ANII Review	4-20-05 Date
--	-------------	------------------	---	-----------------	--	-----------------

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-118</u>	
		Linearity Sheet No.: <u>L-002</u>	
Procedure No.: <u>ACP 1211.27</u>		Revision: <u>1</u>	
Instrument: <u>Panametrics</u>		Epoch III	
Manufacturer		Model No.	
Search Unit: <u>RTD</u>		Serial No. <u>01448103</u>	
Manufacturer		Serial No.	
Cable: <u>2 (RG-174)</u>		<u>12'</u>	
Type		Length	
		<u>0</u>	
		No. of Connectors	
Calibration Standard: <u>IE-30</u>		<u>Carbon Steel</u>	
Serial No.		Material	
		<u>NA / 5.25"</u>	
		Size / Thickness	
Couplant: <u>Humex</u>		Thermometer: <u>3991</u>	
Type		Serial No.	
		Batch No.	

DAC	Instrument Settings
<p style="text-align: center;">Sweep: 0 - 10 = <u>14.45"</u></p> <p><input type="checkbox"/> Depth <input checked="" type="checkbox"/> Metal Path</p>	<p>Pulser: <u>High</u></p> <p>Pulse Energy: <u>High</u></p> <p>Pulse Width: <u>N/A</u></p> <p>Rep Rate: <u>Auto</u></p> <p>Damping: <u>150 Ohms</u></p> <p>Display Mode: <u>Fullwave</u></p> <p>Filter: <u>STD</u></p> <p>Reject: <u>Off</u></p> <p>Pulse Amplitude: <u>Fixed</u></p> <p>Frequency: <u>Fixed</u></p> <p>Range: <u>14.45"</u></p> <p>Velocity: <u>.2332</u></p> <p>Delay: <u>12.98</u></p> <p>Zero Offset: <u>0.0</u></p> <p>Gain - Axial Scan: <u>71.0 dB</u></p> <p>Gain - Circ. Scan: <u>N/A dB</u></p> <p><input type="checkbox"/> Pulse Echo <input checked="" type="checkbox"/> Dual</p>

Field Simulator <u>CS Rompas</u> S/N <u>LMT-17</u>			Calibration Verification			
Reflector:	<u>1/4T SDH</u>	<u>2" RAD</u>	Initial Calibration Time:	<u>09:15</u>	Verification Times:	
Max Amplitude:	<u>80%</u>	<u>80%</u>	Final Calibration Time:	<u>15:26</u>	<u>N/A</u>	<u>N/A</u>
Sweep:	<u>7.5</u>	<u>1.2</u>			<u>N/A</u>	<u>N/A</u>
Gain:	<u>71.0 dB</u>	<u>47.2 dB</u>				

Welds Examined	Report No.	Comments
<u>LCA-D001</u>	<u>105064</u>	<u>Work Order: 1129014</u>
		<u>Squint Angle 5°</u>
		<u>Configuration of Elements: D-SBS</u>
		<u>Zone 2</u>

 Stevermer, A. Examiner	II Level	<u>04/12/05</u> Date	 Dohmen, F. Level III Review	<u>4/19/05</u> Date	 Bowers, J. ANII Review	<u>4-20-05</u> Date
-------------------------------	-------------	-------------------------	------------------------------------	------------------------	-------------------------------	------------------------

DAEC N10 Coverage Plot


Axial scan direction

Examiner- *[Signature]*

Review- _____

Report # 105064


Page _____ of _____



DAEC N10 Coverage Plot

Parallell scan direction

Examiner AK
Review _____
Report # 105064
Page _____ of _____



Nozzle to RPV Coverage Calculation Sheet

Coverage Re-calculated using IWB-2500-7(b) volume 60°

Note: calculations performed using 2D plot only

Nozzle ID N10 LCA-D001

Area required to be examined

Axial scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{8.187} \text{ inches equals } \underline{42.982} \text{ square inches}$$

Parallel scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{8.187} \text{ inches equals } \underline{42.982} \text{ square inches}$$

Total area required to be examined 85.964 square inches required for complete exam

Actual area examined

60° R.L. Axial scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{8.187} \text{ inches equals } \underline{42.982} \text{ square inches}$$

Triangular area not examined (if applies) $\frac{1.46}{1.26}$ base x $\frac{3.37}{2.125}$ height equals $\frac{2.460}{1.339}$ square inches A=bh/2

Axial scan direction area examined 39.183 square inches x 62% due to skirt = 24.2934

60° R.L. Parallel scan direction: Height x width

$$\underline{5.25} \text{ inches} \times \underline{8.187} \text{ inches equals } \underline{42.982} \text{ square inches}$$

Area not examined (if applicable) $\frac{5.25}{5.25}$ height x $\frac{3.3}{2.125}$ width equals $\frac{17.325}{11.1563}$ square inches

$\frac{5.25}{5.25}$ height x $\frac{3.3}{2.125}$ width equals $\frac{11.1563}{14.5005}$ square inches

42.982 inches minus area not examined 28.481 inches equals 14.5005 square inches

Combining all scan directions: 38.794 square inches for total exam

Divide area examined by required area: equals coverage achieved 45.13 % coverage for total exam

Calculations performed by: Frank Dohmen Level III

45.13 60

DAEC Review Gary Park

56.3 45

101.43

50.72

Nozzle to RPV Coverage Calculation Sheet

Coverage Re-calculated using IWB-2500-7(b) volume 45 degree for Inner 15%

Note: calculations performed using 2D plot only

Nozzle ID N10 LCA-D001

Area required to be examined

Axial scan direction: Height x width

0.7875 inches x 8.187 inches equals 6.44726 square inches

Parallel scan direction: Height x width

0.7875 inches x 8.187 inches equals 6.44726 square inches

Total area required to be examined 12.8945 square inches required for complete exam

Actual area examined

45 degree Axial scan direction: Height x width

0.7875 inches x 8.187 inches equals 6.44726 square inches

Triangular area not examined (if applies) 0.7875 1/2 base x 0.7875 height equals 0.310 square inches

Rect. area not examined (if applies) 1.3375 x 0.7875 equals 1.053

Axial scan direction area examined 5.0839 square inches

45 degree shear Parallel scan direction: Height x width

0.7875 inches x 8.187 inches equals 6.44726 square inches

Area not examined (if applies) 3.3 base x 0.7875 height equals 2.599 square inches

Area not examined (if applies) 2.125 base x 0.7875 height equals 1.673 square inches

Parallel scan direction area examined 2.17508 square inches

0 inches x 0 inches equals 0 square inches


Combining all scan directions: 7.25898 square inches for total exam

Divide area examined by required area: equals coverage achieved 56.3 % coverage for total exam

Calculations performed by: Frank Dohmen Level III

DAEC Review Gary Park

ANII Review



INCONEL WELD
BUILD-UP PER
WPS-103-2F43)

PT AFTER PWNT

STNLS STL
OVERLAY PER
WPS-103-1F5 R
WPS-M3-1F5F7

③ END PAGE

OUTS OF ETM HEAD

DEFERANCE LINE
PARALLEL TO TAN LINE

E Nozzle
(RADIAL LINE)

105310 2.010

SEE DETAIL B

MACHINE AFTER
CLADLING OPERATION

SEAM

SEE DETAIL A—

$\frac{1}{8}$ MIN

 $\frac{3}{4}$ NOM

5 $\frac{1}{32}$ MIN (SNELL)

5 1/4 (ORDER)

 $5\frac{19}{32}$ (FORGING)

24³

2

३३

 $13\frac{27}{32} - \frac{1}{4} = 13\frac{25}{32}$

LONGITUDINAL SECTION

15

LC-A-P001

SB

F2
↓

J3
↓

J6
↓

J4→

J5→

SLC

1.2-27

17 10 85

Enclosure 3

Description of Examination Limitations for Nozzle LCA-D001

ULTRASONIC EXAMINATION DATA SHEET

NOZZLE TO SHELL WELD AND INNER RADIUS

Site: DAEC

Report No.: 105064

Calibration Sheet No.: C-119 THROUGH C-122

Data Sheet No.: N/A

Procedure No.: ACP 1211.44 Rev. 0

System: <u>Reactor Vessel</u>	Exam Surface Temp.: <u>88</u> °F	Couplant: <u>Humex</u>
Nozzle ID: <u>LCA-D001 IR</u>	Thermometer S/N: <u>3991</u>	Batch No.: <u>98165</u>

Examination Surface: ID <input type="checkbox"/> OD <input checked="" type="checkbox"/>	Material Type: CS <input checked="" type="checkbox"/> SS <input type="checkbox"/>	Exam Date: <u>04/12/05</u>
L _o Reference: <u>TDC</u>	R _o Reference: <u>WCL</u>	Exam Start: <u>13:20</u>
		Exam End: <u>14:15</u>

Scan Surface	Exam Number	Search Unit Angle / Skew	Scan Sensitivity	Exam Number
Vessel CW	1	70° (+- 12°)	73.1 dB	3, 4
Vessel CCW	2	70° (+- 1° to +- 11°)	73.1dB	1, 2
Blend CW	3	45° (+- 43° to +- 64°)	54.5 dB	1, 2
Blend CCW	4	N/A	N/A	N/A
Nozzle Boss CW	5	N/A	N/A	N/A
Nozzle Boss CCW	6			

Ind. #	Transducer Azimuth Location	Indication Metal Path	Transducer 'R' Location	Transducer Skew	Scan Sensitivity	Exam Number
NRI	N/A	N/A	N/A	N/A	N/A	N/A

REMARKS/LIMITATIONS

WO: 1129014
 100% coverage based on modeling program for nozzle examinations.
 Reference EPRI report no. IR-2004-62.
 70° (+- 1° to 11°)
 Exam obtained 71.69% of required volume due to proximity of skirt weld.
 See attached.

☒ Previous Examination Data Reviewed

 Stevenmer, A. Examiner	II Level	04/12/05 Date	 Dohmen, F. Level III Review	4/19/05 Date	 Bowers, J. ANII Review	4-20-05 Date
-------------------------------	-------------	------------------	------------------------------------	-----------------	-------------------------------	-----------------

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-120</u>	
		Linearity Sheet No.: <u>L-004</u>	
Procedure No.: <u>ACP 1211.44</u>		Revision: <u>0</u>	
Instrument: <u>Panametrics</u>		Epoch III	
Manufacturer: <u>Comp G</u>		Model No. <u>01435501</u>	
Search Unit: <u>Krautkramer</u>		Serial No. <u>75"</u>	
Manufacturer: <u>389-055-750</u>		Size: <u>2.25</u> MHz	
Model: <u>014XX9</u>		Angle / Mode: <u>70° / Shear</u>	
Cable: <u>RG-174</u>		Incident to wedge front: <u>0.9"</u>	
Type: <u>12'</u>			
Length: <u>0</u>			
No. of Connectors: <u>0</u>			
Calibration Standard: <u>IE-30</u>		Carbon Steel	
Serial No. <u>NA / 5.25"</u>		Size / Thickness	
Temp. <u>67</u> °F			
Couplant: <u>Humex</u>		Thermometer: <u>3991</u>	
Type		Serial No.	
Batch No.			

<p style="text-align: center;">DAC</p> <div style="display: flex; align-items: center;"> <div style="margin-left: 10px;"> <p>ID Notch</p> </div> </div> <p style="text-align: center;">Sweep: 0 - 10 = <u>23.34"</u></p> <p><input type="checkbox"/> Depth <input checked="" type="checkbox"/> Metal Path</p>	<p style="text-align: center;">Instrument Settings</p> <table style="width: 100%;"> <tr> <td>Pulser: <u>High</u></td> <td>Frequency: <u>Fixed</u></td> </tr> <tr> <td>Pulse Energy: <u>High</u></td> <td>Range: <u>23.34"</u></td> </tr> <tr> <td>Pulse Width: <u>N/A</u></td> <td>Velocity: <u>.1228</u></td> </tr> <tr> <td>Rep Rate: <u>Auto</u></td> <td>Delay: <u>0.0</u></td> </tr> <tr> <td>Damping: <u>150 Ohms</u></td> <td>Zero Offset: <u>23.52</u></td> </tr> <tr> <td>Display Mode: <u>Fullwave</u></td> <td>Gain - Axial Scan: <u>67.1 dB</u></td> </tr> <tr> <td>Filter: <u>STD</u></td> <td>Gain - Circ. Scan: <u>N/A dB</u></td> </tr> <tr> <td>Reject: <u>Off</u></td> <td><input checked="" type="checkbox"/> Pulse Echo <input type="checkbox"/> Dual</td> </tr> <tr> <td>Pulse Amplitude: <u>Fixed</u></td> <td></td> </tr> </table>	Pulser: <u>High</u>	Frequency: <u>Fixed</u>	Pulse Energy: <u>High</u>	Range: <u>23.34"</u>	Pulse Width: <u>N/A</u>	Velocity: <u>.1228</u>	Rep Rate: <u>Auto</u>	Delay: <u>0.0</u>	Damping: <u>150 Ohms</u>	Zero Offset: <u>23.52</u>	Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>67.1 dB</u>	Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>	Reject: <u>Off</u>	<input checked="" type="checkbox"/> Pulse Echo <input type="checkbox"/> Dual	Pulse Amplitude: <u>Fixed</u>	
Pulser: <u>High</u>	Frequency: <u>Fixed</u>																		
Pulse Energy: <u>High</u>	Range: <u>23.34"</u>																		
Pulse Width: <u>N/A</u>	Velocity: <u>.1228</u>																		
Rep Rate: <u>Auto</u>	Delay: <u>0.0</u>																		
Damping: <u>150 Ohms</u>	Zero Offset: <u>23.52</u>																		
Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>67.1 dB</u>																		
Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>																		
Reject: <u>Off</u>	<input checked="" type="checkbox"/> Pulse Echo <input type="checkbox"/> Dual																		
Pulse Amplitude: <u>Fixed</u>																			

Field Simulator <u>CS Rompas</u> S/N <u>LMT-17</u>			Calibration Verification			
Reflector:	<u>ID Notch</u>	<u>2" RAD</u>	Initial Calibration Time: <u>08:30</u>	Verification Times:		
Max Amplitude:	<u>80%</u>	<u>80%</u>	Final Calibration Time: <u>15:29</u>	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
Sweep:	<u>8.1</u>	<u>0.9</u>				
Gain:	<u>67.1 dB</u>	<u>19.8 dB</u>				

Welds Examined	Report No.	Comments
<u>LCA-D001 IR</u>	<u>105064</u>	<u>Work Order: 1129014</u>
		<u>Wedge S/N: 366-001-206</u>
		<u>Configuration of Elements: Single</u>

 Stevermer, A. Examiner	II Level	04/12/05 Date	 Dohmen, F. Level III Review	4/19/05 Date	 Bowers, J. ANII Review
-------------------------------	-------------	------------------	------------------------------------	-----------------	-------------------------------

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-119</u>	
		Linearity Sheet No.: <u>L-004</u>	
Procedure No.: <u>ACP 1211.44</u>		Revision: <u>0</u>	
Instrument: <u>Panametrics</u> Manufacturer		Epoch III Model No. <u>01435501</u> Serial No.	
Search Unit: <u>Krautkramer</u> Manufacturer		Comp G Model <u>389-055-750</u> Serial No. <u>014XX8</u> Size <u>.75" Round</u> Freq. <u>2.25 MHz</u> Angle / Mode <u>45° / Shear</u> Incident to wedge front <u>0.8"</u>	
Cable: <u>RG-174</u> Type		<u>12'</u> Length <u>0</u> No. of Connectors	
Calibration Standard: <u>IE-30</u> Serial No.		Carbon Steel Material <u>NA / 5.25"</u> Size / Thickness <u>88</u> °F Temp.	
Couplant: <u>Humex</u> Type		<u>98165</u> Batch No. Thermometer: <u>3991</u> Serial No.	

DAC	Instrument Settings
<p style="text-align: center;">Sweep: 0 - 10 = <u>8.696"</u></p> <p><input type="checkbox"/> Depth <input checked="" type="checkbox"/> Metal Path</p>	<p>Pulser: <u>High</u> Frequency: <u>Fixed</u></p> <p>Pulse Energy: <u>High</u> Range: <u>8.696"</u></p> <p>Pulse Width: <u>N/A</u> Velocity: <u>.1228</u></p> <p>Rep Rate: <u>Auto</u> Delay: <u>0.0</u></p> <p>Damping: <u>150 Ohms</u> Zero Offset: <u>16.92</u></p> <p>Display Mode: <u>Fullwave</u> Gain - Axial Scan: <u>47.5 dB</u></p> <p>Filter: <u>STD</u> Gain - Circ. Scan: <u>N/A dB</u></p> <p>Reject: <u>Off</u> <input checked="" type="checkbox"/> Pulse Echo <input type="checkbox"/> Dual</p> <p>Pulse Amplitude: <u>Fixed</u></p>

Field Simulator <u>CS Rompas</u> S/N <u>LMT-17</u>			Calibration Verification			
Reflector:	ID Notch	2" RAD	Initial Calibration Time:	08:49	Verification Times:	
Max Amplitude:	80%	80%	Final Calibration Time:	15:33	N/A	N/A
Sweep:	8.9	1.2				
Gain:	47.5 dB	38.4 dB				

Welds Examined	Report No.	Comments
LCA-D001 IR	105064	Work Order: 1129014
		Wedge S/N: 366-001-204
		Configuration of Elements: Single

 Stevermer, A. Examiner	II	04/12/05	 Dohmen, F. Level III Review	4/19/05	 Bowers, J. ANII Review
Level	Date	Date	Date	Date	Date

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-121</u>	
		Linearity Sheet No.: <u>L-004</u>	
Procedure No.: <u>ACP 1211.44</u>		Revision: <u>0</u>	
Instrument: <u>Panametrics</u>		Epoch III	
Manufacturer: <u>Comp G</u>		Model No. <u>01435501</u>	
Serial No. <u>389-055-750</u>		Serial No. <u>01435501</u>	
Search Unit: <u>Krautkramer</u>		2.25 MHz	
Manufacturer: <u>Comp G</u>		Angle / Mode <u>° / Shear</u>	
Model: <u>389-055-750</u>		Incident to wedge front <u>1.0"</u>	
Serial No. <u>014XXB</u>			
Size <u>.75"</u>			
Round <u>0</u>			
Cable: <u>RG-174</u>			
Type <u>12'</u>			
Length <u>0</u>			
No. of Connectors <u>0</u>			
Calibration Standard: <u>IE-30</u>		67 °F	
Serial No. <u>Carbon Steel</u>		Temp. <u>67</u>	
Material <u>NA / 5.25"</u>		Size / Thickness <u>67</u>	
Couplant: <u>Humex</u>		Thermometer: <u>3991</u>	
Type <u>98165</u>		Serial No. <u>3991</u>	
Batch No. <u>3991</u>			

<p style="text-align: center;">DAC</p> <div style="display: flex; align-items: center;"> <div style="margin-left: 10px;"> <p>ID Notch</p> </div> </div> <p style="text-align: center;">Sweep: 0 - 10 = <u>23.34"</u></p> <p><input type="checkbox"/> Depth <input checked="" type="checkbox"/> Metal Path</p>	<p style="text-align: center;">Instrument Settings</p> <table style="width: 100%;"> <tr> <td>Pulser: <u>High</u></td> <td>Frequency: <u>Fixed</u></td> </tr> <tr> <td>Pulse Energy: <u>High</u></td> <td>Range: <u>23.34"</u></td> </tr> <tr> <td>Pulse Width: <u>N/A</u></td> <td>Velocity: <u>1228</u></td> </tr> <tr> <td>Rep Rate: <u>Auto</u></td> <td>Delay: <u>0.0</u></td> </tr> <tr> <td>Damping: <u>150 Ohms</u></td> <td>Zero Offset: <u>23.52</u></td> </tr> <tr> <td>Display Mode: <u>Fullwave</u></td> <td>Gain - Axial Scan: <u>67.1 dB</u></td> </tr> <tr> <td>Filter: <u>STD</u></td> <td>Gain - Circ. Scan: <u>N/A dB</u></td> </tr> <tr> <td>Reject: <u>Off</u></td> <td><input checked="" type="checkbox"/> Pulse Echo <input type="checkbox"/> Dual</td> </tr> <tr> <td>Pulse Amplitude: <u>Fixed</u></td> <td></td> </tr> </table>	Pulser: <u>High</u>	Frequency: <u>Fixed</u>	Pulse Energy: <u>High</u>	Range: <u>23.34"</u>	Pulse Width: <u>N/A</u>	Velocity: <u>1228</u>	Rep Rate: <u>Auto</u>	Delay: <u>0.0</u>	Damping: <u>150 Ohms</u>	Zero Offset: <u>23.52</u>	Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>67.1 dB</u>	Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>	Reject: <u>Off</u>	<input checked="" type="checkbox"/> Pulse Echo <input type="checkbox"/> Dual	Pulse Amplitude: <u>Fixed</u>	
Pulser: <u>High</u>	Frequency: <u>Fixed</u>																		
Pulse Energy: <u>High</u>	Range: <u>23.34"</u>																		
Pulse Width: <u>N/A</u>	Velocity: <u>1228</u>																		
Rep Rate: <u>Auto</u>	Delay: <u>0.0</u>																		
Damping: <u>150 Ohms</u>	Zero Offset: <u>23.52</u>																		
Display Mode: <u>Fullwave</u>	Gain - Axial Scan: <u>67.1 dB</u>																		
Filter: <u>STD</u>	Gain - Circ. Scan: <u>N/A dB</u>																		
Reject: <u>Off</u>	<input checked="" type="checkbox"/> Pulse Echo <input type="checkbox"/> Dual																		
Pulse Amplitude: <u>Fixed</u>																			

Field Simulator <u>N/A</u> <u>S/N</u> <u>N/A</u>			Calibration Verification			
Reflector:	<u>ID Notch</u>	<u>N/A</u>	Initial Calibration Time:	<u>08:30</u>	Verification Times:	
Max Amplitude:	<u>80%</u>	<u>N/A</u>	Final Calibration Time:	<u>15:29</u>	<u>N/A</u>	<u>N/A</u>
Sweep:	<u>8.1</u>	<u>N/A</u>			<u>N/A</u>	<u>N/A</u>
Gain:	<u>67.1 dB</u>	<u>N/A</u>				

Welds Examined	Report No.	Comments
<u>LCA-D001 IR</u>	<u>I05064</u>	<u>Work Order: 1129014</u>
		<u>Wedge S/N: 366-003-097</u>
		<u>Configuration of Elements: Single</u>
		<u>*Angle: 70° - 12°</u>

<u>Stevermer, A.</u> Examiner	II Level	<u>04/12/05</u> Date	<u>Fred Dohmen</u> F. Dohmen, F. Level III Review	<u>4/19/05</u> Date	<u>J. Bowers</u> Bowers, J. ANII Review	<u>4-20-05</u> Date
----------------------------------	-------------	-------------------------	---	------------------------	---	------------------------

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DAEC</u>		Calibration Sheet No.: <u>C-122</u>	
		Linearity Sheet No.: <u>L-004</u>	
Procedure No.: <u>ACP 1211.44</u>		Revision: <u>0</u>	
Instrument: <u>Panametrics</u>		Epoch III	
Manufacturer		Model No.	
Search Unit: <u>Krautkramer</u>		Serial No. <u>01435501</u>	
Comp G			
Manufacturer		Model	
389-055-750		104XX1	
.75"		2.25	
Round		MHz	
Size		Angle / Mode	
Cable: <u>RG-174</u>		1.0"	
Type		Incident to wedge front	
Length			
12'			
No. of Connectors			
0			
Calibration Standard: <u>IE-30</u>		<u>Carbon Steel</u>	
Serial No.		Material	
		Size / Thickness	
		67 °F	
Temp.			
Couplant: <u>Humex</u>		Thermometer: <u>3991</u>	
Type		Serial No.	
98165		Batch No.	
DAC		Instrument Settings	
<p>AMPLITUDE</p> <p>100 90 80 70 60 50 40 30 20 10</p> <p>100 90 80 70 60 50 40 30 20 10</p> <p>0 10</p> <p>Sweep: 0 - 10 = <u>23.34"</u></p> <p><input type="checkbox"/> Depth <input checked="" type="checkbox"/> Metal Path</p> <p>ID Notch</p>		<p>Pulser: <u>High</u></p> <p>Pulse Energy: <u>High</u></p> <p>Pulse Width: <u>N/A</u></p> <p>Rep Rate: <u>Auto</u></p> <p>Damping: <u>150 Ohms</u></p> <p>Display Mode: <u>Fullwave</u></p> <p>Filter: <u>STD</u></p> <p>Reject: <u>Off</u></p> <p>Pulse Amplitude: <u>Fixed</u></p> <p>Frequency: <u>Fixed</u></p> <p>Range: <u>23.34"</u></p> <p>Velocity: <u>.1228</u></p> <p>Delay: <u>0.0</u></p> <p>Zero Offset: <u>23.52</u></p> <p>Gain - Axial Scan: <u>67.1 dB</u></p> <p>Gain - Circ. Scan: <u>N/A dB</u></p> <p><input checked="" type="checkbox"/> Pulse Echo <input type="checkbox"/> Dual</p>	
Field Simulator <u>N/A</u> <u>S/N</u> <u>N/A</u>		Calibration Verification	
Reflector: <u>ID Notch</u>		Initial Calibration Time: <u>08:30</u>	
Max Amplitude: <u>80%</u>		Verification Times:	
Sweep: <u>8.1</u>		<u>N/A</u> <u>N/A</u> <u>N/A</u> <u>N/A</u>	
Gain: <u>67.1 dB</u>			
Welds Examined		Report No.	
LCA-D001 IR		105064	
		Work Order: 1129014	
		Wedge S/N: 366-003-096	
		Configuration of Elements: Single	
		*Angle: 70° + 12°	
II		04/12/05	
Stevermer, A.		F. Dohmen	
Level		Date	
Examiner		Level III Review	
		4/19/05	
		Date	
		Bowers, J.	
		Date	
		ANII Review	



N10 Limitation Photo

70° +/- (1° to 11°) exam scan surface area was reduced to 826.15 square inches due to proximity of skirt weld. 1152.36 square inches were required for 100% examination. Due to the scan area limitation, only 71.69% of the required volume was examined.

Examiner [Signature] 4/12/05

Review [Signature] 4/12/05

ANII [Signature] 4-20-05


Page ___ of ___

8/22/07	REVISED PER DURF-U0191	TAK	DA	ALT	RS
8/8/95	REVISED PER DURF-0011	DA	GD	SS	SS
12-09-94	DRAFTED FOR VESSEL INSPECTION PROGRAM	MS	DF	GP	SS
DATE	REVISION	DRFTR.	CHK'D.	ENGR.	VER.

NO.	DESCRIPTION	BILL OF MATL.	PROCED.
1	FORGING	SA508 CLASS 2	
2	SAFE END FORGING	SB-166	
3	INSERT	INCONEL 82	
4	1ST CLAD LAYER	309	
5	2ND & 3RD CLAD LAYER	308L	
6	SIDE PLATE	SA533 CLASS 1 GR.B	

FPL:
Inservice Inspection Program
Reactor Pressure Vessel Sketch

REFERENCE DRAWING:
APED-B11-2655-108



DWG. NO. CORE DIFF. PRESSURE & LIQUID
CONTROL NOZZLE MK 3110
REV.

Enclosure 4
to NG-07-0809

Enclosure 4

Inservice Inspection Report I01070


ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: DUANE ARNOLD

Calibration Sheet No.: C-092
Linearity Sheet No.: L-027

Procedure No.: ACP 1211.20 Revision: 3

Instrument STAVELEY SONIC 136 399G
Manufacturer Model No. Serial No.
Search Unit KBA 24384 0.25" 2.25 MHz 45° / SHR 0.35"
Manufacturer Serial No. Size Freq. Angle/Mode Incident to wedge front
Cable RG-174 6' 0
Type Length No. of Connectors
Calibration Standard PIPE SEGMENT S/S 4.0" / .337" 68 °F
Material Size/Thickness Temp.
Serial No. IE-18
Couplant HUMEX 00165 Thermometer 3471
Type Batch No. Serial No.



INSTRUMENT SETTINGS

DAC Construction
Gain-Axial Scan 39.4 dB
Gain-Circ. Scan 44.4 dB
Pulse 222 ns
Damping 500 ohms
Rep Rate 4 kHz
Filter 2
Frequency 2.25 MHz
Reject OFF

Sensitivity
Gain-Axial Scan 51.4 dB
Gain-Circ. Scan 56.4 dB
Range 2.0"
Delay 0.176"
Velocity 0.121 in/us
Sweep N/A
Resolution N/A
Jack R ☐ T ☒

Field Simulator: ROMPAS S/N LMT-032

CALIBRATION VERIFICATION

REFLECTOR:	1.0"	2.0"	Initial Calibration Time	0745	Verification Times	
MAX AMPLITUDE:	62%	25%	Final Verification Time	1511	N/A	N/A
SWEEP:	5.0	10.0			N/A	N/A
GAIN: (dB)	35.0	35.0				
WELDS EXAMINED	REPORT NO.	COMMENTS:				
RBB-J001	101070	NONE				
RBB-J002	101201					
RBB-J003	101202					

Chad Olson II 5/1/01
Examiner Level Date

Michael J. L. Review 5/4/01
Level III Review Date

William M. M. Review 5/5/01
ANII Review Date

Page 1 of 1

ULTRASONIC EXAMINATION DATA SHEET (MANUAL PIPING)

Site: <u>DUANE ARNOLD</u>		Report No.: <u>101070</u>	
		Calibration Sheet No.: <u>C-092</u>	
		Data Sheet No.: <u>N/A</u>	
Procedure No.: <u>ACP 1211.20</u>		Revision: <u>3</u>	
System: <u>RECIRC</u>	Exam Surface Temp: <u>68</u> °F	Couplant: <u>HUMEX</u>	Exam Start: <u>1255</u>
Weld ID: <u>RBB-J001</u>	Thermometer S/N: <u>3471</u>	Batch No.: <u>00165</u>	Exam End: <u>1301</u>
Search Unit: <u>45°</u> Examination Surface: ID <input type="checkbox"/> OD <input checked="" type="checkbox"/> Material Type: CS <input type="checkbox"/> SS <input checked="" type="checkbox"/> Other: <u>N/A</u>			
Lo Reference: <u>TOP DEAD CENTER</u>		Axial Scan Sensitivity (dB): <u>51.4</u>	
We Reference: <u>WELD CENTERLINE</u>		Circ Scan Sensitivity (dB): <u>56.4</u>	

		Performed		Indications		
		Yes	No	Yes	No	
Axial: {	1 With Flow	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<div style="display: flex; align-items: center;"> <div style="margin-right: 10px;">Weld Centerline</div> <div style="border: 1px solid black; padding: 5px; text-align: center;"> Component PIPE WELD-O-LET Component </div> <div style="margin-left: 10px; text-align: center;"> ↑ F L O W ↓ </div> </div>
	2 Against Flow	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Circ CW: {	3 Upstream	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
	4 Downstream	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Circ CCW: {	5 Upstream	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
	6 Downstream	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
	7 L-Wave Base Metal	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
	8 Other <u>N/A</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Indication No.	L (in) From Ref			W (in) From Ref			Sweep Reading			Max Amp %DAC	Examination (1 - 8)
	L-1	L-Max	L-2	W-1	W-Max	W-2	SW-1	SW-Max	SW-2		
NRI											

Remarks:
 No Recordable Indications.
 Reviewed previous Data Report # 91-234. No changes were observed.
 Achieved 35.56% code coverage.

<u>Mike Oba</u> <u>II</u> <u>5/16/01</u> Examiner Level Date	<u>[Signature]</u> <u>05/04/01</u> Level III Review Date <u>Fred Johnson</u> <u>5/4/01</u>	<u>William Mueller</u> <u>5/16/01</u> ANII Review Date
---	---	--

Page 1 of 3

NG-143Z Rev. 3

ULTRASONIC CALIBRATION DATA SHEET (MANUAL EXAMINATION)

Site: <u>DUANE ARNOLD</u>		Calibration Sheet No.: <u>C-093</u>	
		Linearity Sheet No.: <u>L-027</u>	
Procedure No.: <u>ACP 1211.20</u>		Revision: <u>3</u>	
Instrument <u>STAVELEY</u>		SONIC 136	
Manufacturer		Model No.	
Serial No.		Serial No.	
Search Unit <u>KBA</u>	<u>24384</u>	<u>0.25"</u>	<u>2.25 MHz</u>
Manufacturer	Serial No.	Size	Freq.
<u>70° / SHR</u>	<u>0.3"</u>	Incident to wedge front	
Angle/Mode			
Cable <u>RG-174</u>	<u>6'</u>	<u>0</u>	
Type	Length	No. of Connectors	
Calibration Standard <u>PIPE SEGMENT</u>	<u>S/S</u>	<u>4.0" / .337"</u>	<u>68 °F</u>
	Material	Size/Thickness	Temp.
Serial No. <u>IE-18</u>			
Couplant <u>HUMEX</u>	<u>00165</u>	Thermometer	<u>3471</u>
Type	Batch No.	Serial No.	

DAC

Sweep: 0 - 10 = 2.0"

☐ Depth ☒ Metal Path

INSTRUMENT SETTINGS

DAC Construction	Sensitivity
Gain-Axial Scan <u>64.0 dB</u>	Gain-Axial Scan <u>58.0 dB</u>
Gain-Circ. Scan <u>N/A</u>	Gain-Circ. Scan <u>N/A</u>
Pulse <u>222 ns</u>	Range <u>2.0"</u>
Damping <u>500 ohms</u>	Delay <u>0.340"</u>
Rep Rate <u>4 kHz</u>	Velocity <u>0.121 in/us</u>
Filter <u>2</u>	Sweep <u>N/A</u>
Frequency <u>2.25 MHz</u>	Resolution <u>N/A</u>
Reject <u>OFF</u>	Jack R <input type="checkbox"/> T <input checked="" type="checkbox"/>

Field Simulator: <u>ROMPAS</u> S/N <u>LMT-032</u>			
REFLECTOR:		Initial Calibration Time	
<u>1.0"</u>	<u>2.0"</u>	<u>0800</u>	Verification Times
MAX AMPLITUDE:	<u>80%</u>	<u>60%</u>	<u>N/A</u>
SWEEP:	<u>5.0</u>	<u>10.0</u>	<u>N/A</u>
GAIN: (dB)	<u>43.0</u>	<u>43.0</u>	<u>N/A</u>
WELDS EXAMINED	REPORT NO.	COMMENTS:	
<u>RBB-J001</u>	<u>101070</u>	<u>NONE</u>	

<u>Clark Olson</u>	<u>II</u>	<u>5/1/01</u>	<u>William Mueller</u>	<u>5/1/01</u>
Examiner	Level	Date	ANII Review	Date
Level III Review		Date	Page <u>1</u> of <u>1</u>	
<u>Frank Olson</u>		<u>5/4/01</u>		

ULTRASONIC EXAMINATION DATA SHEET (MANUAL PIPING)

Site: DUANE ARNOLD Report No.: 101070
 Calibration Sheet No.: C-093
 Data Sheet No.: N/A

Procedure No.: ACP 1211.20 Revision: 3

System: RECIRC Exam Surface Temp: 68 °F Couplant: HUMEX Exam Start: 1248
 Weld ID: RBB-J001 Thermometer S/N: 3471 Batch No.: 00165 Exam End: 1254

Search Unit: 70° SHR Examination Surface: ID ☐ OD ☒ Material Type: CS ☐ SS ☒ Other: N/A
 Lo Reference: TOP DEAD CENTER Axial Scan Sensitivity (dB): 58.0
 Wo Reference: WELD CENTERLINE Circ Scan Sensitivity (dB): N/A

		Performed		Indications			
		Yes	No	Yes	No		
Axial: {	1 With Flow	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<div style="display: flex; align-items: center;"> <div style="margin-right: 10px;">Weld ----- Centerline</div> <div style="border: 1px solid black; padding: 5px; text-align: center;"> Component PIPE WELD-O-LET Component </div> <div style="margin-left: 10px; writing-mode: vertical-rl; transform: rotate(180deg);"> FLOW ↑ </div> </div>	
	2 Against Flow	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		
Circ CW: {	3 Upstream	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
	4 Downstream	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Circ CCW: {	5 Upstream	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
	6 Downstream	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
	7 L-Wave Base Metal	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
	8 Other <u>N/A</u>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

Indication No.	L (in) From Ref			W (in) From Ref			Sweep Reading			Max Amp %DAC	Examination (1 - 8)
	L-1	L-Max	L-2	W-1	W-Max	W-2	SW-1	SW-Max	SW-2		
NRI											

Remarks:
 No Recordable Indications.
 Reviewed previous Data Report # 91-234. No changes were observed. Scanned 6dB below reference to maintain 5% to 20% ID Roll.
 Achieved 35.56% code coverage.

<u>Clark Olson</u> II <u>5/16/01</u> Examiner Level Date	<u>[Signature]</u> <u>05/04/01</u> Level III Review Date <u>Maui Delaney</u> 5/4/01	<u>William Mueller</u> <u>5/16/01</u> ANII Review Date	Page <u>2</u> of <u>3</u>
---	---	---	---------------------------



COVERAGE PLOT SHEET

SITE: DUANE ADD UNIT: 1

PROJECT: RFQ17

REPORT NO.:

101070

SYSTEM: RECIRC

COMPONENT ID NO: RBB-J001

CONFIGURATION: WELD-O-LET

FLOW

→ PIPE

VAU 2.03 0
VAD 2.03 .858
VACW 2.03 1.015
VACCW 2.03 1.015
8.12 2.888

8.12 ³⁵⁵⁶2.888

35.56 %



Chad Olson
EXAMINER

II 5/1/01
LEVEL DATE

Frank Olson
LEVEL HI REVIEW

05/04/01
DATE

PAGE 3 OF 3

5/4/01 William Mueller 5/5/01 A WII

Enclosure 5

Weld HEA-CA-05 Information



COVERAGE PLOT SHEET

SITE: DAEC UNIT: 1

REPORT NO.:

PROJECT: NMCDA001

I01098

SYSTEM: HEAT EXCHANGER "A"


COMPONENT ID NO: HEA-CA-5

CONFIGURATION: HEAD


FLOW



SHELL



TOP VIEW



STABILIZER BRACKETS
@ 90° INTERVALS

SIDE VIEW

Ryan D. Kott
EXAMINER

II
LEVEL

5/3/01
DATE

William M. Kott
LEVEL III REVIEW
5/8/01

05/07/01
DATE


Page 54
PAGE 55 OF 56
5/10/01





HEB-LLP
A RHR TH Exch

9-25-96



Enclosure 6

Original Form U-1 for Residual Heat Removal Heat Exchanger

FORM U-1 MANUFACTURERS' DATA SHEET FOR PRESSURE VESSELS As required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured by Berlin Chapman, Division of Perflex Corporation, Berlin, Wisconsin
(Name and address of Manufacturer)

2. Manufactured for General Electric Company, San Jose, California
(Name and address of Purchaser)

3. Type Vert. Kind Heat Exch. Vessel No. 721201-2 Natl. Bd. No. 4525 Yr. Built 1971
(Horiz. or Vert.) (Tank, Jacketed, Heat Exch.) (Mfrs. Serial) (State & State No.)

Items 4-9 incl. to be completed for ~~XX~~ or shells of heat exchangers.

4. SHELL: Material SA-516-70 T.S. 70000 Nominal Thickness 10 Corrosion 10 In. Allowance 3 Ft. 5 3/4 In. Length 22 Ft. 2 3/8
(Kind and Spec. No.) (Fig. or P.D. & Spec. Min. T.S.)

5. SEAMS: Long Dbl. weld butt T. No R.T. Complete Sectioned No Efficiency 100 %
(Welded, Dbl., Single, Lap, Butt) (Yes or No) (Spot or Complete) (Yes or No)

If riveted describe seams fully on reverse side of form.

6. HEADS (a) Material SA-516-70 T.S. 70000 (b) Material SA-516-70 T.S. 70000
(Top, bottom, ends) Thickness 13/16" Crown Radius 2:1 Elliptical Ratio 2:1 Conical Apex Angle Concave Hemispherical Radius Flat Diameter Side to Pressure (Convex or Concave)

(a) End Shell flange SA-105-2 3 3/8" thick

If removable, bolts used (Material, Spec. No., T.S., Size, Number) Other fastening (Describe or Attach Sketch)

7. STAYBOLTS: (Material) If hollow (Size of Hole) Attachment (Threaded, Welded) Pitch (Horiz.) X (Vert.) Diam. (Nominal)

8. JACKET CLOSURE: (Describe as gage & weld, bar, etc. if bar, give dimensions, if bolted, describe or sketch)

9. Constructed for max. allowable working press. 450 psi at max. temp. 400° F. less than -20° Min. temp. (when Hydrostatic Test Press 675 psi)

Items 10 and 11 to be completed for tube sections.

10. TUBE SHEETS: Stationary. Material SA-516-70 FBX (Kind & Spec. No.) Diam. 51.3 In. Thickness 5/16 In. Attachment Welded
(Subject to Pressure) (Welded, Bolted)

Floating. Material SA-516-70 (Kind & Spec. No.) Diam. 51.3 In. Thickness 5/16 In. Attachment Welded
(Integral part of channel)

11. TUBES: Material SA-240 O.D. 1 In. Thickness 1/8 In. Gage Number 300 Type H
(Kind & Spec. No.) (Straight or U)

Items 12-15 incl. to be completed for ~~XX~~ channels of heat exchangers.

12. SHELL Material SA-516-70 T.S. 70000 Nominal Thickness 1 In. Allowance 3 Ft. 5 3/4 In. Length 22 Ft. 2 3/8
(Kind and Spec. No.) (Fig. or P.D. & Spec. Min. T.S.)

13. SEAMS: Long Dbl. weld butt T. No R.T. Complete Sectioned No Efficiency 100 %
(Welded, Dbl., Single, Lap, Butt) (Yes or No) (Spot or Complete) (Yes or No)

If riveted describe seams fully on reverse side of form.

14. HEADS (a) Material SA-516-70 T.S. 70000 (b) Material SA-516-70 T.S. 70000
(Top, bottom, ends) Thickness 5/16" Crown Radius 2:1 Elliptical Ratio 2:1 Conical Apex Angle Concave Hemispherical Radius Flat Diameter Side to Pressure (Convex or Concave)

(a) Top, bottom, ends Channel SA-105-2 49 3/8"

(c) Floating (Material, Spec. No., T.S., Size, Number) (b) 6h 1" SA-193 B7

If removable, bolts used (a) (Material, Spec. No., T.S., Size, Number) Other fastening (Describe or Attach Sketch)

15. Constructed for max. allowable working press. 450 psi at max. temp. 400° F. less than -20° Min. temp. (when Hydrostatic Test Press 675 psi)

Items below to be completed for all vessels where applicable.

16. SAFETY VALVE OUTLETS: Number 2 Size 3/4" Location Shell

17. NOZZLES

Port (Inlet, Outlet, Drain)	Number	Diam. or Size	Type	Material	Thickness	Reinforcement Material	How Attached
Inlet	1	16"	Weld end	SA-105-2	1 7/16"		Welded
Outlet	1	16"	Weld end	SA-105-2	1"		Welded
Vent - Drain	2	1"	S.W. Cplg.	SA-105-2			Welded
Drain	1	1"	S.W. Cplg.	SA-105-2			Welded
Level Ind.	2	3/4"	S.W. Cplg.	SA-105-2			Welded

1" test weld heat-treated.

List under remarks other internal or external pressures with coincident temperature when applicable.