	Survey U	Init Release R	ecord	
Design #	EP-WHB-111-3	Revision #	Original	Page 1 of 3
Survey Unit #(s)		W	HB-111-3	
Description	2) EP WHB-111-3 Status Survey Plan  3) Surveys in EP W optimized to measu 3-3 from Survey Re  4) Survey Instruction in accordance with Work Execution Pa document constitute acquisition of surve  5) Instrument efficient	Plum Brook Readis a Class 1, Grook (FSSP) and Technology (FSSP) an	up 3.3 survey un hnical Basis Doc performed using ies representative vas referenced for ey unit are incorpock Services Inco 5-006. Survey incods" and the sur- ions are develop determinations a	nit as per the PBRF Final cument (TBD)-06-004.  It is a scintillation detector to of Cs-137. Sample #EFF or this decision.  It is decision.  I
	Approval Signat	ures		Date:
FSS/Characterizatio		I Rudi	M	10-31-07
Technical Rev FSS/Characterizatio		Mulooc	Q	10-31-07
FSS/Characterizatio	n Manager	R. Cast	Ol -	11/7/00

Form CS-09/1 Rev 0

FSS Design # EP WHB-111-3	Revision # Original	Page 2 of 3
Survey Unit: WHB-111-3		7

## 1.0 History/Description

- 1.1 The subject pipe system is the laundry drain line located on the Waste Handling Building (WHB) -5' el.
- 1.2 EP WHB-111-3 consists of 2" diameter piping that is approximately 30 feet in length.

# 2.0 Survey Design Information

- 2.1 EP WHB-111-3 was surveyed IAW Procedure #BSI/LVS-002.
- 2.2 100% of the 2" ID pipe was accessible for survey. The accessible 2" ID pipe was surveyed by static measurement at one foot increments, for a total of 30 survey measurements.
- 2.3 Surface area for the 2" ID piping is 486 cm² for each foot of piping, corresponding to a total 2" ID piping surface area of 14,593 cm² (1.5 m²) for the entire length of (approximately 30') of 2" piping.

## 3.0 Survey Unit Measurement Locations/Data

3.1 Pipe interior radiological survey forms are provided in Attachment 2 of this release record.

## 4.0 Survey Unit Investigations/Results

4.1 None

#### 5.0 Data Assessment Results

- 5.1 Data assessment results are provided in the EP/Buried Pipe (BP) Survey Report provided in Attachment 1.
- 5.2 All measurement results are less than the Derived Concentration Guideline Level (DCGL) for radionuclide specific EP that corresponds to the 1 mrem/yr dose goal established in Table 3-3 of the FSSP.
- 5.3 When implementing the Unity Rule, provided in Section 3.6.3 of the FSSP, and applying the Nuclide Fraction (NF), provided in TBD-06-004, the survey unit that is constituted by EP WHB-111-3 passes FSS.
- 5.4 Background was not subtracted from the survey measurements and the Elevated Measurement Comparison (EMC) was not employed for this survey unit.

FSS Design # EP WHB-111-3	Revision # Original	Page 3 of 3
Survey Unit: WHB-111-3		

## 5.5 Statistical Summary Table

Statistical Parameter	2" Pipe
Total Number of Survey Measurements	30
Number of Measurements >MDC	30
Number of Measurements Above 50% of DCGL	0
Number of Measurements Above DCGL	0
Mean	0.0093
Median	0.0045
Standard Deviation	0.0115
Maximum	0.0436
Minimum	0.0024

- 6.0 Documentation of evaluations pertaining to compliance with the unrestricted use limit of 25 mrem/yr and dose contributions from Embedded Pipe and radionuclides contributing 10% in aggregate of the total dose for both structural scenarios and soils.
  - 6.1 A review of the survey results has shown that the dose contribution for EP WHB-111-3 to be less than 1 mrem/yr. The dose contribution is estimated to be 0.009 mrem/yr based on the average of the actual gross counts measured.

#### 7.0 Attachments

Attachment 1 - BSI EP/BP Survey Report

Attachment 2 - Pipe Interior Radiological Survey Form

Attachment 3 - DQA Worksheet

Attachment 4 - Disc containing RR for EP WHB-111-3 & Spreadsheet

SECTION 7
ATTACHMENT 1
\_\_\_\_3\_\_ PAGE(S)

Pipe ID	EP WHB-111-3	Survey Location	Evap Pit -5' el.
Survey Date	23-Oct-06	2350-1 #	203488
Survey Time	10:07	Detector-Sled #	238369 / no sled
Pipe Size	2"	Detector Efficiency	0.0009
CGL (dpm/100cm2)			486
pe Area Incorporated by Survey Data (m²)	1.5	Field BKG (cpm)	4.5
Routine Survey	Х	Field MDCR (cpm)	10.3
QA Survey		Nominal MDC (dpm/100cm2)	2,052
		Survey Measurement Results	
	Total Number of Su	rvey Measurements	30
	Number of Meas	surements >MDC	30
	0		
	Number of Measure	ments Above DCGL	0
	ean	0.0093	
	dian  Deviation	0.0045	
	0.0115		
	imum	0.0436	
	Mini	mum STOCK	0.0024
	Survey Unit	Classification	1
		Piping Group	3.3
		Distribution Sample	EP 3-3
	Measure	d Nuclide	Cs-137
	Area Factor	/EMC Used	No
	Pass/F	ail FSS	Pass
	MREM/YR	Contribution	<1
MMENTS:	NOT BACKGROUND	CORRECTED	

EP WHB-111-3 2" Pipe TBD 06-004 Group 3.3

Measurement #	gcpm	псрт	Cs-137 activity (total dpm)	Cs-137 activity (dpm/100cm2)	Co-60 activity (dpm/100cm2)	Eu-152 activity (dpm/100cm2)	Eu-154 activity (dpm/100cm2)	Nb-94 activity (dpm/100cm2)	Ag-108m activity (dpm/100cm2)	Unity
1	48	48	53,333	10,964	541	-	-	-	-	0.00
2	47	47	52,222	10,736	529	-	-		-	0.00
3	35	35	38,889	7,995	394	-	-	-	-	0.00
4	83	83	92,222	18,959	935	-	-	-	-	0.00
5	103	103	114,444	23,527	1,160		-	-	-	0.01
6	63	63	70,000	14,390	710	-	-	-	-	0.00
7	42	42	46,667	9,594	473		-		-	0.00
8	45	45	50,000	10,279	507	-	-	-		0.00
9	52	52	57,778	11,878	586	-	ш.	-	-	0.00
10	41	41	45,556	9,365	462	-				0.00
11	42	42	46,667	9,594	473	-	-	-	-	0.00
12	33	33	36,667	7,538	372		-	-	-	0.00
13	37	37	41,111	8,451	417	-	-	-	-	0.00
14	40	40	44,444	9,137	451	-	-		-	0.00
15	28	28	31,111	6,396	315	-	-	-		0.00
16	33	33	36,667	7,538	372	-	-	-	-	0.00
17	33	33	36,667	7,538	372	-	-	-	-	0.00
18	22	22	24,444	5,025	248	-	-	-	-	0.00
19	27	27	30,000	6,167	304	-	-	-	-	0.00
20	39	39	43,333	8,908	439	-	-	-	-	0.00
21	43	43	47,778	9,822	484	-	-	-	-	0.00
22	34	34	37,778	7,766	383		-		-	0.00
23	27	27	30,000	6,167	304	-	-	-	-	0.00
24	35	35	38,889	7,995	394		-			0.00
25	52	52	57,778	11,878	586	-	-	-	-	0.00
26	141	141	156,667	32,207	1,588	-	-	-	-	0.01
27	380	380	422,222	86,799	4,280	-	-		-	0.04
28	407	407	452,222	92,966	4,584	-		-	-	0.04
29	308	308	342,222	70,353	3,469	-	-	-	-	0.03
30	284	284	315,556	64,871	3,199	-	-	-	-	0.03

# EP WHB-111-3 2" Pipe TBD 06-004 Group 3.3

Measurement #	gcpm	ncpm	Cs-137 activity (total dpm)	Cs-137 activity (dpm/100cm2)	Co-60 activity (dpm/100cm2)	Eu-152 activity (dpm/100cm2)	Eu-154 activity (dpm/100cm2)	Nb-94 activity (dpm/100cm2)	Ag-108m activity (dpm/100cm2)	Unity
									MEAN	0.009
									MEDIAN	0.004
									STD DEV	0.011
									MAX	0.044
									MIN	0.002

SECTION 7
ATTACHMENT 2

3 PAGE(S)

# Pipe Interior Radiological Survey Form

Date: 10/23/06 Time: 1007
Pipe ID#: whs 111-3 Pipe Diameter: 2" Access Point Area: EVAR. P.T
Building: WHB Elevation: -5' System: LAUNDRY DRAIN
$\vee$
Type of Survey Investigation Characterization Final Survey N Other
Gross Co60 Cs
Detector ID# / Sled ID# 44-159 > #238369 / NO 54ED
Detector Cal Date: 9/5/0C Detector Cal Due Date: 9/5/07
Instrument: 2350-/ Instrument ID #: 20348-8
Instrument Cal Date: 7/5/06 Instrument Cal Due Date: 7/5/07
From the Daily Pipe Survey Detector Control Form for the Selected Detector
Background Value 4,5 cpm
MDCR <sub>static</sub> 10.3 cpm
Efficiency Factor for Pipe Diameter (from detector efficiency determination)
$MDC_{static}$ $2.05Z$ $dpm/$ $1.00$ $cm^2$
Is the MDC <sub>static</sub> acceptable? Yes No (if no, adjust sample count time and recalculate MDCR <sub>static</sub> )
Comments: RESURVEY, POST GRIT BLAST EP3-3 COMPLETE
INITIAL SURVEY: 8/28/06
Technician Signature

# Pipe Interior Radiological Survey

Position #	Feet into Pipe from Opening	Count Time (min)	Gross Counts	Gross cpm	Net cpm	dpm/100cm <sup>2</sup>
1	1	1	48	48	nia	nla
2	2.		47	47		1
3	3		35	35		
4	4		83	83		
5	5		103	103		
6	6		63	63		
7	7		42	42	1	
8	8		4.5			
9	9		52	45 52		
10	10	V	41	41	1	1



Package Page 1 of 3

Attachment 3, Page 1



# Pipe Interior Radiological Survey Form (Continuation Form)


Date: 10/23/06
Pipe ID#: WHB/11-3 Pipe Diameter: 2 Access Point Area: EVAP. P.T.
Building: WHB Elevation: -5' System: LAUNDRY DRN.

Position #	Feet into Pipe from Opening	Count Time (min)	Gross Counts	Gross cpm	Net cpm	dpm/100cm <sup>2</sup>	
11	11	1	42	42	nia	nia	
12	12		33	33	1		
13	/3		37	37			
14	14		40	40 28			
14	15		28	28			
16	16		33	33			
12	ίĴ		33	33			
18	18		33 22	22			
19			27	27			
20	19 20		39	39			
21	21		43	4-3			
22	22			34			
23	23		3 <del>4</del> 27	34 27			
24	24		35	35 52			
25	25		52	52			
26	26		141	141			
27	26 27		380 407	380			
28	28		407	407			
29	29		308	308			
30	30	1	284	308 284	<i>y</i>	1	
		•		•			
			4.1				
						27-27	
						**	
				1			

REFERENCE COPY

Package Page Z of 3





SECTION 7
ATTACHMENT 3
\_\_\_\_\_\_ PAGE(S)

	DQA Check Sheet										
	Design #	WHB-111-3	Revision #	Original							
Sı	urvey Unit #			V	/HB-111-3						
			Pre	liminary Data	Review`						
	Answers to the following questions should be fully documented in the Survey Unit Release Record  No N										
1.	Have surveys	ons in the Survey Design?	х								
2.	Is the instrume survey units, o	ow the DCGL <sub>W</sub> for Class 1 and 2			х						
3.	Is the instrume	entation MDC for em	bedded/buried	piping static mea	asurements below the DCGL <sub>W</sub> ?	х					
4.	Was the instru embedded/bur static measure			х							
5.	Was the instru	mentation MDC for	volumetric meas	surements and s	smear analysis < 10% DCGL <sub>W</sub> ?			Х			
6.	Were the MDCs and assumptions used to develop them appropriate for the instruments and techniques used to perform the survey?										
7.	7. Were the survey methods used to collect data proper for the types of radiation involved and for the media being surveyed?										
8.	Were "Special	х									
9.	<ol> <li>Is the data set comprised of qualified measurement results collected in accordance with the survey design, which accurately reflects the radiological status of the facility?</li> </ol>										
			Gi	aphical Data	Review						
1.	Has a posting	plot been created?						Х			
2.	. Has a histogram (or other frequency plot) been created?							Х			
3.	Have other gra	aphical data tools be	en created to as	ssist in analyzing	g the data?			Х			
				Data Analys	sis						
1.	Are all sample	measurements belo	ow the DCGLw (	Class 1 & 2), or	0.5 DCGL <sub>W</sub> (Class 3)?	х					
2.	Is the mean of the sample data < DCGL <sub>W</sub> ?										
3.	If elevated areas have been identified by scans and/or sampling, is the average activity in each elevated area < DCGL <sub>EMC</sub> (Class 1), < DCGL <sub>W</sub> (Class 2), or <0.5 DCGL <sub>W</sub> (Class 3)?							Х			
4.	4. Is the result of the Elevated Measurements Test < 1.0?							Х			
5.	5. Is the result of the statistical test (S+ for Sign Test or $W_r$ for WRS Test) $\geq$ the critical value?							Х			
Cor	nments:	0									
F	SS/Characteriza	ation Engineer (print	/sign) Da/a	e Randa	1 / Ded Royled	Date	10-3	0-07			
F	SS/ Characteriza	ation Manager (print	/sign)	R. Case /	W/1 Am	Date	11/7	101			

Form CS-09/2 Rev 0

# SECTION 7 ATTACHMENT 4 1 DISC