

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
AP1000 Subcommittee

Docket Number: (n/a)

PROCESS USING ADAMS
TEMPLATE: ACRS/ACNW-005
SUNSI REVIEW COMPLETE

Location: Rockville, Maryland

Date: Wednesday, October 31, 2007

Work Order No.: NRC-1835

Pages 1-203

ORIGINAL

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

ACRS OFFICE COPY
RETAIN FOR THE LIFE OF THE COMMITTEE

TROY

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

October 31, 2007

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on October 31, 2007, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected and edited and it may contain inaccuracies.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
(ACRS)

AP1000 SUBCOMMITTEE

+ + + + +

WEDNESDAY

OCTOBER 31, 2007

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B3, 11545 Rockville Pike, at 8:00 a.m., Dr. Mario
Bonaca, Chairman, presiding.

ACRS MEMBERS PRESENT:

- MARIO V. BONACA, Chairman
- WILLIAM J. SHACK, Member
- JOHN D. SIEBER, Member
- SAID ABDEL-KHALIK, Member
- J. SAM ARMIJO, Member
- OTTO L. MAYNARD, Member
- JOHN W. STETKAR, Member
- MICHAEL CORRADINI, Member

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ACNW MEMBERS PRESENT:

JAMES W. CLARKE

MICHAEL T. RYAN

NRC STAFF PRESENT:

DAVID FISCHER

JERRY WILSON

EILEEN MCKENNA

ALSO PRESENT:

ED CUMMINS

ANDREA STERDIS

JIM WINTERS

TERRY SCHULZ

PETER HASTINGS

PHILLIP RAY

EDDIE GRANT

NEIL HAGGERTY

LESLIE KASS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

A G E N D A

INTRODUCTION 4

AP1000 TECHNOLOGY OVERVIEW 9

PASSIVE SYSTEMS, DEFENSE-IN-DEPTH SYSTEMS
INSTRUMENTATION AND CONTROLS, SECONDARY
SYSTEMS, ELECTRICAL SYSTEMS, FIRE PROTECTION . . 36

BREAK 105

PROPOSED REVISIONS TO AP1000 CERTIFIED
DESIGN 107

PART 52 AMENDMENT PROCESS 143

LUNCH 152

ISSUES BEING COLLECTIVELY ADDRESSED BY
THE AP1000 DESIGN-CENTERED WORKING GROUP . . . 153

ADJOURN

P R O C E E D I N G S

(8:02 p.m.)

1
2
3 CHAIR BONACA: Good morning. The meeting
4 will now come to order. This is a meeting of the
5 Advisory Committee on Reactor Safeguards AP1000
6 Subcommittee. I am Mario Bonaca, Chairman of the
7 Subcommittee. Members in attendance today are Said
8 Abdel-Khalik, Sam Armijo, Sanjoy Banerjee I believe
9 will come later, also Dennis Bley, Michael Corradini,
10 Otto Maynard, Bill Shack, Jack Sieber, and John
11 Stetkar will come later, too. They may be also tied
12 to the fact that the ACRS never meets at 8:00, we
13 always meet at 8:30, some people that have missed
14 that, but we are glad to accommodate the Westinghouse
15 people. We also have with us today two members of the
16 Advisory Committee on Nuclear Waste and Materials,
17 James Clarke and Mike Ryan.

18 The purpose of this Subcommittee meeting
19 is to discuss the AP1000 design, proposed revisions to
20 the AP1000 design certification rule, that is 10 CFR
21 Part 52, Appendix D, issues to be resolved
22 collectively for combined license of applicants,
23 referencing AP1000 certified design by the AP1000
24 Design-Centered Working Group, and issues that would
25 be resolved on a plant-specific basis by COL

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 applicants.

2 The Subcommittee will hear presentations
3 by and hold discussions with representatives of the
4 NRC staff, Westinghouse, the AP1000 Design-Centered
5 Working Group, and other interested persons regarding
6 this matter.

7 The Subcommittee will gather information,
8 analyze relevant issues and facts, and formulate
9 proposed positions and actions as appropriate for
10 deliberation by the Full Committee.

11 Mr. David Fischer is the Designated
12 Federal Official for this meeting. The rules for
13 participation in today's meeting have been announced
14 as part of the notice of this meeting previously
15 published in the Federal Register on September 26th,
16 2007.

17 A transcript of the meeting is being kept.
18 It will be made available as stated in the Federal
19 Register notice. It is requested that speakers first
20 identify themselves, and speak with sufficient clarity
21 and volume so that they can be readily heard. We have
22 received no written comments or requests for time to
23 make oral statements from any members of the public
24 regarding today's meeting. Copies of the meeting
25 agenda and the handouts are available in the back of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 the meeting room.

2 We will now proceed with the meeting, and
3 I call upon Mr. Edward Cummins of Westinghouse
4 Electric Company for his introductory remarks. Mr.
5 Cummins.

6 MR. CUMMINS: Thank you very much. My
7 name is Ed Cummins from Westinghouse. Here we are
8 today to talk about the AP1000, and the AP1000 was
9 certified in December 2005. And we are now at a stage
10 where actually yesterday the first Combined Operating
11 License was applied for by TVA for the Bellafonte site
12 referencing the AP1000. And we call this the
13 reference COL application. It's the first one, and
14 it's the one that every other COL applicant will
15 follow for the standard portions.

16 All this discussion is about
17 standardization, and we actually have three licensing
18 activities that we're going to discuss. The first is
19 the revision to the AP1000 design certification. And
20 the purpose of the revision to the AP1000 design
21 certification was to address COL open items that were
22 related to the AP1000 design, and to address design
23 changes or modifications either as a result of
24 customer interaction, or as a result of Westinghouse
25 detailed design process.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 So we applied for the revision to the
2 certified design on May 29th of 2007, and we would
3 expect that that process will go between a year and 18
4 months until we have an FSER and then a licensing
5 process after that. The objective here is to certify
6 information that all of the COLs will reference as
7 part of their standard applications in their COL
8 application, the maximum that we can put in in the
9 certified design.

10 The next level of standardization at the
11 R-COLA, Reference Cola, includes utility processes and
12 procedures that the utilities referencing the AP1000
13 have agreed that they will standardize among
14 themselves, but which are not appropriate for
15 certification because they may want to have a little
16 more flexibility with change in the future to the QA
17 plan, and the plan for operators, and processes that
18 the utilities use, which they have agreed to
19 standardize. And then the last piece of it is the
20 individual COL applications, which, for the most part,
21 will be only addressing the site-specific aspects of
22 their particular application.

23 So in front of the NRC we have three
24 licenses really. There's the revision to the AP1000
25 certified design, there's the portion of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Bellafonte COL application which is the R-COLA, which
2 will be the same for everyone, and there's a portion
3 of the Bellafonte application which is the S-COLA, if
4 you will, for Bellafonte, which is the site-specific
5 information for Bellafonte.

6 After this introduction, I introduce the
7 Westinghouse people. We're also going to have
8 presentations by NuStart, and by one of the COLA
9 applicants, so my team has Andrea Sterdis, Jim
10 Winters, and Terry Schulz, and they'll give you a
11 briefing on the AP1000 design.

12 MEMBER SHACK: Just a quick question to
13 refresh my mind. Your changes in the design
14 certification, are we changing Tier 1 information, or
15 Tier 2 information?

16 MR. CUMMINS: We're changing a little bit
17 of everything, a little bit of Tier 1 information, a
18 little bit of Tier 2, and a little bit of Tier 2*
19 information.

20 MEMBER SHACK: Could you refresh -- what
21 more does it take to change Tier 1 information, than
22 Tier 2 information?

23 MR. CUMMINS: Well, I think - and maybe we
24 need to consult with the NRC experts here, but my
25 belief is in a revision to a certified design it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 almost the same, so Tier 1 you'd need an exemption to
2 the rule, so that there will be some sort of process
3 of getting an exemption for the changes in Tier 1,
4 which are relatively minor, I would say, either
5 progress along the path of design acceptance criteria,
6 design ITAACs, and a few error corrections, and a few
7 small modifications in Tier 1. The Tier 1 design
8 scope is almost the same in the revision.

9 MEMBER ARMIJO: Is this the first time
10 that a certified design has gone through the revision
11 process?

12 MR. CUMMINS: Yes, it is. And, in fact,
13 the 10 CFR 52 did not permit a revision to certified
14 design until the revision that was just, I'll say
15 finalized. It was finalized September 27th, so this
16 is the first time that we have been able to revise the
17 certified design. And from our customers, the COL
18 applicants' perspective, they would prefer for things
19 to be resolved in the certified design because then
20 it's not subject to -- it gets its public interaction
21 at the certification, and it's not subject to hearings
22 at each COL application. So we put in the revision
23 all those things that are going to be standard related
24 to the design. Any other comments or questions?
25 Okay. Then I'll turn it over to Andrea.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. STERDIS: Okay. Good morning. Thank
2 you for inviting us to make this presentation. I'm
3 Andrea Sterdis, and I'm the Manager of the AP1000
4 Licensing and Customer Interface Organization. I
5 directly report to Ed, and I've had the wonderful
6 experience over the last two years to bring not only
7 the DCD revision amendment to the staff in May, but
8 also yesterday to stand out there with my colleagues
9 on the DCWG as we submitted the Reference COLA with
10 TVA and NuStart.

11 This presentation today is here to
12 -- we're here to do a couple of objectives. One is,
13 we want to give you an overview of the technology.
14 The second is, I want to give you a status of where we
15 ended up on AP1000 originally design certification,
16 where we're headed, and then the third thing we're
17 going to do is have Peter Hastings from NuStart, who's
18 going to talk about the Reference COLA, as well as Amy
19 Aughtman from Southern, who is going to talk about the
20 subsequent COLAs this afternoon.

21 As you can see, I'm not going to go
22 through this agenda, but we've got a pretty meaty
23 agenda here. We're going to briefly touch on all of
24 the aspects that were requested as far as the design,
25 and feel free to ask questions as we go along.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Okay. I'm going to start off with the
2 overview of the design certification application.
3 This is the original application which we submitted
4 the DCD and the PRA in March of 2002. The AP1000, for
5 those of you that don't know, is based heavily on the
6 AP600 design and design certification, and was an
7 increase in power rating, which also affected the
8 design. So we submitted a DCD and PRA in 2002, and
9 included in that was the Tier 1 information, where we
10 have the ITAACs, the Inspection Test Analysis and
11 Acceptance Criteria, as well as the Tier 1 descriptive
12 information.

13 Also included are Tier 2 information,
14 which you would recognize as a standard safety
15 analysis report. That's also where our tech specs
16 are. And we have a Chapter 19 which has pulled out
17 the real significant PRA insights. The PRA, itself,
18 is a separate document, not part of the DCD. Ed
19 briefly touched on the fact that we did end up with
20 some Tier 2* information in Tier 2, which, for those
21 of you that that's a new term for, that separates
22 -- it's not quite as important as Tier 1 requiring
23 exemption, but it does require NRC staff approval to
24 make changes.

25 AP1000 PRA report was 4,500 pages, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it's a very complete and robust PRA. It contains
2 detailed Level 1, 2, and 3 PRAs, as well as covering
3 the shutdown, fires, floods, internal events. We also
4 address severe accident phenomenon.

5 This is our trophy. We have two of these,
6 one for the AP600 and AP1000. We actually also have
7 the one for the System 80+, but this is the trophy.
8 This is what we hang on our walls.

9 What do we get with design certification?
10 That's always a question we ask ourselves. It's a
11 question that we've asked with the potential
12 customers, the COL applicants. We interpret the
13 regulation to say that our design certification for
14 the scope that we covered in the design certification
15 provides licensing finality for that level of design.
16 It also establishes the regulatory bases. In other
17 words, the criteria that were used in the design
18 certification remain valid for the lifetime, the
19 regulatory lifetime of that certification.

20 The way we always like to say is, we're
21 like an operating plant. For the scope that we
22 certified, the same rules to change that an operating
23 plant would be subjected to. So, of course, a
24 significant safety impact would need to be addressed
25 by a certified design, but small evolutions in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 criteria do not need to be.

2 The last one is an important one. We
3 didn't finish everything at design certification,
4 because there are things you can't finish, things that
5 require input from a site, things that required input
6 from technology decisions, such as I&C platform
7 choices. So we have what we call Design ITAAC, but we
8 also have COL information items. And I want to talk
9 a little bit about those through this process, so you
10 understand how we got to May when we submitted our
11 revision, as well as how we got to yesterday, when TVA
12 and NuStart, and the DCWG submitted the Reference
13 COLA.

14 DCD defines what needs to be in the COLA.
15 Obviously, the regulation does. What the DCD does,
16 what the Design Certification Rule does is bring that
17 down a level of detail. The Part 52 regulation
18 provides the overview, and the design certification
19 details, particularly the DCD, define what's left to
20 be done.

21 I put on here a pictorial that shows you
22 the DCD on the left. I've got to make sure it's not
23 inverted there, and then out of that DCD came 175 COL
24 information items. These are a variety of things, as
25 Ed said. Some of them are design-related, some of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 them are programmatic aspects, some of them are site
2 interface criteria. Those are the kinds of things
3 that you would find in that numerical listing in
4 Section 1.8 of the DCD, where the COL information
5 items are listed. They are also interspersed
6 throughout the DCD in the appropriate chapters.

7 The ways to deal with those are the three
8 boxes on the right, the design certification
9 amendment. Ed stressed that the reason that we wanted
10 to do the design ones, and we started this a little
11 over two years ago when we started to see activity
12 going forward for COL applications. We looked at the
13 COL items and said a lot of these are standard plant
14 issues, standard design issues. Let's do these once,
15 get them done, and in addition to the advantage Ed
16 pointed out, we also have an advantage that it allows
17 us to further exploit the standardization of our plant
18 design, and that's a distinct advantage in an industry
19 that's really hurting for experienced people, really
20 hurting for a way to actually bring these plants to
21 fruition with the staff that we have, and the staff
22 that we need going forward.

23 The second box is the R-COLA, and that's
24 what we submitted to you yesterday. And those two
25 boxes are green for a reason. They're green because,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 as Ed emphasized, the parts of the design
2 certification amendment that we put forward to exploit
3 the standardization and the parts of the Reference
4 COLA that all of the other subsequent COLAs will be
5 using, those are the things that are the standard
6 parts of the application.

7 We anticipate, and I believe the staff
8 anticipates, that there will be the one issue, one
9 review, one position DCWG mentality put forward. In
10 other words, you solve the problem on our DCD
11 amendment, it applies to all the COLAs. You don't
12 have to come back and reinvent the wheel every time
13 you get a new application.

14 Same thing with the R-COLA. When the R-
15 COLA came in yesterday, in the left-hand margin of
16 every part of that application, there is an annotation
17 that tells you if it is standard COLA input, or
18 Bellafonte-specific COLA input. And that's how the
19 staff will be able to move forward, and be able to be
20 efficient in doing their review. The S-COLA is where
21 the site-specific issues are addressed, site interface
22 criteria would be addressed, because that's something
23 that's individual to each site.

24 MEMBER SHACK: So, literally, each COLA
25 will look exactly the same as far as the R-COLA parts

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are, and you will plug in S-COLA.

2 MS. STERDIS: Absolutely. And you'll hear
3 a little bit more about that this afternoon, because
4 you'll also hear that even where it's different, we
5 have really worked hard as an integrated DCWG team to
6 look at level of detail, content and format, as well
7 as the philosophy for addressing those things that
8 have to be different across the different
9 applications, different sites, different applicants.

10 About two years ago, actually, a little
11 bit before I came back. I worked on AP600 years ago,
12 and I was gone for a while, but I came back in early
13 January 2006, but late 2005, when the activity started
14 to heat up, Ed and his team, Jim and Terry, those
15 guys, they started to look at these open items that we
16 had, these information items, and what could we do.

17 We also had done first-of-a-kind
18 engineering, so the design of the plant had evolved.
19 So they wanted to look at what could we do to deal
20 with this? And at the time, Part 52 did not permit an
21 amendment process to an existing design cert rule. So
22 what they decided was, we would start needling away at
23 these issues, and try to close them standardly, at
24 least as far as the technical staff review is
25 concerned, and then they could be rolled into the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 applications only requiring the hearing process, and
2 the final vetting of that issue. The meat of the
3 technical issue to close a COL information item, or to
4 deal with a design change that was necessitated
5 because of design evolution, those kinds of things
6 could be done once, and submitted in a technical
7 report, reviewed, the staff would generate an SER, and
8 then each of our COL applicants would refer to that.

9 The technical report process was intended
10 to cover, basically, these three categories of changes
11 and additions, and they are both. Sometimes it's an
12 addition. The first one is a good example, the first
13 two are good examples. The standard design COL
14 information items. For example, in Chapter 7, we had
15 a COL item to do, failure modes and effects analysis,
16 and a software hazards analysis. Doesn't make sense
17 to do that if you haven't picked a platform, doesn't
18 make any sense, so we had to close that. Doesn't make
19 sense for each of my applicants to do that, because
20 they're all using my same platform that I've now
21 selected, so we can close that standardly for them.
22 And we can work with the staff. It makes the staff's
23 job more efficient, makes our job more efficient,
24 makes the COLAs more efficient.

25 Same thing with Design ITAAC. We have

1 three areas of Design ITAAC in our design
2 certification, and one is piping, one is the I&C.
3 It's the PMS design, but there's also a Design ITAAC
4 related to the diverse actuation system that
5 correlates to the PMS. The last one is the human
6 factors, main control room design.

7 This last bullet is an important bullet,
8 because you raised the question about the Tier 1
9 changes, and there's a lot of anecdotal discussion
10 about changing the design certification, because of
11 design changes. We did have some changes that have
12 come out of design finalization. Jim is going to talk
13 a little bit about those, Jim, and Terry, as well, but
14 the bar is high for those. We're not improving. We
15 only fix what's broke.

16 The second one can be something that's
17 broke. Some of the areas of the design we do not have
18 the operating experience that an operating plant might
19 have, particularly when you get into the BOP, the
20 secondary side, some of those aspects. Remember, this
21 is a total plant, not just an NSSS, total plant design
22 cert, so we've accepted customer input driven by
23 consensus agreement among the COL applicants for the
24 AP1000, and those changes are also included in our
25 design certification amendment application.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 MEMBER ARMIJO: You know what I'm still
2 confused about is, how much of the design
3 certification is opened up when you start the
4 amendment process? Is the staff going to review the
5 whole thing all over again, or just very well-defined
6 areas where changes are made?

7 MS. STERDIS: The areas that will be open
8 for the staff to review, and will be subject to the
9 revision to the rule making, are clearly defined.
10 They're very narrow, and very focused. We're often
11 asked what percentage. We think it's well under 10
12 percent, and we think that there are -- many of the
13 issues, as I put this slide up that has the 141
14 technical reports, every change that's in the
15 amendment has been included in a technical report,
16 which contains the description of the change, or the
17 description of the addition, what the affect is on the
18 DCD, as well as what the regulatory basis is for that
19 change, so it's a very narrow focused scope. And the
20 existing regulatory basis criteria should remain
21 valid, as well.

22 This kind of gives you a little bit of
23 number, bean counting here, on how we've divvied up
24 these. We have 144 technical reports that we've
25 submitted. Some of those are revisions that have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 happened because of RAI process on the technical
2 report issues, but many of them, I think about 117,
3 118 are original base technical reports. Sixty-three
4 of those address COL information items, 47 justify
5 design changes that impact DCD content, two have been
6 added to address standardization for the COL
7 application. We found some inconsistencies in our Reg
8 Guide Table, in our ISI/IST Tables, so as we were
9 going through the review process with the Bellafonte
10 COL, we actually identified that there were typos,
11 there were inconsistencies, so we've submitted two
12 technical reports to address those so that each of our
13 applicants does not have to deal with basically
14 typographical errors in every COL application.

15 Technical Report 135 is a regulatory
16 requirement. If you submit an application for an
17 amendment, you must address the SAMDA requirement
18 explicitly. We did a detailed evaluation of our
19 SAMDA, and confirmed that none of the changes that we
20 were proposing had an impact on the conclusions of
21 that SAMDA, and we submitted that report.

22 That bullet, plus the 47 to justify design
23 changes, they go hand-in-hand. It addresses the fact
24 that most of these changes are relatively minor. They
25 could have actually been done by the COL applicants as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 50.59-like changes. But, again, our drive is to get
2 this plant to be standard. And it's in all of our
3 best interests, we believe, to put these things into
4 this amendment.

5 CHAIR BONACA: I have a question. Some
6 time ago you said remember, this covers the whole
7 plant.

8 MS. STERDIS: Yes.

9 CHAIR BONACA: And could you give me an
10 example of where it becomes a site issue? For
11 example, I was thinking the electrical system.

12 MS. STERDIS: He's going to give you some
13 -- can you -

14 MR. WINTERS: I'll give you a definition.

15 CHAIR BONACA: I would like to understand
16 the electrical system, clearly, the grid is going to
17 be different from side to side.

18 MS. STERDIS: Yes.

19 MR. WINTERS: Yes.

20 MEMBER MAYNARD: Boiling water, usually.

21 CHAIR BONACA: So if you could just give
22 me an idea of the boundary later on, that would be
23 helpful.

24 MS. STERDIS: Power and water.

25 CHAIR BONACA: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. STERDIS: The last bullet on here
2 provides something that we've worked out with the
3 staff, and with the COL applicants. There was a
4 concern, and we think we've seen a little bit of this
5 in some of the efforts that are ongoing right now. If
6 we submitted Rev. 16, which is what we submitted in
7 May, and then all of a sudden we have RAIs on the
8 technical reports, and we need another revision, well,
9 then our COLs can be out of sync with that. So what
10 we've done, is we've created a technical report that
11 is not any -- no meat to it at all. It's a listing,
12 it's an anchor, it says here are the things that are
13 changing, and each change is related to an RAI
14 response, that type of thing. We just provided that.
15 That was necessary to support the Bellafonte
16 application, and that was submitted. It was mailed on
17 Friday, delivered on Monday.

18 CHAIR BONACA: Do you have a 50.59-type
19 process you are using?

20 MS. STERDIS: Yes, we do. And Jim is also
21 going to talk about the change control board. I know.
22 There's lots of ways to dice the presentation.

23 CHAIR BONACA: If you -

24 MR. CUMMINS: It's a process of how you
25 look at changes. It is not based on regulatory.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. STERDIS: Well, the criteria, Section
2 VIII criteria in Appendix D, which is our rule, our
3 design certification rule, in Section VIII, you find
4 the criteria that we need to evaluate changes against.
5 And what we've done, they look a lot like 50.59
6 questions. And our change control process, those
7 questions are answered for every change that comes
8 forward.

9 CHAIR BONACA: So the staff will rely on
10 that evaluation to determine, for example, what they
11 will review and what they will not review?

12 MS. STERDIS: We have documented -- no,
13 Mario. I think that's not right, because we could
14 have done that, we could have gone that way. We did
15 not, because even though we could screen out using the
16 criterion, say these need to be handled like 50.59-
17 like issues. They don't require staff prior approval.
18 We believe, with five applicants, six sites, a
19 standard plant across the world, that we want to
20 enforce standardization, and the way to do that is to
21 roll these 50.59-like changes into our amendment, and
22 they become part of the standard design certification.

23 CHAIR BONACA: No, but I was talking in
24 terms of what the staff would review and what they
25 would not review.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. STERDIS: They are going to -- we are
2 asking them to review. Eileen.

3 MS. MCKENNA: This is Eileen McKenna from
4 staff, Office of New Reactors. I think a point to keep
5 in mind here is that what they're referring to in this
6 50.59-like process, which is embedded within each of
7 the appendices is specifically aimed at COLs who
8 reference the design, have the capability of
9 implementing the 50.59-like process, to actually
10 change the rule, but certified in the design, so
11 that's an agency rule at this point. It does take an
12 NRC, actually, Commission action to actually change
13 the rule through rule making. And, therefore, even if
14 these changes met the 50.59-like criteria, the staff
15 is still going -- the Agency is still going to have to
16 approve them to actually have them appear in the
17 certified rule.

18 CHAIR BONACA: Thank you.

19 MS. STERDIS: Okay. This slide evolves
20 every day, as Eileen's staff can tell you. We have
21 approximately 500 RAIs received. I believe that number
22 is a little higher now. They're varying levels of
23 safety and regulatory significance, some that deal
24 with the minor changes are a lot narrower in scope,
25 easy to answer, some are significant, and we've had to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 take some time with a couple of them to do some work
2 to get a detailed answer in, structural design of the
3 spent fuel racks, and new fuel racks, for example.
4 More than 460 responses have been provided, and I
5 actually think we're still at around 40, but that's
6 because the numbers increased a little bit.
7 Approximately 120 of those result in revisions to the
8 technical reports being necessary, and only about 60
9 have resulted in additional DCD revision, so that's a
10 pretty good - I mean, we're a little bit more than 10
11 percent, but that's not really a bad thing.

12 We have not pushed back on RAIs at all.
13 We really felt that it was in our best interest to
14 just answer the questions. And you can see by the
15 only 60 of them requiring DCD revisions, that it was
16 more for bringing a new reviewer up to speed on what
17 the design certification covered, what the design
18 basis was for the plant, those kinds of issues, as
19 opposed to the ones that are really solid RAIs, where
20 there was a real need for additional technical
21 information.

22 Our amendment, we submitted our amendment
23 May 29th. You heard Ed say September 27th was the
24 effective date of Part 52 revision permitting an
25 amendment. We knew when the SRM came out in April

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that there was going to be an opportunity to do this
2 amendment. We understood from the SRM that the
3 criteria was consistent with what we were looking for,
4 and we believed that getting this document on the
5 table in front of the staff early was in everyone's
6 best interest.

7 The transition, though, has been a little
8 bumpy, because we started out with -- we have these
9 technical reports, not a small number, 141 of these
10 technical reports, 500 RAIs on them. So getting to
11 move from a technical report that addresses spent fuel
12 rack design into where does that go, nine point what,
13 what sections of the DCD are impacted? We've had a
14 little bit of bump with that, but we're working with
15 the staff, and we've got now a pretty detailed matrix,
16 in fact, that I'm going to deliver to Eileen's staff
17 today. We did a preview of it last week, and it
18 actually provides the detail of how you get from a TR
19 to the SER sections, or backwards, using database
20 technology here, so that the staff will have access to
21 the database, and if the staff reviewer says I want to
22 see every change in the DCD that goes with that
23 technical report, he can do that. If you want to see
24 every technical report that goes with a chapter, he
25 can do that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The acceptance review issues, that was one
2 of them, that's the process one. We've also had some
3 technical issues where the staff has concerns about
4 the adequacy or sufficiency of what we've provided in
5 the technical reports. A lot of us have been around
6 since AP600, small changes. We believed that it was
7 obvious, if you were embedded in the design, it is
8 obvious, this is not a big deal. We have new
9 reviewers, we have reviewers that didn't understand
10 what was the AP1000 design, don't understand,
11 necessarily, what we've accomplished, the scope of the
12 design certification, so we weren't working from the
13 right venue when we were producing these technical
14 reports. We're correcting that. Many of them have
15 been resubmitted. That's why I have about 30
16 revisions of technical reports, that was to
17 substantially increase the amount of information.

18 We've also been doing a lot of
19 communications, telecons, and meetings, to make sure
20 that we're covering exactly what the staff needs, even
21 on these relatively small changes, but as Eileen said,
22 it's part of the rule, we have to justify, we have to
23 make sure we satisfy, we have to make sure we satisfy
24 the reviewer's needs.

25 Westinghouse will be submitting a letter

1 to the staff on Friday, which is very close, to say
2 we're ready, go ahead, start the acceptance review. We
3 anticipate, as Eileen and I talked over the past week,
4 this has been kind of a -- it's been a big hoop for
5 both of us to jump through, but we believe that the
6 jumpstart this is going to give the staff in
7 performing the actual review is going to be worth the
8 pain that we've been seeing for the past three or four
9 weeks.

10 I just listed here, you're going to hear
11 a little bit about these as we go through, but these
12 were some of the amendment content, that is, some of
13 the meat in the content. We have extended the
14 original design certification addresses only hard rock
15 sites. We're extending that, because we have soft
16 soil, and medium soil sites. We've got a revision for
17 the buildings for enhanced protection. I believe Jim
18 is going to address that, as well.

19 We've updated the fuel design approach for
20 Chapter 4. The fuel core design is not final, and it
21 won't be final. There's a COL holder item, or a set
22 of COL holder items that will be done closer to actual
23 fuel load, sometime between license and fuel load.

24 The protection system, the I&C update, we
25 chose platform for the protection system, and we're in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the process of communicating our platform selection
2 for the diverse actuation system to the staff, as
3 well. We updated electrical system. I mentioned that
4 we've had some input from our COL applicants, and this
5 is an area where we've had some input, fast bus
6 transfer, an additional reserve auxiliary transformer.
7 We've had some changes in this area that come about
8 from the input of our COL applicants. We've made
9 progress in the design of the main control room, in
10 the application of the human factors engineering
11 program on the plant.

12 Lastly, you may have heard, we have a new
13 owner, and we have a turbine manufacturer change
14 that's covered in this design certification amendment.

15 MEMBER SIEBER: Do you plan to discuss the
16 seismic spectra in any detail today?

17 MS. STERDIS: No.

18 MEMBER SIEBER: I remember AP1000, it was
19 originally designed to be placed on a hard rock site,
20 a site that has a significant vault 100 miles away
21 with 1,000 feet of sediment free soil, would have to
22 be analyzed outside of your application?

23 MS. STERDIS: No. Go ahead.

24 MR. CUMMINS: We have expanded the site
25 interface scope from hard rock to the site conditions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 defined by the utility requirements document, which
2 is, I'll say all sites. It's not every single -

3 MR. WINTERS: Twenty-six eastern.

4 MR. CUMMINS: Yes. So it goes from soft
5 soil, all the way to hard rock, and envelopes the
6 existing nuclear sites in the east, anyway, and many
7 other sites, also. So it's a -

8 MEMBER SIEBER: Is this available as a
9 document, a separate document?

10 MR. CUMMINS: Yes, it is.

11 MEMBER SIEBER: Could I get a copy of
12 that?

13 MS. STERDIS: Yes. We have made, I just
14 want to point out, we have made significant progress.
15 This area of seismic we knew was going to be a
16 substantial amount of work.

17 MEMBER SHACK: Are we going to talk about
18 this more?

19 MR. CUMMINS: Not today. It's up to you
20 what you would like to talk about.

21 MEMBER SHACK: Just a quick question. The
22 Reg Guide 160 kind of spectra, which I assume this
23 really is, the early site permit plants have been
24 finding they need to make changes in the high-
25 frequency portion. Have you made any changes in your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 high-frequency portion, or is this a Reg Guide 160-
2 like spectra?

3 MR. CUMMINS: It's a Reg Guide 160-like
4 spectra applied to multiple sites. We have been
5 working with industry groups working on this high-
6 frequency issue. I would say that NEI and EPRI really
7 have the lead on this high-frequency issue related to
8 hard rock sites, mostly. And the general approach
9 that they are taking is that the high-frequency is not
10 damaging, and that you can show that Reg Guide 160 is
11 adequate as a basis for design.

12 MEMBER SHACK: Okay. So that's the
13 approach.

14 MR. CUMMINS: That's the approach.

15 MS. STERDIS: Right.

16 MEMBER ARMIJO: Now this list of changes,
17 are these specific changes that the staff is going to
18 be reviewing, in addition to whatever is in those 140
19 reports?

20 MS. STERDIS: These are all included.
21 This is just a list to give you a sense of the types
22 of changes.

23 MEMBER ARMIJO: A sample.

24 MS. STERDIS: Yes. It's a subset.

25 MR. WINTERS: Maybe a different

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 explanation, the technical reports are unique to a
2 topic. Okay? So there is a technical report on the
3 seismic spectra. We have two technical reports on
4 enhanced protection, because they're driven by
5 different reasons. So these are examples of what
6 technical reports are covering, which are technical
7 topics. The bump in the road that Andrea was talking
8 about is a single technical topic, like seismic
9 spectra, spans many chapters. And, of course, an SER
10 has to be written by chapter, so we have to make the
11 conversion with staff so that the SER can be written
12 by chapter supporting all the technical topics that we
13 covered in the 140 technical reports. So this is a
14 sampling of those.

15 MS. STERDIS: Right. And last week I was
16 here for the Vogtle ESP ACRS meeting, and the one
17 question I had to answer, I just want to repeat for
18 you all because you weren't all here last week, and
19 that was that, as Ed was saying, this is a standard
20 spectra, and the design, the standard plant design is
21 being done to that standard spectra, so you will not
22 be doing a design for the Vogtle-specific spectra.
23 That was the question that I answered last week.

24 I talked a little bit about this Post-
25 Revision 16. What we submitted in May was Revision

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 16. The original design certification that was
2 approved in December of 2005 was Revision 15 of the
3 DCD. We found it was appropriate to go forward from
4 Revision 15, and not start over in our numbering. And
5 you see Rev bars in Rev. 16 that identify the changes.
6 And, as I said, we've developed a detailed matrix road
7 map that ties each change, not each section, each
8 change to a technical report, and vice versa. But the
9 day after this went in, we had more RAIs, we had more
10 work going on, we had the COL review, where we were
11 getting ready for the Bellafonte application to come
12 in. We found other things. We needed to make sure we
13 tracked them, keeping them in a pile in my office was
14 not going to work, so what we did is we came up with
15 this TR134, and the 134, the Post-Rev. 16 changes are
16 basically editorial consistency errors that we found.
17 We missed an impact in another section, so we've gone
18 through, we've done more searching, more looking for
19 additional consistencies, so we have surfaced some.

20 Subsequent RAIs and additional technical
21 reports, the seismic folks have been a very active
22 crew, and we're on Revision 2 or 3 of one of their
23 documents. We actually have several documents that
24 deal with the seismic spectra, and one of them, I
25 believe, on Revision 2 or 3.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The last one is COLA standardization
2 impacts, trying to make sure we stay lock-step. This
3 DCWG thing, I think on February 8th, 2006, when Dave
4 Matthews stood up and talked about, everyone said wow,
5 that sounds really great. We've lived it. We have
6 lived that for more than 18 months, not just
7 Westinghouse, the NuStart, the COL applicants,
8 everyone has lived it. And all of their application
9 preparers are an integral part of that team, as well.

10 The result, this bottom box is really
11 important. The result is COLA standardization, and
12 each of the COLAs that you will see on the AP1000,
13 there's a minimal number of departures. What does
14 that mean? Five, maybe, five to ten departures in the
15 COLAs.

16 This is a slide I'm very proud of. This
17 is a slide Peter Hastings, and the DCWG team put
18 together this little logo. This logo says it all,
19 because this is the way we work. We all work together
20 revolving around each other, and we work with NEI on
21 licensing issues that are standard across the
22 industry. We work with our DCWG team on areas that
23 maybe we can't do standard across the industry, but we
24 can do standard for every one of the AP1000s, and then
25 as an integral part of that, the design certification

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 amendment, every technical report, every RAI response,
2 and every section of the design certification
3 amendment has gone through our NuStart team members,
4 with a documented review process. We put it out. When
5 it goes out for our internal red team, it goes to
6 their team, and we get a minimum of two utility
7 commentors, we resolve comments, and we incorporate.

8 Same thing happens on the R-COLA. The R-
9 COLA was produced in the same manner. Westinghouse
10 was integrally involved in the reviews of those R-COLA
11 sections, and we will continue to support not only the
12 R-COLA as it goes through the review, but the final
13 preparations of the S-COLAs, as well as the NRC staff
14 interactions in those areas. We 100 percent expect
15 that there will be RAIs issued on the Bellafonte
16 application, that Bellafonte and NuStart, or TVA and
17 NuStart, they're going to turn to us and say this is
18 a design certification issue, can you handle this? We
19 know we're going to be involved. And, again, the
20 bottom line is the result is a licensing
21 standardization, and that's what we're going for.

22 In order to be successful as an industry,
23 we have to be efficient, effective, have high quality,
24 and be successful in driving the overall safety
25 conclusions of this plant. The only way we can do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that in the environment we have today is by following
2 this DCWG process.

3 MEMBER MAYNARD: Is later somebody going
4 to talk a little about the decision-making process
5 among the applicants to maintain standardization?

6 MR. CUMMINS: Peter Hastings.

7 MEMBER MAYNARD: That's fine.

8 MS. STERDIS: Okay. With that, if there
9 are no other questions, I'm going to turn it over to
10 Jim.

11 MR. WINTERS: Good morning. My name is
12 Jim Winters. I work for Westinghouse on the AP1000.
13 We are happy to be here, read your invitation, and
14 tried to meld a familiarization discussion for those
15 that aren't familiar with AP1000, as well as a
16 discussion of what point changes we've made from the
17 design certification in Rev. 16. That means that we
18 don't have a lot of time to talk about anything in
19 detail, but we're clearly very happy to answer any
20 questions, and we're more than happy to come again, if
21 there's a long discussion required.

22 MEMBER SIEBER: We can have future
23 meetings.

24 MR. WINTERS: That's right.

25 (Laughter.)

1 MR. WINTERS: I'm sure we will. And we
2 know the way here, so it's no problem there.

3 I wanted to start off by describing AP1000
4 to those who aren't familiar with it. People that
5 have been in the industry a long time say well, what
6 are you trying to tell me? The AP1000 is a PWR. I
7 know what a PWR is. Let's get on with the good stuff.
8 Well, first thing I want to say is, AP1000 is
9 different.

10 From its inception as AP600, AP1000 has
11 challenged the paradigms of the nuclear industry in
12 our approach to safety, our approach to construction,
13 our approach to licensing, our approach to
14 standardization, our approach to -- it goes on and on.
15 And the different -- AP1000 is different than the
16 challenge of paradigms, something that has to be
17 absorbed, or else the review time takes forever,
18 because you keep looking at this plant through the
19 paradigms that you grew up with.

20 First of all, it's different in two major
21 areas, in the plant itself, and what's certified, and
22 in the philosophy that we have to go forward with this
23 design. First of all, we have a paradigm shift from
24 the Westinghouse approach to life. Westinghouse used
25 to be, other than service and fuels company, an NSSS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 company, but AP1000 is an entire plant. From the very
2 beginning, it was designed as an entire plant, from
3 turbine to toilet. We included a lot of help from
4 AES, but it's hard to separate the balance of plant
5 from the nuclear island, because we integrated it, and
6 we went after certifications for the entire plant.
7 Talk about that in a minute.

8 The second is the passive safety design.
9 All of our response to defined design accidents can be
10 done in the passive mode. For our purposes, passive
11 is defined as no need for AC power, period. We have
12 to use AC power for anything, then it's not passive.
13 We do use stored energy, we use natural forces, like
14 gravity, so something falling out of the sky, if it
15 hits you on the head, you did not think that was
16 passive. But, for us, that's passive, because it was
17 not driven by AC power.

18 Our philosophy here is different from the
19 industry in the past, in that we believe we should
20 have one design, a standard design, a standard design
21 that the -- the philosophy for that was built way back
22 in the 80s when the industry, and NRC, and ACRS, and
23 the Commission created 10 CFR 52, which does create a
24 basis for taking a standard design certified, and
25 going forward with it in multiple sites.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 As a result, you have to have a mindset of
2 no changes, and we'll talk about what we consider to
3 be no changes. Obviously, there are times that you
4 need to change the design for good and valid reason,
5 like it doesn't work, or it's not safe. But other
6 than that, you set a standard, you start building
7 those standards, and then maybe you reset the standard
8 in the future.

9 So let's first talk about the plant and
10 how it's different. First of all, it includes the
11 entire thing. In our Lexicon, that means the
12 buildings of containment, auxiliary building, annex
13 building, the words go containment is containment. We
14 all know what that is. Our auxiliary building is the
15 building that's around the containment. It's on the
16 same base mat as containment. Those two buildings
17 hold all, let me emphasize that, all safety-related
18 equipment and seismic related equipment. There is no
19 seismic-related or safety-related equipment outside
20 those buildings, and they are all on a common base
21 mat.

22 MEMBER ARMIJO: You're talking the first
23 three that -

24 MR. WINTERS: The first two, containment
25 and auxiliary.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Okay.

2 MR. WINTERS: The annex building is our
3 access control hot machine shop, locker room, health
4 physics building, turbine building houses the turbine,
5 rad waste building is basically an interim storage
6 place before rad waste is shipped off-site. Diesel
7 generator building, of course, we have one, we do have
8 diesel generators, because if you have AC, you don't
9 need to challenge your safety systems. Terry will
10 talk about that later this morning. But it's not a 1E
11 diesel. It's, from an electrical point of view, it's
12 just a pair of diesels for investment protection.

13 And everything inside those buildings is
14 in our design certification, plus the associated yard
15 structures, that includes fire water tanks, boric acid
16 tanks, demineralized water tanks, and the things that
17 -- fuel oil tanks, and the things that sit around the
18 yard, plus the underground piping that supports that.

19 MEMBER CORRADINI: So just a
20 clarification. You made a point about the common base
21 mat in the first two structures.

22 MR. WINTERS: Right.

23 MEMBER CORRADINI: So no intervention, no
24 action is needed for how long in the base design?

25 MR. CUMMINS: Seventy-two hours.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WINTERS: Right. No off-site
2 intervention for seven days, so that you can replenish
3 your water supplies, or something of the 72-hour
4 systems after 72 hours with on-site equipment.

5 Okay. The passive design, we'll talk more
6 about passive core cooling later, but all of the
7 regulated safety response systems are passive. Our
8 core cooling is passive, our ultimate heat removal is
9 passive, the guys that have to be in the control room,
10 the people that have to be in the control room,
11 they're life-safety is held with passive heat removal,
12 passive oxygen supply for 72 hours, no intervention
13 from outside. The ultimate heat sink is off the
14 containment, that's passive. We rely just on natural
15 circulation of air around the containment to take the
16 heat away. For our requirements to have part of your
17 fire protection system, which is fire protection for
18 your safety-related equipment, the seismic, well, all
19 of our seismic equipment is on one base mat. It's
20 also passive. The fire hoses and the sprinklers are
21 fed by a tank by gravity. Many of our security
22 features, especially the post 9/11 security features,
23 are also passive. We've made additions to our passive
24 stable of design solutions.

25 This is a picture of what's in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 certification. The heavy blue line, everything inside
2 that heavy blue line, we consider to be within the
3 standard design, standard plant design, and within the
4 certification. That's covered in Chapter 1, Section
5 1.8 of the DCD. If you'll notice, the yellow building
6 is the containment shield building and auxiliary
7 building. That's that common base mat we just talked
8 about, the yellow building. The blue building is the
9 turbine building, the green building is the annex or
10 access control building, the pink building is the rad
11 waste building. And the orange structures around
12 there, there's two fire water tanks, two diesel oil
13 tanks, and service water heat exchanger cooling tower.
14 So everything inside that blue line, there is one
15 extension in 1.8, and that is in a security space, the
16 blue line does include the delay fence, which is the
17 fence between the protected area fence and the
18 buildings.

19 Outside that blue line is, we consider to
20 be site-specific, and will be covered in the COLA
21 applications. That includes the tower heat sink.
22 This picture shows a hyperbolic cooling tower, but it
23 can be anything that supplies circ water at our
24 conditions. Recognize that circ water is not safety-
25 related in this plant, so it can be whatever the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrross.com

1 utility wants it to be.

2 MEMBER CORRADINI: One other question.

3 MR. WINTERS: Yes.

4 MEMBER CORRADINI: So where is the spent
5 fuel pool, in pink or yellow?

6 MR. WINTERS: It's in yellow.

7 MEMBER CORRADINI: Yellow. Thank you.

8 MR. WINTERS: So what's outside the blue
9 line needs to be covered in a COLA because the entire
10 picture has to be covered by the COLA.

11 We all know what a PWR is. It's a
12 reactor, hot water running through the reactor going
13 to steam generator. AP1000 is exactly different than
14 what you're expecting. We call it a two-loop plant,
15 because it has two steam generators. It has two hot
16 legs, but it has four cold legs. Those are each
17 driven by a reactor coolant pump, so we have four
18 reactor coolant pumps. That's the first difference,
19 so we have split cold leg.

20 The reactor coolant pumps are mounted
21 directly to the bottom of the steam generator channel
22 head. Second difference. So we don't have a cross-
23 over pipe. In other plants, operating plants today,
24 there are a number of thermal problems in trying to
25 get the natural circulation going when you have pumps

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 where cold water can collect, or hot water can
2 collect, you have to flush it out. We don't have that
3 problem here, because there are no humps in our
4 primary circuit.

5 The reactor coolant pumps are can motor
6 pumps, that is, the motor is within the pressure
7 boundary of the reactor coolant. Not having a shaft
8 seal means that we've eliminated the shaft seal
9 system, all the water that leaks off, and all the
10 water that we have to put into the seal. It also
11 eliminates the oil lubricated bearings. Our bearings
12 are water lubricated, because they're within the
13 reactor coolant boundary. It also eliminates the fire
14 protection system from that oil system that isn't
15 there.

16 CHAIR BONACA: But you have flywheels,
17 don't you?

18 MR. WINTERS: We have a flywheel.

19 CHAIR BONACA: Because the early ones
20 didn't have flywheels.

21 MR. WINTERS: The AP600 had a flywheel,
22 and AP1000 has a bigger flywheel.

23 MEMBER CORRADINI: So just a design -- I'm
24 sorry.

25 MR. WINTERS: Excuse me. Let me finish

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this answer.

2 MEMBER CORRADINI: Okay.

3 MR. WINTERS: The flywheel, however, is
4 within the reactor coolant boundary.

5 MEMBER SIEBER: Right.

6 MR. WINTERS: Okay?

7 CHAIR BONACA: Yes.

8 MEMBER CORRADINI: So for an old 3411
9 megawatt thermal plant, there were four steam
10 generators. The design change was this way because of
11 what?

12 MR. WINTERS: Okay. For an old
13 Westinghouse 3400, there would be four steam
14 generators.

15 MEMBER CORRADINI: Right.

16 MR. WINTERS: For the new Westinghouse,
17 which includes CE, Combustion Engineering, there would
18 be two steam generators. The evolution of AP1000,
19 however, came before the acquisition of Combustion
20 Engineering, and it is just a large AP600. AP600 was
21 two loops, and that was a classic Westinghouse style.
22 Okay? That was the right number of megawatts per
23 steam generator.

24 However, when we went to AP1000, we said
25 hey, we've got the ANO, for example. Westinghouse had

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 done replacement steam generators for ANO. Those are
2 of the size we need here, so we'll just adopt the CE
3 style, and just go to a bigger steam generator,
4 instead of adding loops. And that's how the genesis
5 of AP1000 evolved.

6 CHAIR BONACA: So you have two cold legs,
7 and one hot leg?

8 MR. WINTERS: So that was the evolution.

9 MEMBER CORRADINI: And the -- I understand
10 the thinking process. The engineering advantage is
11 minimal?

12 MR. WINTERS: The engineering -

13 MEMBER CORRADINI: I'm trying to
14 understand the engineering advantage.

15 MR. WINTERS: The engineering advantage of
16 just making the steam generators bigger, and growing
17 the reactor vessel down a little bit to get from 600
18 to 1000, is that all the work that we did on
19 structures and auxiliary piping, most piping systems,
20 which had been laid out by that time for AP600, we had
21 \$400 million worth of design effort in the AP600. If
22 we did not change the diameter of the reactor vessel,
23 and did not change the diameter of the containment
24 building, then all the stuff around it we didn't have
25 to change. We already had that design in the bag for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 AP600.

2 To go from AP600 to AP1000 doesn't change
3 your need for compressed air. It's the same, HVAC the
4 same, service water pretty much the same. And so as
5 a result, just making the steam generators bigger, as
6 long as we could keep those other diameters the same,
7 allowed us to take all that design and move it, just
8 call it AP1000.

9 MEMBER CORRADINI: So one little last
10 detail, and I'll be quiet for a while.

11 MR. WINTERS: Sure.

12 MEMBER CORRADINI: So you go from 34
13 -- you go from 2,000 megawatts thermal, to 3411
14 megawatts thermal. Did the containment volume change?

15 MR. WINTERS: Yes.

16 MEMBER CORRADINI: But the reactor vessel
17 volume did not.

18 MR. WINTERS: No, it also got bigger.
19 Everything got taller. The reactor vessel got taller
20 from the nozzles down, which meant that we changed
21 nothing but the link with the reactor vessel. The
22 containment vessel got taller to get more volume. To
23 do that, the only change we had to make in piping is
24 the piping running up the side of containment, and the
25 wires going up on the side -- we had to stretch them,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 make them longer, and those are the basic changes we
2 made -

3 MEMBER CORRADINI: The pressurizer got
4 taller.

5 MR. WINTERS: Pressurizer got larger. It
6 was taller, even taller for a while, and now it's a
7 little bit taller. So we had to have more volume,
8 obviously, in the pressurizer.

9 CHAIR BONACA: Is 3411 the maximum power
10 you generate for this plant?

11 MR. WINTERS: It's the maximum power that
12 this plant is licensed, or certified for.

13 CHAIR BONACA: But at some point -

14 MR. WINTERS: At some point, we'll have
15 operating experience enough to support a decision of
16 whether an uprate is possible.

17 MEMBER CORRADINI: I was under the
18 impression the Chinese wanted to go to 1,400 megawatts
19 electric on the same design.

20 MR. WINTERS: They may but -

21 MEMBER CORRADINI: I just wanted to bring
22 that up, since that -

23 MR. CUMMINS: You've been reading the
24 newspaper.

25 (Laughter.)

1 MEMBER CORRADINI: I once in a while do
2 that.

3 MR. CUMMINS: The Chinese want to be able
4 to use the technology, and one way to use it is if you
5 apply it - we have a requirement to transfer the
6 technology, so if you can apply it with a new design,
7 then you really understand the technology. And
8 whatever the number is that they have, 1,400 or 1,700,
9 and the configuration is yet to be determined, and
10 Westinghouse will participate some in this, as
11 advisor/consultant/instructor.

12 MEMBER CORRADINI: Okay. I understand.

13 MR. CUMMINS: And, so, it could be a
14 three-loop plant, or it could be a two-loop plant. I
15 think the largest two-loop plant now is going to be
16 this APR1400 for the Koreans, growing out of the
17 System 80+, so that is more than 4,000 megawatts
18 thermal. I don't know the number exactly.

19 MR. WINTERS: But it also has active
20 safety systems, and is a little bit -

21 MR. CUMMINS: So you can have a larger
22 plant.

23 MEMBER CORRADINI: Okay. Thank you.

24 MEMBER SIEBER: Just to clarify for me,
25 going from the 600 to the 1000, make the containment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 bigger, basically to give you more heat capacity? And
2 the IRWST is larger, diameter is the same, but it's
3 deeper?

4 MR. WINTERS: No, we just filled it up
5 more.

6 MEMBER SIEBER: Well, that's -

7 MR. WINTERS: There's more water. The
8 actual layout of inside containment has the top and
9 the bottom of the IRWST, the same as AP600.

10 MEMBER SIEBER: Okay.

11 MR. WINTERS: We just put more water in.

12 MEMBER SIEBER: Now the depressurization
13 blowdown valves, more of them, or they're bigger?

14 MR. WINTERS: The big ones are bigger.
15 The first three stages are the same.

16 MEMBER SIEBER: Okay. That avoids you
17 using electrical safety systems?

18 MR. WINTERS: Right.

19 MEMBER SIEBER: And still doesn't
20 necessarily screw up the containment a lot.

21 MR. WINTERS: Yes. It's the same
22 recovery. Screw up is a relative term.

23 MEMBER SIEBER: Either way.

24 MR. WINTERS: It's the same recovery as
25 AP600.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: Right.

2 MR. WINTERS: Yes, there's going to be a
3 mess in the bottom of your containment if you have to
4 go to safety, all passive safety systems.

5 MEMBER SIEBER: Okay. Thank you.

6 MR. WINTERS: Okay. Let's go on. So here
7 are the passive core cooling systems. You'll notice
8 they're kind of lumped together. All this equipment
9 is inside containment. Terry will show you how the
10 work. But the point to remember is, it's all inside
11 containment. And that energy is passed to the
12 containment shell, and then no fluids are passed
13 through. When you're in full safety mode, passive
14 safety mode, no fluids pass through containment, only
15 energy. Energy passes through the wall of containment
16 and is removed by air passing over containment, or
17 water draining onto containment to get evaporative
18 heat transfer.

19 MEMBER CORRADINI: And you said something,
20 just to clarify. So that after the first 72 hours,
21 the facility, or the plan is to recharge those water
22 tanks -

23 MR. WINTERS: No.

24 MEMBER CORRADINI: Okay.

25 MR. WINTERS: After the first 72 hours,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you can leave it -

2 MEMBER CORRADINI: You made some comment
3 about adding water. I didn't know where you meant it.

4 MR. WINTERS: You could, if you wanted to.

5 MEMBER CORRADINI: Okay.

6 MEMBER SIEBER: But the decay heat curve
7 is coming down.

8 MR. WINTERS: Is way down.

9 MEMBER SIEBER: And, so, the -- basically
10 wetting the containment is no longer necessary.

11 MR. WINTERS: Right. That's exactly
12 right.

13 MEMBER ARMIJO: Could you move back one
14 slide and show me, where is the IRWST on that
15 particular drawing?

16 MR. WINTERS: On the left, it's the
17 rectangular blue, right there. And what you're seeing
18 is a cross-section -- if you look in pan view, it goes
19 about 175 degrees around the containment.

20 MEMBER CORRADINI: It's a suppression
21 pool, Sam.

22 MR. WINTERS: It's a suppression pool,
23 yes.

24 MEMBER ARMIJO: It didn't look very big.

25 MR. WINTERS: It's 800,000 gallons for a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 rough estimate.

2 MEMBER SHACK: You have a containment
3 vent. Right?

4 MR. WINTERS: 600,000, sorry. 600,000.
5 I'm sorry?

6 MEMBER SHACK: You have a containment
7 vent.

8 MR. SCHULZ: We have a containment vent
9 capability. It's not credited in the PRA for any
10 design basis event, so with this containment design,
11 the chances of needing containment venting are so low
12 that we don't even model them in the PRA. The chances
13 of losing cooling -

14 MEMBER SHACK: It's still there. It
15 hasn't disappeared.

16 MR. SCHULZ: Yes. What you -- if you
17 looked at all the valves, and pipes, and whatever, you
18 wouldn't find it. We make use of some existing piping
19 that's for shutdown cooling, and a cross-connection
20 from that to spent fuel pit, to provide a vent
21 capability.

22 MEMBER SIEBER: Not putting it in the PRA
23 is not quite fair, though, because its mere existence
24 is a vulnerability.

25 MR. SCHULZ: The vulnerability is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 addressed in terms of containment isolation, or lack
2 thereof.

3 MEMBER SIEBER: Right.

4 MR. SCHULZ: So I think that part of it,
5 you could also contend that it could be -- its use
6 might be abused, or misused. That is covered with
7 careful writing of EOPs, and CMG-type information.

8 MEMBER SIEBER: Almost as good as not
9 having it.

10 MEMBER CORRADINI: Just to make sure I
11 understand, though, that all current PWRs have the
12 ability to vent. This venting, though, goes through
13 some sort of filtration, in difference to current,
14 what I remember in the old containments, butterfly
15 valves through containment. Is that correct?

16 MR. SCHULZ: This goes through the
17 shutdown cooling system, containment penetrations, and
18 from there into the spent fuel pit under water.

19 MEMBER CORRADINI: Okay.

20 MR. SCHULZ: So the spent fuel pit water
21 provides some trapping of activity.

22 MEMBER CORRADINI: All right. Thank you.

23 MR. WINTERS: So the combination of our
24 passive approach on the right replaces all of the
25 stuff that's outside containment on the left. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that's one of the beauties of this design.

2 In plan view, and in building structure,
3 that results in this kind of a reduction. Now you
4 recognize we kind of cheated on this, because Sizewell
5 has got a lot of extra stuff on it, but this is a
6 scale comparison, so units are about the same size,
7 although Sizewell has a little more power. The colors
8 represent the four channels of safety. You'll notice
9 that all of our colors are on that one base mat, and
10 all the evolutionary plant colors are scattered around
11 the yard, because they've got ultimate heat sinks, and
12 diesel generators, or in the case of Sizewell, gas
13 turbines, and other things necessary to support safety
14 and cool-down, where in AP1000 we don't.

15 MEMBER ABDEL-KHALIK: Are these drawings
16 to the same scale?

17 MR. WINTERS: Yes, sir.

18 Now the philosophy of one design. We have
19 a class mentality, class meaning like a ship class.
20 We've tried to impart on our design team the
21 philosophy that shipyards have relative to building
22 cruise ships, or casino ships. We have one design
23 certification, which we tried to put as much possible
24 design information as we could so the COLA applicants
25 themselves would not have to re-explain that. That

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 meant that they all need to be the same.

2 Westinghouse has 24 potential plants we're
3 discussing with people today, 12 in the U.S. that have
4 been declared. Those are our five utilities, one
5 utility has two sites, so that's 12 plants that we all
6 know about for the U.S.

7 The five utilities have banded together
8 into a buyers group, so that they recognize that if
9 they want the change, if any one of them wants a
10 change, that it's a problem for them, because it's
11 outside the standard. We, Westinghouse, won't
12 necessarily make that change unless all five want the
13 change. If all five want the change, we consider the
14 design to be broken, and we go through our process,
15 which includes a 50.59-like process, and a bunch of
16 those questions that come out of Appendix D. And then
17 determine the technical merit of that, and usually
18 make that change. For example, in the spent fuel pit,
19 they wanted - we've got to have more fuel in our spent
20 - we've got to be able to store more fuel, so just
21 make the building bigger. Well, we had already done
22 our seismic design, and we weren't about to make the
23 building bigger, and they recognized that, so we came
24 up with a different spent fuel packing arrangement and
25 rack design so that we could get more spent fuel into

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the same pit. We wouldn't have done that if there
2 wasn't a consensus of our buyers group, so there is a
3 cross-industry approach to this standard design,
4 standard license, standard - it goes all the way down
5 to we cannot get a human factors complete until we
6 have a set of standard operating procedures, which
7 we're already writing, so the utilities will start, or
8 each of the licensees will start with a full set of
9 operating procedures that have been run through a
10 standard review process to get our human factors and
11 control room certified. And that is also borne out in
12 the active multi-COLA Design-Centered Working Group.

13 Just as an aside, our design meets the
14 utility requirements document, which is a plant
15 specification written by 16 utilities, so that it is
16 a real effort, an emphasis on standardization in our
17 philosophy.

18 MEMBER SHACK: How many sources are there
19 for your forgings for your pressure vessel?

20 MR. WINTERS: Many. But if you said how
21 many sources are there for the two ultra big forgings?

22 MEMBER SHACK: Yes.

23 MR. WINTERS: One. This is the regulatory
24 process, and you've seen it, you'll hear more about
25 it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: At what point would
2 you go from one design class to another?

3 MR. WINTERS: That'll probably be a
4 commercial -- we have the five lead applicants now.
5 They're going to be in a group. We'll call that Wave
6 One. When the next set of people decide they want to
7 build in the United States, or somewhere else, there
8 may be some - let's make it better changes in-between
9 there, and it will be based - that decision of when to
10 switch waves will be a commercial decision.

11 MEMBER ABDEL-KHALIK: And would that be
12 handled as a completely new application, or as a
13 modification to the -

14 MR. WINTERS: Probably as a modification,
15 but we don't know what's in it yet, so it's hard to
16 say. But we'd probably call it another modification,
17 amendment.

18 I don't mean to go into this a lot, except
19 that we do have a design certification, and we've only
20 made a few changes, or we've made a few plus minor
21 changes in this Rev. 16 approach. So here we are back
22 to our picture of what's in the certification.

23 CHAIR BONACA: Can I ask a question?

24 MR. WINTERS: Yes.

25 CHAIR BONACA: Going back to the previous

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 slide. What's your judgment of what could be a
2 reasonable time between combined operating license and
3 operations, because of the simplification, and so and
4 so forth?

5 MR. WINTERS: We're -- the schedule that
6 we talk about, which isn't necessarily a contractual
7 schedule, but a schedule we talk about has some period
8 before combined operating license that you can do
9 work. You can't do safety-related structural work
10 until you have a combined operating license. Okay?
11 So that time before construction starts can be 18
12 months to two years, where you buy your large
13 forgings, you start putting down your construction
14 facilities, you could dig the hole. The construction
15 period that we talk about, which includes the
16 construction acceptance criteria, from first concrete
17 to fuel load is 48 months, four years. We say it
18 takes about six months for commissioning, and your
19 acceptance testing. It'll probably take a little
20 longer than that on the first unit, because we have
21 some one-unit-only tests to do. It'll take less than
22 that on follow units, because we're just doing the
23 same tests on the same design. But approach then is
24 48 plus 6 from first concrete for the first few units.

25 We believe that on the Nth unit, I don't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 know what N is, five, three, eight, that we've shown
2 we can do it in 36 months from first concrete to fuel
3 load, so you've heard that, as well.

4 So we're back to this picture. On the
5 electrical side, to answer your question, inside the
6 standard design is our side of the main transformers.
7 It includes the whole reserve auxiliary transformers
8 and the station transformers. From the main
9 transformers out, is the licensee's responsibility.
10 So we have the generator, there are no changes. If
11 someone comes up with a change, we have two questions
12 on our change process that people have to answer
13 before they start. What isn't safe that you're
14 fixing, and what doesn't work that you're fixing?

15 If the answer is none of those, then no to
16 both of those questions, I'm making it better, we say,
17 you know, we've really gone too far for the first wave
18 to make it better. A COLA has been submitted, and
19 we're going to get to perturb that process, so we have
20 a very rigorous approach, and graded approach to
21 changes. Changes that don't affect the DCD are
22 handled with a little less review and process than
23 those that do affect the DCD or COLA. Those that have
24 no affect outside of a functional group, have a whole
25 lot less of this administrivia attached to it, so we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 do have a graded approach. All of them -

2 CHAIR BONACA: The philosophy, clearly, I
3 mean, although, all these units will be built on
4 existing sites where there are operating plants.

5 MR. WINTERS: Not all. Of the 12 plants
6 for the United States, one is total greenfield site,
7 and one is a site that has a foundation on it with no
8 operating plants, and another, like Bellafonte, has
9 two built plants, but no operating plants, so it is a
10 variety of sites.

11 CHAIR BONACA: But, in any event, the
12 philosophy is such that you would have no shared
13 systems.

14 MR. WINTERS: No, no shared systems. All
15 of them are dual unit sites, and there's nothing
16 shared, except the access road. Okay. That's an
17 exaggeration, but there are no shared systems.

18 CHAIR BONACA: Okay.

19 MR. WINTERS: We do have a full 3D model.
20 We're not going to talk about it today, but that's to
21 give you an idea of what the plant looks like, again,
22 for those who haven't been involved in it. Okay?

23 So we're going to switch to Terry now, and
24 Terry is going to go into more detail of how the
25 passive systems work, and what few modifications we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 made to them in Rev. 16.

2 MR. SCHULZ: Thank you, Jim. Good morning.
3 My name is Terry Schulz. I also work in the
4 Westinghouse AP1000 Engineering Department. I've been
5 involved in the design of the passive systems since we
6 started back in the late 1980s. And what I'm here to
7 talk about today is both the passive safety systems,
8 and then what we call defense-in-depth systems.

9 The passive safety systems, as Jim has
10 mentioned, we have kind of a special meaning for that
11 word, and it includes one-time alignment of valves to
12 initiate our passive features. Those valves are
13 powered by batteries in some cases, in other cases
14 they're fail-safe valves, air operated-type valves.
15 There's no support systems needed once the systems are
16 actuated, no AC power, in fact, no DC power once you
17 get actuated, no operating pump, cooling water, HVAC,
18 chilled systems.

19 MEMBER STETKAR: Excuse me. I haven't had
20 the benefit of sitting through the AP600, so I'm kind
21 of new to this process. No DC power, no I&C, so the
22 operators have no indications -

23 MR. SCHULZ: What I was speaking about was
24 the mechanical systems, like the core cooling,
25 containment cooling systems.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: So you do have an
2 operating I&C.

3 MR. SCHULZ: WE have an operating I&C
4 system that continues throughout the accident. It is
5 powered by batteries.

6 MEMBER STETKAR: Uninterruptible power
7 supplies and so forth?

8 MR. SCHULZ: Yes.

9 MEMBER STETKAR: Okay. What kind of
10 analyses have you done on 72-hour room heat-up without
11 HVAC?

12 MR. SCHULZ: We have done those analysis
13 to show that both the control room, and the I&C
14 cabinet rooms stay within their design temperature
15 limits.

16 MEMBER STETKAR: Uninterruptible power
17 supply limits?

18 MR. SCHULZ: I think those are -

19 MEMBER STETKAR: Oka. That's probably too
20 much detail.

21 MR. SCHULZ: We've looked at those -- they
22 tend to be no challenging, because there's no heat
23 sink, no heat source in there. They're actually more
24 of a heat sink.

25 MEMBER STETKAR: All DC driven, not AC

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 driven?

2 MR. WINTERS: No AC, all batteries. The
3 structural design, especially designed, like for the
4 control room, to be a heat sink.

5 MR. SCHULZ: To enhance the heat -

6 MR. WINTERS: To enhance the heat removal
7 in a passive way from the room. The ceiling of the
8 control room has extra concrete to have a large
9 thermal mass, and fins on the bottom, so that the heat
10 transfer into that thermal mass is enhanced, just so
11 we can remain passive for 72 hours.

12 MEMBER ARMIJO: I'm still a little
13 confused on your definition of passive, is that you
14 don't require AC power. And in these systems, you
15 have to align the valves to get these passive systems
16 working.

17 MR. WINTERS: Yes.

18 MEMBER ARMIJO: And, presumably, that
19 alignment doesn't require AC power, or does that
20 alignment -

21 MR. SCHULZ: Does not.

22 MEMBER ARMIJO: Does not. But then you
23 installed a number of what you call multiple reliable
24 power sources to avoid unnecessary actuations, so -

25 MR. SCHULZ: Those are non-safety

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 features. One of the things that I'm going to try to
2 do today is to make clear what is passive safety, 1E,
3 seismic, tech spec design, and what is not safety,
4 what we call defense-in-depth, and what the
5 capabilities and the regulatory oversight of that is,
6 because that was one of the big questions that we
7 discussed, especially in AP600, which is the same
8 basic arrangement and philosophy, and there was an
9 industry/staff debate and discussion about how
10 important were diesel generators? They used to be
11 safety. We came in saying they aren't safety. How
12 important are they? That was a very important
13 discussion, and the second part of my presentation
14 will have some slides that focus on the resolution
15 that we came to on those features.

16 CHAIR BONACA: For example, you'll have
17 charge -

18 MR. SCHULZ: Yes, we have.

19 CHAIR BONACA: They will not be receptive
20 later, but you can use them if you had to.

21 MR. SCHULZ: Correct.

22 CHAIR BONACA: The whole issue here is to
23 eliminate the nuclear classification and the safety-
24 related, but you do have backups.

25 MR. SCHULZ: That's right. And one of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 things I'll show you a little bit of information on is
2 from a PRA perspective, how important those features
3 are. So if you took them away, what do you have left,
4 from a core melt frequency, large release frequency
5 point of view, which is one of the major things to
6 judge the importance of the non-safety features.

7 But continuing here, another
8 characteristic of the passive features is that they
9 greatly reduce the operator actions that are needed to
10 keep the plant safe in design-basis accidents. They
11 mitigate design-basis accidents without the need for
12 non-safety systems to work, so they do Chapter 15-type
13 mitigation without use of charging pumps, or diesels.

14 We also have an objective that we placed
15 on ourselves, that we could meet the NRC safety goals
16 without credit for the non-safety features. Again,
17 the objective there was to provide a sort of minimum
18 level of protection by the passive safety features,
19 and not be too reliant on the non-safety features in
20 the plant.

21 We do have active non-safety features in
22 the plant. In most cases they are there to support
23 normal operation. In some cases, it's a transient
24 response, or anticipated-type events, so that includes
25 the diesel generators, and some startup feedwater

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 equipment. I'll give you some more information on
2 that.

3 Typically, those features include
4 redundant active components, pumps power by diesels.
5 They don't necessarily have redundant separated
6 mechanical piping systems, because those are -- the
7 failures of those kind of systems are much lower
8 probability. And, again, these aren't safety features,
9 so we don't have to deal with separation for fire
10 protection, and that kind of thing. And, as I
11 mentioned, they're not required to mitigate design-
12 basis accidents.

13 We do, however, look very hard for adverse
14 interactions between the active and passive features.
15 We did testing along those lines, and it's something
16 that we look at from an analysis point of view, so
17 that if an active system operating can make an
18 accident worse, at least to a certain point, we
19 include that in the accident analysis, but only
20 because it makes it worse. Where it makes the
21 accident better, we don't credit it.

22 CHAIR BONACA: The accident analysis, I
23 mean, which one are your front line systems, come
24 first, the passive or the active?

25 MR. SCHULZ: In terms of actual sequence

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of operation, anticipated sequence, the active systems
2 are designed to come on first.

3 CHAIR BONACA: Come on first.

4 MR. SCHULZ: Okay? And if they operate
5 properly, the passive systems will not be challenged,
6 will not be actuated. If they don't work properly,
7 then the plant conditions would degrade somewhat, and
8 then the passive safety features would come on.

9 Jim showed you this picture. I'll speak
10 just a little bit more about it. This is showing you
11 the passive core cooling features. Again, it's all
12 inside containment. The large water storage tank is a
13 refueling water storage tank in containment, refueling
14 water storage tank. We have -

15 CHAIR BONACA: Going back to the previous
16 question just for -- so your accident analysis, you
17 have to demonstrate -- you demonstrated separate
18 systems will provide the required safety.

19 MR. SCHULZ: I'm sorry?

20 CHAIR BONACA: I mean, although the front
21 line systems are going to be the active ones, you are
22 not testing them really in the accident analysis.
23 You're testing the passive systems.

24 MR. SCHULZ: Yes. So in Chapter 15, the
25 plant protection mitigation, accident mitigation is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 provided by the passive features.

2 MEMBER ABDEL-KHALIK: So how would you
3 define the initial conditions for the safety analysis?

4 MR. SCHULZ: The way we traditionally do.
5 In most of the -

6 MEMBER ABDEL-KHALIK: Vis-a-vis reality.

7 MR. SCHULZ: Pardon me?

8 MR. WINTERS: Vis-a-vis reality, he said.

9 MR. SCHULZ: We generally for everything
10 but large break LOCA, we do a conservative analysis,
11 so we look at limiting bounding, initial pressure
12 levels, and whatever for the accident analysis. We
13 consider the potential operation of active features
14 that could drive those conditions to be more limiting,
15 like the operation of the makeup pumps trying to say
16 overfill the pressurizer during a Condition 2 mass
17 addition event. We look at the operation of startup
18 feedwater to potentially add to the overfill potential
19 of the steam generators during a tube rupture event.
20 In both cases, we have safety-related isolation
21 features of those active features that will come into
22 play at a certain point in the transient, and stop the
23 adverse interaction before it gets to be unacceptable.

24 MR. CUMMINS: Maybe I could help. The
25 initiating conditions are set by the set points in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I&C system that cause the actuation of the plant trip,
2 or the actuation of various passive systems, so at
3 some point -- I mean, what Terry said is, you can take
4 all the worst conditions less than the set point, but
5 as soon as you get to the set point, we assume that
6 the I&C system causes the corrective action that's
7 appropriate.

8 MR. WINTERS: And even though in real life
9 we would take credit for the non-safety active
10 systems, in the analysis, we don't.

11 MEMBER ABDEL-KHALIK: Well, that's the
12 reason for my question. I guess when it gets to
13 specific examples, we'll be able to see how that
14 works.

15 MR. WINTERS: Yes.

16 MR. CUMMINS: If the non-safety active
17 systems are correctly used, you never get to the set
18 point.

19 MR. SCHULZ: And, again, what we -- this
20 philosophy was developed in AP600, implemented in
21 AP1000. The DCD Rev. 15 incorporates all this in the
22 safety analysis, and the DCD. And we haven't really
23 changed that in Rev. 16.

24 MEMBER ABDEL-KHALIK: To follow-up on your
25 comment, on the other hand, there are situations where

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 the actuation of those active systems can create an
2 initial condition for the passive system that's worse
3 than if that was the primary system on which you rely
4 on.

5 MR. CUMMINS: That's true, but the active
6 systems are controlled in the end by the set point.
7 I mean, when you get to the set point, the I&C takes
8 over, regardless of what the active systems are doing,
9 and it actuates the passive systems.

10 MR. SCHULZ: And isolates active features
11 -

12 MR. CUMMINS: As necessary.

13 MR. SCHULZ: As necessary, and those
14 conditions are accounted for in the safety analysis.

15 CHAIR BONACA: So I assume the analysis
16 where the active systems are able to keep you away
17 from the passive systems. Okay? Give you success.
18 Are they modeled and analyzed in the accident
19 analysis?

20 MR. SCHULZ: No.

21 CHAIR BONACA: They're not?

22 MR. SCHULZ: No, because we don't rely on
23 them. It's not important in the DCD.

24 MR. CUMMINS: So the approach for the
25 licensing is that the active systems do as bad a job

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 as they could possibly do to create the worst initial
2 conditions that you could possibly have, without
3 reaching a set point, and then the set point occurs.
4 If the active features still would cause more
5 problems, it's terminated by some passive system, we
6 isolate it.

7 CHAIR BONACA: We'll have to see, but you
8 talked before of the interaction between safety and
9 non-safety systems, and a good example is the current
10 design of plants, is the PRV was never modeled in
11 accident analysis, because it was supposed to be a
12 good thing. It wasn't in all cases, I guess.

13 MR. SCHULZ: Well, we do, for example, in
14 our steam generator, have power-up and refill still,
15 and we do look at adverse opening and sticking opening
16 of those valves. They are not safety-related to open,
17 so we don't take credit for them when we're trying to
18 look at steam generator over-pressurization. We do
19 look at them if their operation can make the accident
20 worse, and in a tube rupture from a dose point of
21 view, if those valves do open, and stick open as a
22 failure, then that is a worse operation. Again, it's
23 consistent with our philosophy of looking at operation
24 of non-safety features where they can make accident
25 consequences and parameters worse, and not taking

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 credit for them, or they would mitigate or reduce the
2 consequences of the accident.

3 CHAIR BONACA: So there will be some
4 conditions where the active system would not be
5 sufficient, because you have to go to the passive
6 systems.

7 MR. SCHULZ: Right. Either because the
8 active systems are not capable of mitigating the
9 event, or because they can be considered to not work,
10 because they're not tech spec'd, they're not required,
11 they're not 1E, they're not a safety feature to work.

12 MEMBER ABDEL-KHALIK: So, big picture,
13 there would be two different sets of set points, one
14 for actuating the active systems, and one which
15 represents a more degraded condition that would result
16 in the actuation of -

17 MR. SCHULZ: Generally speaking, you have
18 to realize that the active systems are non-safety.
19 They are controlled by the control grade I&C, not the
20 protection system. Okay? You're not safety-related,
21 so -

22 MEMBER ABDEL-KHALIK: But in terms of
23 plant parameters, deviations from normal -

24 MR. CUMMINS: Yes, you have the right
25 idea. The active systems are actuated, but not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 actuated with a safety-related I&C system. They're
2 actuated with a non-safety related I&C system. And if
3 they need to be terminated, we isolate them with the
4 passive systems, by closing valves, or by -

5 CHAIR BONACA: I mean, in the current
6 design that you have at Westinghouse, you have your
7 charging pumps, which are also safety injection pumps.
8 I mean, they play both roles.

9 MR. CUMMINS: Yes.

10 CHAIR BONACA: And here you have
11 discharging pumps, which are not safety injection
12 pumps, also they play also a role of safety injection.

13 MR. CUMMINS: That's right. So we have a
14 set point for them to come on. They come on.

15 CHAIR BONACA: But you don't have to
16 demonstrate that with those you will meet the LOCA
17 requirements.

18 MR. CUMMINS: We don't have to demonstrate
19 that.

20 CHAIR BONACA: You don't have to do that.

21 MR. CUMMINS: No.

22 MR. SCHULZ: In fact, they are not very
23 capable of that, because they don't have recirculation
24 capability.

25 CHAIR BONACA: Okay.

1 MR. SCHULZ: We've intentionally designed
2 that out of those systems, because we didn't want that
3 complication in the design, so they can make up for
4 leakage, or maybe big leaks, but when you start
5 getting into maybe greater than one inch breaks, they
6 really can't mitigate that accident.

7 MR. CUMMINS: Another way to say this -

8 CHAIR BONACA: What if your passive
9 systems did not work? I mean, it's true you have this
10 active system that is running, and you have your
11 diesels running them, but you don't know really what
12 the ultimate results of the analysis will be, because
13 you haven't performed that. Right?

14 MR. CUMMINS: The active systems don't
15 mitigate every single accident. They mitigate some of
16 the more -

17 MR. SCHULZ: Probable.

18 MR. CUMMINS: Probable accidents. Yes.

19 MEMBER SHACK: I thought it was everything
20 but the large break LOCA.

21 MR. SCHULZ: No, there's issues, like a
22 feed line break, the startup feedwater really can't
23 deal with a feed line break. So there still are some
24 low probability events, and in some cases, too, at
25 higher probability events, that you have more, maybe

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 active feature options. And when you get to low
2 probability events, you have some or maybe a
3 combination of active/passive. There's some -- one of
4 the slides I'll show you at the end of my presentation
5 actually is sort of the levels of defense, and
6 combinations of systems, and what's active, and what's
7 passive, and what's safety and non-safety.

8 MEMBER ABDEL-KHALIK: But even though you
9 don't include the plant response consequent to the
10 initiation of these active systems, you don't include
11 that in the safety analyses. You must have done that
12 to be able to come up with the set points for
13 actuation of the passive systems.

14 MR. SCHULZ: That's the sizing. We did
15 that kind of analysis to come up with the sizing of
16 the active systems. Okay? So we looked at loss of
17 main feedwater, and we sized the startup feedwater, so
18 that on a reasonable design-basis, not a conservative-
19 safety-basis, those pumps can maintain the steam
20 generator water level above the safety set point.
21 Okay?

22 Now given the size of those pumps, and
23 capability of that system, we then look at the safety
24 analysis, and we look at situations where the system
25 doesn't work at all. We look at it as it works as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 designed, and we analyze the different combinations of
2 safety event, plus the operation of the active
3 features to see when we run into the passive safety
4 set points. And that's what we do for Chapter 15, is
5 looking at the potential operation of the active
6 features to either make the accident worse, in which
7 case we include that in Chapter 15. If it makes the
8 accident better, then we keep looking for the events
9 that are more limiting, where we don't get credit
10 benefit for the active features in Chapter 15 now.

11 MEMBER ABDEL-KHALIK: Thank you.

12 MR. SCHULZ: Okay. The passive core
13 cooling system has several water supplies. It has
14 accumulators. Accumulators are very similar to the
15 current operating plants. One difference is that they
16 inject through an access or injection line. They
17 don't inject into the cold legs, which is typical of
18 the operating plants. We did that so that we did not
19 have to take a spill of accumulator in a large break
20 LOCA, so both our accumulators function in a large
21 break LOCA.

22 A unique feature we have is a core makeup
23 tank. These tanks are of full reactor cooling system
24 pressure. They are filled with water. The injection
25 of them is a natural circulation kind of injection, so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 they have a pressure balance line that comes from the
2 cold legs, and goes up to the top of the tank. These
3 are core makeup tanks. The massive water in the core
4 makeup tanks is about equal to the reactor coolant
5 system mass.

6 MEMBER CORRADINI: So you essentially have
7 doubled by the pressure balance line, you're just
8 doubling the inventory.

9 MR. SCHULZ: Doubling the inventory, but
10 this inventory is cold, and it's borated. Okay? So
11 it's not hot.

12 MEMBER CORRADINI: Slightly borated there,
13 is it not?

14 MR. SCHULZ: Significantly, it's 4,000
15 ppm. It's higher than refueling, a little bit higher
16 than refueling concentration.

17 MEMBER SIEBER: Did you end up with a
18 problem injecting what I consider really cold water
19 into a hot vessel from the standpoint of brittle
20 fracture, that kind of stuff?

21 MR. SCHULZ: We have to look at that. One
22 of the reasons why people in the past didn't always
23 use reactor vessel injection lines is because of that
24 concern, and so if you go into the loops, it's a
25 little easier to do the mechanical analysis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: Right.

2 MR. SCHULZ: So this is a trade-off
3 between optimizing the system design, and the
4 challenge of designing the reactor vessel.

5 MEMBER SIEBER: Have you done that
6 analysis yet?

7 MR. SCHULZ: We have done analysis there.
8 I don't think the final ASME stress reports are done,
9 but we have done significant work in that area to make
10 sure there's no feasibility issues with that.

11 MEMBER SIEBER: When do you expect -- that
12 should be a part of the design certification. Right?

13 MR. CUMMINS: That is -- there is a COL
14 action item which is stress reports for the major
15 equipment, and we're closing that COL action item in
16 this.

17 MEMBER SIEBER: Maybe I can ask Dave, when
18 staff gets that response, that I can get a copy of it.

19 MR. FISCHER: Certainly.

20 MEMBER CORRADINI: And so the logic, just
21 to go back to a design logic, you said it, I want to
22 make sure I understood it. The design logic is that
23 putting the CMTs directly into the core avoids the
24 chance, avoids a broken line as one of the places that
25 essentially eliminates the use of the CMT?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCHULZ: It eliminates the chance for
2 big breaks.

3 MEMBER CORRADINI: Reduces. Okay.

4 MR. SCHULZ: For big breaks, it eliminates
5 it. Obviously, that line can still break. And, in
6 fact, that is probably the most challenging break
7 location for our plant, is the break of one of these
8 eight inch direct vessel injection lines, which does
9 spill one over to accumulators, one over to core
10 makeup tanks. And I'll actually show you in four or
11 five slides what that accident analysis looks like,
12 and we still keep the core covered in that situation.
13 But let me finish a little bit of the system
14 operations -

15 MEMBER CORRADINI: That's fine. I just
16 wanted to understand the connection. Thank you.

17 MR. SCHULZ: Sure. The core makeup tanks
18 have a significant volume, but it's not infinite.
19 They operate kind of like high head safety injection
20 pumps, they can inject at any reactor coolant system
21 pressure. They're not an accumulator that takes the
22 gas pressure to inject. It's a pressure balance line
23 to the cold leg, so any pressure they can inject.

24 As these tanks start to drain, if they
25 start to drain in a small break LOCA, that level in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the tank triggers the automatic depressurization
2 system, so we use those tanks as kind of an indication
3 of inventory in the reactor coolant system, because
4 they don't start draining until the cold leg is void.
5 And then when you're in that situation, you're
6 obviously in an inventory challenged situation. The
7 depressurization valves -

8 MEMBER SIEBER: Reactor pressure is
9 basically atmospheric?

10 MR. WINTERS: Not yet.

11 MR. SCHULZ: Not yet. Okay.

12 MEMBER SIEBER: If you don't have a gas
13 pocket, what causes -- once you get the break, those
14 tanks depressurize. Right?

15 MR. SCHULZ: They follow the RCS pressure.
16 Okay? Depending on the break size, the pressure can
17 be up, if it's a smaller break. A bigger break, it
18 comes down very quickly.

19 MEMBER SIEBER: So you're relying on
20 gravity to -

21 MR. SCHULZ: Yes.

22 MEMBER SIEBER: -- overcome all the
23 friction and everything.

24 MR. SCHULZ: Right. And we've done a lot
25 of analysis, a lot of testing, both system and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 integral testing to show that this kind of a feature
2 works, and works well in this plant. We've actually
3 done full two integral tests that have reactor vessel,
4 two steam generators, two core makeup tanks, DVI
5 lines, passive RHR and all that stuff, ADS valves to
6 show that the core makeup tank injection capabilities
7 not only work, but work as designed.

8 MEMBER CORRADINI: At full pressure.

9 MR. SCHULZ: At full pressure, or any
10 pressure -

11 MEMBER CORRADINI: No, I understand that,
12 but you were commenting on the testing. I couldn't
13 remember, is this the Italian -- the test -

14 MR. SCHULZ: The Spez testing is a full
15 pressure test. Yes.

16 MEMBER CORRADINI: Okay. Fine.

17 MEMBER ARMIJO: These tanks are never to
18 be used, except for accident?

19 MR. SCHULZ: They have no normal function.

20 MEMBER ARMIJO: No other function?

21 MR. SCHULZ: That's right. That's true of
22 basically all of our safety features. They are not
23 dual purpose features. They are only used during
24 transients where non-safety features don't work, or in
25 more severe accidents, where they're the only

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 protection.

2 So the core makeup tank level is what
3 triggers ADS. We have four stages, three of them are
4 connected from the top of the pressurizer over to the
5 refueling water storage tank through a sparger. The
6 sparger is in there solely to reduce the consequences
7 of those valves operating. This is not a pressure
8 suppression containment, it's a large dry PWR
9 containment, so we don't need those spargers to
10 operate to minimize the containment pressure.

11 MEMBER ABDEL-KHALIK: So the level drop in
12 the core makeup tanks, by itself, no coincident with
13 a decrease in pressure, would actuate this
14 depressurization system.

15 MR. SCHULZ: Well, not by itself. There
16 is some coincident logic, but you need to have
17 actuated a safety injection signal, which is a core
18 makeup tank injection signal, which trips the reactor,
19 starts the core makeup tanks. You need that signal,
20 which is two out of four logic, plus two out of four
21 logic from either core makeup tank level
22 instrumentation.

23 MEMBER ABDEL-KHALIK: Okay.

24 MEMBER CORRADINI: I'm sorry we're asking
25 you to review this, but just to repeat what you said,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 so you had to essentially open a valve to get to the
2 CMT?

3 MR. SCHULZ: Yes.

4 MEMBER CORRADINI: Now the balance line is
5 always open.

6 MR. SCHULZ: Right.

7 MEMBER CORRADINI: But the discharge line
8 must be open.

9 MR. SCHULZ: The discharge line has two
10 parallel normally closed fail open air-operated
11 valves.

12 MEMBER CORRADINI: Okay.

13 MR. SCHULZ: So it's fail-safe type design
14 for the core makeup tanks. You lose air pressure, you
15 lose power to the valve, it opens.

16 MEMBER CORRADINI: Thank you.

17 MR. SCHULZ: That same kind of arrangement
18 is also provided in the passive OHR, which is our
19 transient decay heat removal safety feature. We don't
20 rely on auxiliary feedwater pumps in this plant. We
21 have startup feedwater pumps, but they're not safety.
22 The safety feature in case of loss of off-site power
23 or loss of feedwater, or feed line break is the
24 passive OHR, which is connected directly to the
25 reactor coolant system piping. It's arranged somewhat

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 like the core makeup tank. There's an inlet line that
2 comes from the hot legs to the top of the heat
3 exchanger. There's an outlet line that comes back to
4 the steam generator channel head. That outlet line is
5 normally isolated. The inlet line is normally open,
6 so the system always relies on the reactor coolant
7 system pressure. The outlet valves are just like the
8 core makeup tanks, normally closed, fail open, air-
9 operated valves. So it's fail-safe, this design.

10 MEMBER ARMIJO: If that happens during
11 normal operation, the water in those core makeup tanks
12 don't go into the vessel?

13 MR. SCHULZ: The water in the core makeup
14 tanks is not going to be driven strongly by the normal
15 pressure condition in the reactor coolant system.
16 It's basically taking an inlet from the cold leg, and
17 it's injecting into the downcomer. Now there is a
18 pressure drop there. There's also a velocity head
19 recovery in there, so the pressure is actually only
20 allow for a small core makeup tank flow in that
21 condition.

22 MEMBER CORRADINI: But if you had the
23 discharge open, there would be flow.

24 MEMBER SIEBER: Yes, but it's more like a
25 migration than a flow.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: With the pump running,
2 there will be flow.

3 MR. SCHULZ: There will be some flow, but
4 it will be less than the design flow, because when we
5 normally actuate core makeup tanks, part of the logic
6 is to automatically redundantly safety-related trip
7 the reactor coolant pumps. So any time we have a
8 safety injection signal in this plant, we trip the
9 reactor coolant pumps.

10 MEMBER MAYNARD: But if those valves
11 inadvertently open for any reason during operation,
12 you're going to start borating -

13 MEMBER CORRADINI: I was going to say,
14 it's a boration -

15 (Simultaneous speech.)

16 MEMBER MAYNARD: A boration event start
17 shutting the power down if you don't get the valves
18 shut pretty soon, that you'd be -

19 MR. SCHULZ: Yes, there are consequences.
20 But my point was that they are not very severe
21 consequences, or very rapid consequences. But, yes,
22 there will be some boration.

23 MEMBER MAYNARD: That was in the right
24 direction, so -

25 MR. SCHULZ: Yes. Now if the same thing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 happens to the passive OHR, it's a little different,
2 in that the way that piping arrangement is set up,
3 it's taking an inlet from the hot leg, returning to
4 the pump suction. So if the pump is running, there's
5 a substantial pressure drop there in the normal flow
6 direction, so that will force flow through the passive
7 OHR, so you'll get a substantial flow through the
8 passive OHR, and a substantial bump in heat removal.
9 That is specific analysis we perform in Chapter 15 to
10 look at the consequences of that, and it's a Condition
11 2-type event, and we show that there's no core damage
12 in that kind of a situation.

13 MEMBER SIEBER: You don't have any kind of
14 a check valve in there to prevent back flow?

15 MR. SCHULZ: Well, the way the piping is
16 arranged, it will never go backwards. Okay? The pump
17 is running, it goes more strongly in the passive flow
18 direction. If the pump isn't running, then it still
19 goes in the same direction.

20 MEMBER SIEBER: What's the pump DP, about
21 150 pounds?

22 MR. SCHULZ: It's somewhat less than that.
23 It's relatively high in this plant, because -

24 MEMBER SIEBER: I figured it would be.

25 MR. SCHULZ: -- of the long core and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 flow rates we're putting through it, so it's a little
2 higher than -- if you look at AP600, the pump heads
3 are quite a bit lower than on AP1000.

4 MEMBER ABDEL-KHALIK: So in this plant,
5 any accident scenario you trip the reactor coolant
6 pump.

7 MR. SCHULZ: No. Any accident scenario
8 that creates a safety injection signal. There are
9 other safety signals that, for example, if you -

10 MEMBER ABDEL-KHALIK: So a loss of
11 inventory event.

12 MR. SCHULZ: Yes. Yes. So in order to
13 get safety injection going, one of the consequences is
14 we turn off the reactor coolant pumps, and we start
15 the core makeup tanks. And that puts them in the
16 design operating condition for those tanks.

17 CHAIR BONACA: One comment I would like to
18 make. You know you're running somewhat late, so I
19 want to make sure we don't short-change the afternoon
20 presentation.

21 MS. STERDIS: No. We have to stick to the
22 presentation schedule this afternoon.

23 CHAIR BONACA: So you may want to manage
24 the presentation -

25 (Off the record comments.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR BONACA: The purpose of the meeting
2 was to get information, so I think we're not wasting
3 time. I think as you go forward you may want to look
4 at some slides, maybe you want to bypass.

5 MR. SCHULZ: Let me try to just point to
6 it quickly here. This is a section through the
7 containment, just to give you a feeling for the layout
8 of the key passive features. You see on the right
9 side the accumulator and the core makeup tank. The
10 elevation of the core makeup tank is important,
11 because of the natural circulation operation. You see
12 on the left side of the containment the passive OHR,
13 which is sitting in the IRWST. The IRWST provides a
14 large heat sink for that heat exchanger. It'll take
15 maybe about an hour to heat that tank up to boiling,
16 and then after that, you start steaming to the
17 containment. The containment would start to
18 pressurize, passive containment would come on, and
19 that would then cool the containment, providing your
20 ultimate heat sink, would also collect the condensate,
21 the steam that condenses on the containment is
22 collected in basically a gutter-like arrangement that
23 goes all the way around at the operating deck, and
24 then directs the water back into the IRWST. And then
25 that means we could basically operate the passive OHR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 indefinitely without -- even though we're boiling, but
2 we're bringing the water condensate back.

3 This is a little animation to try to give
4 you a feeling for the integrative operation of the
5 passive core cooling system in a LOCA. So here we
6 have a cold leg break LOCA, pressurizer level starts
7 coming down, pressurizer level in this case, or
8 pressure would trigger the safety injection signal,
9 which stops the reactor coolant pumps and starts the
10 passive OHR. So as the passive core cooling features
11 get actuated, they'll start appearing on the page
12 here.

13 Initially, when the cold legs are voided,
14 you'll get a hot water/cold water circulation mode
15 going on. When the cold legs void in a bigger small
16 break LOCA, then you start draining the core makeup
17 tank. When it drains to about two-thirds full, it
18 triggers ADS Stage 1, 2, and 3, which again are
19 connected from the top of the pressurizer over to the
20 sparger.

21 MEMBER CORRADINI: The balance line is off
22 the cold leg. Right?

23 MR. SCHULZ: The balance line is off the
24 cold leg, yes. So it's a cold leg voiding that
25 triggers the CMT draining. Okay? Stages 1, 2, and 3

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 start bringing the pressure down. They insure that
2 the accumulators inject, which are about 700 psi.
3 When the accumulators are injecting rapidly, the core
4 makeup tanks actually slow down and stop for a while,
5 while the accumulators are injecting. Once the
6 accumulator empties, that flow from the accumulator
7 goes away, the core makeup tanks continue injecting.
8 A very low level in the core makeup tank actuates
9 Stage 4, which comes directly off the hot legs, and
10 goes directly into the containment. Those are squib
11 valves, and they provide a very effective
12 depressurization of the reactor coolant system down to
13 nearly atmospheric pressure, which then allows water
14 from the IWRST to inject by gravity into the reactor.
15 Ultimately, that tank will drain down anywhere between
16 four to five - excuse me - two to four hours, and then
17 on a lower level, we initiate a recirculation. This
18 is also done by gravity. It's a little hard to see in
19 this picture, but the water level in the containment
20 is sufficient to drive water through screens by
21 gravity into the reactor coolant system.

22 MEMBER ARMIJO: Where does all that water
23 wind up, all the water that's coming out of the LOCA,
24 and location, does that wind up around the vessel?

25 MR. SCHULZ: It's all open, including

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 under the vessel, in the compartments. We've put a
2 lot of concrete in the basement of this plant to
3 engineer and design the flood-up levels, so that we
4 get the desired level, which is around the reactor
5 vessel flange. In a LOCA, the levels will go up that
6 high.

7 MEMBER ARMIJO: Okay.

8 MR. SCHULZ: And that's what drives the
9 recirculation. This was something that was tested
10 extensively at Oregon State University testing, which
11 was another integral facility, which had all the high
12 pressure features, but also had models for the
13 containment, and the flood-up so that we could
14 actually experimentally show that the recirculation
15 part of it works.

16 Maybe to save time, I won't talk very much
17 about this event. This is a limiting small break LOCA,
18 break of one of the injection lines, so the injection
19 supplied by the core makeup tank, the top right-hand
20 figure there, is from one core makeup tank. The other
21 one is spilling. You see the sort of gap in flow.
22 That's when the accumulator is injecting, so we don't
23 have a gap in reactor injection, it's that the
24 accumulator, the core makeup tank slows down and stops
25 for a period of time while the accumulator is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 injecting very rapidly. Key feature, the bottom left-
2 hand curve, which shows that the core stays covered
3 through this eight inch break DVI LOCA.

4 MEMBER ARMIJO: What are all those little
5 spikes going down? What's happening there?

6 MR. SCHULZ: You tend to see oscillations.
7 You also seem them in the IRWST injection, and it has
8 to do with, the system basically is almost providing
9 too much water, so we're tending to fill up the hot
10 legs, and when we fill up the hot legs, it tends to
11 retard steam venting, and the pressure goes up a
12 little bit, and the flow does down a little bit, but
13 there's no threat to core cooling, because we're
14 tending to overfill the system. So that's what's
15 going on there.

16 Again, we've had lots of discussions with
17 your predecessors.

18 MEMBER ARMIJO: I understand. I'm just
19 trying to understand what's going on there. Does that
20 little dotted line mean something, that's a level you
21 can't get below?

22 MR. WINTERS: That's the top of the core.

23 MR. SCHULZ: That's the top of the core.

24 MEMBER ARMIJO: Got it.

25 MR. SCHULZ: And none of this changes for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 Rev. 16. The changes we made didn't impact this.

2 I'd like to talk now about passive
3 containment cooling. As Jim mentioned, we have a
4 steel shell containment pressure vessel. We use that
5 pressure vessel as basically a heat exchanger in an
6 accident, and in order to maximize the effectiveness
7 of that removal mechanism, we pour water on the
8 outside of the containment shell. We control the
9 distribution of that so that we get a relatively
10 uniform spread out of water. We have a tank that's
11 elevated and supported by the concrete structure.
12 That tank will run for 72 hours. We have a set of
13 standpipes that control the flow rate roughly to
14 minimize the total volume of the tank. The water is
15 initiated by actually three 100 percent valves, two of
16 them are fail-open air-operated valves, and one of
17 them is a motor-operated valve. The third path was
18 added for PRA reasons. It's not needed for design-
19 basis, but it is fully safety-related 1E power
20 supplies.

21 MEMBER CORRADINI: I'm sorry. Say that
22 again. I'm sorry. Could you repeat that?

23 MR. SCHULZ: The water draining from the
24 -- the initiation of the water draining onto the
25 containment is actuated by three normally closed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 valves. If any one of them opens, that provides
2 sufficient flow. Two of them are normally closed,
3 fail-open air-operated valves, just like what we do in
4 core makeup tanks, and the passive OHR. The third
5 path is diverse, it's different, intentionally,
6 because of PRA common mode failure considerations.
7 It's a motor-operated valve. Again, normally closed.
8 All three paths are safety-related 1E actuated by the
9 protection system.

10 MEMBER CORRADINI: And so the MOV is run
11 off of DC power.

12 MR. SCHULZ: That's right.

13 MEMBER CORRADINI: So I don't remember,
14 but just a bounding. If there's no water drainage, do
15 you have a problem relative to back pressure in
16 containment?

17 MR. SCHULZ: Well, from a LOCA performance
18 point of view, things work better at higher pressure,
19 so that's not an issue. The issue of concern is the
20 containment pressure versus the design pressure.
21 That, obviously, is a beyond design-basis
22 consideration, and we do look at that in the PRA.

23 MEMBER CORRADINI: Okay.

24 MR. SCHULZ: So we've got analysis on air-
25 only cooling, and we basically show that we can go at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 least 30 hours with no air-cooling from the very
2 beginning, without exceeding -

3 MR. WINTERS: No water.

4 MR. SCHULZ: Sorry, with no water, air-
5 only cooling, and not exceed the failure pressure, or
6 actually emergency stress limit in the containment.

7 MEMBER CORRADINI: Okay. Thank you.

8 MEMBER ABDEL-KHALIK: Now does all the
9 water that you spray on top flashes out?

10 MR. SCHULZ: It evaporates, it doesn't
11 boil. Okay? And this is -- again, we did a lot of
12 testing to show that. The initial water flow is
13 rather high, much higher than decay heat, and we do
14 that -- this is showing the operation here, while I
15 answer your question, try to answer your question.
16 That initial water flow is very high to do two things,
17 to spray a water film over the dome and sides rather
18 quickly to establish cooling quickly. It also
19 minimizes the chance of water evaporating before it
20 gets around the containment. It also exceeds decay
21 heat significantly, such that the containment pressure
22 will come down in about five hours to less than half
23 design. Okay? So it's pretty effective in knocking
24 the peak pressure down.

25 Depending on how severe the accident

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 really is, we might have some water that doesn't get
2 evaporated, and we have drains, redundant drains
3 located around the operating deck, and that will drain
4 off the water, if we do get some water down there.

5 MEMBER ABDEL-KHALIK: So it never really
6 impacts the air flow, the natural circulation air flow
7 around the containment.

8 MR. SCHULZ: Right. It would never impede
9 that air flow. That certainly is a consideration.

10 MEMBER ARMIJO: Well, you don't want to
11 get too much water coming in, more than what you want,
12 that what you can evaporate.

13 MR. SCHULZ: It's not a safety issue, it's
14 more of if we put more water than we need, we're kind
15 of wasting water, and we're not effectively using the
16 water that we've built this expensive tank on top for.
17 Okay? So that's why we use the standpipes to roughly
18 control the flow rate. All four standpipes are
19 covered, the flow rate is rather high. When we start
20 uncovering standpipes, obviously, water stops going in
21 that standpipe, and the flow slows down.

22 Again, this is a picture of the
23 containment. This is actually not the latest, latest
24 version of it, but it at least shows you the general
25 style. The air inlets are around the top of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 cylinder, all the way around, 180 degrees, 360
2 degrees, and that was based on wind tunnel testing,
3 that insight that it should be high, not low, and that
4 avoids wind effects causing or impeding air flow
5 through the cooling. In the center of the containment
6 above is an exhaust, cylindrical exhaust that goes up
7 through the water storage tank.

8 MEMBER CORRADINI: So how much did the
9 containment have to grow in free volume, and how much
10 did the axial height have to increase to go from 2,000
11 megawatts to 3411?

12 MR. SCHULZ: Well, we did a couple of
13 things that were important there. One of them was to
14 increase the volume, and I think it's about a 25
15 percent increase in volume. We had like a 73 percent
16 increase in power, so that -- now the volume of the
17 reactor coolant system didn't go up 73 percent. Okay?
18 So there's a mass energy kind of trade-off there. We
19 also increased the design pressure of the containment,
20 so it's a higher design pressure by changing material,
21 and making material slightly thicker.

22 MEMBER CORRADINI: So it's higher by?

23 MR. WINTERS: Twenty-five feet.

24 MEMBER CORRADINI: Twenty-five feet.

25 Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WINTERS: About.

2 MEMBER CORRADINI: Okay. And then how
3 -- I asked about the water. Where is the air inlet,
4 air intakes and discharges for the natural -

5 MR. SCHULZ: The air inlets are 360
6 degrees around that elevation.

7 MEMBER CORRADINI: Oh, 360 degrees. Okay.

8 MR. SCHULZ: The air comes in, goes down
9 outside of a baffle, and at the operating deck, or
10 about there, the annulus is sealed, all the
11 containment penetrations are down below, so the
12 electrical, mechanical penetrations are not open to
13 the atmosphere. The air turns and goes up in a narrow
14 gap next to the containment, and then exhausts out
15 through the center in the containment here.

16 MEMBER CORRADINI: The gap, the internal
17 gap is about a foot?

18 MR. SCHULZ: On this side, I think it's a
19 little less. Is it?

20 MR. WINTERS: It's about a foot.

21 MR. SCHULZ: The total -

22 MEMBER CORRADINI: It's 360 with grading?

23 MR. SCHULZ: On the inlets?

24 MEMBER CORRADINI: To stop birds, and -

25 MR. SCHULZ: These exteriors are also

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 grading. This is a concrete radiation sky shine
2 shield here, so there's no direct site from the
3 containment out into the atmosphere.

4 MEMBER CORRADINI: Okay. Thank you.

5 MR. CUMMINS: Now one of the changes we
6 did make was the air inlets were changed from big
7 holes to little holes, so that we could -

8 MR. WINTERS: Make them external hazards.

9 MR. CUMMINS: External hazards.

10 MEMBER ABDEL-KHALIK: So the weight of
11 this big over structure is still transmitted to the
12 cylindrical part of the concrete.

13 MR. WINTERS: The concrete structure holds
14 up the tank. Right. There's no structural connection
15 from the standing, freestanding steel pressure vessel
16 containment to the concrete, except at the very
17 bottom.

18 MEMBER ABDEL-KHALIK: Okay.

19 MR. CUMMINS: It's embedded in concrete at
20 the bottom.

21 MR. WINTERS: The concrete building is
22 completely structurally separate from the containment
23 vessel, except at the bottom.

24 MR. SCHULZ: This basically shows that the
25 passive system is very effective at reducing the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pressure. It also makes the point that steam line
2 break, which actually has the highest pressure is not
3 really impacted by passive containment cooling. It's
4 impacted primarily by the initial volume, and to some
5 extent some passive heat sinks. But by the time
6 passive containment cooling really comes into play,
7 the peak pressure is already passed.

8 This summarizes some key margins, typical
9 plant versus AP1000. Basically, the point here is
10 that passive systems are very effective, as we've
11 implemented them, and providing improved margins in
12 the design. Again, we could spend days going into all
13 the different events that make up that.

14 One point I did want to make is that one
15 of the COL items was the long-term cooling containment
16 debris issue. There were a lot of inherent
17 characteristics and design features of AP1000 that
18 provide a more robust and design is less likely to
19 have an issue here. However, we are still discussing
20 that with the staff.

21 One of the changes we did make in Rev. 16
22 is to significantly increase the screen area. Our
23 recirc screens had a total area of about 280 square
24 feet in Rev. 15 of the DCD. Now that may sound puny,
25 but we don't have safety pumps, we don't have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 containment spray pumps, so all the velocities in that
2 small screens were still very low. They're
3 drastically lower than that now, because we've gone up
4 to like 5,000 square feet, so we've really, we think,
5 as far as screen area, done even more than what
6 current plants are doing. Again, we have much lower
7 flow rates in this plant than a typical plant, because
8 we don't have the pumps that are designed for early-on
9 removal of decay heat, plus containment spray, so they
10 end up with much, much higher flow rates than we have.

11 Another feature that's very unique to
12 AP1000 is severe accident, and, in particular, the
13 capability of retaining a molten core, damaged core
14 inside the reactor vessel. This animation kind of
15 shows you the progress of that event. And, again,
16 it's a beyond design basis, somehow we failed to cool
17 the core, and you end up with the core overheating,
18 melting, and relocating into the lower head of the
19 reactor vessel. Initially, the water that leaves the
20 reactor coolant system pours down under the reactor
21 vessel. Then we eventually, either by accident
22 injection or by manual operator action, dump the
23 refueling water storage tank into the containment, and
24 the containment floods up to about the reactor vessel
25 flange.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 A key feature of this is the reactor
2 vessel insulation design, which is intentionally
3 designed to both provide effective insulation during
4 power operation, and to provide inlets at the bottom,
5 engineering inlets, and steam vent outlets about this
6 elevation to support a natural circulation cooling of
7 the outside of the reactor vessel.

8 In Rev. 16 of the DCD, we resolved a COL
9 item which required us to show that we had analyzed
10 the insulation to the loads that we get during this
11 event. We've done testing. The testing allowed us to
12 define the structural loads we would get on insulation
13 during this event, and we've developed the insulation
14 design to the point where we actually were able to do
15 that stress analysis. Along the way, we also made
16 some changes to the detailed inlet and outlet vents,
17 so there was kind of a combination of COL stress
18 analysis resolution, plus design finalization, detail
19 change to the insulation design.

20 MEMBER CORRADINI: So what's the gap
21 between insulation and the vessel, a few inches?

22 MR. SCHULZ: It's like six inches around
23 the cylinder. It varies around the head, generally
24 increasing as you go down toward the bottom of the
25 head. And, again, this was all as a result of testing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that we did to provide the desired flow rates, and
2 velocities, and heat removal from the lower head of
3 the vessel.

4 MEMBER SHACK: As I recall, if your in-
5 vessel retention doesn't work, you mentioned the
6 utilities requirement document. You don't meet the
7 spreading requirements of the utility requirements
8 document, do you?

9 MR. CUMMINS: I think we met it for AP600,
10 but we didn't increase it for AP1000.

11 MR. SCHULZ: Now I think that the general
12 consensus is that that spreading requirement is not
13 going to do a lot for you, because there are rather
14 different ways that the vessel head can fail, and
15 debris come out. And if it happens to spread out,
16 then that spreading requirement will do something for
17 you, but it won't necessarily do that. It might come
18 out in a pile in one side of the room, in which case
19 the spreading requirement doesn't help you a whole
20 lot.

21 In our PRA, if the reactor vessel in-
22 vessel retention doesn't work, we assume that we'll
23 get a containment failure, where we might not in all
24 cases, but we do assume that. We have shown that we
25 don't get a -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: That's an assumption in
2 your PRA, that if you take that branch point, you're
3 going to assume instantaneous or late containment
4 failure?

5 MR. SCHULZ: Late.

6 MEMBER CORRADINI: Okay.

7 MR. SCHULZ: Now we actually don't from a
8 probability point of view differentiate between late
9 and early, though. We just have large release
10 frequency, we don't have large early, or large late.

11 MEMBER CORRADINI: Okay.

12 MR. SCHULZ: So every containment failure
13 is really treated as an early fail, even though it
14 really isn't. We did show that when the vessel head
15 fails, that we won't get a steam explosion, for
16 example, that would fail the containment.

17 MEMBER MAYNARD: I didn't see any
18 containment spray, or any of that, so are there any
19 chemicals in there? Do you use any sort sodium
20 hydroxide, trisodium phosphates?

21 MR. SCHULZ: We do use trisodium
22 phosphate. We store it in baskets, so when the
23 containment floods up and we get, of course, a large
24 level change, so it's not so hard to find a location
25 that wouldn't normally get flooded with little spills,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 but would get flooded in an accident. And that's how
2 we get the TSP into the water solution, is through
3 flood-up and dissolving of the TSP.

4 MEMBER CORRADINI: So the reason you have
5 that is why?

6 MR. SCHULZ: To retain Iodine in the
7 water, and to avoid stress corrosion cracking on the
8 stainless steel.

9 MEMBER CORRADINI: To avoid stress
10 corrosion cracking, stainless steel, during what?

11 MR. SCHULZ: In a post-accident situation,
12 if you could get some chlorides into the water from
13 concrete.

14 MEMBER CORRADINI: Let me reverse the
15 question. If it weren't there, what would change in
16 the PRA for source term release?

17 MR. SCHULZ: Well, it wouldn't be just the
18 PRA, but the design-basis off-site dose analysis makes
19 certain assumptions about Iodine getting trapped in
20 the water, and if you don't have the correct pH, then
21 the Iodine won't stay in the water, or a certain
22 percentage might get into the atmosphere, and -

23 MEMBER CORRADINI: Based on analysis
24 assumptions.

25 MR. SCHULZ: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: Okay. Thank you.

2 MR. SCHULZ: Okay. We're now at 9:40.

3 MEMBER ARMIJO: Moving right along.

4 CHAIR BONACA: Why don't we take a break
5 now. We need to take a break, and get together again
6 at let's say 10:30.

7 (Whereupon, the proceedings went off the
8 record at 10:13 p.m., and went back on the record at
9 10:31 p.m.)

10 CHAIR BONACA: Okay, we are back into
11 session. Just to assure that we do not lose this
12 afternoon's presentations. They're important to us
13 and I know that some of the presenters have flights
14 out, so we cannot delay the meeting.

15 I would like to have Westinghouse complete
16 its presentation by 11:20, 11:25, I believe. You
17 should be able to because I understand that the
18 proposed revision to AP1000 certified design already
19 has been covered.

20 MS. STERDIS: Right, between what I
21 presented first thing as well as the discussion of
22 some of the changes that Terry and Jim have in their
23 presentation, that's covered.

24 CHAIR BONACA: So you should be able to do
25 it without shortchanging the presentation. But at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 least if you can set that as a goal as you go through.
2 So with that, I'll turn it over to Mr. Schulz again.

3 MR. SCHULZ: I'm now going to talk about
4 nonsafety features, active features. I've already
5 mentioned that these are typically integral operation.
6 They minimize challenges to the passive systems. I'm
7 not required to mitigate design basis events.
8 Typically, these feature are simplified versions of
9 safety features that you have in the current plants.

10 And I'll show you some examples of that.
11 Also, typically, the equipment is not designed to
12 ASME, not Seismic 1 design. It has not the full
13 separation of prior flood type protection. The
14 buildings they're located in, some of this equipment
15 is located in the turbine building. Some of it's
16 outside buildings that are not seismic, not safety.
17 And that's consistent with their design intent.

18 A couple of examples is start-up
19 feedwater.

20 CHAIR BONACA: What kind of reliabilities
21 do you expect of this system?

22 MR. SCHULZ: Well, we calculate it in the
23 PRA based on their failure vulnerabilities. We
24 include a little bit extra maintenance on
25 availability. We don't necessarily make the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 reliability per demand less. And then we basically
2 calculate it based on how many components we have,
3 common mode failures, actuation reliabilities and
4 things like that. So it does come out to be somewhat
5 less reliable than an active system, an active safety
6 system, but typically because there's less components,
7 less separation and for what I would call real
8 reasons, we don't artificially just reduce the
9 reliability.

10 CHAIR BONACA: Okay.

11 MR. SCHULZ: Here you see an example of
12 the sort of feedwater system as two motor-driven,
13 electric motor-driven pumps, typical PWR would have a
14 third pump at least, a turbine-driven pump so it would
15 have diversity and more redundancy. One of the
16 features of this system is that it is automatic flow
17 control. So as the system gets turned on, it doesn't
18 tend to excessively feed the steam generators. So
19 this is a very nice operational feature that is not
20 available typically in the current plants where you
21 don't have automatic throttling because it's a safety
22 feature.

23 Again, both pumps are powered each by a
24 diesel, so if you lose off-site power the system is
25 available. If the system works properly, then the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 passive RHR is not actuated, at least in loss of
2 feedwater, loss of off-site power events.

3 If you actually have a pipe break,
4 feedline break and spill half of the flow from the
5 system, then it would not be sufficient to provide
6 core cooling and passive RHR would be actuated.
7 That's an example.

8 Another example is the shutdown cooling
9 system which we call the normal RHR system. It's a
10 two-pump system which again is very much like most
11 operating plants. One difference is is that it's got
12 a common suction and discharge line going through the
13 containment. And again, because we don't really need
14 physical separation, file separation, that's an
15 acceptable design.

16 We have a lot of enhancements in this to
17 improve shutdown cooling though. It's a higher design
18 pressure system, 900 psi, so it won't rupture. It's
19 exposed to full reactor cooling system operating
20 pressure. We have additional isolation valves,
21 typically at least three. Most of the operating
22 plants have two. So in terms of inner system LOCA
23 PRA, this system improves the situation relative to
24 the operating plants.

25 MEMBER CORRADINI: You said a couple of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 things I want to make sure I understand. So this is
2 for all intent and purpose, this is what one would see
3 within the aux building in a current PWR.

4 MR. SCHULZ: Yes.

5 MEMBER CORRADINI: Okay.

6 MR. SCHULZ: The location of the pumps and
7 heat exchangers are, in this case, even though it's
8 not a safety system, the piping system, I'll point out
9 in this case is fully ASME seismic. We did that
10 because to avoid issues with if you're running this
11 system, during a shutdown condition and you did have
12 a seismic event, you wouldn't break the piping and
13 then potentially have a challenge to losing too with
14 outside containment. But it's not one emoter. The
15 power supply is not one. But in terms of location,
16 yes. Same general location.

17 MEMBER MAYNARD: But the piping heat
18 exchangers are all designed for system pressure?

19 MR. SCHULZ: They're designed for 900 psi.

20 MEMBER MAYNARD: Oh, okay.

21 MR. SCHULZ: Which is higher than a
22 typical Westinghouse plant and that's sufficient so
23 that if you expose it to 2200 psi or something, it
24 will rupture. It will probably bend the store.
25 You'll get things like that happening, but you won't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 get gross failure of the pressure boundary.

2 MEMBER SIEBER: I think it's important,
3 the ASME code --

4 MR. SCHULZ: Pardon me?

5 MEMBER SIEBER: Does it meet the normal
6 service typing requirement of the ASME code?

7 MR. SCHULZ: Correct.

8 MEMBER SIEBER: At 900 it does, but at
9 full reactor pressure, it doesn't.

10 MR. SCHULZ: That's right.

11 MEMBER SIEBER: So you're riding on the
12 margin there.

13 MR. SCHULZ: Yes. But again, it's a PRA
14 kind of consideration. We think that's appropriate.

15 MEMBER SIEBER: The factor of safety is
16 three. That gets you up 2000 pounds.

17 MR. SCHULZ: The spent fuel cooling system
18 is similar to the shutdown cooling system. Two pumps
19 have two heat exchangers. Normally used to cool the
20 spent fuel pit and spent fuel. But it's not the
21 safety feature. The safety feature is blow it off of
22 the water that's additionally in the pool and in
23 adjacent pools that can be open to the spent fuel pit.

24 We also have makeup from the passive
25 containment cooling water supply. So a limiting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 condition for spent fuel cooling is if you offload the
2 whole core and you have all of that decay heat in the
3 spent fuel pit, then we can actually devote all the
4 water in the constant containment cooling water
5 storage tank to the pit and we do have tech specs on
6 when you can use and should use that water for either
7 service.

8 MEMBER SIEBER: That's an operator manual
9 action?

10 MR. SCHULZ: The long-term makeup, yes.
11 You don't need that.

12 MEMBER SIEBER: It's a switchover.

13 MR. SCHULZ: You don't need that for quite
14 a long time. And in fact, there's a table in the DCD
15 that is shown here and I won't go into all the
16 scenarios that we look at. All these scenarios are
17 based on assuming a seismic event initially which
18 breaks off the spent fuel pit suction line which
19 drains a few feet of water off of the spent fuel pit,
20 so that we lose some water as a result of that. If we
21 didn't have the seismic event, we'd start from a
22 normal water level.

23 And then this talks about time to
24 saturation, what the water level is at 72 hours and 7
25 days.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Is that containment
2 cooling water borated?

3 MR. SCHULZ: No.

4 MEMBER ARMIJO: So if it goes into the
5 storage pit, it's increasing reactivity.

6 MR. SCHULZ: It's not a problem because
7 what you're making up for is boil off.

8 MR. WINTERS: The boron is already there.

9 MR. CUMMINS: The boil, the boron mostly
10 stays in the water.

11 MEMBER ABDEL-KHALIK: Unless you're adding
12 the water at a faster rate than you're boiling off.

13 MR. SCHULZ: That's right. And in one of
14 their requirements here is for the operators to
15 control that so that it doesn't grossly overflow.

16 Now in Rev. 16 of the DCD, we increased
17 the number of fuel assemblies that we can store in the
18 pit. Again, as Jim mentioned, this was a utility
19 desire and the utilities all agreed that they wanted
20 more storage so we worked out a change and implemented
21 that in Rev. 16. Now that didn't affect decay heat
22 level very much because that's basically old fuel. A
23 little bit, but not very much.

24 Another thing that we did which is a
25 security-type situation is look at a scenario where

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 somehow you drain the spent fuel pit. And then how do
2 you cool the fuel? And what we provided is a spray
3 capability and this is not really discussed in the
4 DCD, but some of the interconnections are shown. We
5 basically have two separate spray headers, one along
6 each -- of two walls of the spent fuel pit. They're
7 independently supplied from -- one from the passive
8 containment cooling, the red lines. And the green
9 lines on the upper side of the pit are water supply
10 comes from the fire protection system pumps.

11 So there's two independent ways of
12 spraying water in the spent fuel pit. In case there's
13 no water in there at all, you can keep the fuel so
14 that it doesn't ignite.

15 The next two slides talk about levels of
16 defense and we've talked briefly about how the active
17 features provide first level in most scenarios. The
18 passive features provide a second level. They're the
19 safety level. But in this plant we've got more levels
20 than that typically, and these extra levels are
21 typically used in beyond design basis PRA kind of
22 scenarios. One example is passive feed and bleed
23 kind of pooling, backs up the passive RHR. So in a
24 PRA scenario, you assume that or calculate that the
25 start up feedwater fails, the passive RHR fails, now

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 what happens? Well, what happens is you can feed and
2 bleed using ADS valves, using core makeup tanks, and
3 there's several mixtures of features you can use for
4 the feed and bleed cooling.

5 And one way of looking at that is in a
6 picture, is for say a loss of off-site power, look at
7 the first level of defense is the startup feedwater,
8 it's automatic. You're on safety. The second level
9 of defense is, in fact, our safety case that's shown
10 in the DCD, passive RHR. And the passive containment
11 cooling has to work with it to ultimately get the heat
12 out of the containment.

13 Then there's several modes of feed and
14 bleed cooling. One of them using ADS stages one, two,
15 and three, and the normal RHR as an injection pump.
16 Another one is strictly passive, using core makeup
17 tanks and ADS stage four and the final one is sort of
18 a backup to what happens if core makeup tanks work and
19 we've shown that accumulators without core makeup
20 tanks are sufficient to support a feed and bleed
21 cooling type scenario.

22 One of the insights from this is or the
23 significance is that if you look at our core melt
24 frequencies they're very low and this is really what's
25 driving that. A lot of redundancy and diversity in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the mechanical systems. In terms of nonsafety
2 features, with something that was systematically
3 looked at, the process in policy was set up in AP600
4 days and the same approach applied to AP1000. It
5 involved use of PRA and deterministic thinking.
6 Ultimately, the main outcome of this was to develop
7 some availability investment protection type controls
8 which are defined in the DCD in Chapter 16-3. They
9 are not tech specs, so that they kind of look a bit
10 like tech specs. They don't require the plant to shut
11 down, but they do require the plant to try to keep
12 these investment protection active defense-in-depth
13 systems operable.

14 A brief summary of core melt frequencies,
15 the main thrust of this, again, it was in support of
16 how important are nonsafety features. And this second
17 column, you see the base AP1000, both core melt and
18 large release frequency with all the systems and then
19 without nonsafety features, and of course, the numbers
20 get somewhat larger. And then you see that compared
21 against the NRC safety goal and basically you can see
22 that without the nonsafety mitigation capabilities, we
23 still meet the NRC safety goals.

24 MEMBER STETKAR: Have you looked at how
25 that might change if you considered a full risk

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 assessment with fires, seismic, a seismic risk
2 assessment, not a seismic margins. A fire analysis,
3 flooding, all of the other --

4 MR. SCHULZ: We have flooding. We have
5 shutdown. We have a conservative fire model in here.
6 So we think we've bound --

7 MEMBER STETKAR: What does internal events
8 mean then? As opposed to --

9 MR. SCHULZ: This actually isn't the whole
10 story.

11 MEMBER STETKAR: It's okay.

12 MR. SCHULZ: We haven't quantified
13 seismic, so I don't know the answer to that.

14 MEMBER STETKAR: That's fine.

15 MS. STERDIS: Okay, next slide.

16 CHAIR BONACA: What is quantified seismic?
17 Are you going to do that?

18 MR. CUMMINS: No, it's one of the
19 allowable seismic margins and the basic is a subset,
20 .5 g for failures or for cliffs.

21 MS. STERDIS: I am going to talk briefly
22 about the I & C and the human factors. Both of those
23 areas, as I indicated earlier are areas where we had
24 design ITAAC based on technology, evolving technology.
25 But we did certify aspects of the I&C and the HFE

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 programs and processes and design in the design
2 certification that was completed in 2005.
3 Specifically, it includes things like the functional
4 requirements for the I&C, what the reactor trip
5 functions are, what the safety feature functions are,
6 the emergency safety feature actuation, post-accident
7 monitoring, our minimum inventory dedicated inventory
8 of controls and alarms and displays was part of the
9 certification.

10 We also certified the design process, what
11 kind of process were we going to use for both the
12 development of the I&C when we selected a platform
13 technology for PMS, when we selected a platform
14 technology for the DAS system.

15 Same thing in the human factors area. We
16 selected, we certified a process and we're in the
17 implementation of those processes now. Basically,
18 we're going through and we're systematically
19 developing the designs consistent with the process
20 that was certified and basically closing out each of
21 those design ITAACs, that's the goal.

22 I'm going to talk a little bit about what
23 the I&C systems look like.

24 Next slide, please.

25 Ultimately, there are three major levels

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of I&C in this plant. There's the control system
2 which is the plant-wide, non-1E system for all normal
3 displays and controls. It's an integrated system. It
4 is microprocessor and software based. It is Ovation-
5 driven. And we have extensive experience, both
6 domestically and internationally using the Ovation
7 platform.

8 The safety system, what we call the PMS,
9 is a plant-wide 1E system that covers all safety-
10 related displays and controls and the automatic
11 actuation functions. We've selected our Common Q
12 platform to implement that system on and we're going
13 forward with that system. That system has been
14 implemented in the U.S., Palo Verde's core protection
15 calculators, Vogtle's diesel sequencer are implemented
16 in that platform.

17 In addition, my previous life was
18 engineering manager on the ringals upgrade and that
19 upgrade will be installed in 2009 in the Ringals plant
20 and it includes the entire safety system on the Common
21 Q platform.

22 The diverse system, we're in the process
23 of choosing the diverse system platform. We're going
24 to come in with the tech report on what the platform
25 is. Again, that contributes to the closure of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DAC, the design ITAAC. This is a very limited scope,
2 non-1E system. It's there to provide the mechanism to
3 address software common mode failures in the
4 protection system. It meets -- our selection of the
5 platform is just the next step. We've already
6 certified the diversity of defense-in-depth. We have
7 an FSER that concludes that our design of the diverse
8 actuation system, as well as our design of the PMS was
9 sufficient at design certification to say that we meet
10 BTP-19.

11 CHAIR BONACA: Safety systems, is it
12 simply an actuation system or is also a control?

13 MS. STERDIS: It is not a control system.
14 It is a safety system. There are manual controls and
15 there are indications as well, and displays.

16 CHAIR BONACA: So again, it is an
17 actuation system.

18 MS. STERDIS: An actuation system.

19 MEMBER SIEBER: Is your protection system
20 separate from your control system?

21 MS. STERDIS: Yes.

22 MEMBER SIEBER: Separate platform,
23 separate wiring?

24 MS. STERDIS: Yes.

25 MEMBER SIEBER: Separate transducers?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. STERDIS: Yes. I'm sorry, shared
2 sensors between the control system. I'm sorry, you're
3 right. Shared sensors between the control systems and
4 the protection systems. We do have separate -- yes.

5 MR. SCHULZ: DAS is completely separate.

6 CHAIR BONACA: And the platforms are
7 different?

8 MS. STERDIS: Yes. Three different
9 platforms.

10 MEMBER CORRADINI: Just one more time, you
11 guys know this stuff better than I do. Between the
12 control system and the safety -- same sensors, after
13 that, a different path.

14 MS. STERDIS: Yes.

15 MEMBER CORRADINI: Okay, and then you said
16 with the diverse system, a different set of sensors as
17 well? Did I hear that right/

18 MS. STERDIS: Yes.

19 MEMBER SIEBER: Very limited in scope.

20 MS. STERDIS: Very limited in scope.

21 MEMBER SIEBER: So that's how you get 3-D.

22 MS. STERDIS: This slide I'm going to skip
23 in the interest of time, but it does give you an idea
24 of systems that we have. The architecture drawing is
25 the drawing that would show you this is a different

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 system in the interfaces to the plant, the sensors and
2 the components.

3 Next slide, please.

4 We do have a compact control room design
5 on this plant. It is designed for one reactor
6 operator and one supervisor. There will be a series
7 of displays, both non-1E and class 1-E. The plant
8 status and overview wall panel is a non-1E system.
9 It's driven from the Ovation system. The detailed
10 display via the work station video displays which are
11 located on the operators' work stations, those are
12 also non-1E, also driven from Ovation.

13 The small number, we have a very small
14 number of dedicated displays. I alluded to those.
15 They're referred to often in the advanced plant world
16 as the minimum inventory. Those displays are -- they
17 are Class 1E displays and controls on those. There
18 are also the diverse non-1E. We do continue to meet
19 IEEE 603 separation and independence requirements
20 throughout our I&C design.

21 Our communications philosophy and our
22 implementation of the communications philosophy, as
23 well as our architecture drawings, all support and
24 justify those basic premises of independence between
25 the different safety divisions, as well as separation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 between nonsafety and safety.

2 We have recently, within the last --
3 actually, it's not that recently. Last December and
4 January, we submitted two technical reports to address
5 how our design implementation continues to meet those
6 fundamental IEEE 603 requirements.

7 MEMBER SIEBER: When you apply design
8 principles to the control room design human factors,
9 can an operator tell whether he's in a control system,
10 a safety system, or diverse system just by the
11 instrumentation and the layouts, switch colors,
12 whatever?

13 MS. STERDIS: Part of that, the answer is
14 yes, to where we are in the design of the main control
15 room and it will continue to be yes, but that's worked
16 out as you go through. Remember, the human factors
17 program is a feedback loop. We've done some
18 preliminary. We've done two sets of engineering
19 tests. Our NuStart folks have donated operators that
20 have been involved in that sort of cycling through and
21 that will continue as we progress through, but that is
22 a basic premise.

23 MEMBER SIEBER: And control rooms for all
24 plants will be standardized?

25 MS. STERDIS: Absolutely, all the way down

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to the operating procedures, alarm response
2 guidelines, all of the things that you're used to
3 being implemented individually, based on a high level
4 of principles are no longer independent. They are
5 standard. EOPs have been written for this plant.

6 MEMBER SIEBER: And the existing plant,
7 that's where the owner always wanted to add his
8 personal imprint.

9 MS. STERDIS: We're doing that up front.

10 MEMBER SIEBER: It's going to be a
11 difficult challenge.

12 MS. STERDIS: We're getting that imprint
13 up front by the integration of the engineering team
14 and the builders' group that was referred to a little
15 earlier. That's happening now.

16 MEMBER SIEBER: Thank you.

17 MR. CUMMINS: To be fully clear, however,
18 some of the site-related systems like groundwater,
19 they'll be different. So the screens will look
20 different.

21 MEMBER SIEBER: Because the plant is
22 different too.

23 MR. CUMMINS: Right, but that's way --
24 that's three screens out of 40,000 or something.

25 MEMBER SIEBER: It's probably at the end

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of the control board anyway.

2 MR. CUMMINS: This is all on a computer
3 screen.

4 MEMBER STETKAR: Do you have an emergency
5 control room on this? Auxiliary or whatever you want
6 to call it?

7 MS. STERDIS: We have a remote shutdown
8 work station, yes.

9 MEMBER STETKAR: Are the -- does that
10 handle only safety functions or also nonsafety?

11 MS. STERDIS: The work station that would
12 be available there would have everything on it.

13 MR. WINTERS: It's redundant --

14 MEMBER SIEBER: It's harder to restress a
15 plant.

16 MR. CUMMINS: It can do everything.

17 MEMBER STETKAR: Do the -- this is a lot
18 of detail, so a single scope from the main control
19 room to the remote shutdown to the actuated or are
20 they in parallel?

21 MR. WINTERS: The logic cabinets, the main
22 control room talks to logic cabinets. Remote shutdown
23 talks to logic cabinets. Logic cabinets talk to the
24 plant.

25 MS. STERDIS: Similarly, for the controls,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there's a similar configuration. There are non-1E
2 controls for normal operation and then there are
3 safety-related controls and non-safety diverse
4 actuation controls.

5 Again, the number of safety-related
6 components to be actuated is small, so this number is
7 very small. We are using our advanced alarm
8 management techniques that have evolved and we have
9 used those on other projects around the world and
10 lastly, there is a computerized procedure system here
11 that's being implemented. It's been described as part
12 of the original design certification.

13 Next slide, please.

14 This is just a little schematic that I put
15 in that shows -- I will point out to you that this is
16 an old drawing. Our friends at the utilities have
17 come in and we've redesigned the layout to incorporate
18 some integrated operating experience from the training
19 programs that they've had, the events they've had, and
20 we're currently in the process of regenerating this
21 cartoon-like figure, but our actual drawings for the
22 layout of the revised control room are already
23 available.

24 The reason why this is not really a change
25 to the DCD is that was not really part of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 certified design. It's part of the evolution of the
2 human factors engineering program and the control room
3 design and it will be part of the closure or the
4 resolution of the design ITAAC.

5 MEMBER MAYNARD: On the previous slide,
6 you said it's designed for one operator, one
7 supervisor. Is that the expected normal complement or
8 is that going to be the license requirement or I'm a
9 little confused on --

10 MS. STERDIS: Definitely a license
11 requirement.

12 MR. CUMMINS: There are in regulations
13 some minimum operator which we did not challenge. And
14 our customers don't seem to want to challenge. So
15 when we say that we have one operator who can operate
16 the plant, but we're going to have as many operators
17 as the current regulations require. So it's more than
18 one.

19 MS. STERDIS: This is a COL information
20 item too, and it is being addressed in the COL
21 application. It's in chapter 18.

22 MEMBER SIEBER: Do you have -- maybe you
23 can tell me about how many local control stations
24 outside the control room you have.

25 MR. WINTERS: Some of the package units

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 like compressed air or the diesel generator have some
2 local stuff.

3 MEMBER SIEBER: But nothing that actually
4 controls the plant proper. It's all offshoot system.

5 MS. STERDIS: Integrated system. Okay,
6 that's it.

7 MR. WINTERS: The next four topics, three
8 of them are ones that were in John -- Dave's request
9 to us for topics. And the fourth we put in so that we
10 can make sure we talk to you about the differences
11 between Rev. 15 and Rev. 16.

12 On the first one here which is structures,
13 we're talking about the building itself and recognize
14 that the only seismic building is this auxiliary
15 building containment type building.

16 MEMBER SIEBER: Containment of seismic.

17 MR. WINTERS: Right, it's within the
18 shield building.

19 MEMBER ABDEL-KHALIK: Just roughly, what
20 is the footprint of that footprint area?

21 MR. WINTERS: About 250 by 175.

22 MR. SCHULZ: But it is not really fully
23 rectangular.

24 MR. WINTERS: It's not rectangular. It's
25 got the hump on it. But it's about that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And this is to reinforce that. But the
2 current design certification --

3 MEMBER CORRADINI: So it is just one acre.

4 MR. WINTERS: Okay.

5 MEMBER CORRADINI: Forty-three thousand
6 square feet.

7 MR. WINTERS: It's small.

8 MEMBER CORRADINI: It's small.

9 MR. WINTERS: Yes. The Rev. 15, current
10 design is consistent with rock site only. What we've
11 done is -- Rev. 16 is now consistent with the
12 integrated seismic input as I've described earlier
13 which includes soil sites in the Eastern United
14 States.

15 As a result, what we wanted to do is
16 change the input without changing the structure itself
17 because we had a lot of design work into the building
18 structure. Changes we've made or we found out that
19 the pressurizer, although was okay for seismic, there
20 are valves and the ADS valves sit on top of it and the
21 tall, skinny pressurizers swung those around that they
22 had high g forces that even though we thought we could
23 pass, the valve vendors didn't want to test them for
24 those. So Rev. 16 has a shorter, squatter pressurizer
25 over the same volume with the same relative limits on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 instrumentation and trip points and everything else.
2 Actually, it ends up better for our control purposes,
3 but it's different from Rev. 15 to Rev. 16, so that we
4 could get qualified valves.

5 MEMBER ABDEL-KHALIK: And those valves are
6 also qualified for liquid discharge, is that correct?

7 MR. SCHULZ: The valves that Jim is
8 talking about are motor-operated valves, not the
9 safeties. They're the EDS valves, not the safeties.
10 They're the EDS valves, not the power-uprated relief
11 valves. They are designed to open and operate under
12 steam, two-phase type conditions that we see during
13 EDS operations.

14 I don't think we predict to actually have
15 during an ADS which is a LOCA-type scenario, not an
16 over-pressure scenario. We don't predict to get water
17 to those valves.

18 MR. CUMMINS: There are also relief
19 valves.

20 MR. WINTERS: We have two relief valves.

21 MR. CUMMINS: And they are not for water,
22 right? I'm not quite sure of that.

23 MEMBER ABDEL-KHALIK: Are any of the
24 valves on top of the pressurizer qualified for liquid
25 release?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCHULZ: The ones that -- I don't know
2 the answer, the spring-loaded safety valves. What we
3 find for ATWS mitigation, which would be beyond the
4 design basis type event.

5 I don't know the --

6 MR. CUMMINS: I believe we said in our
7 accident analysis we never have water.

8 MR. SCHULZ: In design basis accidents,
9 that's true. We don't over pressurize in any design
10 basis accident. So we don't get water to those
11 valves. In the scenario where they'd have to be
12 qualified for --

13 MEMBER ABDEL-KHALIK: So you never get
14 into a scenario where you have bleed and feed at high
15 pressure?

16 MR. SCHULZ: We do, but we don't use the
17 safety valves for that. We use the EDS valves. We
18 don't stay at pressure. We depressurize.

19 In the process of depressurizing, we go
20 through steam, two-phase mixtures, not water.

21 MEMBER ABDEL-KHALIK: Okay, thank you.

22 MEMBER SIEBER: At the risk of messing up
23 your presentation, I'd like to go back to slide 23 and
24 tell me on slide 23 which are the seismic pieces and
25 what are not.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WINTERS: Just the yellow one.

2 MEMBER SIEBER: Yellow and pink somebody
3 said.

4 MR. WINTERS: Just yellow. No pink.
5 Okay, the pressurizer change wasn't driven by this
6 adding of soil sites. It was, as we discovered, as we
7 went down the path that the detailed analysis
8 accelerated those valves too much.

9 The seismic analysis done to expand our
10 site base did not create any real design changes, just
11 input changes in and out. However, we did change the
12 shield building to reflect new external hazards
13 concerns and we have a couple of pictures here.

14 This is the new shield building
15 enhancement. This is high in the shield building
16 where the air vents are. And the top is up here and
17 the cylindrical part is down below. This is high.

18 And what we have are a number of angled
19 events. They're usually three or four in a row, all
20 360 degrees around. We have a steel liner inside and
21 outside and concrete and rebar holding the concrete
22 together.

23 MEMBER CORRADINI: Enhancements are a
24 thicker concrete wall or the steel shell on either
25 side?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WINTERS: Both. In this area.
2 Sticker in this area. It's got the liner. The old
3 vents were large. There were only 16 of them.

4 MEMBER CORRADINI: You had mentioned that.

5 MR. WINTERS: And they were straight
6 through with a grate. These are not angled so that --

7 MEMBER CORRADINI: Sixteen inch squares.

8 MR. WINTERS: Right. Thank you. And
9 these now are angled so that if any fluid like rain or
10 external events or whatever, hits those, they tend to
11 drain out instead of in where when we had the straight
12 through you didn't know where it was going to go.

13 And there are smaller individual areas.
14 The total area is not much smaller than it was before,
15 but the individual areas are small.

16 That was the enhancement.

17 MEMBER CORRADINI: Thank you.

18 MR. WINTERS: We also enhanced the shield
19 building roof. We changed the support beams. We made
20 them thicker and changed where the concrete is and
21 where the steel is to make it more impact-resistant.
22 And we changed the shield building cylindrical
23 surface. We didn't make it thicker, but instead of
24 reinforced concrete, now it's a plate, concrete plant
25 arrangement like our module designs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So the Rev. 16 shield building looks
2 different than the Rev. 15 and in the process of all
3 of that, the top got lowered 5 feet, as well. So it
4 does look different.

5 MEMBER SIEBER: Do you have a set of
6 seismic characterizations like accelerations and
7 frequencies that now become something against which
8 you can evaluate the site?

9 MR. WINTERS: Yes. We had one before, but
10 the soft salicytes wouldn't fit under the curve. So
11 now we have one that they do.

12 CHAIR BONACA: Is the thicker rebar all
13 the way down to the basement?

14 MR. WINTERS: No.

15 MR. WINTERS: If we look here, no rebar.
16 From this elevation down to the operating deck there
17 are no -- there's no rebar. It's just the plate with
18 reinforcement on the inside, stiffeners, studs,
19 concrete and then plate with stiffeners and studs on
20 the inside.

21 CHAIR BONACA: So the stiffeners go all
22 the way down to the basement?

23 MR. WINTERS: Right.

24 MR. CUMMINS: Once you get underground,
25 the plates disappear and there's an overlap of rebar.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We transition by having the rebar come up between the
2 plates so that you have a concrete transition.

3 MR. WINTERS: Also, the concrete gets much
4 thicker and becomes bulk concrete to cradle the
5 containment bottom and to hold all the --

6 CHAIR BONACA: There would be significant
7 reinforcement.

8 MEMBER MAYNARD: I don't see any tendons
9 here. You don't have any --

10 MR. WINTERS: No.

11 MEMBER ABDEL-KHALIK: The overall height
12 is five feet shorter. Did that affect the inventory
13 in that storage tank on top?

14 MR. WINTERS: No.

15 MEMBER ABDEL-KHALIK: Where did you gain
16 five feet?

17 MR. WINTERS: Lowered the roof towards the
18 containment. The whole tank came down.

19 Containment stayed the same size, so
20 there's less free space between the bottom of the tank
21 and the containment.

22 Secondary systems, there is a change.
23 First, remember that all of our secondary systems are
24 nonsafety-related. I don't know if you intended to
25 include auxiliary systems like mechanical and volume

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 control or component cooling water. Most of those are
2 also nonsafety. So there's not a large impact, even
3 what we did find.

4 However, we did change the turbine. It's
5 reference -- now it's not referenced by name, but the
6 values, the parameters that go in Chapter 10 of the
7 DCD that are associated with the turbine have now
8 changed from the Rev. 15 MHI turbine to the Rev. 16
9 Toshiba turbine.

10 Actually, the Toshiba turbine has more in-
11 service because it has some than the MHI turbine. So
12 anyhow, that's the one we reference. In order to
13 reference it, of course, we had to ensure that its
14 post-trip behavior, its overspeed trip and initiation
15 and late attachments met all the rules that had
16 previously been met for the Rev. 15 design
17 certification. And they do.

18 MEMBER ABDEL-KHALIK: What kind of bypass
19 capability do you have at this plant?

20 MR. CUMMINS: Forty percent.

21 MEMBER ABDEL-KHALIK: Forty percent.

22 MR. CUMMINS: It is combined with a
23 reactor trip, partial reactor trip function so that
24 you can get 100 percent both ejections. So you
25 combine the -- you need bypass when you have a large

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 decrease in power, so if you have 100 percent, a 10
2 percent decrease in power, the bypass will work and
3 there will be a partial trip. And the plant will
4 remain on line.

5 MEMBER ABDEL-KHALIK: What's a partial
6 trip? It's a run back?

7 MR. CUMMINS: Yes.

8 MR. WINTERS: Faster amp back. For
9 electrical systems, first of all, we only have three.
10 We do not have 1E AC. So we only have 1E DC non, and
11 non-1E AC. DC was not changed.

12 AC we fixed to incorporate requests from
13 the power utilities, and that's to add a reserve
14 auxiliary transformer as Andrea indicated.

15 What these additions do is minimize the
16 number of reactor trips you get from a secondary side
17 fault or something because it trips over to the other
18 side and the electrical system keeps working and
19 doesn't propagate back into the primary site. And so
20 from trip reporting and availability point of view is
21 very important to our customers to do that.

22 On fire protection -- 1E DC, the certified
23 unchanged certification, we have four independent 1E
24 DC, one for each safety train. Batteries, logic,
25 distribution, connections to valves, and a spare

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 battery for the 72 hours or 24 hours.

2 Yes, go ahead.

3 MEMBER STETKAR: Finish your sentence.

4 MR. WINTERS: And we've built those into
5 the plant, as you'll see in the fire protection later,
6 in such a way that they're separated from their birth
7 by concrete walls.

8 And it basically -- you can lose one whole
9 channel in the plant that's still safe. In fact, it's
10 still operational.

11 MEMBER STETKAR: Now let me ask a
12 question. I'll try to ask this in a way -- focus on
13 one battery, that's all I have. How long will that
14 battery last at its design load, how many hours?

15 MR. WINTERS: The 24-hour batteries will
16 last at least 24 hours. We have two channels that
17 also have 72-hour batteries on them. Last at least 72
18 hours.

19 MEMBER STETKAR: Each battery.

20 MR. WINTERS: Each battery.

21 MEMBER STETKAR: So you have two 24s and
22 two --

23 MR. WINTERS: Four 24s.

24 MEMBER STETKAR: Four 24s and two 72s.

25 MR. WINTERS: Right. That may be is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sound bite that sometimes we throw out here is that
2 these actuations of safety-related, passive safety
3 valve. but most you actuate during the worst accident
4 is 20 of those, about 20. A lot of them actuate based
5 upon the lost air, the spring does it, but some of
6 them have DC.

7 In most cases, they actuate within the
8 first 20, 25 minutes of the initiation. And once
9 moved to its safety position it's not moved again.
10 There's no control here. It's just resetting the
11 valve. After they're reset, there is no control. So
12 the fact that we have instrument power is so that the
13 operators can watch what's happening. If it gets AC
14 back, he can go do something, but there's no control
15 required after that first half hour.

16 And then there's no control at all. It's
17 really just resetting the valves.

18 MEMBER STETKAR: So this -- yes, what's
19 the non-1E battery life? The nonsafety, whatever.

20 MR. CUMMINS: Four sets. One is sort of
21 a motor set for lube oil. That is three or four, I'll
22 it instrumentation and control, the nonsafety
23 instrumentation and control. And they also power some
24 things. So there are basically three batteries. They
25 also have the ability to tie to the spare battery.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: What's their design life?

2 MR. CUMMINS: Their design life is at full
3 load, two hours.

4 MEMBER STETKAR: Thanks.

5 MEMBER SIEBER: Things like emergency
6 lights and security and all that, that stuff is on
7 their own batteries?

8 MR. WINTERS: They're on their own
9 batteries.

10 So the last one is fire protection and I
11 guess people had questions. There have been no
12 changes from the certified design to the new certified
13 design. We incorporated division separation was
14 designed in. We don't count on wrapping or that kind
15 of thing. They're separated by fire walls outside
16 containment. There were separate fire zones. And
17 their separation inside containment, two channels run
18 in one direction under the operating deck and the
19 other two channels run in a totally different
20 direction way far away and they come back together at
21 the unit, at the components, of course, inside
22 containments that there's been separation designed in
23 throughout.

24 And we've also done a couple little
25 changes of where equipment is placed and in particular

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the diverse actuation system actuate an equipment so
2 that we can have adequate protection from externally
3 induced fires that's the B, Bravo five Bravo, large
4 fire and explosion thing. So that we can get into
5 passive safety from opposite ends of the aux building
6 independently. And we believe we satisfy the B5B
7 approach.

8 MEMBER STETKAR: You mentioned earlier you
9 had a fully passive fire protection capability.

10 MR. WINTERS: For the seismic.

11 MEMBER STETKAR: For the yellow buildings.

12 MR. WINTERS: Right. What that is is --

13 MEMBER STETKAR: It's a tank.

14 MR. WINTERS: No, it's dedicated 18,000
15 gallons of that passive containment cooling tank.
16 It's got it's on standpipe. That gives us enough
17 height to have flow head to satisfy the requirement of
18 two hose streams at 75 gpm for three hours anywhere in
19 the aux building.

20 MR. CUMMINS: So the top few inches of the
21 tank are dedicated --

22 MR. WINTERS: To fire protection. That
23 fire protection.

24 CHAIR BONACA: Okay, so questions.

25 MR. CUMMINS: Questions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR BONACA: We are going to have a
2 brief presentation of part 52, right. And we'd like
3 to hear that.

4 (Pause.)

5 CHAIR BONACA: Thank you for your
6 presentation, by the way. I wish we had had more
7 time.

8 MS. STERDIS: We'll be back.

9 MR. WILSON: Mr. Chairman, my name is
10 Jerry Wilson. I am a member of the Working Group that
11 recently updated the licensing processes in part 52.
12 I also worked on the original part 52. I'm prepared
13 this morning to talk about how the Commission has
14 revised the amendment process for existing design
15 certifications in order to facilitate the types of
16 amendment that Westinghouse has requested. But in the
17 interest of time, I'm prepared and pleased to just
18 answer questions, any questions the Committee may have
19 on the amendment process. So whichever you'd prefer.

20 CHAIR BONACA: I mean, you do have one
21 slide.

22 (Laughter.)

23 MR. WILSON: All right, let me just start
24 that in the original design certification, the
25 Commission's focus was on finality and the benefits of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 standardization. And so they created a special
2 backfit requirement for certified designs. It looks
3 like I just got a time out.

4 (Pause.)

5 I think everyone has a handout. And so
6 looking at this slide, the original 5263, the finality
7 provision consisted of items one and two, the
8 compliance exception to the backfit rule and the
9 protection or what we refer to as the special
10 standards.

11 Well, after that and during the course of
12 reviews, we had a number of interactions with industry
13 sources and they requested that finality standard be
14 modified so that it would, so that industry could make
15 certain changes to the designs after the certification
16 that was issued. And that's what the Commission did
17 in this most recent rulemaking.

18 And you'll see in this list that we issued
19 five additional standards or provisions on there. I
20 have little shorthand summaries of each of them. The
21 first one, the Commission put in to facilitate the
22 ability to make changes to the design certification
23 rules. We felt that the finality standard prevented
24 that. So you'll notice that we incorporated the
25 standards from the latest 50.59 into each of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 design certification rules and we used this provision
2 three to accomplish that.

3 Next provision we wanted to have the
4 ability for applicants to actually complete the design
5 information, to complete the design ITAAC in a generic
6 manner so that each of the referencing applicants
7 would use that and that would enhance standardization.
8 That's why the Commission put in that provision.

9 As a result of requests from commenters
10 who wanted the ability to correct errors that may have
11 been discovered since the certification, the
12 Commission put in a provision allowing for the
13 correction of material errors and those are errors
14 that are significantly and adversely affect the design
15 function of the analysis and the design control
16 document, so we added that provision. Also, the
17 industry requested the ability to make beneficial
18 changes. What the Commission did with that is they
19 basically put in the existing 51.09 backfit standard
20 which allows for substantial increases in safety,
21 reliability, or security, provided they're cost
22 beneficial.

23 And then commenters also requested a
24 variety of other reasons to amend certifications and
25 we created what I typically refer to as our catch-all

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 provision that if there are other changes that a
2 vendor would like to make that the referencing
3 applicant supported, and that would achieve additional
4 standardization, rather than doing that on a case-by-
5 case basis. We have this one where it contributes to
6 increased standardization. And so the Commission made
7 all of those changes basically in response to requests
8 from the industry to facilitate these amendments.

9 Now important points on this, Provision
10 (a)(3) says that once the certification is amended,
11 everyone who references that certification has to
12 incorporate those amendments. But the Commission
13 recognized that that burden may not be shared equally
14 in a situation if we looked down the future where
15 there are some plants that are already built and
16 operating or under construction. Other plants that
17 are just starting the referencing. So the Commission
18 put a provision in A.2 that said we're going to give
19 special consideration to each of those referencing
20 applicants and their particular situation in
21 determining whether or not these amendments will, in
22 fact, be accepted and required for each of the
23 referencing applicants.

24 That's a very shorthand presentation of
25 how the Commission changed the amendment process and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 as Westinghouse has stated, they have officially filed
2 under the new version, the version I show in this
3 slide or in your handout, to amend the existing AP1000
4 design certification.

5 CHAIR BONACA: Under item 5, correct
6 material errors, you specifically talk about errors
7 which can be substantial or significant to the design.
8 Wouldn't that reopen -- isn't there a potential for
9 reopening the certification process?

10 MR. WILSON: I'm not quite sure what you
11 mean by reopening, but let me work through an example.
12 And I'll pick because Westinghouse talked about
13 changes in their proposed pressurizer design. Let me
14 for the purposes of discussion call that an error.

15 Westinghouse is proposing to correct that.
16 I believe that would fit under that particular
17 provision of the rule. Now understand the amendment
18 process places everyone on the same footing. It
19 doesn't matter if he's the original designer,
20 Commission, or other members of the public. Everyone
21 can petition and request an amendment.

22 So let's say in the course of the review,
23 the staff and be careful about this. Staff's focus is
24 on those changes, but let's say they became aware of
25 some other error that also met this standard. They

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 could also request as part of this amendment process
2 that that error be corrected.

3 But this is not a re-review of the whole
4 application. Staff's review is on the proposed
5 changes.

6 MEMBER SIEBER: So it's possible under the
7 provisions of 52.63 that every plant could be
8 different, every other plant in the so-called
9 standardized plants?

10 MR. WILSON: No, that's the purpose of the
11 provision (a)(3) is that once it's amended, the
12 Commission expects everyone to meet the amended
13 version of the design.

14 MEMBER SIEBER: Or some further design
15 after you apply this again, right?

16 MR. WILSON: Yes.

17 MEMBER SIEBER: Keep stepping up the
18 ladder.

19 CHAIR BONACA: With exceptions for those
20 which are already licensed.

21 MR. WILSON: No, everyone.

22 CHAIR BONACA: Oh, everyone. Then I
23 misread this.

24 MR. WILSON: That's why we have that
25 special consideration provision. We want to be sure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we have taken into consideration those disparate
2 burdens from the person who is already in operation or
3 the person under construction versus the person who is
4 just referenced like TVA just referenced the AP1000.

5 MEMBER CORRADINI: I guess I thought I
6 understood it, then when you clarified Mario's
7 conception, I'm confused.

8 So let's say for the sake five plants
9 ordered this with the changes -- ordered this or have
10 this AP1000 package class, whatever it was called.
11 And then along comes another class that's developed.
12 That would not fit within this. That would be a
13 different certification because the way I heard it
14 before, Westinghouse would come in with a modification
15 to the current certification. So I'm trying to
16 understand --

17 MR. WILSON: Let's work through that.

18 MEMBER CORRADINI: I'm trying to
19 understand how this all hands together.

20 MR. WILSON: Right now, there's an AP1000
21 certification, Appendix D to part 52. And if you read
22 in there, you'll see that certification is done to
23 Revision 15 of their documentation.

24 Westinghouse is coming and asking to amend
25 that certification. Now for the purposes of this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 discussion let's assume that it's revision 16 that
2 gets approved. I'm skeptical of that, but let's
3 assume that.

4 (Laughter.)

5 I'm going to go in there. I'm going to
6 erase 15 and put in 16. Rev. 15 certification no
7 longer exists. Everybody has to conform with rev. 16
8 now.

9 MEMBER SIEBER: But if you build a plant
10 on the rev. 15 --

11 MR. WILSON: I'm sorry, but you've got
12 conform with rev. 16.

13 MEMBER SIEBER: Well, then you go up to --

14 MR. WILSON: Let me finish before --

15 MEMBER SIEBER: -- (a)(1)(6).

16 MR. WILSON: Everyone has to conform with
17 rev. 16. Now we've taken into consideration, as part
18 of that review, those burdens that that operating
19 plant had and if they decided it still should apply,
20 then they would have to conform.

21 Now let's say you're that operating plant.
22 And you were unhappy about the resolution of that
23 rulemaking. You could come in and request an
24 exemption for your particular plant from that --

25 MEMBER SIEBER: The seismic backfit for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this means changes in the structure, the containment,
2 and all kinds of things, so the only choice you would
3 have to continue operation is to get an exemption.

4 MR. WILSON: That may be the case. It
5 depends on what's going on. That's -- and so the
6 timing is very important in how this amendment process
7 works.

8 MEMBER ABDEL-KHALIK: What we heard this
9 morning was going from one design class to the next
10 design class would likely be done through this
11 amendment process. Is that consistent with what
12 you've just described?

13 MEMBER CORRADINI: It doesn't sound like
14 it.

15 MR. WILSON: I am not sure what you mean
16 by design class --

17 MR. FISCHER: Can you use the mic, please?

18 MR. HASTINGS: This is Peter Hastings.
19 I'm the DCWG lead for AP1000 and I'll be speaking this
20 afternoon.

21 I think it's a matter of degree. If it's
22 a fairly minor change, be coordinated with the DCWG
23 and with the customers at the time. If it's a
24 significant change, Jim also said it would be a
25 commercial decision how to roll out that wave. If it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 was to change to a three-loop plant, that's not likely
2 going to be an amendment to the AP1000 appendix D
3 that's going to be a new design certification.

4 MEMBER CORRADINI: Design certification.

5 MR. WILSON: And just for clarification we
6 have to put in the regulations dealing with that
7 example he just talked about. I'll cite 52.59(c). At
8 some point if it becomes so extensive, it's a
9 different plant, then you're back to the beginning and
10 it's a new design certification.

11 MEMBER CORRADINI: Okay, thank you.

12 MEMBER SIEBER: Or it could be another
13 exemptions to the specification itself, the certified
14 design.

15 MR. WILSON: You can do plant-specific
16 changes. Today, I'm just talking about generic
17 amendments. I'm not discussing plant-specific
18 ventures.

19 CHAIR BONACA: Okay, any further
20 questions? That's quite informative.

21 With that, I thank you for the
22 presentation and we will recess for lunch and come
23 together as 12:15. So get back on time and we'll have
24 time for the afternoon presentations.

25 (Whereupon, at 11:33 a.m., the meeting was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 recessed, to reconvene at 12:15 p.m.)

2 CHAIR BONACA: We'll resume the meeting
3 now and the next person on the agenda is Mr. Hastings
4 from NuStart, and he will talk to us about issues
5 addressed by the AP1000 Design-Centered Working Group.

6 MR. HASTINGS: And I will refer you to the
7 handout package that has the NuStart cover sheet on
8 it. Unfortunately, Ms. Aughtman is not going to be
9 able to join us. She took ill a couple of days ago
10 and tried to rally last night with an early turning in
11 but she woke up this morning and could barely get out
12 of bed. And so we put her back on a plane to try to
13 get well. She, among the large contingent of DCWD
14 folks who have been working very hard to pull of the
15 Bellafonte seal applications succeeded in running
16 herself into the ground. So -- but with me today --
17 well, first of all, let me introduce myself. I'm
18 Peter Hastings. I'm the Licensing Manager for Nuclear
19 Plant Development for Duke Energy but I'm also the
20 DCWG, AP1000 DCWG lead and we'll talk a little bit
21 about how the DCWG is structured.

22 Unfortunately, Amy, in addition to not
23 being able to be here to make her part of the
24 presentation, had the memory stick with the
25 presentation on it, so that's why we had to use the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 handouts. With me is Phil Ray, who's the Licensing
2 Lead for TVA and the point of contact for the
3 Bellafonte application on behalf of the DCWG; also
4 Eddie Grant and Neil Haggerty who are our leads for
5 the development of the NuStart application for the
6 Bellafonte site and so I'd certainly invite them to
7 weigh in with any questions that I can't answer as we
8 go along and I think Andrea is going to join us as
9 well.

10 Let me refer you to Slide Number 1. This
11 is the frisbee diagram that really represents the
12 collaboration of the DCWG members.

13 CHAIR BONACA: NuStart is the complex of
14 this organization.

15 MR. HASTINGS: Yes, correct. And the
16 reason I wanted to include this graphic as more than
17 just a decoration is to explain the relationship of
18 the DCWG to NuStart. The NuStart consortium is
19 pursuing two applications; one for the AP1000 and one
20 for the GE ESPWR. We had already divided the NuStart
21 team into two halves, one of which was the half that
22 consisted of the declared applicants for the AP1000
23 design and so when the design-centered review approach
24 was formulated, it was a very natural fit for the
25 AP1000 team within NuStart. So the NuStart AP1000

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 team, because all of the AP1000 declarants,
2 coincidentally, are members of NuStart, that team
3 because the AP1000 Design-Centered Work Group. So
4 it's worked out very, very well and speaking on behalf
5 not as the lead but the spokesman among equals, I can
6 tell you that I'm very pleased and proud to be
7 representing them here today.

8 The Bellafonte site was chosen by NuStart
9 as the site to be developed by NuStart for the AP1000
10 application and so very similarly it became the
11 natural fit as the reference point for the AP1000 and
12 the design-centered review approach was formulated.
13 I want to clarify though, a little bit about the --
14 what the staff and we have agreed since was a rather
15 unfortunate terminology because it's a little
16 misleading. The reference COLA (phonetic) is really
17 the carrier of standard content. It might imply that
18 it's -- and it is a COLA that other COLAs will
19 reference and that's not the case.

20 The subsequent COLAs, an equally
21 unfortunate term, simply refers to those COLAs that
22 use the same standard content that come after the
23 reference COLA. So all of the COLAs will incorporate
24 by reference the design control document, the
25 Westinghouse certified design, but they won't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 incorporate by reference each other's COLAs. That
2 just was going to get way too ugly, and so we
3 abandoned any thought of doing that early on. Because
4 I don't have a slide that speaks to it specifically,
5 one of the committee members had asked for some -- a
6 little bit of explanation on our decision process for
7 how we handle changes in standard content. So this is
8 as good a time as any to elaborate on that a little
9 bit.

10 We are very proud to just submit the
11 Bellafonte application yesterday and it is the
12 reference-planned application. The next application
13 that comes in will be in a few weeks. It's a little
14 bit of a horse race right now between who it will be.
15 It will either be the Duke, Lee Nuclear Application,
16 possibly the South Carolina Electric and Gas, VC
17 summer application, possibly the Progress Energy
18 Harris Application. They're all working on their own
19 paths and they'll be submitted when they're ready.

20 Obviously, we're certainly not competing
21 with each other to be second in the door. But
22 inevitably, between now and the time the first S-COL
23 application is submitted, someone is going to find
24 something, at typo in the DCD, a typo in the reference
25 COLA, what have you and so we are putting into place

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 within the DCWG and within NuStart, a configuration
2 management process so that take as an example, when
3 the Lee application discovers a typographical error in
4 the Bellafonte reference application, in the standard
5 content, we'll identify that to NuStart, to the DCWG.
6 The DCWG committee will, through a configuration
7 management process, vote out whether that qualifies as
8 a change to standard content or not.

9 The way we envision this happening is that
10 before the next S-COL application goes in, we'll
11 publish some sort of an errata report to the reference
12 plant application. Those errata, once they're decided
13 by the DCWG, are valid changes to standard content.
14 Then the S-COL application will incorporate that
15 change and it will be identified as an errata to the
16 reference plan and then at some point when it makes
17 sense and obviously, as a function of the significance
18 of the change, we'll do a true-up of all those
19 applications to maintain the standard content.

20 CHAIR BONACA: Let me ask you a question
21 now. Since we do not have exhibits on display, tell
22 us when you're changing slides and what is the
23 exhibit.

24 MR. HASTINGS: And with more substantive
25 changes that may occur through the RAI process, will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 be handled very similarly. An RAI to one of us is an
2 RAI to all of us particularly when it touches standard
3 content. And so when Phil is contacted with
4 preliminary information from the staff that looks like
5 it's headed toward an RAI, he immediately calls the
6 rest of the DCWG and in fact, during the acceptance
7 review period, we're going to be having daily
8 conference calls with the staff to make sure that we
9 have a good handle early on with any issues that they
10 may be having.

11 And as the RAI responses change standard
12 content, we will keep the reference plant application
13 and the standard content within it under very close
14 configuration and control and then those changes will
15 roll out to the S-COL applications as well. So does
16 that -- I don't recall who was asking about the
17 details.

18 MEMBER SIEBER: What companies are
19 entering the leading plant or are they?

20 MR. HASTINGS: The lead plant is the TVA
21 Bellafonte application. Duke Energy has got the lead
22 nuclear Units 1 and 2. South Carolina Electric and
23 Gas has the VC Summer Units 2 and 3. Southern Nuclear
24 has Vogtle Units 3 and 4 and Progress Energy has
25 Harris 2 and 3 and Levy County, Units 1 and 2.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And in fact, that's the bulk of the
2 content of Slide Number 2. The benefits of the design
3 centered review approach have been elucidated before
4 and they're pretty clear. Any time you can handle one
5 issue through one review and one decision, one
6 approach, one position, it makes a lot of sense. It
7 makes for a much more efficient review. We've seen
8 that already through review of some of the technical
9 reports.

10 We've seen it with early collaboration
11 within the DCWG and early interaction, pre-application
12 interactions with the staff and the resolution of
13 issues and submittal of technical reports. It's been
14 very effective so far. And of course, the more
15 standardization that we have the more efficient that
16 process will be.

17 And as Andrea mentioned during the
18 presentation this morning, even when they're site
19 specific content, we're trying to maintain a
20 consistency in terms of level of detail so that
21 there's no one application that makes another one look
22 strange for some reason.

23 I've been through the DCWG membership so
24 I won't repeat that but I will re-emphasize, we've
25 been coordinating the DCWG within the AP1000 community

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 very, very closely, regular routine meetings. Because
2 NuStart is also pursuing ESBWR application, we've also
3 been collaborating very closely with the ESBWR team
4 because we're all NuStart and both class of plants and
5 we have a lot of commonality there.

6 We're also collaborating with NEI and the
7 entirety of the new plant community at the NEI/COL
8 task force level and as I mentioned, with the NRC
9 staff where we've had several pre-application meetings
10 over the course of the last two years and we started
11 off that set of meetings with a prioritized set of
12 topics that have been very useful to talk through,
13 things like level of detail on radwaste systems, the
14 QA program applicability, the review of the NEI
15 templates on radiation protection, quality assurance,
16 maintenance room and so forth have been very useful,
17 very helpful.

18 On Slide 3, this is just a very high level
19 summary of what the license application looks like.
20 This is for the AP1000 but most of the other
21 applications are similar, not identical, but similar
22 in structure. So we have what we call Part 0 which is
23 basically just the cover letter and the affidavits and
24 so forth.

25 Part 1 contains general and administrative

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 information which includes identification of a
2 reference plan, the listing of the contents of the
3 application itself, or excuse me, the decommissioning
4 report, discussion about the financial qualifications
5 for construction and so forth.

6 Part 2 is the FSAR proper. And of course,
7 it contains all the information required for the FSAR
8 and we'll go into more detail on all these in a few
9 moments. Part 3 is the environmental report, the
10 technical specifications, emergency plan. You can
11 read down the list and see what the contents are.

12 Part 11 is -- consists of those documents
13 that we incorporate by reference. For the Bellafonte
14 application, for reasons I can go into in a little
15 while, it only consists of one document, the quality
16 assurance program document for Bellafonte. I will
17 point out in particular Part 9. It is information
18 that is not safeguards information but is withheld
19 either because it's proprietary or SUNSI (phonetic) or
20 personal information or so forth. So when you see the
21 public version of the document, neither Part 9, which
22 is the withheld information, nor Part 8, which is the
23 safeguards information, will be in that public
24 version.

25 A little more detail on each of that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 parts; Part 1, the general financial information
2 includes the 50.33 information on financial
3 qualification and also for Bellafonte some proprietary
4 information that as I've mentioned, actually exists in
5 Part 9.

6 What you'll see in the parts that contain
7 that proprietary information where that information
8 has been moved. In the public version, you'll see --
9 I guess in those versions, you'll see a redacted page
10 where that information would have been included. Part
11 2, the FSAR, incorporates by reference Appendix D of
12 Part 52, the design certification rule. We actually
13 also refer to DCD Reg 16 which is under review and
14 we'll talk about that in more detail shortly.

15 The FSAR for the COLA is structured
16 virtually identically with some very minor exceptions
17 to the structure for the design certification. So
18 each section of the FSAR, one of the first statement
19 it makes is this section, the corresponding section of
20 the DCD is incorporated by reference and then
21 additional information is added. And we'll go into
22 the FSAR in a little bit more detail later.

23 Part 3, the environmental report, which is
24 based on the guidance of NUREG-1555. Part 4 contains
25 the technical -- site specific technical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 specifications. It starts with incorporation by
2 reference of the DCD generic tech specs and bases.
3 The bracketed information for the most part is filled
4 in. There are some brackets that are the subject of
5 license conditions that remain to be filled in, for
6 example, rod drop time has not been specified.

7 And then we have a section that includes
8 the entirety of the tech specs that incorporate that
9 bracketed information, so we have both versions of
10 that in the application itself. Part 5 is the
11 emergency plan, including state and local
12 certifications, state and local plans, evacuation time
13 estimates and references to the emergency planning
14 ITAAC that are contained in Part 10.

15 An example of the EP ITAAC is the
16 successful completion of the -- of a substantial
17 exercise prior to fuel up. Part 6 is reserved for
18 limited work authorization information. Bellafonte is
19 not currently seeking an LWA, so that section is blank
20 for Bellafonte. Part 7 contains information on
21 departures and exemptions. And it's a very short
22 section which is a mark of the success of the DCWG
23 effort and the collaboration that we've had with
24 Westinghouse. We only have two exemptions and three
25 departures and they're not particularly complicated.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We have a fitness for duty rule exemption
2 that we've taken as an elective measure and this is
3 consistent with the rest of the industry, to -- an
4 exemption from the current regulation because we're
5 describing in advance what we know the regulation is
6 going to change to and so we've got a forward looking
7 exemption there. The other exemption is purely
8 administrative. The use of the DCD document numbering
9 simply didn't fit in every case because the regulation
10 calls for use of the DCD format for the COLA and we
11 have a minor exemption for that and the departures
12 from the formatting are clearly spelled out in the
13 COLA itself.

14 Then the departures, we have the standard
15 departure which will apply to all AP1000 which is
16 related to the same difference in document numbering.
17 And then we have two site specific departures, one of
18 which is a vagary of the service water system for
19 Bellafonte and the other is pretty consistently but
20 not universally adopted by all of the AP1000
21 applicants and that is a relocation from what the DCD
22 indicates of where the technical support center is
23 located physically, and I'll explain that later in the
24 presentation.

25 Part 8, as I mentioned, is the safeguards

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 information. It's the security plans and of course,
2 we won't talk about that in any detail at this
3 meeting. Part 9 is the other withheld information,
4 the nine safeguards information. There is some
5 financial proprietary information from TVA in Part 9.
6 There are also a very small number of layout drawings
7 that were -- that we agreed with the staff were SUNSI
8 that are in this as well.

9 Actually, the only reason they're in there
10 is because of a departure to the relocates the
11 operational support center. It's actually designated
12 on a couple of layout drawings, so we had to make that
13 change. Part 10 includes ITAAC and proposed license
14 conditions and I won't belabor -- and by the way, I
15 apologize, I'm on Slide 9 for those that -- I won't go
16 through the entire list of license conditions. One of
17 the more notable ones is the implementation milestones
18 for operational programs. We have a table in Section
19 13-4 of the FSAR that describes the implementation
20 milestones for various operational programs. And
21 that's a consequence of advanced discussion with the
22 staff, work with the staff on the development of how
23 we were going to describe operational programs without
24 piling up a bunch of ITAAC. I mean, the alternatives
25 available to us through SECY-05-0197 were that you can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 either have ITAAC for operational programs or you can
2 sufficiently describe the operational programs in the
3 FSAR and include implementation milestones so that the
4 staff can come in and inspect compliance with those
5 programs as part of that implementation.

6 Part 10 also contains a proposed
7 environmental protection plan and the security and
8 emergency planning ITAAC and the site specific ITAAC
9 in addition to what's in the DCD. Part 11 as I
10 mentioned earlier, is information that's incorporated
11 by reference. The QA program description is the only
12 document that's included in there today. And the
13 reason for that is that the other information we're
14 incorporating by reference is available elsewhere say
15 in ADAMS or we didn't have it in a timely manner to
16 put in this appendix for example, TR-134 and in
17 discussions with the staff we can certainly make a
18 conforming change to add that back into the DVD as the
19 staff sees fit.

20 So on Slide 11 we start going through in
21 some detail the individual chapters of the FSAR and as
22 an intro to the FSAR which as a reminder is Part 2 of
23 the COLA, we incorporate by reference in the
24 application Rev 16 of the design control document as
25 amended by Technical Report 134 which Andrea talked

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 about earlier today. And as a reminder, TR-134 is --
2 represents the minor corrections and minor changes
3 that have occurred since Rev 16 of the DCD was
4 submitted. You'll see the term IBR used throughout
5 the presentation. Just to make it clear, that's what
6 that means, is incorporation by reference. We do
7 incorporate by reference a handful, a small handful of
8 documents, the DCD, the TR-134 that amends the DCD and
9 then four NEI templates that have been submitted and
10 either approved or are currently under review by the
11 staff and those four documents are a training program
12 description, a maintenance rule program description,
13 a radiation protection program description and an
14 ALARA document, and so we incorporate those documents
15 by reference into the COLA as well.

16 There are probably another half dozen or
17 so NEI templates that we also refer to but we don't
18 incorporate them by reference. We adopt them or
19 describe them in some detail further in the FSAR.
20 I'll apologize, the standardization of COL
21 applications bullet there is an artifact from a
22 previous presentation. You really won't see the
23 entire IBR, essentially IBR or IBR plus in this
24 presentation and you won't see them in the COLA. That
25 was sort of a Rosetta Stone from earlier presentation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and I intended to take that out. I apologize for any
2 confusion.

3 On Slide 12, here are some of the metrics
4 on the FSARs and the extent to which they're
5 standardized. And I'll tell you up front, the number
6 -- any percentage of standardization to these
7 documents should be taken with a grain of salt because
8 it depends on how you measure it. If you measure it
9 by number of sections we're 80 percent standard. If
10 you measure it by number of pages, well, it's less
11 than that, because the site specific Chapter 2 is a
12 big document. So just for that caveat, by section
13 we're about 80 percent standard across the entire
14 AP1000 fleet and again, most of Chapter 2, site
15 specific.

16 We issued with the response to RIS-2006-06
17 and 2007-08, I think, standardization matrix that was
18 sort of our key to how we were tackling the documents
19 as they were being developed. And you see an excerpt
20 from the latest RIS response here for Chapter 1.
21 Virtually every section has some amount of information
22 incorporated by reference from the DCD. If you count
23 up the number of sections that are standard or
24 partially standard, you can see a substantial number
25 of sections there have standard information in them.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Thirty-six of the sections have -- are either site
2 specific or partially site specific and if you add up
3 182 and 36, you get greater than 193 because there are
4 some overlap. There are some sections that have both.
5 As you saw in the description of the Part 7 departures
6 report, we have a very small number of departures and
7 we think that's a real success story. It's -- as I
8 mentioned, it's a real mark of the collaboration that
9 we've had among the AP1000 applicants and
10 Westinghouse.

11 Slide 13, one of the ways that we -- very
12 helpful, thank you. And of course, the first one he
13 throws up is the first one you can't read, so he
14 didn't have my TV on.

15 (Laughter.)

16 MALE PARTICIPANT: I asked him to put it
17 on.

18 MR. HASTINGS: I appreciate it.
19 Incorporation by reference, electronic review of
20 documents, cross-referencing to documents that are
21 incorporated by reference, and understanding how
22 information is standard from one AP1000 application to
23 the next can be very complicated and daunting and
24 we're sympathetic. We think it's far and away the
25 most efficient way to conduct the review. We think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 the staff agrees with us but it's not always intuitive
2 and so what we've done for our application is
3 annotated virtually every paragraph of the FSAR with
4 one of these left margin annotations. And I won't
5 bore you with all the details but basically you can
6 tell by looking at the left margin annotation once you
7 figure out what they stand for, whether something is
8 standard or site specific, whether it's conceptual
9 design information, a departure or closure of the COL
10 information item or supplemental information.

11 It takes a little while to get used to how
12 this reads, but it is very, very helpful once you have
13 the key in your mind. We think that the staff will
14 agree it's very helpful to be able to look at a
15 section and know that's standard content and to know
16 that I can go to another AP1000 and unless they've
17 taken a site specific exception to the standard
18 content, it will be identical. Particularly helpful,
19 we think, for subsequent COL applications.

20 MEMBER ABDEL-KHALIK: The staff would have
21 to take your word for that margin notation or the --

22 MR. HASTINGS: They can certainly hold
23 the two pages up to the light and see that they are
24 identical if they choose to do that.

25 MEMBER ABDEL-KHALIK: No, I mean, if you

1 have different paragraphs, you can't do that. They're
2 not going to be --

3 MR. GRANT: The wording should be
4 identical.

5 MEMBER ABDEL-KHALIK: No, I mean, you're
6 referencing a specific paragraph in a specific
7 document, correct? And you're telling them that this
8 paragraph is identical to the paragraph in that other
9 document.

10 MR. HASTINGS: Correct.

11 MEMBER ABDEL-KHALIK: This becomes a very
12 cumbersome process for the staff if they really want
13 to verify that your notation is correct.

14 MR. HASTINGS: That -- it could be. We're
15 hopeful that they would only feel compelled to do that
16 on a sample basis because the intent of this -- the
17 primary intent of this is for subsequent COL
18 applications not to have to spend a lot of time and
19 energy reviewing something that's already been
20 reviewed and accepted as standard content.

21 MEMBER CORRADINI: So I have a question to
22 go with this. I hesitate. So in this electronized
23 world we're in, why not have a hot link so you press
24 on your notation that takes you to the other place?

25 MR. HASTINGS: Well, the reason is that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 want to make it efficient. We don't want to --

2 MEMBER CORRADINI: Make it easy? Sorry.

3 (Laughter)

4 MR. HASTINGS: You had an opening there.
5 No, it gets back to one COL application not
6 referencing another one.

7 MEMBER CORRADINI: I understand.

8 MR. HASTINGS: We're really not inviting
9 the staff to review two applications at once. We're
10 just trying to point out to them that this is standard
11 content. The idea of the one review, one position
12 approach was that once the staff has reached a
13 conclusion on a particular piece of standard content,
14 they shouldn't have to do that review again, except on
15 a confirmatory basis to make sure it will be a
16 standard. And we would expect some review of that on
17 a sample basis.

18 MEMBER ABDEL-KHALIK: But, you know, I
19 mean, we're not saying that somebody will
20 intentionally mislead the staff by doing this but this
21 is a process that is, in my mind, just fraught with
22 the possibility of error.

23 MR. GRANT: Essentially, what it will take
24 is -- if this were the Bellafonte application and this
25 were the Harris application, you would hold these up

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and go.

2 MEMBER ABDEL-KHALIK: But somebody has to
3 do that.

4 MR. GRANT: Well, but they have to review
5 the other piece of that. If they're not doing, "Yeah,
6 those are the same", then they're reviewing every word
7 on this page and comparing it to their acceptance
8 criteria and determining whether or not it meets that
9 acceptance criteria and writing the Safety Evaluation
10 Report. If they can put all of that aside and go,
11 "That's just like what I reviewed last week", I've
12 already written the Safety Evaluation Report. I've
13 already compared it to all of the acceptance criteria.
14 All I have to do is change the name to protect the
15 innocent and send out the next SECY --

16 MEMBER ABDEL-KHALIK: So you're comparing,
17 you know, the process of taking two pages and making
18 sure that indeed, this paragraph is the same as the
19 one I've reviewed before against the process of
20 actually reviewing the paragraph. But somebody has to
21 actually verify that those paragraphs are the same.

22 MR. HASTINGS: And again, we would expect
23 that that would happen on a sample basis, yes.

24 MEMBER ABDEL-KHALIK: Thank you.

25 MR. HASTINGS: That is part of our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 configuration management of the various documents that
2 an S-COLA applicant is not allowed to include standard
3 information unless it's standard. He's not allowed to
4 change it without the DCWG agreeing that it's a change
5 to standard content. If for Lee, for example, we
6 prepare a paragraph that for whatever site specific
7 reason we decide we're not going to use the standard
8 content, we're obligated to change the left margin
9 annotation to indicate that that's site specific
10 information. And we do have -- to answer Dr.
11 Corradini's question, we do have hot links back to the
12 DCD.

13 MEMBER CORRADINI: Oh, you do, okay, okay,
14 well, then that's important.

15 MR. HASTINGS: And that's the bulk of --

16 MEMBER CORRADINI: Because that's the
17 basis, right, in terms of your standardization.

18 MR. HASTINGS: Right, and there are
19 chapters of the FSA that have no content except for
20 reference back to --

21 MEMBER CORRADINI: Okay, okay, good.

22 MR. HASTINGS: Okay, on Slide 14, just a
23 high level summary of the COL information items.
24 There are 175 of them in the standard DCD. About 66
25 and I say about because some of them are multi-part

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 and some of them get counted twice by some people and
2 so that the number varies a little bit, but there are
3 about 66 that were eliminated one way or another with
4 REV 16, 48 of them because they were closed and that
5 included seven that were deleted because they were
6 just entirely redundant to ITAAC and then 18 that were
7 rebucketed from COL information items to COL holder
8 items, typically consisting of things that required
9 as-built confirmations. It's very difficult to leave
10 them on as well.

11 The remainder of the COL information items
12 are closed in the COL application itself. Again,
13 that's -- the COL left margin indication flags those
14 items. That information is in the COL information
15 items. A couple of examples of COL holder items are
16 shown on Slide 15. Just to give you a frame of
17 reference, what we mean by COL holder item, is it
18 typically information that's needed but can't be
19 confirmed until some point after receipt of the
20 license. And this is one of the options available in
21 Reg Guide 1.206 about how you flag information that is
22 a forward looking commitment. So these are included
23 in the license conditions that we referred to earlier.

24 Slide 16, we'll go through the FSAR
25 chapters fairly quickly. If you have any questions or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 see anything that causes you confusion, just feel free
2 to stop me. Chapter 1 again, introduction of general
3 design, excuse me, general description, and this is
4 incorporation by reference of Appendix D, discussion
5 of the format of the balance of the FSAR, material
6 that's incorporated by reference has some COL
7 information item closure in it and contains a new
8 section 1.10 on impact of multi-unit construction.
9 The DCD is predicated on a single unit. All of the
10 AP1000s are in configurations. Some are at sites for
11 the existing operating units and so we have a
12 discussion of the administrative controls associated
13 with construction on Unit X against Unit Y that is
14 operating at the time, be it an existing operating
15 unit or Unit 1 while you're building Unit 2.

16 Chapter 2, certainly the largest site
17 specific chapter, as you'd expect, the FSAR are on
18 Slide 17. The standard departure 1.1-1 is the
19 formatting, the document formatting departure that I
20 mentioned earlier. This is the chapter that describes
21 that the site characteristics against the site
22 parameters in the DCD. Slide 18, Chapter 3 is
23 primarily incorporation by reference of the DCD, some
24 dual unit information there as well. In this case,
25 things like turbine missiles from the second unit,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 impacts on the first unit. The in-service testing
2 program description, for snubbers and valves. You'll
3 notice there's no articulated pumps but that's a no
4 set for this particular section.

5 Slide 19 is almost entirely incorporation
6 by reference. There's one COL holder item to a rear
7 consumption of the BNR limits. Slide 20, again,
8 mostly incorporation by reference, also includes the
9 description of the in-service inspection program.
10 Slide 20, Chapter 6 again, mostly incorporation by
11 reference. It includes description of the containment
12 lead rate testing program. This is one of the program
13 descriptions that we submitted early on via technical
14 report to the staff and we just actually received an
15 SER on that particular one a few days ago. It
16 describes Class 2 and 3 in-service inspection.

17 Slide 22, Chapter 7 is entirely
18 incorporation by reference. There is no new
19 information in Chapter 7. That said, Chapter 7 with
20 ECD also describes that. So there is more information
21 to come during development or during review of the REV
22 16 of the DCDM proposals.

23 MEMBER MAYNARD: Wouldn't you rate Chapter
24 7 for some site specific implementation and control?

25 MR. HASTINGS: Sorry?

1 MEMBER MAYNARD: Wouldn't there be some
2 potential in Chapter 7 for some site specific on
3 instrumentation and control for cooling water systems,
4 pipe feed --

5 MS. STERDIS: For those systems, that
6 would be outside the scope of what's required by the
7 SRP and the accompanying REV Guide 170, Rev Guide 1206
8 content. It would be -- you're right, there is site
9 specific controls associated with like the cir water
10 system but they don't reach the level of significance
11 that puts them into Chapter 7.

12 MR. HASTINGS: Chapter 8, we're on Slide
13 23 again, mostly IBR, does contain some conceptual
14 design information replacement and information on the
15 site specifics which are in grid information. Slide
16 24, Chapter 9 is mostly incorporation by reference.
17 It has the site specific departure for Bellafonte that
18 talks about a different routing that they have for the
19 blow-down flow path that goes to the waste water
20 system exclusively, whereas in the BCD there are
21 options it can blow down to and just because of the
22 vagaries of their site layout, they have chosen that
23 departure. There are other similar departures on some
24 of the S-COLs as well but this one is unique to
25 Bellafonte.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Full-text incorporation, just to dwell on
2 this a little bit, in some cases if you try to do
3 incorporation by reference plus addition of
4 supplemental information or departures or addition of
5 conceptual design information, it just gets so
6 confusing you literally can't read it. So in those
7 cases we've just done full text incorporation and then
8 just --

9 MEMBER CORRADINI: And then just insert
10 the new stuff in there.

11 MR. HASTINGS: Correct, yeah.

12 MEMBER SIEBER: Do you mark it in any way?

13 MEMBER CORRADINI: Like underline it or
14 something?

15 MEMBER SIEBER: Or a solid bar?

16 MR. GRANT: It's marked as separator bars
17 that divide it into groups such that if there is
18 information that is a pure repeat of the design
19 certification document, we have a DCD out in the left
20 margin annotation, then there will be a separator bar.
21 Then there will be some new information and it will be
22 labeled as CDI, Conceptual Design Information, and
23 then there will be another separator bar and then
24 there will be more information that is pure repeat of
25 the DCD.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: So everything is going to
2 be in order.

3 MR. GRANT: Yeah, everything is in order.

4 MEMBER SIEBER: And you can tell where it
5 came from.

6 MR. GRANT: You can, yes.

7 MR. GRANT: Now, it doesn't -- what it
8 doesn't do is provide you nice clean paragraphs like
9 you had in the DCD because we're going to break it up
10 a bit when we separate it so that we can show where it
11 came from. But it's in the order.

12 MEMBER SIEBER: Well, that's all right.

13 MR. HASTINGS: On to Slide 25, Chapter 10
14 another example of where it just made sense to add in
15 some Conceptual Design Information using the flow
16 extent incorporation method that Eddie just referred
17 to. Slide 26, again, waste management mostly
18 incorporation by reference, some additional
19 information to describe the radiation and effluent
20 monitoring program. And by the way, that's an example
21 of one of the operational program descriptions that
22 we've put in with milestones in 13.4 pursuant to SECY-
23 05-0197.

24 Slide 27 radiation protection, again,
25 mostly incorporation by reference with the addition of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ALARA description, information on dose to construction
2 workers and radiation protection program. There is an
3 Appendix 12AA that's included here, simply because the
4 NEI template that provides this program description
5 information and the format of the DCD 12.5 would have
6 resulted in more confusion than made sense, so we just
7 created an appendix to keep those separate.

8 MEMBER SIEBER: I would think some
9 radiation protection is so driven by company policy,
10 that they would differ significantly from company to
11 company.

12 MR. HASTINGS: It is -- there is always
13 going to be for operational programs in particular a
14 natural tension between standardization with your
15 existing operating fleet and standardization with the
16 AP1000 fleet, and we've got a very strong commitment
17 on the part of our management to err on the side of
18 standardization with the operating fleet. We would
19 expect that on any given program that's going to find
20 its own center.

21 MEMBER SIEBER: Well, if you use that at
22 a station worker, you're almost stuck with that.

23 MR. HASTINGS: There will be some of that
24 and there will be some give and take along the way,
25 I'm sure. Interestingly enough, everyone has adopted

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the new QA program description which is pretty popular
2 for fleet standardization but everybody is committed
3 to the AP1000 standard. Now, some, and Duke is one of
4 them, intends to conform their existing operating
5 fleet program to the new program that we've committed
6 to for the AP1000. So there's some in the other
7 direction as well.

8 MEMBER SIEBER: Okay, thank you.

9 MR. HASTINGS: Chapter 13 on Slide 28,
10 again, mostly IRB. The --

11 MEMBER SIEBER: That's probably not
12 correct.

13 MR. HASTINGS: Oh, yeah, that's a good
14 point. Yeah, this one -- that's probably a typo.

15 MR. GRANT: I think that one slipped past
16 us.

17 MR. HASTINGS: Mostly IBR is probably not
18 correct for 13. 13 also, and this is not
19 controversial but just because it's a little
20 different, for 13.3 and 13.6, this actually provides
21 pointers to other parts of the document. 13.3
22 contains the -- or points to the emergency plan. 13.6
23 points to the security plan and so they are just
24 pointers to those external documents.

25 And 13.4 is the section that contains the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 table that has the operational program milestones that
2 I referred to earlier. 13.7 is a fitness for duty
3 section that is a new section, not in the DCD and that
4 conforms to the NEI template for proposed fitness for
5 duty program.

6 MEMBER SIEBER: You have a new rule
7 coming.

8 MR. HASTINGS: We know, we've been
9 watching.

10 MR. GRANT: And in fact, the new rules
11 that came out September 28th that revised Part 52.
12 Why we have a new section that wasn't in the DCD
13 because it requires that we address the fitness for
14 duty.

15 MR. HASTINGS: Chapter 14 a description of
16 the initial test program. It also contains the site
17 specific ITAAC screening. We've adopted the ITAAC
18 screening criteria from the DCD and applied it to the
19 site specific line items. Chapter 15, mostly IBR. We
20 did move a failure analysis for one of the tanks to
21 Chapter 2 because it just made more sense in the
22 context, so site description, we maintained in Chapter
23 15 and we didn't want it in two places.

24 Chapter 16, a pretty short chapter because
25 the tech specs are equal in part, so again, this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 largely points to a separate external document that's
2 also part of the application.

3 MEMBER SIEBER: There will always be an
4 external document to the FSAR.

5 MR. HASTINGS: Correct.

6 MEMBER SIEBER: Right. And your
7 application.

8 MR. HASTINGS: It's part of the
9 application. It will be attached to the license.

10 MEMBER SIEBER: As a separate piece.

11 MR. HASTINGS: Yeah. Chapter 17 again,
12 shorter than one might otherwise infer because it
13 points to the QA program description that's contained
14 in Part 11. So 17.5 is a very simple pointer to Part
15 11 of the application and it is the QAPD which was
16 submitted by NEI and approved by the staff not too
17 long ago with the addition of a bracket of information
18 that's company and site specific.

19 17.6 is a description of the maintenance
20 rule program, again, another NEI template that was
21 incorporated by reference. Slide 33, Chapter 18 is
22 human factors and is mostly incorporation by
23 reference. This is the site specific departure for
24 relocating of the technical support center and
25 operational support center. And a little background

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 on that, most of AP1000 applicants have elected to
2 move the TFC out of its BCD location for the purpose
3 of combining the TFC to serve both units. It varies
4 a little bit where it will go and not everyone wanted
5 to do that which is why it will show up those -- in
6 this case, four different site specific departures but
7 the departure language is very similar from one
8 application to the next.

9 MEMBER SIEBER: If you have two control
10 rooms you're going to have a major programming job to
11 make it work, right?

12 MR. HASTINGS: And there was -- initially
13 we perceived that it might be a challenge because of
14 the criteria and the regulatory guidance about things
15 like access to the control room and so forth but
16 through -- and this was another good example of very
17 good interactions with the staff in advance where we
18 concluded as a group that the communication technology
19 that was available today and certainly that we expect
20 to be available in four, five years, obviated the need
21 for that two-minute access as a routine requirement
22 for --

23 MEMBER SIEBER: And the original purpose
24 of the two minute rule was two-fold. One is because
25 some TSCs didn't have a lot of instrumentation. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 other one was to provide operators with command
2 presence. Here comes the boss, shape up, kind of
3 thing.

4 MR. HASTINGS: They're all ITAAC
5 associated with the TSC that we're not taking a
6 section to that talk about access to the appropriate
7 information from the control room.

8 MEMBER SIEBER: Yeah, okay.

9 MEMBER ABDEL-KHALIK: Long-term, is there
10 anything that prevents any of the people in this group
11 from going to a different fuel vendor and getting
12 their completely different fuel design?

13 MR. HASTINGS: Not that I know of, apart
14 from the pleadings of Westinghouse which --
15 (laughter).

16 MEMBER SIEBER: You said fuel?

17 MEMBER ABDEL-KHALIK: Yeah.

18 MEMBER SIEBER: Who is licensed on a
19 reload by reload basis.

20 MR. GRANT: You know, we're just trying to
21 make sure that nothing in this process --

22 Well, once a licensee gets a license then
23 they can individually submit for changes, exceptions,
24 whatever, whether it be for fuel design or any other
25 part of the design.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: So how would the
2 impact the standardization goal? Would they have to
3 go back and redo their safety analysis calculations?

4 MR. HASTINGS: Sure, they would have to
5 confirm that whatever their new fuel design and this
6 is true whether it's -- whoever provides the fuel
7 would have to confirm that the new core design fits
8 within the envelope of what they've been licensed for.

9 MEMBER SIEBER: And every licensee would
10 have to do that and anything you would put in the
11 original COL would not apply to reloads. So you have
12 to do that analysis every time you get ready to reload
13 that plant.

14 MR. HASTINGS: And again, that's true
15 irrespective of which vendor is providing the fuel.
16 The extent to which standardization and things like
17 that continues in the long term will be in large part,
18 commercial considerations.

19 534, just to see if everybody is paying
20 attention, should not be titled inherent safety
21 features but PRA. I apologize for the typo there and
22 Chapter 19 is -- all but one section is incorporated
23 by reference and 1959 has some information on
24 confirmation of applicability and PRA configuration
25 control for Reg Guide 1200. That's the overview of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the COLA.

2 We went through it pretty quickly in the
3 interest of time. I'm sure we will be back so we can
4 take any questions now or later that you have on the
5 COLA itself.

6 MEMBER SHACK: On the PRA, I mean, you're
7 going to hand the baseline PRA over to the licensee?

8 MS. STERDIS: Absolutely. The baseline
9 PRA has been deemed to be applicable to all the sites
10 that are applying to our -- using our technology. The
11 key areas -- we have two areas, we have two COL
12 information items in Chapter 19. One dealt with
13 external hazards and making sure that any particular
14 site specific external hazards were addressed in our -
15 - the PRA.

16 The second one was a list of a potential
17 for evaluating sites to make design impacts so that
18 the limited part of the design that we said was not
19 covered in the design certification are any of those
20 site specific design aspects going to impact the PRA?
21 So we worked with the DCWG, Westinghouse worked with
22 them. We prepared two technical reports including two
23 checklists. One is we asked for input from each of
24 the sites regarding the external hazards and the
25 initiating frequency and they provided that input and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in TR I believe it's 101, TR-101 and this is reflected
2 in Rev 16 of the -- Chapter 19 of the Rev 16, we got -
3 - we reassessed the external load events and ensured
4 that our consideration of those or modeling of those
5 in the PRA, the standard PRA, allows that PRA to be
6 applicable to each of those six sites.

7 The other one, once we gave them a
8 checklist and said, "These are the significant
9 assumptions that you need to look at and consider as
10 part of your -- and look at your site specific design,
11 circ water, switch yard design and tell us if there's
12 anything here that you're not consistent with to come
13 back. We might A, have to do an evaluation for you,
14 or B do a modeling change in the PRA."

15 We never got to the point of doing either
16 the evaluation or modeling -- or remodeling of the
17 PRA. Because of the limited significance of those
18 aspects of the design, everybody came back and said,
19 "No, we're fine with this. We're good". We checked
20 and they have on file the completed checklist and in
21 their file is a statement of fact validation to
22 support their COL application.

23 So Chapter 19 for all intents and purposes
24 is incorporated by reference and we will turn that
25 over to them.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HASTINGS: On to Slide, I think it's
2 20 -- 35, excuse me, most of the issues that the DCWG
3 is working through and dealing with we really already
4 talked about because Westinghouse is part of the DCWG.
5 We're certainly reliant on their success with the
6 design certification amendment, that it's implied in
7 our COL applications. The COL applications
8 incorporate Rev 16. We've spent a lot of time working
9 with Westinghouse to understand what COL information
10 items we thought made sense to roll up into the DCD
11 because it's more efficient to take care of that once
12 than it is to take care of it five or six times.

13 And so most of the issues on this list are
14 not new and many of these we've talked about today
15 already. One is the ever-present issue of design
16 finality. How do we continue to work closely with the
17 staff to make sure that we maintain the veracity of
18 the certified design and that we don't stumble into a
19 place where we're re-opening something that we think
20 has already been approved.

21 Thresholds for changes is really another
22 issue that we're seeing in the DCD amendment and the
23 review of it. We want to make sure that we maintain
24 a consistent understanding with the staff on when more
25 information is needed on a particular subject

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 particularly when it's a change to something that's
2 been reviewed before. Configuration management for
3 standard content, we talked about earlier in this
4 presentation, very, very important for us to maintain
5 standard content consistent from one application to
6 the next. And I mentioned to you some of the
7 procedures that we're using to make sure that
8 happened.

9 Many of the issues that we've talked about
10 are being worked at the industry level with the NEI
11 COL task force. We've spent probably half of our time
12 as a group in the last two years working hand in glove
13 with the staff on the evolution of the regulations and
14 the guidance. The staff's been very forthcoming with
15 that information as it's being developed. Some of it
16 didn't come together quite as quickly as we or the
17 staff would have preferred, but for where we were at
18 the time and where we are now, I think from our part,
19 we think we did a pretty good job and we certainly
20 applaud the staff for that as well.

21 There's a lot of work going on now to
22 understand what the construction inspection program is
23 going to look like, ITAAC verification, trying to
24 borrow from things like the Reactor Oversight Program,
25 those elements of the program that make sense for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 construction inspection. We've worked very closely
2 and this is mostly a logistical issue, but it's been
3 very demanding and again, we've worked very closely
4 with the staff on the guidance for submittal of
5 electronic documents. It's not as easy as you think.

6 And I will say that in particular the
7 staff that's working the electronic guidance piece,
8 because they understand how vulnerable we are as
9 licensees, as applicants, as the guidance is evolving
10 and changing, and we're all sort of trying to feel our
11 way through that. They've been very, very gracious
12 with things that they get that don't quite pass what
13 they thought needed to pass in order for it to get
14 loaded into ADAMS and that's been a real success story
15 as well.

16 It continues to evolve but we're very
17 close. I think we're converging on a solution and
18 again, they've been great to work with in that regard.

19 MEMBER SIEBER: Do you have a way of just
20 submitting changes to the electronic documents or do
21 you have to send in the whole thing over and over
22 again?

23 MR. HASTINGS: I don't know the answer to
24 that.

25 MS. STERDIS: We haven't pursued it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HASTINGS: Yeah, we haven't pursued
2 page changes. Leslie, do you -- Leslie Kass of NEI is
3 sort of our point person.

4 MS. KASS: Using the new electronic
5 submittals tool that we have that the Office of
6 Information Services has developed, you would send in
7 your updated application and you would have to send in
8 the whole thing, you know, but you could leave the
9 files that are unchanged, you know, those would be
10 from your last submittal and would remain unchanged
11 and simply there is a way to label the ones that are
12 new, so that those will get loaded into ADAMS. But
13 there is an electronic process that actually for the
14 first submittal of the STP application, public version
15 took 39 minutes to get into ADAMS, so it is a very
16 efficient electronic process that we've worked out
17 with the staff.

18 MR. HASTINGS: And it's certainly easier
19 to submit the entire application when it's one DVD as
20 opposed to 7,000 pages.

21 MEMBER SIEBER: The more you do it, the
22 better I like it.

23 MR. HASTINGS: Continuing on the COL task
24 force level, the task force with the support of NEI,
25 has produced a number of templates that have made some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 operational program description information much
2 easier to incorporate by reference and get it
3 consistent across the industry to the extent we can.
4 The technical issues, again, no different that what
5 was described this morning. We're working very
6 closely with Westinghouse to make sure we've got the
7 right seismic considerations, to make sure that we've
8 got a spectrum that incorporates both soft soil sites
9 as well as the hard rock site, working through the
10 path forward on resolution of that and then the
11 operational programs I mentioned earlier. There are
12 several of those and making sure we hit the mark there
13 to give the staff enough information for them to draw
14 the reasonable assurance conclusion without getting to
15 the point where we have to submit the entire program
16 itself has been pretty successful so far.

17 Moving onto the next slide and I'll
18 apologize again for the absence of our colleague, Ms.
19 Aughtman. You wouldn't have enjoyed her presenting,
20 believe me. She was not well. And I will not do her
21 presentation justice but I'll give it a shot. Moving
22 on to 37, there are some site specific issues that
23 you'd expect. Having said that, the challenges
24 associated with site specific information that has to
25 be incorporated, site specific departures that have to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 be taken into account because of the vagaries of a
2 given site, in no way diminish the value of the
3 standardized approach and to a company, every DCWG
4 member continues to reiterate how important that is.

5 There are different types of sites, even
6 within the AP1000 community. We have a number of
7 sites that have existing operating units. We have two
8 sites that have partially constructed plants. The Lee
9 site was 50 percent complete on Unit 1 when it was
10 cancelled back in the early '80s. Bellafonte Units 1
11 and 2 were almost complete when they were stopped.

12 And so that's not quite Greenfield, but
13 pretty close. There's some of the infrastructure on
14 both those sites that will be borrowed for the new
15 plant but not a lot. And then there's one to the
16 Greenfield site. We do try to maintain a common
17 approach to resolution of site specific issues
18 whenever it makes sense to do so. We try to keep our
19 emergency plans roughly consistent. There are
20 obviously details at the state and local level that
21 aren't common, but we try to keep those as consistent
22 as possible.

23 We do try to coordinate with the DCWG
24 whenever an issue comes up because it's not always
25 obvious when an issue comes up or that it's standard

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 rather. Sometimes these things will evolve and
2 they'll become clear as was the case with the passive
3 plant emergency action levels for the emergency
4 planning, that it really was a generic topic. And
5 then, of course, the DCWG as we know it today, will
6 evolve as the effort evolves and eventually the DCWG
7 and the builder's group, the buyers group, depending
8 on what you want to call it, will become one and the
9 same. But maintaining standardization once you
10 actually go into construction is just as important in
11 terms of efficiency as it is in getting a license.

12 Next slide, please. The benefits, pretty
13 obvious, but we'll reiterate them. It's been of
14 tremendous value to us to -- in the preparation and
15 review of the COL application and just to remind you
16 of what Andrea said this morning, in addition to the
17 two-member minimum review on changes to the DCD and
18 the technical reports that Westinghouse has submitted,
19 every section of the COL application by procedure,
20 received at least a two-member review, in most cases
21 a three or four or five-member review to make sure
22 that we were A, getting the right number of
23 independent eyes on the document, but also to make
24 sure we maintain that cross-pollination across the
25 different companies and the different cultures.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Certainly to the extent you're developing
2 a standard product, it supports conformance with the
3 URD, it supports the finalization, consistent
4 finalization with the design across sites and I can't
5 say it enough, the more you standardize, the more
6 efficient we're all going to be going forward.

7 Next slide, please. This slide, I think,
8 is a little bit mistitled. These are site specific
9 features that really aren't standard, but again, we
10 tried to maintain the approach and the philosophy and
11 the level of detail as consistently as we can.
12 Obviously, because of where you are on the site or
13 where you are in the country and what your site looks
14 like, you'll have different details on circ water and
15 raw water, different company choices based on their
16 operating experience and based on certain aesthetic
17 considerations of whether you use a mechanic draft
18 tower or hyperbolic tower.

19 The issue we talk about before on the
20 stand-alone TFC, the details of some of the other site
21 buildings like maintenance facilities, admin
22 buildings, training facilities, a lot of that is
23 determined to topography. A lot of it is based on
24 synergy with the existing operating units. Clearly,
25 if you've got an operating site with a nice new

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 training center, like Summer has, you're not going to
2 go build another one. So but again, we try to learn
3 from each other as we're doing all of these things.
4 The builder's group has a site layout subgroup and an
5 operation subgroup and they try to make as common a
6 decision as they can on where people are going to put
7 their maintenance buildings and training facilities
8 and so forth.

9 Next slide. This is the one I am least
10 familiar with and these are some of the site specific
11 issues for Vogtle. Amy is from Southern Nuclear and
12 so she's the COLE for Vogtle. And Vogtle is a little
13 different in several aspects. Every site has its own
14 unique aspects to it. In the case of Vogtle, they're
15 in the middle of an ESP review, and so they'll
16 incorporate by reference not only the DCD but also
17 their ESP. They've also requested unlimited work
18 authorization as part of their ESP. So that
19 introduces a whole separate layer of complexity that
20 the rest of us don't enjoy.

21 They also have raw water that comes from
22 both the Savannah River and from groundwater. They
23 have a co-located combustion turbine plant that they
24 have to take into account as an external hazard. They
25 also have the soft soil sight. They and Levee County

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have a different set of seismic issues to deal with,
2 although we're trying to maintain the design
3 consistent so that it satisfies all of those sites.
4 And then obviously, all of us have our own switchyard
5 design, our own site specific emergency plans. The
6 organizational details will vary from one company to
7 the next and then obviously, as a consequence of the
8 site itself, the security plans will look different.

9 MEMBER SIEBER: I would advise for the
10 Vogtle site, to get the seismic portion of the
11 application in as early as you can.

12 MS. STERDIS: Yes, I'm going to speak on
13 behalf of Amy. I was here last week for their ACRS
14 subcommittee meeting representing Westinghouse as part
15 of their team, and we were very clear that what
16 they're doing is they're developing their site
17 specifics backdrop and then it's evaluated to show
18 that it's bounded by the generic spectra that we've
19 been working on so the design -- that is actually part
20 of their ESP. They're site specific and then the
21 comparison.

22 MEMBER SIEBER: So that's later this week.

23 MS. STERDIS: Yes, you're going to see it.

24 MEMBER SIEBER: Prepared.

25 MS. STERDIS: Yes, I think it's actually

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 tomorrow, yeah.

2 MEMBER SIEBER: Yes, it is.

3 MR. HASTINGS: That concludes our
4 presentation. We've very pleased to have been invited
5 to come here in support of Westinghouse. I'm sure
6 we'll have an opportunity to thank Westinghouse for
7 coming in support of one of our meetings in the
8 future, and we look forward to working with the
9 Committee, continue working with the staff. The one
10 thing we've found in the last couple of years is the
11 more we talk, the better it is for everybody. So we
12 encourage more of these meetings and look forward to
13 them. Any questions?

14 MEMBER SIEBER: We appreciate your coming
15 in and providing a good presentation to us.

16 MR. HASTINGS: Pleasure, and I want to re-
17 emphasize, it's not me, it's us. This is absolutely
18 a team and you will see that behavior continue going
19 forward.

20 MEMBER SIEBER: Good. You'll be here for
21 BWRs also?

22 MR. HASTINGS: We'll be out there, out
23 there watching.

24 MR. GRANT: Not unless Westinghouse
25 changes their design an awful lot.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Laughter)

2 (Off the record comments)

3 MEMBER SIEBER: I thought I heard somebody
4 say that and I'm scratching my head to figure out
5 which one of you on that screen up there would do
6 that.

7 MR. HASTINGS: That would be more than
8 just a departure.

9 MR. GRANT: I think that will be a
10 different set of people that will come and chat.

11 MEMBER SIEBER: Okay.

12 CHAIR BONACA: And I appreciate your
13 coming and telling us about all these things because
14 it gives us a sense of the path ahead, things we will
15 have to be involved with and I appreciate the
16 presentation for Westinghouse, that was very helpful.
17 I wish we had more time to spend on that but maybe
18 we'll have another opportunity in the future.

19 MS. STERDIS: I expect that, as I
20 indicated earlier, that we will be sending a letter in
21 this week for the staff to begin their acceptance
22 review of our amendment application on next week,
23 November 5th and I expect that I would come to a
24 conclusion in that acceptance review and the
25 development of the detailed schedule for the staff

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 review of the amendment application that we will be
2 setting up dates and times. We have found in our
3 AP600 and AP1000 experience that the more we come and
4 talk about the issues, because AP1000 is different,
5 because Part 52 is different and because we continue
6 to break new ground, more often is better, so that
7 we're all clear on where we're all headed together.

8 And I didn't know if you wanted to make
9 some closing --

10 MR. CUMMINS: Well, I think that we're
11 still available if you want to have questions.

12 MS. STERDIS: That was Ed's comments.

13 MR. CUMMINS: We appreciate the
14 opportunity to have come today and we're quite willing
15 to finish your schedule if you wanted to have some
16 more questions or want to do something in the
17 remaining time.

18 CHAIR BONACA: I refer to the members
19 whether or not they have any specific questions at
20 this time. I don't see any, so I think at this time,
21 it's fine. With that, if there are no further
22 comments or questions, yeah, please.

23 MS. STERDIS: No, we're good.

24 CHAIR BONACA: No? Okay, so if there are
25 no further questions or comments, then I will adjourn

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the meeting. Thank you for coming.

2 (Whereupon, at 1:29 p.m. the above-
3 entitled matter concluded.)

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

CERTIFICATE

This is to certify that the attached proceedings
before the United States Nuclear Regulatory Commission
in the matter of:

Name of Proceeding: Advisory Committee on
Reactor Safeguards

Docket Number: n/a

Location: Rockville, MD

were held as herein appears, and that this is the
original transcript thereof for the file of the United
States Nuclear Regulatory Commission taken by me and,
thereafter reduced to typewriting by me or under the
direction of the court reporting company, and that the
transcript is a true and accurate record of the
foregoing proceedings.



Charles Morrison
Official Reporter
Neal R. Gross & Co., Inc.

Bellefonte 3&4

Lee Nuclear 1&2

Summer 2&3

Vogtle 3&4

Harris 2&3

Levy 1&2




NuStart Energysm

AP1000 Design-Centered
Work Group
Presentation to ACRS

Peter Hastings
AP1000 DCWG Lead
October 31, 2007

NuStart Energy Development, LLC - All Rights Reserved



NuStart Energysm

AP1000

DCWG


Duke Energy[®]

SOUTHERN COMPANY

SCE&G[®]
A SCANA COMPANY

AP1000

 Westinghouse

 **Progress Energy**

TVA

Bellefonte 3&4

Lee Nuclear 1&2

Summer 2&3

Vogtle 3&4

Harris 2&3

Levy 1&2

Introduction

- **Design Centered Review Approach**
 - "One issue, one review, one position"
 - Maximum benefit achieved with higher degree of standardization
 - Site specific issues coordinated
- **AP1000 DCWG Members**
 - R-COLA – Tennessee Valley Authority, Bellefonte
 - S-COLAs
 - South Carolina Electric & Gas, Summer
 - Duke Energy, Lee Nuclear
 - Progress Energy, Shearon Harris & Levy County, FL
 - Southern Nuclear, Vogtle
- **DCWG Coordination**
 - With AP1000 applicants
 - With ESBWR DCWG
 - With NEI
 - With NRC Staff: prioritized pre-application discussion topics

COL Application

- **Cover Letter, Affidavits, etc. ("Part 0")**
- **Part 1 – General & Administrative Info**
- **Part 2 – Final Safety Analysis Report**
- **Part 3 – Environmental Report**
- **Part 4 – Technical Specifications**
- **Part 5 – Emergency Plan**
- **Part 6 – Limited Work Authorization Information**
- **Part 7 – Departures & Exemption Requests**
- **Part 8 – Safeguards Information**
- **Part 9 – Other Withheld Information**
- **Part 10 – License Conditions & ITAAC**
- **Part 11 – Other IBR Documents**

BLN COLA Highlights

- **Part 1 – General and Financial Information**
 - Addresses 52.77 requirement to include 50.33 information
 - Includes some proprietary information (moved to Part 9)

- **Part 2 – Final Safety Analysis Report**
 - Incorporates by reference the DC rule – section 1.1
 - Each FSAR section references appropriate DCD section(s)
 - Format and outline follow that of the DCD
 - More detail later

BLN COLA Highlights

- **Part 3 – Environmental Report**
 - Based on NUREG-1555

- **Part 4 – Technical Specifications**
 - IBR of DCD GTS (including Bases) – no departures/exemptions
 - COL item – Fill in brackets – most filled in
 - Some brackets remain – proposed License Condition in Part 10
 - Section A includes information on brackets
 - Section B includes a full set of PSTS and Bases

BLN COLA Highlights

- **Part 5 – Emergency Planning Information**
 - Site specific licensee Emergency Plan
 - Includes Certifications and Cross-references
 - State and local plans
 - Evacuation Time Estimate
 - EP ITAAC in Part 10

- **Part 6 – LWA (not requested for Bellefonte)**

BLN COLA Highlights

- **Part 7 – Departures and Exemptions**
 - Exemptions (2)
 - Fitness for duty program description per expected rule
 - COLA organization and numbering per guidance
 - Departures (3)
 - STD DEP 1.1-1
 - Administrative departure for organization and numbering for the FSAR sections
 - BLN DEP 9.2-1
 - Service Water System (SWS) blowdown flow path
 - BLN DEP 18.8-1
 - TSC & OSC relocations

BLN COLA Highlights

- **Part 8 – Safeguards Information (separate submittal)**
 - Security Plans
 - Not discussed in this public meeting

- **Part 9 – Withheld Information**
 - Proprietary, SUNSI (no personal identification information)
 - Some information from Part 1, Part 2, Part 3

BLN COLA Highlights

- **Part 10 – Proposed License Conditions with ITAAC**
 - Proposed License Conditions to:
 - Incorporate ITAAC into COL
 - Complete Holder items prior to initial fuel load
 - Implement Operational Programs by specific milestones in 13.4
 - Provide Fire Protection Program revision criteria
 - Provide Security Program revision criteria
 - Provide operational readiness schedule
 - Provide Vendor AE Constructor qualifications
 - Provide Startup Program revision criteria
 - Complete bracketed items in Tech Specs
 - Incorporate Environmental Protection Plan
 - Draft Environmental Protection Plan
 - ITAAC – Security, Plant Specific, Emergency Planning

BLN COLA Highlights

- **Part 11 – Incorporated by Reference Information**
 - Quality Assurance Program Description

FSAR


- COL applications based on incorporation by reference of DCD Rev 16 plus TR-134 (DCD errata and other minor changes)
- "IBR" = Incorporation By Reference
 - DCD Rev 16
 - TR-134
 - Various templates
- Standardization of COL Applications (FSAR)
 - "Entirely IBR" – DCD incorporation (no COL Info Items)
 - "Essentially IBR" – DCD incorporation, some additional information required to address COL Info Item(s)
 - "IBR plus" – DCD incorporation with significant amount of additional information
 - Does not necessarily reflect minor supplemental information

FSAR Standardization

Sect.	IBR	STD	PS
1.1	IBR	X	X
1.2	IBR		X
1.3	IBR		
1.4	IBR		X
1.5	IBR		
1.6	IBR	X	
1.7	IBR		X
1.8	IBR	X	X
1.9	IBR	X	X
1.10	new	X	X
1A	IBR	X	

Excerpted from AP1000 Standardization Matrix

- **Extent of standardization:**
 - ~80% by section
 - Most of FSAR Ch 2 is site specific
- **From AP1000 Standardization Matrix**
 - IBR: virtually all chapters/sections incorporate DCD
 - Standard or partially standard: 182 of 193 (includes "all IBR")
 - Plant-specific or partially plant-specific: 36 of 193
- **Limited DCD departures**



Left Margin Annotations (FSAR)

MARGIN NOTATION	DEFINITION AND USE
STD DEP X.Y.Z-#	FSAR information that departs from the generic DCD and is common for parallel applicants. Each Standard Departure is numbered separately at an appropriate level, e.g., STD DEP 9.2-1, or STD DEP 9.2.1-1
NPP DEP X.Y.Z-#	FSAR information that departs from the generic DCD and is plant specific. NPP is replaced with a plant specific identifier. Each Departure item is numbered separately at an appropriate subsection level, e.g., NPP DEP 9.2-2, or NPP DEP 9.2.1-2
STD COL X.Y-#	FSAR information that addresses a DCD Combined License Information item and is common to other COL applicants. Each COL item is numbered as identified in DCD Table 1.8-2 and FSAR Table 1.8-202, e.g., STD COL 4.4-1, or STD COL 19.59.10.5-1
NPP COL X.Y-#	FSAR information that addresses a DCD Combined License Information item and is plant specific. NPP is replaced with a plant specific identifier. Each COL item is numbered as identified in DCD Table 1.8-2 and FSAR Table 1.8-202, e.g., NPP COL 4.4-1, or NPP COL 19.59.10.5-1
NPP CDI or STD CDI	FSAR information that addresses DCD Conceptual Design Information (CDI). Replacement design information is generally plant specific; however, some may be common to other applicants. NPP is replaced with a plant specific identifier. STD is used if it is common. CDI information replacements are not numbered.
STD SUP X.Y-#	FSAR information that supplements the material in the DCD and is common to other COL applicants. Each SUP item is numbered separately at an appropriate subsection level, e.g., STD SUP 1.10-1, or STD SUP 9.5.1-1
NPP SUP X.Y-#	FSAR information that supplements the material in the DCD and is plant specific. NPP is replaced with a plant specific identifier. Each SUP item is numbered separately at an appropriate subsection level, e.g., NPP SUP 3.10-1, or NPP SUP 9.2.5-1
DCD	FSAR information that duplicates material in the DCD. Such information from the DCD is repeated in the FSAR only in instances determined necessary to provide contextual clarity.

Bellefonte 3&4

Lee Nuclear 1&2

Summer 2&3

Vogtle 3&4

Harris 2&3

Levy 1&2

Summary of COL Information Items

- **175 COL Information Items (DCD Rev 16 Table 1.8-2)**
- **48 closed in DCD Rev 16**
 - Includes seven deleted because of redundancy to ITAAC
- **18 COL Items transition to COL Holder Items (proposed license condition in Part 10)**
- **Remainder closed via COL application**
 - Includes three covered by operational program TRs

COL Holder Items (Examples)

3.7-3 Seismic Interaction Review

- *The seismic interaction review will be updated by the Combined License holder for as-built information. This review is performed in parallel with the seismic margin evaluation. The review is based on as-procured data, as well as the as-constructed condition. The as-built seismic interaction review is not provided with the COL application, but is completed prior to fuel load.*

5.3-4 Reactor Vessel Materials Verification

- *The Combined License holder will complete prior to fuel load verification of plant-specific belt line material properties consistent with the requirements in subsection 5.3.3.1 and Tables 5.3-1 and 5.3-3. The verification will include a pressurized thermal shock evaluation based on as procured reactor vessel material data and the projected neutron fluencies for the plant design objective of 60 years. This evaluation report will be submitted for NRC staff review.*



FSAR Chapter 1

Introduction and General Description

- ▣ Mostly IBR of DCD, IBR of Part 52 Appendix D, STD DEP 1.1-1
- ▣ Discussion of format, e.g., LMAs and numbering of Figures, Tables, & References
- ▣ Lists - acronyms, RG usage, SRP conformance, RG conformance
- ▣ Complete list of material incorporated by reference
- ▣ Summary of Departures as Table 1.8-201, e.g., STD DEP 1.1-1
- ▣ STD COL 1.9-1, 2*, 3* (RGs, BLs & GLs, and USI/GSIs)
- ▣ COL Item tabulation as Table 1.8-202
- ▣ New Section 1.10 on multi-unit site construction considerations

FSAR Chapter 2

Site Characteristics


- **Mostly site specific material, STD DEP 1.1-1**
- **Comparison of BLN Site Characteristics to DCD Site Parameters**
 - Combined listing of DCD Tier 1 Table 5.0-1 and Tier 2 Table 2-1
- **SUP material and COL items**

FSAR Chapter 3 Design of SSCs

- Mostly IBR of DCD
- Dual unit information (DCD is for single unit)
- Inservice testing program description
 - Snubbers
 - Valves (no pumps)
- SUP material and COL items

FSAR Chapter 4 Reactor

- Mostly IBR of DCD
- COL items



FSAR Chapter 5 Reactor Coolant System

- Mostly IBR of DCD
- Inservice inspection program (Class 1)
- SUP material and COL items



FSAR Chapter 6

Engineered Safety Features

- Mostly IBR of DCD
- Containment leak rate testing program
 - (per approved NuStart TR)
- Inservice inspection program (Class 2 & 3)
- SUP material and COL items

FSAR Chapter 7 Instrumentation and Controls

- All IBR of DCD

FSAR Chapter 8 Power Systems

- Mostly IBR of DCD
- Conceptual design information (CDI) replacement
- Switchyard and grid information
- SUP material and COL items



FSAR Chapter 9 Auxiliary Systems

- Mostly IBR of DCD; STD DEP 1.1-1
- BLN DEP 9.2-1 - service water cooling tower blowdown
- Full-text incorporation in 9.2.8 - Turbine building closed cooling water (CDI replacement)
- SUP material and COL items



FSAR Chapter 10

Steam and Power Conversion

- Mostly IBR of DCD
- Full-text incorporation for 10.4.5 – Circulating water (CDI replacement)
- Inservice inspection program (Class 2 & 3)
- SUP material and COL items

Bellefonte 3&4 Lee Nuclear 1&2 Summer 2&3 Vogtle 3&4 Harris 2&3 Levy 1&2

FSAR Chapter 11

Radioactive Waste Management

- **Mostly IBR of DCD**
- **Radiation and effluent monitoring program**
- **SUP material and COL items**

FSAR Chapter 12

Radiation Protection

- Mostly IBR of DCD
- 12.1 - ALARA
- 12.4 - Dose to construction workers
- 12.5 - Radiation protection program (Appendix 12AA)
- SUP material and COL items

FSAR Chapter 13

Conduct of Operations

- Mostly IBR of DCD; STD SUP 1.1-1
- 13.1 - Organization - generic terms
- 13.2 - Training
- EP (13.3) and SGI (13.6) are separate documents
- 13.4 - Operational Programs
- 13.5 - Procedures
- 13.7 - Fitness for duty (not in DCD)
- SUP material and COL items



FSAR Chapter 14 Initial Test Program

- Mostly IBR of DCD
- ITAAC criteria
- ITAAC screening
- SUP material and COL items

Bellefonte 3&4

Lee Nuclear 1&2

Summer 2&3

Vogtle 3&4

Harris 2&3

Levy 1&2

FSAR Chapter 15 Accident Analysis

- **Mostly IBR of DCD**
- **Tank failure analysis moved to Chapter 2**
- **SUP material and COL items**


FSAR Chapter 16

Technical Specifications

- **Mostly IBR of DCD**
- **16.1 – Plant specific TS in Part 4**
- **SUP material and COL items**

FSAR Chapter 17 Quality Assurance

- Mostly IBR of DCD; STD DEP 1.1-1
- Quality assurance program description (QAPD) in Part 11
- 17.5 & 17.6 not in DCD
- SUP material and COL items



FSAR Chapter 18

Human Factors Engineering

- **Mostly IBR of DCD**
- **BLN DEP 18.8-1 – Moved TSC & OSC**
- **SUP material and COL items**

FSAR Chapter 19 Engineered Safety Features

- Mostly IBR of DCD
- SUP material and COL items

DCWG Issues

- **Finality (certified design)**
- **Threshold for changes (level of detail)**
- **Configuration management for standard content**
- **NEI Level (COL Task Force)**
 - Evolving regulation and guidance
 - Construction inspection
 - Electronic submittal guidance
 - Templates (RP/ALARA, QAPD, Training)
- **Technical issues**
 - Operational programs
 - Seismic
 - DAC



NuStart Energysm

AP1000 Plant Specific Issues
Summary to ACRS

Amy Aughtman
Southern Nuclear, Vogtle 3&4 COL Lead
October 31, 2007

Plant Specific Issues

- Combination of site specific challenges
 - Sites with partially constructed plants
 - Sites with existing operating units
 - Greenfield site
- Site-specific issues, common approach where feasible
- High level of coordination within DCWG
- AP1000 Builders Group standardization efforts

Standardization of Site Specific Features

□ Benefits

- Supports COLA preparation and review
- Supports URD conformance
- Supports Design Finalization
- Supports AP1000 fleet standardization philosophy and goals of making the plant design as standard as possible
- Potential savings to utilities through efficiencies gained in design, procurement, construction and operation


Standardization of Site Specific Features

- Circulating Water pumps and pump intake structure
- Raw Water pumps and pump intake structure
- Training facilities
- Admin. Building
- Maintenance facilities
- Stand alone TSC
- Natural draft cooling tower and Mechanical draft cooling tower

Plant Specific Issues for Vogtle 3&4

■ Examples

- IBR ESP
- LWA requested
- Raw Water provided from combination of river water and groundwater
- Consideration of hazards from existing co-located combustion turbine plant
- Soil site
- Switchyard design
- Emergency Plan (Vogtle ESP)
 - Common Technical Support Center for four units
- Organization description
- Security Plan



NuStart Energysm


Duke Energy[®]

SOUTHERN COMPANY

SCE&G[®]
A SCANA COMPANY

AP 1000

 **Westinghouse**

 **Progress Energy**

TVA

Bellefonte 3&4


Lee Nuclear 1&2

Summer 2&3

Vogtle 3&4

Harris 2&3

Levy 1&2



U.S.NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

Amendment Process for certified designs

Jerry N. Wilson, PE
Division of New Reactor Licensing
Office of New Reactors

§ 52.63 Finality of standard design certifications

(a)(1) Amendment via rulemaking:


- (i) Compliance exception
- (ii) Adequate Protection Back-fit
- (iii) Reduce unnecessary regulatory burden
- (iv) Complete design acceptance criteria
- (v) Correct material errors
- (vi) Substantial Increase Back-fit
- (vii) Contributes to increased standardization

(a)(2) Cost/benefit consideration for plants licensed or under review

(a)(3) Any modification the NRC imposes on a design certification rule under paragraph (a)(1) of this section will be applied to all plants referencing the certified design, . . .

AP1000 Presentation to the ACRS

October 31, 2007



AP1000



Opening Remarks

Ed Cummins, Vice President
Regulatory Affairs and Standardization

AP1000

Introduction

Andrea Sterdis, Manager
AP1000 Licensing and Customer
Interface

October 31, 2007

AP1000

Agenda

AP1000

- 8:15 Design Certification Overview Andrea Sterdis
- 8:45 Technology Overview Jim Winters
- 9:10 Passive Safety Systems Terry Schulz
- 9:40 Defense-In-Depth Terry Schulz
- 9:55 I&C Andrea Sterdis
- 10:15-10:30 BREAK
- 10:30 Structures Jim Winters
 - Secondary Systems
 - Electrical Systems
 - Fire Protection

Agenda (continued)

AP1000

- 11:15 Design Certification Amendment
Process Jerry Wilson
- 11:30-12:15 LUNCH
- 12:15 DCWG and R-COLA Issues Peter Hastings
- 1:45 Subsequent COLA Amy Aughtman
- 2:15 Wrap-up

Design Certification Overview

Andrea Sterdis


October 31, 2007

AP1000

AP1000 Design Certification Application **AP1000**

- Submitted DCD and PRA March 28, 2002
 - AP1000 Design Control Document (DCD) – 7000 pages
 - Tier 1 Information
 - Inspections, Tests, Analysis and Acceptance Criteria (ITAAC)
 - Tier 2 - Information
 - Standard Safety Analysis Report
 - Technical Specifications
 - PRA Insights
 - AP1000 PRA Report submitted – 4500 pages
 - Detailed Level 1, 2, 3 including shutdown, fires, floods
 - Addresses severe accident phenomenon

Design Certification Rulemaking



The United States
Nuclear Regulatory Commission

hereby certifies the

AP1000 Standard Plant Design

as set forth in Appendix D of 10 CFR Part 52
Dated the 23rd day of January 2006.

Podger
Director
Office of Nuclear Reactor Regulation


Luigi
Chairman
U.S. Nuclear Regulatory Commission

Design Certification Approved December 30, 2005

Design Certification


AP1000

- Provides Licensing Finality for Design
- Establishes Regulatory Bases
- Identifies COL Information Items



COLA Content Defined by DC Rule

AP1000



175 COL
Information
Items

DC
Amendment

R-COLA

S-COLA


Technical Report Generation

AP1000

- Standard Design COL Information Items
- Design ITAAC areas
 - Piping
 - I&C (PMS Design)
 - Main Control Room/Human Factors Engineering
- Limited number of design changes
 - Design Finalization
 - Customer Input—Standard Plant

Technical Report Submittals

AP1000 TRs Submitted to NRC (excluding Revisions)



Technical Report Subjects

AP1000

- 63 to address COL Information Items
- 47 to justify design changes that impact DCD content
- 2 to address standardization for COLA content
- TR 135 provides SAMDA confirmation for design certification amendment
- TR 134 provides DCD Post-Revision 16 impacts to support COLA standardization

NRC Status of TR Reviews

AP1000

- Approximately 500 RAIs received
 - Varying levels of safety/regulatory significance
 - 460 responses provided
 - Less than 40 still outstanding
 - Approximately 120 resulting in TR revisions
 - Approximately 60 resulting in DCD revisions

Design Certification Amendment

AP1000

- Application submitted May 29, 2007 (DCD Revision 16)
- 10 CFR 52 Revision Effective September 27, 2007
- Transition from Technical Report Review to Integrated DCD Revision Review
- Acceptance Review Issues
 - Technical
 - Process
- Acceptance Review to Begin November 5, 2007

Design Certification Amendment

AP1000

- Extension of seismic spectra to soil conditions
- Revision of buildings for enhanced protection
- Update of fuel design approach
- Protection system I&C update
- Update of electrical system
- Progress on HFE
- Turbine manufacturer change

Post-Revision 16 Configuration Control

AP1000


- AP1000 COL Applications Reference DCD Revision 16 + Post-Revision 16 Changes
 - Editorial/Consistency Impacts
 - Subsequent RAIs and Technical Report Impacts
 - COLA Standardization Impacts
- TR 134 Identifies Post-Revision 16 Changes

**Result is COLA Standardization
Minimal Departures**

AP1000 DCWG Teamwork

AP1000

- Licensing Issues
- Design Certification Amendment
- R-COLA
- S-COLA



Result is Licensing Standardization

AP1000 Overview

Jim Winters

412-374-5290

winterjw@westinghouse.com



AP1000

AP1000 is Different

AP1000 is Different

AP1000

- Plant
 - Entire plant
 - Passive design
- Philosophy
 - One design
 - No changes

The Plant

AP1000

- Our Design Certification includes:


- Containment
- Auxiliary Building
- Annex Building
- Turbine Building
- Radwaste Building
- Diesel Generator Building
- Everything in buildings
- Associated yard structures

- It is based upon:

- Passive Design
- Passive Core Cooling
- Passive Control Room Habitability
- Passive Containment Cooling
- Passive Seismic Fire Protection
- Passive Security Features

Entire Plant


AP1000



Reactor Coolant System


AP1000

- **Reactor Vessel**
 - W 3XL Vessel
 - No bottom-mounted instrumentation
 - Improved materials - 60 yr life
- **Δ125 Steam Generators**
 - ANO RSG
- **Reactor Coolant Pump**
 - Canned motor pumps
 - AP600, early commercial reactors
- **Simplified Main Loop**
 - Same as AP600
 - Reduced welds / supports




AP1000 Passive Core Cooling System

AP1000




Passive Containment Cooling System **AP1000**




Simplification of Safety Systems Dramatically Reduces Building Volumes

AP1000

Standard PWR




AP1000



AP1000 Smaller and Dramatically Simpler than Evolutionary Plants

AP1000




The Philosophy

AP1000

- One Design (Class Mentality)
 - One Design Certification
 - 24 potential plants today (12 in the U.S.)
 - Buyers Group in the U.S.
 - Single, active, multi-COLA Design Centered Working Group
 - Design meets URD

Regulatory Process

AP1000




*** Public Comment Opportunity**

AP1000 Design Certification

AP1000

- Goal of AP1000 Design Certification was to achieve maximum licensing basis closure for design aspects
- Scope not limited to NSSS
- Outside “boundary” is site specific and non-safety




The Philosophy (cont.)

AP1000

- “No” changes
 - Design must be safe and correct
 - Design Certification is for entire plant
 - Each difference from Design Certification must be identified in each COL (added NRC and public review)
 - Additions and additional details are not changes
 - We have a graded approach to design change “burden”

AP1000 3D Model

AP1000



AP1000 Passive Systems

Terry Schulz

AP1000 Approach to Safety

AP1000

- **Passive Safety-Related Systems**

- Use “passive” process only, no active pumps, diesels,
 - One time alignment of valves
 - No support systems required after actuation
 - No AC power, cooling water, HVAC, I&C
- Greatly reduced dependency on operator actions
- Mitigate design basis accidents without nonsafety systems
- Meet NRC PRA safety goals without use of nonsafety systems


- **Active Nonsafety-Related Systems**

- Reliably support normal operation
 - Redundant equipment powered by onsite diesels
- Minimize challenges to passive safety systems
- Not required to mitigate design basis accidents

AP1000 Passive Core Cooling System


AP1000

- PRHR HX
 - Natural circ. heat removal
 - Replaces AFWS pumps
- Passive Safety Injection
 - Core Makeup Tanks
 - Full RCS pres, natural circ. inject
 - Replaces HHSI pumps
 - Accumulators
 - Similar to current plants
 - IRWST Injection
 - Low pres (replaces LHSI pumps)
 - Containment Recirculation
 - Gravity recirc. (replaces pumped recirc)
 - Automatic RCS Depressurization
 - Staged, controlled depressurization
 - Stages 1-3 to IRWST, stage 4 to Containment




PXS Equipment Layout

AP1000



Passive Safety Injection Operation During a LOCA




AP1000



PXS Provides Improved Margin DVI LOCA Case (Limiting)




- PXS Provides Effective Core Cooling
 - CMTs, Accum and IRWST provide injection
 - 1/2 CMT, Accum, IRWST line spill to contain.
 - ADS effectively reduces the RCS pressure
 - Core remains covered with significant margin



Passive Containment Cooling System


AP1000




- PCS Water Storage Tank
 - Provides 72 hr drain
 - Afterwards use on/offsite water
 - Air only cooling prevents failure
 - Flow decreases with time
 - 4 standpipes control flow
- PCS Flow Rates
 - High initial flow
 - Rapidly forms water film
 - Effectively reduces cont pressure
 - Later flows match decay heat
- 3 Redundant Drain Paths
 - 2 AOV, 1 MOV
 - Improves PRA reliability
- DCD Rev 16, Increase Wet Bulb Temp
 - Needed for Florida
 - No impact on containment pressure

Passive Containment Cooling Operation During a LOCA

AP1000



PCS Equipment Layout



PCS Provides Effective Cooling LB LOCA and Steam Line Breaks




- **AP1000 Containment**

Provides Increased Margins


	AP600	AP1000
– LB LOCA	1.6	3.6
– MSLB	0.9	1.7

(Design - Peak pres (psi))

AP1000 DECL LOCA Containment Pressure



Main Steam Line Break Pressure



- **Main Steam Line Break is Limiting**

- Not sensitive to passive containment cooling performance

AP1000 Increases Safety Margins

AP1000

	Typical Plant	AP1000
• Loss Flow Margin to DNBR Limit	~ 10-14%	~15%
• Feedline Break (°F) Subcooling Margin	>0°F	~140°F
• SG Tube Rupture	Operator actions required in 10 min	Operator actions NOT required
• Small LOCA	3" LOCA core uncovers PCT <1500°F	< 8" LOCA NO core uncovery
• Large LOCA PCT (°F) with uncertainty	1700 - 2200°F	2124°F (1)
• ATWS, Pres (psig) (% core life)	3200 psig 90%	2800 psig 100%

Note (1) ASTRUM analysis shows AP1000 Large LOCA PCT is actually < 1600°F


AP1000 Addresses Contain. Recirculation Debris Issue

AP1000

- No Fibrous Debris Generated by LOCA
 - Most operating plants use fiberglass insulation; significant fiber generated
 - In AP1000 all insulation in LOCA jet zone is RMI; no fiber generated
- Enhanced Debris Settling
 - Deep floodup levels with low flows / velocities
 - Long delays before initiation of recirculation
- Protective Plates Above Screens
 - Prevents particles (coating debris, etc) from being transported to screens
- Large Screens Provided
 - Increased in DCD Rev 16; 280 ft² to 5000 ft²
- Coatings Inside Containment
 - Non-safety related - if detached, will settle before reaching screens
 - Reduced use of coatings inside containment (stairs, cabinets, etc)

Severe Accidents Addressed

AP1000



- Core-Concrete Interaction
 - Ex-vessel cooling retains damaged core
 - Tests and analysis of IVR reviewed by U.S. NRC
 - Prevents core-concrete interaction
- High Pressure Core Melt
 - Eliminated by redundant, diverse ADS
- Hydrogen Detonation
 - Prevented by redundant igniters and plant layout features
- Steam Explosions
 - Prevented by IVR
- DCD Rev 16 resolved COL item includes changes to RV insulation design



AP1000 Defense in Depth

Terry Schulz


AP1000 Active Nonsafety Features

AP1000

- **Active Nonsafety Functions**
 - Reliably support normal operation
 - Minimize challenge to passive safety systems
 - Not required to mitigate design basis accidents
 - Not required to meet NRC safety goals
- **Active Nonsafety Design Features**
 - Simplified designs (fewer components, separation not required)
 - Redundancy for more probable failures
 - Automatic actuation with power from onsite diesels
- **Active Nonsafety Equipment Design**
 - Reliable, experienced based, industrial grade equipment
 - Non-ASME, non-seismic, limited fire / flood / wind protection
 - Availability controlled by procedures, no shutdown requirements
 - Reliability controlled by maintenance program


AP1000 Startup Feedwater System

AP1000




AP1000 Normal RHR System

AP1000



AP1000 Spent Fuel Cooling

AP1000



Safety Spent Fuel Cooling Provided by Water Heatup, Boiloff

AP1000

Event	Time to Saturation(1) (hours)	Height of Water Above Fuel at 72 Hours(4) (feet)	Height of Water Above Fuel at 7 Days(4) (feet)
Seismic Event(2) – Power Operation Immediately Following a Refueling(7)	6.5	1.6	1.6
Seismic Event(8) – Refueling, Immediately Following Spent Fuel Region Offload(3)(7)	4.68	8.3	8.3
Seismic Event(8) – Refueling, Emergency Full Core Off-Load(3) Immediately Following Refueling(7)	1.37	8.3	8.3

- In DCD Rev 16, the spent fuel pool capacity has increased from 619 to 889 fuel assemblies.


Notes:

1. Times calculated neglect heat losses to the passive heat sinks in the fuel area of the auxiliary building.
2. Seismic event assumes water in the pool is initially drained to the level of the spent fuel pool cooling system connection simultaneous with a station blackout. Fuel cooling water sources are spent fuel pool, fuel transfer canal (including gate), and cask washdown pit for 72 hours. Between 72 hours and 7 days fuel cooling water provided from passive containment cooling system ancillary water storage tank.
3. Fuel movement complete, 150 hours after shutdown.
4. See subsection 9.1.3.5 for minimum water level.
5. Alignment of PCS water storage for supply of makeup water permits maintaining pool level at this elevation. Decay heat in reactor vessel is less than 9 MW, thus no PCS water is required for containment cooling.
6. Alignment of the PCS ancillary water storage tank and initiation of PCS recirculation pumps provide a makeup water supply to maintain this pool level or higher above the top of the fuel.
7. Seismic event assumes water in the pool is initially drained to the level of the spent fuel pool cooling system connection simultaneous with a station blackout. Fuel cooling water sources are spent fuel pool, fuel transfer canal (including gate), cask washdown pit, and passive containment cooling system water storage tank for 72 hours. Between 72 hours and 7 days fuel cooling water provided from passive containment cooling system water storage tank and passive containment cooling system ancillary water storage tank. The number of fuel assemblies refueled has been conservatively established to include the worst case between an 18-month fuel cycle plus 5 defective fuel assemblies (69 total assemblies or 44% of the core) and a 24-month fuel cycle plus 5 defective fuel assemblies (77 total assemblies or 49% of the core).
8. Seismic event assumes water in the pool is initially drained to the level of the spent fuel pool cooling system connection simultaneous with a station blackout. Fuel cooling water sources are spent fuel pool, fuel transfer canal (including gate), cask washdown pit, and passive containment cooling system water storage tank for 7 days.

SFP Cooling Assuming Complete Pool Drain, Incorporated in DCD Rev 16

AP1000

- Beyond design basis event B5B
 - Pool assumed to completely drain
- Event assumed to occur just when full core is placed in SFP
- Provide redundant sprays with diverse water supplies
 - FPS and PCS used for water
- Provide sufficient spray to keep below zirconium ignition temperature






AP1000 Provides More Levels of Defense

AP1000

- First Level is Usually Nonsafety Active Features
 - Automatically actuated before passive features
 - High quality industrial grade equipment
- Another Level is Safety Passive Features
 - Provides safety case for licensing
 - Highest quality nuclear grade equipment
- Other Passive Features Provide Additional Levels
 - Example; passive feed/bleed backs up PRHR HX
- Available for All Shutdown and At-Power Conditions
 - More likely events have more levels of defense

Loss of Offsite Power Levels of Defense

AP1000



AP1000 Importance of Non-Safety Systems

AP1000

- Determined Safety Importance of Non-Safety Systems
 - Part of the resolution of Regulatory Treatment of Non-Safety Systems (RTNSS) Policy Issue
 - Included PRA sensitivity studies / evaluations
 - Initiating event frequency evaluations
 - Mitigation importance evaluations, calc CMF/LRF without NNS
 - CDF and LRF less than NRC safety goals
 - Also included deterministic evaluations
 - ATWS rule, long term shutdown (> 72 hr), seismic
 - DCD contains availability controls for selected NSS features
 - Similar to Tech Spec, but without plant shutdown requirements

Importance on Nonsafety Systems

AP1000

	Base AP1000	w/o NNS Systems (1)	NRC Safety Goal
Core Damage Frequency			
Internal Events at Power	2.40E-07	2.10E-06	
Internal Events at Shutdown	1.20E-07	9.70E-07	
Total	3.60E-07	3.07E-06	1.0E-04 /yr
Large Activity Release Frequency			
Internal Events at Power	1.90E-08	4.30E-07	
Internal Events at Shutdown	2.00E-08	3.80E-07	
Total	3.90E-08	8.10E-07	1.0E-06 /yr

Notes:

- (1) Sensitivity study with same IE frequencies but no mitigation credit for nonsafety systems (CVS, SFW, RNS, onsite / offsite AC power, DAS).

AP1000 Instrumentation & Control

Andrea Sterdis

- **I&C systems are included in the Certified Design**
 - Functional requirements
 - The design process
 - Test and acceptance criteria
 - A conceptual design

A detailed I&C design is being developed based on the functional requirements, using the certified design process, and meeting the certified acceptance requirements.

- Control System
 - Plant wide non-1E system for all normal displays & controls
 - Microprocessor / software based, multiplexed communications
- Safety System
 - Plant wide 1E system for all safety displays & controls
 - Microprocessor / software based, multiplexed communications
- Diverse System
 - Limited scope non-1E system, PRA based displays & controls
 - Backs up Safety I&C where common mode failure a risk
 - Different microprocessor & software than Safety I&C
 - No multiplexing

- **Protection and Safety Monitoring System (PMS)**

- RT, ESF, NI, QDPS, and component control (Westinghouse Common Q)

- **Diverse Actuation System (DAS)**

- Backs up PMS (Platform/Vendor Selection in Progress)
- Different architecture, hardware & software from PMS

- **Plant Control System (PLS)**

- BOP, NSSS, rod control, rod position indication (Emerson Ovation)


- **Data Display and Processing System (DDS)**

- Non-Class 1E displays, alarms, analysis, logging, archiving (Emerson Ovation)

Non-Class 1E communication network

Architecture

AP1000




Human Factors Engineering

AP1000

- Compact Control Room
 - Designed for 1 Reactor Operator and 1 Supervisor
- Displays
 - Plant status / overview via wall panel (non 1E)
 - Detail display via workstation video displays (non 1E)
 - Small number dedicated displays; safety (1E) & diverse (non 1E)
- Controls
 - Soft controls (non 1E) for normal operation
 - Small number dedicated switches; safety (1E) & diverse (non 1E)
- Advanced Alarm Management
- Computerized Procedures

AP1000 Compact Control Room

AP1000



AP1000 Structures

Jim Winters

412-374-5290

winterjw@westinghouse.com



AP1000 Structures

AP1000

- All safety related and seismically qualified equipment is on a single basemat for Auxiliary and Shield Buildings
- Current Design Certification is for conditions consistent with a rock site
- Current Design Certification is for external hazards as required by current regulations


AP1000 Structures Changes

AP1000

- Pressurizer changed to allow valves to meet seismic accelerations
- Seismic input envelop changed to encompass soil sites
- Seismic analysis redone to reflect new seismic input (no design changes)
- Shield building changed to reflect new external hazards concerns
- NRC staff is currently reviewing our submittals

Shield Building Enhancements

AP1000



Shield Building Roof Enhancements

AP1000


PCCS Storage Tank

(Remains unmodified)

Shield Building Roof Design Enhancements

Cylindrical Wall Design Enhancements

Air Inlet Design Enhancements



AP1000 Secondary Systems

Jim Winters

412-374-5290

winterjw@westinghouse.com

AP1000 Secondary Systems

AP1000

- AP1000 secondary systems are non safety related
- Current Design Certification is based upon an MHI turbine
- Change is to a Toshiba turbine with attendant information changes to Chapter 10
- Items with potential impact on safety were investigated and found acceptable:
 - post trip behavior
 - overspeed trip initiator
 - blade attachments

AP1000 Electrical Systems

Jim Winters

412-374-5290

winterjw@westinghouse.com

AP1000 Electrical Systems

AP1000

- AP1000 has only 3 electrical systems
 - 1E DC
 - Non-1E DC
 - Non-1E AC
- Only changes were to incorporate Operating Experience to increase unit availability
 - Add a Reserve Auxiliary Transformer
 - Add Fast Bus Transfer

AP1000 Fire Protection

Jim Winters

412-374-5290

winterjw@westinghouse.com


AP1000 Fire Protection

AP1000

- Same as Certified AP1000 design
 - Division separation designed in
 - Firewalls outside containment
 - Separation inside containment
- No changes
- Adequate protection from externally induced fires

AP1000 Presentation to the ACRS

October 31, 2007



AP1000

