



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381-2000

William J. Museler
Site Vice President, Watts Bar Nuclear Plant

OCT 20 1993

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of the Application of) Docket Nos. 50-390
Tennessee Valley Authority) 50-391

WATTS BAR NUCLEAR PLANT (WBN) - RESPONSE TO NRC REQUEST FOR TVA TO INSPECT THE REACTOR VESSEL HEAD PRESSURE HOUSING WELDS

The staff requested TVA perform liquid penetrant inspections on a sample of control rod drive mechanism (CRDM) pressure housing to reactor head welds on one of the WBN reactor heads. This testing is the result of cracking problems identified with the pressure housings (adaptor tube) to the reactor closure head at the French national utility Ringhals 2 plant. TVA selected eight CRDM housings on the WBN Unit 2 reactor head to inspect. The eight housings are identified on the attached sketch with an "H." Both reactor vessels at WBN are a Westinghouse design, similar to that of the French Ringhals 2 plant. The Unit 2 head was selected because of ease of entry and to prevent interference with Unit 1 activities.

The inspection method employed by TVA was a solvent removal penetrant performed in accordance with the examination procedure and acceptance requirements of American Society of Mechanical Engineers (ASME) Section III. Seven of the eight welds inspected were found to be acceptable. The rejected weld exhibited two linear indications, approximately 1/8 inch long and 5/64 inch long separated by about 5/8 inch. The indications were very faint and appeared to be the result of a lack of fusion between weld passes. There was also evidence of grinding at the location of the indications which gave the appearance that the vendor had previously identified the indications, but failed to completely remove them. These could have been the result of the vendor using a water washable penetrant that may not be as sensitive as solvent removal penetrant. There was no evidence of cracking in any of the samples selected.

290049

9310290206 931020
PDR ADDCK 05000390
Q PDR



DO30

U.S. Nuclear Regulatory Commission
Page 2

OCT 20 1993

TVA removed the indications by grinding to a maximum of 1/16 inch and re-examining the area. All of the work was done to ASME Section III requirements, with Authorized Nuclear Inspector (ANI) involvement, and Westinghouse concurrence. A copy of the liquid penetrant examination and visual inspection records are attached.

Based on the results no further examinations of the CRDM pressure housing to reactor head welds are planned at WBN.

If you should have any questions, contact P. L. Pace at (615)-365-1824.

Very truly yours,



William J. Museler


cc (Enclosures):

NRC Resident Inspector
Watts Bar Nuclear Plant
Rt. 2, P.O. Box 700
Spring City, Tennessee 37381

Mr. P. S. Tam, Senior Project Manager
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

R.V. HEAD PENETRATIONS - WAT (UNIT 2)




TVA NUCLEAR POWER RECORD OF LIQUID PENETRANT EXAMINATION

DATE OF EXAMINATION: 8-12-93 REPORT NO.: WBN-TVA-1093-01101
 PROCEDURE NO.: N-PT-9 REVISION NO.: L TC NO.: 9.3-16
 ASME SECTION ~~III~~ SECTION VIII X ANSI B31.1 AL ACCEPTANCE CRITERIA
 ASME SECTION ~~III~~ 8-12-93 SECTION XI NR 8-12-93 ANSI B31.1 NR 8-12-93 APP.A X APP.B NR 8-12-93
 CODE CLASS/CATEGORY A
 ORIGINAL EXAMINATION X RE-EXAMINATION NR 8-12-93
 WELD JOINT NO.: 2-HEAD-068-0001-J1, R9, J11, G15, A7, G5, E9, & L7
 ITEM OR SYSTEM DESCRIPTION CRDM HOUSINGS to the Closure Head
 REFERENCE DRAWING NO.: DRAWING USED TO LOCATE WELDS ATTACHED TO WORK INSTRUCTIONS

PART TEMPERATURE: 94 °F SURFACE THERMOMETER NO.: E18805 DUE 12/23/93

PENETRANT MATERIALS

BRAND NAME: MAGNAFLUX SPOT CHECK NR 8-12-93
 SHERWIN DUBL CHECK X
 OTHER NR 8-12-93



INSPECTION MATERIAL	TYPE	LOT OR BATCH NO.
PENETRANT	DP-40	211-F1
REMOVER	DR-60	224-F4
DEVELOPER	D-100	216-G6

RESULTS OF EXAMINATION: SATISFACTORY 7 SAT UNSAT. 1-UNSAT NOI NO.: NR 8-12-93

EXPLANATION OF UNSATISFACTORY RESULTS: 2-HEAD-068-0001-J1 WAS FOUND TO HAVE 2 LINEAR INDICATIONS
① 1.06" LONG 1/8" IN LENGTH AND ② 1.25" WITH A LENGTH OF 5/16", THESE TWO INDICATIONS ARE APPROX 5/8" APART
WELD WIDTH IS APPROXIMATELY 1/2" WITH INDICATIONS CENTERED.

REMARKS: INDICATIONS EVALUATED PER PS. 3. M. 1.1 REVS AS REQUIRED BY WORK INSTRUCTIONS
REFER TO E. LOOPE NE ON 8-12-93 TO EVALUATE INDICATIONS NR 8-12-93

EXAMINED BY: Wayne A. Connell LEVEL: II
 EVALUATED BY: Wayne A. Connell LEVEL: II
 REVIEWED BY: John A. Mizgall LEVEL: II DATE: 8-12-93
 ANII REVIEW BY: NONE DATE: NONE

ATTACHMENT 1
Page 1 of 1

TVA NUCLEAR POWER
RECORD OF LIQUID PENETRANT EXAMINATION

DATE OF EXAMINATION: 9-16-93 REPORT NO.: WBNTVAW93-01273
 PROCEDURE NO.: NPT-9 REVISION NO.: 6 TC NO.: 9346
 ASME SECTION I _____ SECTION VIII X AM-9-16-13 ANIR 831.1 _____ ACCEPTANCE CRITERIA
 ASME SECTION III ✓ SECTION XI _____ ANIR 831.7 _____ APP. A ✓ APP. B _____
 CODE CLASS/CATEGORY: 1
 ORIGINAL EXAMINATION _____ RE-EXAMINATION ✓
 WELD JOINT NO.: 2-HEAD-068-0001-J1
 ITEM OR SYSTEM DESCRIPTION: CRDM Housing to the Closure Head
 REFERENCE DRAWING NO.: W 6865492 sht 3 of 7 Rev. 11

PART TEMPERATURE: 94 °F SURFACE THERMOMETER NO.: E18463 due 12-23-93

PENETRANT MATERIALS

BRAND NAME: MAGNAFLUX SPOT CHECK _____
 SHERWIN DUBL CHECK ✓
 OTHER _____

INSPECTION MATERIAL	TYPE	LOT OR BATCH NO.
PENETRANT	DP40	211 F1
REMOVER	DR60	224 F4
DEVELOPER	D-100	030-e6

RESULTS OF EXAMINATION: SATISFACTORY ✓ UNSAT. _____ NOI NO.: _____
 EXPLANATION OF UNSATISFACTORY RESULTS: None

REMARKS: This inspection is a re-inspection of indications recorded on Inspection Report WBN-VA-W93-0101. The indications were removed by disk sand. RE-Exam was acceptable, no indications present in area shown on original report which was the only area re-examined. James 9-16-93

EXAMINED BY: John Amize LEVEL: 2T
 EVALUATED BY: John Amize LEVEL: 2T
 REVIEWED BY: Will Ezell LEVEL: II PREVIOUS DATE: 9/16/93
 ANR REVIEW BY: B. Earmuff DATE: 9/16/93

APPENDIX A

QA1-10.01
Revision 5
Page 1 of 3

QUALITY CONTROL INSPECTION RECORD

Inspection Record Number WBN-TVA-W93-01273
 Work Document IR 068HZ
 System OGS Unit 2
 Safety-Related Yes No
 Organization/Foreman MUDS / D. Mathis

Description PT NVT on Reactor Head
weld CRDM leading to the closure head.
 Procedure NPT-9 / NVT-3 Revision 6 TC 93/6 / 6
 Partial Inspection Yes No (See Remarks)

ITEM	MATERIAL/EQUIPMENT NUMBER	DRAWING REVISION	M&TE NUMBER	CALIBRATION DUE DATE	READING	S/U
1	2-HEAD-068-0001-J1	W686 J492 slt 3 of 7 R11	E18463	12-23-93	94°F	5
2	2-HEAD-068-0001-J1	W686 J492 slt 3 of 7 R11				

ATTRIBUTE CODE	NOMENCLATURE	INITIAL INSPECTION SAT ITEM	INSPECTION UNSAT ITEM	INSPECTOR'S INIT/LEVEL/DATE	C/A TAKEN	C/A TAKEN BY SIGNATURE/DATE	CORRECTIVE ACTION VERIFICATION SAT ITEM	INSPECTION UNSAT ITEM	INSPECTOR'S INIT/LEVEL/DATE
<i>See attached page 2 of 3</i>									

C/A Taken: W-Rework; P-Replace; T-Return; Delete; D-Documentation; Delete; N-Instruction Change; F-Design Change; X-SCAR/PER

<input checked="" type="checkbox"/> A	Current Craft Workmanship	Probable Cause:
<input type="checkbox"/> B	Existing (Old) Workmanship	
<input type="checkbox"/> C	Design Engineering Output Error (DCNs)	
<input type="checkbox"/> D	Workplan or Maintenance Request Error	
<input type="checkbox"/> E	Material Defects	Acknowledged By: Foreman

REMARKS: This inspection is a re-exam of weld 2-HEAD-068-0001-J1. The original exam recorded on the inspection report WBN-TVA-W9301101 was unacceptable due to 2 large indications see original report for locations. Craft removed the indications by sawing. Visual exam & P.T. exam was acceptable. Craft removed the maximum weld metal in area of indications. Engineering to determine maximum Partial Inspection Point-of-Departure weld metal removed. James 9-16-93

Item 1 above is NPT-9 inspection & Item 2 is NVT-3 inspection see attached page 2 of 3 for attached inspection

NOTE: NA'd blanks on this inspection record have been evaluated by the inspector and have been determined not applicable to this inspection.

QC Inspector/Date J.P. Armiger / 9-16-93 Level III Duration Time 1.0 Trainee Nine

Reviewed By/Date _____ / _____ Level _____

APPENDIX U
Page 1 of 1

SURFACE EVALUATION SHEET

Weld Removal []
ARC Strike Removal []
Base Metal Indication Removal [✓]

I.D. # 1568
Weld # Removed NONE
Weld Map VENDOR - NONE
WMCR(s) N/A

Component 2-HEAD-068-0001 ①
Diam N/A Thick N/A
Manufacturer's Min. Wall N/A ②
Design Min. Wall _____ per _____
CAQR#/Memo#/NE Engr. & Contact Date _____

Location

SEE PT REPORT NUMBER
WBN-TVA-W93-01101
IN PACKAGE.

Material Spec & Grade _____

Final Size (L/W/D) _____
TVA Class A ASME Class 1
WID PRO62HZ

① CRDM HOUSINGS TO CLOSURE HEAD PER
C181077

ED WOPE	NE	8/31/93
RE NAME	REU	DATE

Inspection Hold Points	Procedure Reference	Hold Points			
		Required	Released		
Preliminary Thickness Check		WE	ANI	WI	ANI
E VT	N-VT-3	X			
V PT/MT	N-PT-9	X	ANI	9-16-93	9/16/93
A ACID ETCH	NONE				
U Thickness Check	N-VT-3 ②	X			
A					
T					
I					
O					
N					

Comments/Instructions
 ② THE DEPTH REMOVAL MUST BE DOCUMENTED FOR NIE EVALUATION WHEN MEASURABLE.
 NOTE: FOR WATHE CORRUPTION STVAC SHALL PERFORM INSPECTIONS. CRAFT SHALL REMOVE THE LEAST AMOUNT OF MAT'L POSSIBLE. NOTE: PERSONNEL REQUIRED TO WITNESS THIS WORK - FOLLOW NE'S INSTRUCTIONS. PRELIMINARY PT IS FOR INFO ONLY.
 ③ ANI WIT.PNT ONLY ON CRDM # J-1. ←
 Depth of Removal less 1/16" maximum
 ④ Part no WBN-TVA-W93-01273 (AMT) 9-16-93
 Ref. Documents for Defect Correction
 CAQR # _____
 WELD # _____

WE [Signature] Date 8/31/93
Preparation
WE [Signature] Date 8/31/93
Review

ANI [Signature] Date 9/14/93
Review

FINAL ACCEPTANCE REVIEW

WE [Signature] Date 9/20/93
REASON: _____

ANI [Signature] Date 9/23/93

DCRM TO FILE WITH WID _____
Retention: Lifetime
Form SSP-7.50-13, Rev. 2

Responsibility: DCRM