



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381

OCT 21 1994

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of the Application of)
Tennessee Valley Authority)

Docket No. 50-390

WATTS BAR NUCLEAR PLANT (WBN) - UNIT 1 - REACTOR CONTAINMENT BUILDING
INTEGRATED LEAK RATE TEST (CILRT) - SUPPLEMENTAL TEST RESULTS

TVA's letter of September 19, 1994, transmitted the summary technical report for the CILRT conducted on WBN Unit 1 June 22-29, 1994. As committed in that letter, the Enclosure to this letter provides a supplemental report of test results for local leak rate tests (LLRT) which were not performed prior to the CILRT. These tests were completed on September 24, 1994, and include the water inventory tests required for the containment spray and residual heat removal (RHR) spray isolation valves, and the hydrogen analyzer system loop test outside the hydrogen analyzer isolation valves.

If you should have any questions, contact Bruce S. Schofield at (615)-365-1857.

Sincerely,

Dwight E. Nunn
Vice President
New Plant Completion
Watts Bar Nuclear Plant

Enclosure
cc: See page 2

020007

9411020141 941021
PDR ADOCK 05000390
A PDR

A017
11

OCT 21 1994

cc (Enclosure):

NRC Resident Inspector
Watts Bar Nuclear Plant
Rt. 2, Box 700
Spring City, Tennessee 37381

Mr. P. S. Tam, Senior Project Manager
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

ENCLOSURE

WATTS BAR NUCLEAR PLANT UNIT 1
REACTOR CONTAINMENT BUILDING INTEGRATED LEAK RATE TEST
SUPPLEMENTAL REPORT