

Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381

APR 2 1 1995

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D.C. 20555

Gentlemen:

In the Matter of the Application of
Tennessee Valley AuthorityDocket Nos. 50-390
50-391

WATTS BAR NUCLEAR PLANT (WBN) UNITS 1 AND 2 - REGULATORY GUIDE (RG) 1.97, REVISION 2, POSTACCIDENT MONITORING SYSTEM (PAM) - SUPPLEMENTAL RESPONSE (TAC NOS. M77550 AND M77551)

This letter provides a revision to Deviation 20, associated with Variable 18, and Deviation 33, associated with Variable 95, identified in TVA's letters dated August 31, 1990 and May 9, 1994, concerning conformance to RG 1.97, Revision 2 for WBN. This letter also provides minor revisions to Variables 96 and 103 to be consistent with the WBN design criteria. These revisions do not deviate from the requirements of RG 1.97, Revision 2.

Enclosure 1 identifies the revisions for the affected variables and provides the detail and justification for those revisions. Enclosure 2 provides a revised variables table. Enclosure 3 provides the revisions to Deviations 20 and 33.

If you should have any questions concerning this matter, please telephone John Vorees at (615) 365-8819.

Sincerely

Raul R. Baron Nuclear Assurance and Licensing Manager (Acting) Watts Bar Nuclear Plant

Enclosures cc: See page 2

9504280343 950421 PDR ADDCK 05000390 A PDR





U.S. Nuclear Regulatory Commission Page 2

APR 2 1 1995

.

Enclosures cc (Enclosures): NRC Resident Inspector Watts Bar Nuclear Plant Rt. 2, Box 700 Spring City, Tennessee 37381

> Mr. P. S. Tam, Senior Project Manager U.S. Nuclear Regulatory Commission One White Flint North 11555 Rockville Pike Rockville, Maryland 20852

U.S. Nuclear Regulatory Commission Region II 101 Marietta Street, NW, Suite 2900 Atlanta, Georgia 30323

۰,

WATTS BAR NUCLEAR PLANT

REGULATORY GUIDE 1.97, REVISION 2 LIST OF CORRECTIONS

(FROM MAY 9, 1994 AND AUGUST 31, 1990 LETTERS)







WATTS BAR NUCLEAR PLANT REGULATORY GUIDE 1.97, REVISION 2 LIST OF CORRECTIONS

The following revisions have been found to be necessary to TVA's letters to NRC dated August 31, 1990 and May 9, 1994. Revisions incorporated will be denoted with revision bars. For each revision, the variable, change and justification are provided.

• •

| VARIABLE/ <u>DEVIATION</u> | CHANGE <u>DESCRIPTION</u> | JUSTIFICATION |
|-------------------------------|---|--|
| Variable 18/ Deviation 20 | Added justification for not monitoring the position of safety relief valves which are also Containment Isolation Valves (CIVs). | Safety relief valves will not be monitored for position because these valves are in the normal containment isolation position. These valves are not currently covered by a deviation. |
| Variable 95/ Deviation 33 | Revised required range and its basis. | Revisions to supporting calculations required these changes. |
| Variable 96 | Revised required range. | Revisions to supporting radiation calculations as a result of 10 CFR 20 revisions. |
| Variable 103 | Revised "1 channel" under redundant channels to "portable." | Revision made to be consistant with the design criteria. |

.

.

| Var Num | Variable Name | RG 1. Type/Cat | .97 tegory | Wa Type | atts e/Cat | Bar tegory | Redundant Channels | RG 1.97 Range From | RG 1.97 Range To | Minimum Watts Bar Range From | Minimum Watts Bar Range to | Range Units | Display Location | Sensor Location | EQ | SE | QA | Power Supply | Notes | |
|------------|---|-------------------|---------------|------------|---------------|---------------|---------------------------------|-----------------------|-------------------------|------------------------------------|----------------------------------|----------------|---------------------|--------------------|-----|-----|-----|-----------------|---|----------|
| 1 | Auxiliary Feedwater Flow | | D2 | A1 | | D2 | P1 P2 2 Channels Per Loop | 0 | 110% Design | 0 | 700 | GPM | MCR | АВ | YES | YES | YES | 1E | (See Note 1) | |
| 2 | Containment Lower Comp Atm Temperature | | D2 | A1 | | D2 | P1 P2 2 Channels | 40 Deg F | 400 Deg F | 0 | 350 | Deg F | MCR | RB | YES | YES | YES | 1E | Deviation #8 | |
| 3 | Containment Pressure (Narrow Range) | B1 C1 | | A1 B | 81 C1 | D2 | 4 Channels | 10 Psia | Design Pressure | -2 | 15 | PSIG | MCR | RB | YES | YES | YES | 1E | Deviation #24 | |
| 4 | Containment Radiation | С3 | 5 E1 | A1 | С3 | E1 | P1 P2 2 Upper 2 Lower | 1 | 1.0E7 | 1 | 1.0E7 | R/hr | MCR | RB | YES | YES | YES | 1E | Deviation #36 | |
| 5 | Containment Sump Level (Wide Range) | B1 C1 | | A1 B | 1 C1 | D2 | P1 P2 | Bottom Of Contmnt | 600k Gal. Equivalent | 0 | 20 | Ft | MCR | RB | YES | YES | YES | 1E | Deviation #32 | |
| 6 | Core Exit Temperature | B3 C1 | | A1 B | 1 C1 | D2 | P1 P2 8 PAM 1 8 PAM 2 | 200 | 2300 | 200 | 2300 | Deg F | MCR | RB | YES | YES | YES | 1E | Minimum Of 16 Operable Thermo Couples. 4 From Ea Quadrant (See Note 1) Deviation #30 and 37 | ich # |
| 7 | Main Steam Line Radiation | C2 | E2 | | C2 | E2 | 1 Channel Per Steam Gen | 1.0E-1 | 1.0E3 | 1.0E-1 | 1.0E3 | uCi/cc | MCR | RB | YES | NO | YES | NON-1E | | ß |
| 8 | Nuclear Inst. (Source Range) | | | A1 B | 1 | D2 | P1 P2 | NA | NA | 1 | 1.0E6 | CPS | MCR | RB | YES | YES | YES | 1E | | · |
| 9 | RCS Pressurizer Level | | D1 | A 1 | | D1 | P1 P2 P3 | Bottom | Тор | 0 | 100 | % | MCR | RB | YES | YES | YES | 1E | (See Note 9) | |
| 10 | RCS Pressure Wide Range | B1 C1 | | A1 B | 1 C1 | D2 | P1 P2 P3 | 0 | 3000 | 0 | 3000 | PSIG | MCR | AB | YES | YES | YES | 1E | (See Note 9) | |
| 11 | RCS Temperature T Cold | B1 | | A1 B | 1 C1 | D2 | 4 Channels 1 Per Loop | 50 | 750 | 50 | 700 | Deg F | MCR | RB | YES | YES | YES | 1E | (See Note 1) Deviation #1 | |
| 12 | RCS Temperature T Hot | В1 | | A1 | | D2 | 4 Channels 1 Per Loop | 50 | 750 | 50 | 700 | Deg F | MCR | RB | YES | YES | YES | 1E | (See Note 1) Deviation #1 | |
| | | | | | | | | | | | | | | | | | | | | |

.

| Var Num | Variable Name | RG 1.97 Type/Categ | , Jory | Watts Type/Cat | Bar tegory | Redundant Channels | RG 1.97 Range From | RG 1.97 Range To | Minimum Watts Bar Range From | Minimum Watts Bar Range to | Range Units | Display Location | Sensor Location | EQ | SE | QA | Power Supply | Notes |
|------------|---|-----------------------|-----------|-------------------|---------------|----------------------------------|-----------------------|-----------------------|------------------------------------|----------------------------------|----------------|---------------------|--------------------|-----|-----|-----|-----------------|--|
| 13 | Refueling Water Storage Tank Level | D | 2 | A1 | D2 | P1 P2 | Тор | Bottom | 100 | 0 | % | MCR | YD | YES | YES | YES | 1E | |
| 14 | Steam Generator Level (Narrow Range) | | | A1 B1 | | P1 P2 P3 3 Channels Per SG | NA | NA | 0 | 100 | % | MCR | RB | YES | YES | YES | 1E | (See Note 1 & 9) |
| 15 | Steam Generator Pressure | D | 2 | A1 B1 | D2 | P1 P2 2 Channels Per SG | Atmos. pressure | 20% Of Safety | 0 | 1300 | PSIG | MCR | AB | YES | YES | YES | 1E | Deviation #3 |
| 16 | Subcooling Margin Monitor | B2 | | A1 B2 C1 | D2 | P1 P2 | 200* | 35* | 200* | 35* | Deg F | MCR | RB | YES | YES | YES | 1E | *200 Deg Subcooling To 35 Deg Superheat |
| 17 | Auxiliary Building Passive Sump Level | | | B1 C1 | | P1 P2 | NA | NA | 12.5 | 72.5 | Inches | MCR | AB | YES | NO | YES | NON-1E | |
| 18 | Containment Isolation Valve Position Indication | B1 | | B1 | D2 | 1 Per Valve | Closed | Not Closed | Closed | Not Closed | 1 | MCR | RB/AB | YES | YES | YES | 1E | Deviation #20 |
| 19 | Containment Hydrogen Concentration | C1 | | B1 C1 | D2 | P1 P2 | 0 | 30 | 0 | 10 | % | MCR | RB | YES | YES | YES | 1E | Deviation #2 |
| 20 | Control Rod Position | в3 | | | D3 | 1 Channel Per Bank | Full In | Not Full In | 0 | 235 | Steps | MCR | RB | NO | NO | NO | NON-1E | Deviation #35 |
| 21 | Nuclear Inst (Intermediate Range) | В1 | •• | В1 | D2 | P1 P2 | 1.0E-6% | 100% Pwr | 1.0E-8% | 200% | Power | MCR | RB | YES | YES | YES | 1E | |
| 22 | REACTOR VESSEL LEVEL | B1 _, | | B1 C1 | D2 | P1 P2 Plasma Display | Bottom Of Core | Top Of Vessel | , | | | | | YES | YES | YES | 1E | (See Note 5) |
| 22a | Static Mode (Pumps Not Running) | | | | | | | | 0 | 100 | % | MCR | RB | | | | | 0% Represents Reactor Vessel Empty |
| 22b | Dynamic Mode (Pumps Running) | • • | | | | | | | 20 | 100 | % | MCR | RB | | | | | 100% Represents Reactor Vessel |
| 23 | Containment Pressure (Wide Range) | B1 C1 | | C1 | | P1 P2 | 0 | 4x Design Pressure | -5 | 60 | PSIG | MCR | RB | YES | YES | YES | 1E | |
| 24 | Shield Building Vent (Noble Gas Activity) | C2 | E2 | C2 | E2 | 2 1 Channel | 1.0E-6 | 1.0E4 | 1.0E-6 | 1.0E4 | uCi/cc | MCR | AB | YES | NO | YES | NON-1E | |
| | | | | | | | | | • | | | | | | | | | |

.

| Var Num | Variable Name | RG 1.97 Type/Category | Watts Bar Type/Category | Redundant Channels | RG 1.97 Range From | RG 1.97 Range To | Minimum Watts Bar Range From | Minimum Watts Bar Range to | Range Units | Display Location | Sensor Location | EQ | SE | QA | Power Supply | No | otes |
|------------|---|--------------------------|----------------------------|-----------------------------|-----------------------|---------------------|------------------------------------|----------------------------------|----------------|---------------------|--------------------|-----|-----|-----|-----------------|------------------------|----------------------|
| 25 | ABGTS High Pressure Alarm | | D2 | 1 Channel Per Fan | NA | NA | NA | -0.2 | In. H20 | MCR | AB | YES | NO | YES | NON-1E | | |
| 26 | ACAS Pressure | D2 | D2 | 1 Channel Per Train | Plant | Specific | 0 | 150 | PSIG | MCR | AB | YES | NO | YES | NON-1E | | |
| 27 | AFW Valve Status | | D1 | 1 Channel Per Valve | NA | NA | 0pen | Closed | NA | MCR | AB | YES | YES | YES | 1E | | |
| 28 | Accumulator Flow Isolation Valve Status | D2 | D3 | 1 Channel Per Valve | 0pen | Closed | 0pen | Closed | NA | MCR | АВ | NO | NO | NO | NON-1E | Deviatior | n #16 |
| 29 | Accumulator Tank Level | D2 | D3 | 1 Channel Per Tank | 10% | 90% | 7632 | 8264 | GAL | MCR | RB | NO | NO | NO | NON-1E | Deviation | n #15 |
| 30 | Accumulator Tank Pressure | D2 | D3 | 1 Channel Per Tank | 0 psig | 750 psig | 0 | 700 | PSIG | MCR | RB | NO | NO | NO | NON-1E | Deviation | n #6 |
| 31 | Annulus Pressure | | D2 | 1 Channel | NA | NA | -10 | 0 | In. H2O | MCR | RB | YES | NO | YES | NON-1E | | |
| 32 | Aux. Feed Pump Turbine Steam Supply Isolation Valve Status | | D3 | 1 Channel Per Valve | NA | NA | Open | Closed | NA | MCR | AB | NO | NO | NO | NON-1E | | |
| 33 | Battery Current (125V dc Vital) | D2 | D2 | 1 Channel Per Battery | Plant | Specific | -200 | +600 | AMPS | MCR | AB | YES | NO | YES | N/A | | |
| 34 | Bus Voltage (125V dc Vital) | D2 | D2 | 1 Channel Per Battery | Plant | Specific | 75 | 150 | VOLTS | MCR | AB | YES | NO | YES | N/A | | |
| 35 | Bus Voltage (480V Shutdown) | D2 | D2 | 1 Channel Per Train | Plant | Specific | 0 | 600 | VOLTS | MCR | AB | YES | NO | YES | N/A | | |
| 36 | Bus Voltage (6.9kv Shutdown) | D2 | D2 | 1 Channel Per Train | Plant | Specific | 6400 | 7400 | VOLTS | MCR | AB | YES | NO | YES | N/A | Analog Sc Digital D | cales and Display |
| 37 | CCS Surge Tank Level Abnormal | | D3 | 1 Channel Per Train | NA | NA | 0 | 100 | % | MCR | AB | NO | NO | NO | NON-1E | | |
| 38 | Centrifugal Charging Pump Total Flow | D2 | D2 | 1 Channel | 0 | 110% Design | 0 | 1000 | GPM | MCR | AB | YES | NO | YES | NON-1E | | |
| | | | | | | | | | | | | | | | | | |

,

| Var Num | Variable Name | RG 1.97 Type/Category | Watts Bar Type/Category | Redundant Channels | RG 1.97 Range From | RG 1.97 Range To | Minimum Watts Bar Range From | Minimum Watts Bar Range to | Range Units | Display Location | Sensor Location | EQ | SE | QA | Power Supply | y Notes |
|------------|---|--------------------------|----------------------------|-------------------------|-----------------------|---------------------|------------------------------------|----------------------------------|----------------|---------------------|--------------------|-----|----|-----|-----------------|--|
| 39 | Charging Header Flow | D2 | D3 | 1 Channel | 0 | 110% Design | 0 | 110 | GPM | MCR | AB | NO | NO | NO | NON-11 | E Deviation #17 |
| 40 | Component Cooling Water To ESF Flow | D2 | D2 | 1 Channel Per HX | 0 | 110% Design | 0 | 5561 | GPM | MCR | AB | YES | NO | YES | NON-11 | |
| 41 | Component Cooling Water Supply Temperature | D2 | D2 | 1 Channel Per Train | 32 Deg F | 200 Deg F | 50 | 150 | Deg F | MCR | AB | YES | NO | YES | NON-1E | E Deviation #7 |
| 42 | Condensate Storage Tank Water Level | D1 | D3 | 1 Channel Per Tank | Plant | Specific | 0 | 385,000 | GAL | MCR | AB | NO | NO | NO | NON-1E | Not Primary Source of Aux. Feed Water See Varible 27 |
| 43 | Containment Air Return Fan Status | D2 | D2 | 1 Channel Per Fan | Plant | Specific | 0n | Off | NA | MCR | RB | YES | NO | YES | NON-1E | E (Breaker Status) |
| 44 | Containment Cooling Valve Status | | D3 | 1 Channel Per Valve | NA | NA | 0pen | Closed | NA | MCR | AB | NO | NO | NO | NON-1E | E |
| 45 | Containment Spray Flow | D2 | D2 | 1 Channel Per Train | 0 | 110% Design | 0 | 4400 | GP M | MCR | AB | YES | NO | YES | NON-1E | E |
| 46 | Containment Spray HX Outlet Temperature | | D2 | 1 Channel Per HX | NA | NA | 0 | 200 | Deg F | MCR | AB | YES | NO | YES | NON-1E | : |
| 47 | Containment Sump Water Level (Narrow Range) | B2 C2 | D3 | 1 Channel | Botton Of Sump | Top Of Sump | 2 | 66 | Inches | MCR | RB | NO | NO | NO | NON - 1E | E Deviation #12 |
| 48 | Containment Sump Water Temperature | D2 | D2 | 1 Channel | 50 Deg F | 250 Deg F | 50 | 400 | Deg F | MCR | AB | YES | NO | YES | NON-1E | Used RHR Inlet Temperature Loop which is qualified |
| 49 | Diesel Generator Power | D2 | D2 | 1 Channel Per DG | Plant | Specific | 0 | 4.8 | MWATTS | MCR | AB | YES | NO | YES | N/A | |
| 50 | Diesel Generator Volts | D2 | D2 | 1 Channel Per DG | Plant | Specific | 0 | 6900 | VOLTS | MCR | AB | YES | NO | YES | N/A | |
| 51 | ECCS Valve Status | | D2 | 1 Channel Per Valve | NA | NA | 0pen | Closed | NA | MCR | AB | YES | NO | YES | NON-1E | |
| 52 | ERCW Header Flow | | D2 | 1 Channel Per Header | NA | NA | 0 | 20,000 | GPM | MCR | * | YES | NO | YES | NON-1E | * See Note 8 |

Page No. 5 04/18/95

. .

Enclosure 2

,

| Var Num | Variable Name | RG 1.97 Type/Category | Watts Bar Type/Category | Redundant Channels | RG 1.97 Range From | RG 1.97 Range To | Minimum Watts Bar Range From | Minimum Watts Bar Range to | Range Units | Display Location | Sensor Location | EQ | SE | Po QA Si | wer Jpply | Notes | |
|------------|--|--------------------------|----------------------------|--------------------------------|-----------------------|---------------------|------------------------------------|----------------------------------|----------------|---------------------|--------------------|-----------------|------|-------------|--------------|-------------|---|
| 53 | ERCW Supply Temperature | | D2 | 1 Channel Per Header | NA | NA | 32 | 200 | Deg F | MCR | AB | YES | NO | YES NO |)N-1E | | |
| 54 | Emergency Gas Treatment Damper Position | D2 | D2 | 1 Channel Per Damper | Open | Closed | Open | Closed | NA | MCR | AB | YES | NO | YES NO |)N-1E | | |
| 55 | Emergency Ventilation Damper Status | D2 | D2 | 1 Channel Per Damper | Open | Closed | 0pen | Closed | NA | MCR | АВ | YES | NO | YES NO | №-1 E | | |
| 56 | Hydrogen Recombiner Status | | D3 | 1 Channel Per Recombiner | NA | NA | On | Off | NA | MCR | RB | NO | NO I | NO NO | IN-1E | | |
| 57 | Igniter Group Status | | D3 | 1 Channel Per Group | NA | NA | 0n | Off | NA | MCR | RB | NO | NO I | NO NO |)N-1E | | |
| 58 | Inverter Current (120V ac Vital) | D2 | D2 | 1 Channel Per Inverter | Plant | Specific | 0 | 167 | AMPS | AB | AB | YES | NO | YES N/ | 'A Loca | l Indicatio | n |
| 59 | Inverter Voltage (120V ac Vital) | D2 | D2 | 1 Channel | Plant | Specific | 115 | 125 | VOLTS | AB | АВ | YES | NO | (ES N/ | A Loca | l Indicatio | n |
| 60 | Letdown Flow | D2 | D3 | 1 Channel | 0 | 110% Design | 0 | 144 | GPM | MCR | АВ | NO | NO I | NO NO | N-1E Devi | ation #18 | |
| 61 | MCR Pressure | | D3 | 1 Channel | NA | NA | 0 | 0.50 | In. H2O | MCR | СВ | NO | NO I | NO NO | N-1E | | |
| 62 | MCR Radiation Level | | D2 | 1 Channel | 1.0E-1 | 1.0E4 | 1.0E-1 | 1.0E4 | mR/hr | MCR | MCR | YES | NO N | NO NO |)N-1E | | |
| 63 | Main Feedwater Flow | D3 | D3 | 1 Channel Per Loop | 0 | 110% Design | 0 | 4,372,700 | lb/hr | MCR | AB | NO ^r | NO N | IO NO | N-1E | | |
| 64 | Normal Emergency Boration Flow | D2 | D2 | 1 Channel | 0 | 110% Design | 0 | 150 | GPM | MCR | AB | NO [°] | NO Y | ES NO | N-1E Devi | ation #4 | |
| 65 | THIS LINE INTENTIONALLY LEFT BLANK | | | | | | - | | | | | · . | | | | (| |
| 66 | Pressurizer Heater Status (Electric Current) | D2 | D2 | 1 Channel Per Group | Plant | Specific | 0 | 50.5 | AMPS | MCR | AB | YES | NO Y | ES NC | N-1E (See | Note 3) | |
| | | | | | | : | | | | | | : | | | | | |

·

| Var Num | Variable Name | RG 1.97 Type/Category | Watts Bar Type/Category | Redundant Channels | RG 1.97 Range From | RG 1.97 Range To | Minimum Watts Bar Range From | Minimum Watts Bar Range to | Range Units | Display Location | Sensor Location | EQ | SE | QA | Power Supply | N | otes | |
|------------|---|--------------------------|----------------------------|------------------------|-----------------------|---------------------|------------------------------------|----------------------------------|----------------|---------------------|--------------------|-----|----|-----|-----------------|------------------------------------|----------------|-----|
| 67 | Pressurizer Pressure Relief Valve Pos. (PORV, Block & Code) | D2 | D2 | 1 Channel Per Valve | Closed | Not Closed | Closed | Not Closed | | MCR | RB | YES | NO | YES | NON-1E | | | |
| 68 | Pressurizer Relief Tank Level | D3 | D3 | 1 Channel | Тор | Bottom | 0 | 100 | % | MCR | RB | NO | NO | NO | NON-1E | | | R |
| 69 | Pressurizer Relief Tank Pressure | D3 | D3 | 1 Channel | 0 | Design Pressure | 0 | 100 | PSIG | MCR | RB | NO | NO | NO | NON-1E | | | |
| 70 | Pressurizer Relief Tank Temperature | D3 | D3 | 1 Channel | 50 Deg F | 750 Deg F | 50 | 400 | Deg F | MCR | RB | NO | NO | NO | NON-1E | Deviation | n #11 | |
| 71 | RCP Seal Injection Flow | | D3 | 1 Ch Per RCP | NA | NA | 0 | 13.2 | GPM | MCR | АВ | NO | NO | NO | NON-1E | | | |
| 72 | RCS Head Vent Valve Status | | D2 | 1 Channel Per Valve | NA | NA | Closed | Not Closed | NA | MCR | RB | YES | NO | YES | NON-1E | | | |
| 73 | RHR Heat Exchanger Outlet Temperature | D2 | D2 | 1 Channel Per HX | 32 Deg F | 350 Deg F | 50 | 400 | Deg F | MCR | AB | YES | NO | YES | NON-1E | Deviation | ר #9 | |
| 74 | RHR Pump Flow (RHR System Flow) | D2 | D2 | 1 Channel Per Pump | 0 | 110% Design | 0 | 5500 | GPM | MCR | AB | YES | NO | YES | NON-1E | | | |
| 75 | RHR Valve Status | | D3 | 1 Channel Per Valve | NA | NA | Open | Closed | NA | MCR | АВ | NO | NO | NO | NON-1E | | | R |
| 76 | Reactor Coolant Pump Status (Motor Current) | D3 | D3 | 1 Channel Per Pump | Plant | Specific | 0 | 712 | AMPS | MCR | AB | NO | NO | NO | NON-1E | | | |
| 77 | Safety Injection Pump Flow | D2 | D2 | 1 Channel Per Pump | 0 | 110% Design | 0 | 715 | GPM | MCR | AB | YES | NO | YES | NON-1E | | | |
| 78 | Safety Injection System Valve Status | | D3 | 1 Channel Per Valve | NA | NA | 0pen | Closed | NA | MCR | AB | NO | NO | NO | NON-1E | | | |
| 79 | Spent Fuel Pool Level Alarm | | D2 | 1 Channel | NA | NA | 748ft 11-1/2in | 749ft 2-1/2in | ft,in | MCR | AB | YES | NO | YES | NON-1E | ≷ange Ref and High Setpoint≲ | lects Alarm | |
| 80 | Spent Fuel Pool Temperature Alarm | | D2 | 1 Channel | NA | NA | | 127 | Deg F | MCR | AB | YES | NO | YES | NON-1E | Jpper Rar Set point | nge Is Al | arm |

.

)

| Var Num | Variable Name | RG 1.97 Type/Category | Watts Bar Type/Category | Redundant Channels | RG 1.97 Range From | RG 1.97 Range To | Minimum Watts Bar Range From | Minimum Watts Bar Range to | Range Units | Display Location | Sensor Location | EQ | SE | QA | Power Supply | Notes |
|------------|--|--------------------------|----------------------------|------------------------|-----------------------|---------------------|------------------------------------|----------------------------------|----------------|---------------------|--------------------|-----|-----|-----|-----------------|---|
| 81 | Steam Generator Blowdown Isolation Valve Status | | D2 | 1 Channel Per Valve | NA . | NA | Closed | Not Closed | NA | MCR | RB | YES | NO | YES | NON-1E | |
| 82 | Steam Generator Level (Wide Range) | D1 | D1 | 4 Channels 1 Per SG | Tube Sheet | Separators | 0 | 100 | % | MCR | RB | YES | YES | YES | 1E | Deviation #10 |
| 83 | Main Steam Flow | D2 | D2 | 1 Channel Per S/G | NA | NA | 0 | 4,500,000 | lbs/hr | MCR | AB | YES | NO | YES | NON-1E | |
| 84 | Tritiated Drain Collector Tank Level | D3 | D3 | 1 Channel Per Train | Тор | Bottom | 4 | 96 | % | MCR | AB | NO | NO | NO | NON-1E | Local Indication Deviation #25 |
| 85 | Volume Control Tank Level | D2 | D3 | 1 Channel | Тор | Bottom | 0 | 100 | % | MCR | AB | NO | NO | NO | NON-1E | Deviation #19 |
| 86 | Waste Gas Decay Tank Pressure | D3 | D3 | 1 Channel Per Tank | 0 | 150% Design | 0 | 150 | PSIG | MCR | AB | NO | NO | NO | NON-1E | Local Indication Deviation #23 |
| 87 | Radiation Exposure Meters | E3 | | NA | NA | NA | NA | NA | NA | NA | NA | NA | NA | NA | NA | Deviation #22 |
| 88 | Airborne Radiohalogens And Particulates | E3 | E3 | Portable | 1.0E-9 | 1.0E-3 | 1.0E-9 | 1.0E-3 | uCi/cc | ANALYSIS | SAMPLE | NO | NO | NO | NA | Airborne I-131 and particulates |
| 89 | Plant And Environs Radiation | E3 | E3 | Portable | 1.0E-3 | 1.0E4 | 1.0E-3 | 1.0E4 | RAD/hr | PORTABLE | PORTABLE | NO | NO | NO | NA | |
| 90 | Plant and Environs Radioactivity (portable instr.) | E3 | E3 | PORTABLE | NA | NA | NA | NA | NA | ANALYSIS | SAMPLE | NO | NO | NO | NA | Multi Channel Gamma Ray Spectrometer |
| 91 | Auxiliary Building Vent (Noble Gas) | E2 | E2 | 1 Channel | 1.0E-6 | 1.0E3 | 1.0E-6 | 1.0E-2 | uCi/cc | MCR | АВ | YES | NO | YES | NON-1E | Deviation #13 |
| 92 | Auxiliary Building Vent (Flow Rate) | E2 | E2 | 1 Channel | 0 | 110% Design | 0 | 250,800 | CFM | MCR | AB | YES | NO | YES | NON-1E | |
| 93 | Auxiliary Building Vent (Part & Halogens) | E3 | E3 | 1 Channel | 1.0E-3 | 1.0E2 | 1.0E-3 | 1.0E-2 | uCi/cc | ANALYSIS | SAMPLE | NO | NO | NO | NON-1E | Sampling With Onsite Analysis Capability |
| 94 | Condenser Vacuum Exhaust Vent (Flow R _A ; | E2 te) | E2 | 1 Channel | 0 | 110% Design | 0 . | 45 | SCFM | MCR | TB | YES | NO | YES | NON-1E | |
| | | | | | | | | | | | | | | | | |

| Var Num | Variable Name | RG 1.97 Type/Catego | ory | Watts Ba Type/Categ | ir Jory | Redundant Channels | RG 1.97 Range from | RG 1.97 Range To | Minimum Watts Bar Range From | Minimum Watts Bar Range to | Range Units | Display Location | Sensor Location | EQ | SE | QA | Power Supply | Notes | |
|------------|--|------------------------|-----|------------------------|------------|--|-----------------------|---------------------|------------------------------------|----------------------------------|----------------|---------------------|--------------------|-----|----|-----|-----------------|--|-----------|
| 95 | Condenser Vacuum Pump Exhaust Vent (Noble Gas) | C3 | E2 | C3 | E2 | 1 Channel | 1.0E-6 | 1.0E5 | 2.4E-7 | 2.4E3 | uCi/cc | MCR | ТВ | YES | NO | YES | NON-1E | Deviation #33 | |
| 96 | ERCW Radiation Monitors | | | | E2 | 1 Channel Per Discharge Point | NA | NA . | 3.3E-4 | 1.65E-2 | uCi/cc | MCR | AB | YES | NO | YES | NON-1E | | |
| 97 | POST ACCIDENT SAMPLE SYSTEM | | E3 | | E3 | 1 System | | | | | | GRAB | PASF | NO | NO | NO | NON-1E | | |
| 97a | Reactor Coolant Chloride Concentration | | Е3 | | E3 | | 0 | 20 | 1 | 20 | ppm | NA | SAMPLE | | | | | Deviation #29 | |
| 97b | Reactor Coolant Dissolved Hydrogen | | E3 | | E3 | | 0 | 2000 | 10 | 2000 | cc/kg (STP) | NA | SAMPLE | | | | | Deviation #21 | |
| 97c | Reactor Coolant Disolved Oxygen | | E3 | | E3 | | 0 | 20 | 1 | 20 | ppm | NA | SAMPLE | • | | | | Deviation #34 | |
| 97d | Reactor Coolant Total Dissolved Gas | | E3 | | E3 | | 0 | 2000 | 100 | 2000 | cc/kg (STP) | NA | SAMPLE | | | | | Deviation #34 | |
| 97e | Reactor Coolant Boron | B3 | E3 | | E3 | | 0 | 6000 | 50 | 6000 | ppm | NA | SAMPLE | | | | | Deviation #26 | |
| 97f | Reactor Coolant PH | | E3 | | E3 | | 1 | 13 | 1 | 13 | рH | NA | SAMPLE | | | | | | |
| 97g | Reactor Coolant Sample Activity | C1 | E3 | C3 | E3 | | 10uCi∕ml | 10Ci∕ml | 10uCi∕ml | 10Ci∕ml | Cî/ml | NA | SAMPLE | | | | | Deviation #5 | |
| 97h | Reactor Coolant Gamma Spectrum | | E3 | | E3 | ۰. | NA | NA | NA | NA | NA | ANALYSIS | SAMPLE | NA | NA | NA | NA | Isotopic Analys | |
| 98 | CONTAINMENT AIR | | | | | • . | | | | | | | | | | | | | |
| 98a | Containment Air H2 | | E3 | | E3 | | 0% | 30% | 0% | 10% | By Vol | ANALYSIS | SAMPLE | NA | NA | NA | NA | Also Measured b Hydrogen Analyz Deviation #2 | 'Y :er |

.

Enclosure 2

| Var Num | Variable Name | RG 1.97 Type/Category | Watts Bar Type/Category | Redundant Channels | RG 1.97 Range From | RG 1.97 Range To | Minimum Watts Bar Range From | Minimum Watts Bar Range to | Range Units | Display Location | Sensor Location | EQ | SE | QA | Power Supply | No | tes |
|----------------|--|--------------------------|----------------------------|--|-----------------------|---------------------|------------------------------------|----------------------------------|----------------|---------------------|--------------------|-----|----|-----|-----------------|----------------------|---------------------------|
| 98b | Oxygen Content | E3 | | NA | NA | NA | NA | NA | NA | NA | NA | NA | NA | NA | NA | Deviation | #27 |
| 98c | Gamma Spectrum Sample | E3 | E3 | S NA | NA | NA | NA | NA | NA | ANALYSIS | SAMPLE | NA | NA | NA | NA | Isotopic | Analysis |
| 9 9 | Shield Building Vent Flow | E2 | E2 | 2 1 Channel Per Unit | 0 | 110% Design | 0 | 30,800 | CFM | MCR | AB | YES | NO | YES | NON-1E | | |
| 100 | Shield Building Vent Monitor (Particulate And Iodine) | E3 | E3 | 1 Channel Per Unit | 1.0E-3 | 1.0E2 | 1.0E-3 | 1.0E2 | uCi/cc | NA | SAMPLE | NO | NO | NO | NON-1E | Sampling Analysis | With Onsite Capability |
| 101 | Steam Generator Discharge Vent (Flow Rate and Noble Gas) | E2 | E2 | 2 1 Channel Per Release Point | 1.0E-1 | 1.0E3 | NOTE 4 | NOTE 4 | | MCR | AB | YES | NO | YES | NON-1E | | |
| 102 | METEOROLOGY | | | | | | | | | | | | | | | | |
| 102a | Vertical Temperature Difference | E3 | E3 | 1 Channel | -9 | +18 | -9 | +18 | Deg F | MCR | YD | NO | NO | NO | NON-1E | | |
| 102b | Wind Direction | E3 | E3 | 1 Channel | 0 | 360 | 0 | 3 60 | Deg | MCR | YD | NO | NO | NO | NON-1E | | |
| 102c | Wind Speed | E3 | E3 | 1 Channel | 0 | 67 | 0 | 50 | MPH | MCR | YD | NO | NO | NO | NON-1E | Deviation | #28 |
| 103 | Radiation Exposure Rate | E2 | E3 | Portable | 1.0E-1 | 1.0E4 | 1.0E-3 | 1.0E4 | R/hr | NA | NA | NO | NO | NO | NA | Deviation | #31 |

REGULATORY GUIDE 1.97 POSTACCIDENT MONITORING TABLE OF VARIABLES

Page No. 10

Notes:

1. The following parameters are identified as diverse.

ParameterDiverse ParameterT (Hot)Core Exit TemperatureCore Exit TemperatureT (Hot)T (Cold)SG PressureAuxiliary Feedwater FlowSG NR/WR Level

2. Deleted

- 3. Pressurizer Heater Status required only for safety-related heater banks (backup heater 1A-A and 1B-B).
- 4. Recorder shall be provided for duration of release from all discharge points.

| Noble Gas Activity | 1.0E-1 to 1.0E3µCi/cc |
|--------------------|---|
| Steam Flow Rate | 0 to 4945200 lb/hr to PORV and Safety Valves |
| | 0 to 63375 lb/hr to Aux. Feedwater Pump Turbine |

- 5. The vessel level on plasma display is compensated actual vessel level derived from microprocessor algorithm using the upper range, lower range, dynamic range differential pressure, wide range temperature, and wide range pressure.
- 6. Deleted.
- 7. Deleted.
- 8. Transmitters are located in the ERCW pipe tunnel underneath the yard between the Auxiliary Building and the refueling water storage tank.
- 9. The requirements for Category I variables which require a third independent channel to resolve ambiguity resulting when redundant displays disagree are being implemented at WBN as follows:

The loop instrumentation for each channel is assigned to a redundant protection set (I, II, III, and IV) and electrical independence is maintained from sensor to display. Physical separation is maintained from the sensor to the isolator in the Auxiliary Instrument Room. From the isolator to the indicator in the Main Control Room, third channel (PAM 3) cables may be routed with either PAM 1 or PAM 2 cables (but not both) depending on its associated protection set.

•

. . .

.

WATTS BAR NUCLEAR PLANT REGULATORY GUIDE 1.97, REVISION 2

REVISIONS TO DEVIATIONS



WATTS BAR NUCLEAR PLANT REGULATORY GUIDE 1.97, REVISION 2 REVISIONS TO DEVIATIONS

DEVIATION 20

VARIABLE 18

Containment Isolation Valve (CIV) Position

DEVIATION FROM RG 1.97 GUIDANCE

RG 1.97, Revision 2, recommends that the CIV position indication should meet the requirements of a B1 variable (which encompasses position indication for the duration of the event). WBN's reactor coolant system (RCS) letdown CIVs flow control valves (FCV)-62-72, -73, -74, and -76 will be submerged postaccident inside containment. These valves' limit switches are not qualified for operation during post submergence.

In addition, safety relief valves which are also designated as CIVs are not monitored for position.

JUSTIFICATION

The RCS letdown CIVs close on an SI signal, Phase A signal, or a low pressurizer level signal. The valves and associated position indication limit switches are qualified to perform their intended safety functions prior to being submerged. The limit switch for the valve position indication is located on the valve and hence subject to submergence. The limit switch is not qualifiable for submergence. The limit switch performs its intended safety function well before submergence. Valve positions are indicated both in the Main Control Room and the Technical Support Center.

Once the limit switches are flooded, it must be assumed that the control circuit fuses will be blown and position indication will be lost. This indication circuit, however, is isolated from the other CIV indication circuits.

The solenoids for these valves are included in WBN's environmental qualification (E) program and will vent to automatically close the FCVs as required under accident conditions. An analysis in WBN's E binder demonstrates that once closed, a submergence failure of the solenoid will not cause the FCV to change position. Hence the valves are considered closed and no further indication is required.

For safety relief valves, position indication is not necessary since these valves are constantly in their containment isolation position (i.e., closed). Verification that these valves have accomplished their containment isolation function is not necessary since they do not change position to provide this function.

WATTS BAR NUCLEAR PLANT Regulatory guide 1.97, revision 2 Revisions to deviations

DEVIATION 33

VARIABLE 95

Condenser Vacuum Pump Exhaust Vent (Noble Gas)

DEVIATION FROM RG 1.97 GUIDANCE

The RG 1.97, Revision 2 required range for the condenser vacuum pump exhaust monitors is 1.0E-6 to 1.0E+5 $\mu{\rm Ci/cc}$.

JUSTIFICATION

TVA has determined the total gas required range of the condenser vacuum pump exhaust monitors to be less than the 1.0E-6 value in RG for the low end of the range and 2.4E+3 μ Ci/cc at the upper end of the range.

The steam generator tube rupture (SGTR) is the only credible accident monitored by the condenser vacuum pump exhaust monitor. NUREG-0800, Revision 2 requires that the SGTR accident be analyzed using the highest isotope concentrations allowed by the Watts Bar Technical Specifications. The specific activity of the reactor coolant is limited to:

a) Less than or equal to 1 microcurie per gram dose equivalent Iodine-131, and

b) Less than or equal to $100/\bar{E} \ \mu Ci/gm$

The dose equivalent I-131 is more than 4 times more restrictive than the $100/\bar{E}$ limit. The $100/\bar{E}$ is more conservative and is selected to demonstrate that the monitor will remain on scale during the most severe accident. The highest concentration of mixed noble gas isotopes that can be present under the $100/\bar{E}$ limit is $1.45E+3~\mu Ci/cc$ as determined in TVA calculation WBNAPS3-048. For the SGTR source spectrum, the maximum measurable concentration for the condenser vacuum pump exhaust monitors is 3.53E+4. Therefore, the Watts Bar required range for the condenser vacuum pump exhaust monitors or the sGTR source spectrum.