



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381

MAY 02 1995

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of the Application of)
Tennessee Valley Authority)

Docket Nos. 50-390

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1 - REPLACEMENT ITEMS PROGRAM (RIP)
CORRECTIVE ACTION PROGRAM (CAP) - REMAINING INVENTORY

The purpose of this letter is to inform NRC of TVA's plan to disposition the remaining Materials Improvement Project (MIP) inventory within TVA's corrective action program rather than under the RIP CAP procedure. As discussed in TVA's letter to NRC dated March 23, 1995, TVA believes that the RIP CAP has accomplished its stated objectives and that curtailment of evaluations of the remaining populations under the RIP CAP and Site Standard Practice (SSP)-10.C, "Evaluation of Installed Safety-Related Items," is appropriate. The remaining MIP inventory includes items which have been identified in previous TVA/NRC correspondence as "on hold for RIP" and the remaining "indeterminate" warehouse inventory. This population will be addressed in accordance with TVA's Appendix B Corrective Action Program under Significant Corrective Action Report (SCAR) WBP900537SCA. A description of the corrective action plan is provided in the enclosure to this letter, however, it does not supersede any previous commitments associated with Construction Deficiency Report CDR 390/91-34 concerning future releases of "indeterminate" inventory.

If you have any questions, contact P. L. Pace at (615) 365-1824.

Sincerely,

Paul R. Baron
Nuclear Assurance and
Licensing Manager (Acting)

Enclosure

cc: See page 2

9505100085 950502
PDR ADOCK 05000390
A PDR

2030
1/1

U.S. Nuclear Regulatory Commission
Page 2

MAY 02 1995

Enclosure

cc (Enclosure):

NRC Resident Inspector
Watts Bar Nuclear Plant
Rt. 2, Box 700
Spring City, Tennessee 37381

Mr. P. S. Tam, Senior Project Manager
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

U.S. Nuclear Regulatory Commission
Region II
141 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

ENCLOSURE

WATTS BAR NUCLEAR PLANT UNIT 1
CORRECTIVE ACTION PLAN

- Review appropriate data bases to determine those items in the remainder population which have had previous safety-related issuances.
- Prepare procurement engineering packages for any 10 CFR 50.49 TVA Items Identification Codes (TIICs) not previously addressed.
- Prepare procurement engineering packages for any Release Tracking Log (RTL) TIICs not previously addressed.
- Review the remaining population and provide a "use-as-is" evaluation of the remaining TIICs.
- For each item, annotate the appropriate data system to flag those items that are dispositioned by this Corrective Action Program process.
- Complete the above listed corrective actions by July 28, 1995.