Mr. O. J. Zeringue
Chief Nuclear Officer
And Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

SUBJECT: RELIEF FROM ASME CODE REPAIR REQUIREMENTS FOR CANOPY SEAL

WELDS WATTS BAR NUCLEAR PLANT (TAC NO. M99677)

Dear Mr. Zeringue:

By letter dated September 20, as supplemented October 10, 1997, the Tennessee Valley Authority (TVA) submitted a request for relief from the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI repair requirements under 10 CFR 50.55a(a)(3)(i) for the Watts Bar Nuclear Plant, Unit 1. The request addressed repair of two reactor vessel lower canopy seal welds by weld buildup rather than the removal of the defects and performing a Code weld repair.

The NRC staff hereby grants the requested alternative pursuant to 10 CFR 50.55a(a)(3)(i), since it is authorized by law and will not endanger life, property, or the common defense and security and is otherwise in the public interest, giving due consideration in granting relief to the burden upon the licensee that could result if the ASME Code requirements were imposed on the facility.

The staff has reviewed the information provided in TVA's September 20 and October 10, 1997 letters. The staff's evaluation and conclusions are contained in the Enclosure. The staff finds that the alternate repair and inspection of the two lower canopy seal welds provides an acceptable level of safety and quality. Accordingly the staff authorizes the use of such alternative pursuant to 10 CFR 50.55a(a)(3)(i).

Sincerely,

Original Signed by:
Frederick J. Hebdon, Director
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

DFO/

Docket No. 50-390

Enclosure: Safety Evaluation

cc w/enclosure: See next page

DISTRIBUTION:

R. Martin

J. Johnson, RII

Docket File PUBLIC

M. Banic

B. Clayton

WBN Rdg.

OGC

M. Tschiltz, EDO

J. Zwolinski

G. Hill (2)

T. Harris (e-mail SE to TLH3)

F. Hebdon

ACRS

DOCUMENT NAME: G:\WBN\WB99677.RR

*See previous concurrence

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PDII-3/PM(1)	E PDII-3/LA	E OGC*	PDII-3/D ,) C
NAME	RMartin /	BClayton &	CMarco	FHebdon 😾
DATE	02// 2/98	02/12/98	02/06/98	02/12/98

9802240119 980212 PDR ADOCK 05000390 P PDR



MRG FLF CENTER COPY

February 12, 1998

Mr. O. J. Zeringue
Chief Nuclear Officer
and Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

SUBJECT: RELIEF FROM ASME CODE REPAIR REQUIREMENTS FOR CANOPY SEAL WELDS WATTS BAR NUCLEAR PLANT (TAC NO. M99677)

Dear Mr. Zeringue:

By letter dated September 20, as supplemented October 10, 1997, the Tennessee Valley Authority (TVA) submitted a request for relief from the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI repair requirements under 10 CFR 50.55a(a)(3)(i) for the Watts Bar Nuclear Plant, Unit 1. The request addressed repair of two reactor vessel lower canopy seal welds by weld buildup rather than the removal of the defects and performing a Code weld repair.

The NRC staff hereby grants the requested alternative pursuant to 10 CFR 50.55a(a)(3)(i), since it is authorized by law and will not endanger life, property, or the common defense and security and is otherwise in the public interest, giving due consideration in granting relief to the burden upon the licensee that could result if the ASME Code requirements were imposed on the facility.

The staff has reviewed the information provided in TVA's September 20 and October 10, 1997 letters. The staff's evaluation and conclusions are contained in the Enclosure. The staff finds that the alternate repair and inspection of the two lower canopy seal welds provides an acceptable level of safety and quality. Accordingly the staff authorizes the use of such alternative pursuant to 10 CFR 50.55a(a)(3)(i).

Sincerely,

Original Signed by:
Frederick J. Hebdon, Director
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-390

Enclosure: Safety Evaluation

cc w/enclosure: See next page

DISTRIBUTION:

Docket File

R. Martin

J. Johnson, RII

PUBLIC

M. Banic

B. Clayton

WBN Rdg.

OGC

M. Tschiltz, EDO

J. Zwolinski

G. Hill (2)

T. Harris (e-mail SE to TLH3)

F. Hebdon

ACRS

DOCUMENT NAME: G:\WBN\WB99677.RR

*See previous concurrence

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

NAME RMartin BCLayton CMarco	
	FHebdon 📆
DATE 02/1/2/98 02/1/2/98 02/06/98	02/12/98



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

February 12, 1998

Mr. O. J. Zeringue
Chief Nuclear Officer
and Executive Vice President
Tennessee Valley Authority
6A Lookout Place
1101 Market Street
Chattanooga, Tennessee 37402-2801

SUBJECT: RELIEF FROM ASME CODE REPAIR REQUIREMENTS FOR CANOPY SEAL

WELDS WATTS BAR NUCLEAR PLANT (TAC NO. M99677)

Dear Mr. Zeringue:

By letter dated September 20, as supplemented October 10, 1997, the Tennessee Valley Authority (TVA) submitted a request for relief from the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI repair requirements under 10 CFR 50.55a(a)(3)(i) for the Watts Bar Nuclear Plant, Unit 1. The request addressed repair of two reactor vessel lower canopy seal welds by weld buildup rather than the removal of the defects and performing a Code weld repair.

The NRC staff hereby grants the requested alternative pursuant to 10 CFR 50.55a(a)(3)(i), since it is authorized by law and will not endanger life, property, or the common defense and security and is otherwise in the public interest, giving due consideration in granting relief to the burden upon the licensee that could result if the ASME Code requirements were imposed on the facility.

The staff has reviewed the information provided in TVA's September 20 and October 10, 1997 letters. The staff's evaluation and conclusions are contained in the Enclosure. The staff finds that the alternate repair and inspection of the two lower canopy seal welds provides an acceptable level of safety and quality. Accordingly the staff authorizes the use of such alternative pursuant to 10 CFR 50.55a(a)(3)(i).

Sincerely,

Frederick J. Hebdon, Director

Project Directorate II-3

Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-390

Enclosure: Safety Evaluation

cc w/enclosure: See next page

Mr. O. J. Zeringue Tennessee Valley Authority

CC:

Mr. J. A. Scalice, Senior Vice President Nuclear Operations Tennessee Valley Authority 6A Lookout Place 1101 Market Street Chattanooga, TN 37402-2801

Mr. Jack A. Bailey, Vice President Engineering & Technical Tennessee Valley Authority 6A Lookout Place 1101 Market Street Chattanooga, TN 37402-2801

Mr. Richard T. Purcell, Site Vice President Watts Bar Nuclear Plant Tennessee Valley Authority P.O. Box 2000 Spring City, TN 37381

General Counsel Tennessee Valley Authority ET 10H 400 West Summit Hill Drive Knoxville, TN 37902

Mr. Raul R. Baron, General Manager Nuclear Assurance Tennessee Valley Authority 4J Blue Ridge 1101 Market Street Chattanooga, TN 37402-2801

Mr. Mark J. Burzynski, Manager Nuclear Licensing Tennessee Valley Authority 4J Blue Ridge 1101 Market Street Chattanooga, TN 37402-2801

WATTS BAR NUCLEAR PLANT

Mr. Paul L. Pace, Manager Licensing Watts Bar Nuclear Plant Tennessee Valley Authority P.O. Box 2000 Spring City, TN 37381

Mr. William R. Lagergren, Plant Manager Watts Bar Nuclear Plant Tennessee Valley Authority P.O. Box 2000 Spring City, TN 37381

Regional Administrator U.S. Nuclear Regulatory Commission Region II 61 Forsyth Street, SW., Suite 23T85 Atlanta, GA 30303-3415

Senior Resident Inspector
Watts Bar Nuclear Plant
U.S. Nuclear Regulatory Commission
1260 Nuclear Plant Road
Spring City, TN 37381

County Executive Rhea County Courthouse Dayton, TN 37321

County Executive Meigs County Courthouse Decatur, TN 37322

Mr. Michael H. Mobley, Director Division of Radiological Health 3rd Floor, L and C Annex 401 Church Street Nashville, TN 37243-1532