



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381

William J. Museler
Site Vice President
Watts Bar Nuclear Plant

DEC 22 1992

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of the Application of) Docket Nos. 50-390
Tennessee Valley Authority) 50-391

WATTS BAR NUCLEAR PLANT (WBN) UNITS 1 AND 2 - NRC BULLETIN 90-01 - LOSS OF
FILL-OIL IN TRANSMITTERS MANUFACTURED BY ROSEMOUNT - SUPPLEMENTAL RESPONSE

This letter supplements TVA's response to the subject bulletin dated
January 31, 1992, for WBN.

Rosemount issued to the utilities Technical Bulletin No. 4 to the Master
Suspect List of transmitters on December 5, 1991. This list was received
within TVA concurrent with the process of issuing the above-referenced letter
dated January 31, 1992, and, consequently, did not receive a review until
after the issuance of the WBN response. Following the review of the
Rosemount Technical Bulletin, TVA identified additional Model 1153
transmitters from the technical bulletin list that were located in WBN
storage inventory. These transmitters were returned to Rosemount for
refurbishment on October 14, 1992. No transmitters from the list were found
installed in Unit 1.

The following is a list of the suspect transmitters found in storage:

<u>Unit ID No.</u>	<u>Model No.</u>	<u>Serial No.</u>
FT-3-142	1153DB5PB	405447
FT-3-147A	1153DB5PB	405449
FT-3-147B	1153DB5PB	405451
2-FT-3-163A	1153DB5PB	405567

300024
9212300152 921222
PDR ADOCK 05000390
PDR

JE39 1/0

U.S. Nuclear Regulatory Commission
Page 2

DEC 22 1992

One additional transmitter from the technical bulletin with the Serial No. 405446 was identified as being installed in WBN Unit 2. Corrective action for this transmitter will be handled as committed for WBN Unit 2 in the January 31, 1992 letter.

No commitments are identified in this letter. If you have any questions concerning this matter, please telephone John Vorees at (615) 365-8819.

Very truly yours,



William J. Museler

cc: NRC Resident Inspector
Watts Bar Nuclear Plant
P.O. Box 700
Spring City, Tennessee 37381

Mr. P. S. Tam, Senior Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. B. A. Wilson, Project Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323